

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Joseph M. Farley - Unit 1 DOCKET NUMBER (2) 050003481 PAGE (3) 1 OF 1

TITLE (4) Special Report: Fire Detection System Inoperable For More Than Fourteen Days

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
04	25	88	88	013	00	05	24	88			050003481

OPERATING MODE (9) 6 THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 50. (Check one or more of the following) (11)

20.402(b)	20.405(c)	50.73(a)(2)(iv)	73.71(b)
20.405(a)(1)(i)	50.38(c)(1)	50.73(a)(2)(v)	73.71(c)
20.405(a)(1)(ii)	50.38(c)(2)	50.73(a)(2)(vii)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)
20.405(a)(1)(iii)	50.73(a)(2)(i)	50.73(a)(2)(viii)(A)	Special Report per Tech. Spec. 3.3.3.9
20.405(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)	
20.405(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
<u>J. D. Woodard, General Manager-Nuclear Plant</u>	<u>205 899-5156</u>

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

At 2115 on 4-11-88, fire detection system 1A-22 was disabled in order to support modifications to the containment cooler service water piping. Due to the scope of the work, the system could not be returned to service within fourteen days. Technical Specification 3.3.3.9 requires the fire detection system to be returned to operable status within fourteen days or a Special Report must be submitted within the following 30 days. Therefore, this Special Report is being submitted.

The work was completed and system 1A-22 was declared operable at 1330 on 5-14-88. Technical Specification action statement requirements have been met for the inoperable fire detection system.

8805310136 880524
PDR ADOCK 05000348
S PDR

IE 22
/1

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291-0400
Telephone 205 250-1835

R. P. McDonald
Senior Vice President



Alabama Power
the southern electric system

May 24, 1988

Docket No. 50-348

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555


Dear Sir:

Joseph M. Farley Nuclear Plant - Unit 1
Licensee Event Report No. LER 88-013-00

Joseph M. Farley Nuclear Plant, Unit 1, Licensee Event Report No. LER 88-013-00 is being submitted in accordance with 10CFR50.73.

If you have any questions, please advise.

Respectfully submitted,


R. P. McDonald

RPM/JAR:dst-V8.45

Enclosure

cc: IE, Region II

IE22
||