



SOUTHERN CALIFORNIA
EDISON

An EDISON INTERNATIONAL Company

R. W. Krieger
Vice President
Nuclear Generation

October 8, 1998

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: Docket No. 50-361 and 50-362
Revised 30-Day Report
Licensee Event Report No. 1998-018
San Onofre Nuclear Generating Station, Unit 2 and Unit 3

This letter provides Licensee Event Report (LER) 1998-018 for an occurrence involving the use of instrumentation during surveillances, to measure the flow rate in the Charging System, without accounting for Total Loop Uncertainties.

The health and safety of neither the public nor plant personnel were affected by this occurrence.

Any actions listed are intended to ensure continued compliance with existing commitments as discussed in applicable licensing documents; this LER contains no new commitments. If you require any additional information, please so advise.

Sincerely,

LER No. 1998-018

cc: E. W. Merschoff, Regional Administrator, NRC Region IV
J. A. Sloan, NRC Senior Resident Inspector, Units 2 and 3
J. W. Clifford, NRC Project Manager, San Onofre Units 2 & 3
Institute of Nuclear Power Operations (INPO)

9810190147 981008
PDR ADOCK 05000361
S PDR

P. O. Box 128
San Clemente, CA 92674-0128
714-368-6255
Fax 714-368-6185

11
Terr