

## ADMINISTRATIVE CONTROLS

### 6.1 RESPONSIBILITY

#### 6.1.1

The Vice President & Director Oyster Creek shall be responsible for overall facility operation. Those responsibilities delegated to the Vice President & Director as stated in the Oyster Creek Technical Specifications may also be fulfilled by the Deputy Director. The Vice President & Director shall delegate in writing the succession to this responsibility during his and/or the Deputy Directors absence.

### 6.2 ORGANIZATION

#### 6.2.1 OFFSITE

The organization for GPU Nuclear Corporation for management and technical support shall be functionally as shown on Figure 6.2.1.

#### 6.2.2 FACILITY STAFF

The facility organization shall be as shown on Figure 6.2.2 and:

a. Each on duty shift shall include at least the shift staffing indicated on Figure 6.2.2.

b. At all times when there is fuel in the vessel, at least one licensed senior reactor operator shall be on site and one licensed reactor operator shall be at the controls.

c. At all times when there is fuel in the vessel, except when the reactor is in COLD SHUTDOWN or REFUEL modes, two licensed senior reactor operators and two licensed reactor operators shall be on site, with at least one licensed senior reactor operator in the control room and one licensed reactor operator at the controls.

d. At least two licensed reactor operators shall be in the control room during all reactor startups, shutdowns, and other periods involving planned control rod manipulations.

e. ALL CORE ALTERATIONS shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.

f. An individual qualified in radiation protection measures shall be on site when fuel is in the reactor.

g. A Fire Brigade of at least 5 members shall be maintained onsite at all times. The Fire Brigade shall not include the minimum shift crew necessary for safe shutdown of the facility or any personnel required for other essential functions during a fire emergency.

h. A Shift Technical Advisor shall be on site at all times except when the reactor is in the Shutdown or Refuel modes with reactor coolant temperature less than 212°F.