

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

May 17, 1988

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Subject: Catawba Nuclear Station, Unit 1  
Docket No. 50-413  
Special Report

Gentlemen:

Pursuant to Technical Specification 3/4.8.1.1.3, please find attached Revision 1 to the Special Report which was submitted on April 6, 1988 concerning a Diesel Generator 1A valid failure, and three invalid failures. Duke Power personnel has determined that start attempt number 627, which was originally classified as an invalidated failure, should be changed to a valid failure as indicated in the enclosed revision.

Very truly yours,

*H. B. Tucker JGT*  
Hal B. Tucker

JGT/22/sbn

Attachment

xc: Dr. J. Nelson Grace, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. P. K. Van Doorn  
NRC Resident Inspector  
Catawba Nuclear Station

8805310179 880517  
PDR ADOCK 05000413  
S DCD

*IR22*  
*11*

SPECIAL REPORT, REVISION 1  
CATAWBA NUCLEAR STATION, UNIT 1  
TWO DIESEL GENERATOR 1A VALID FAILURE  
ON MARCH 7, 1988  
AND TWO INVALID FAILURES  
ON MARCH 8, 1988

While performing the operability verification of Diesel Generator (D/G) 1A on March 7, 1988, the D/G failed to reach the required 441 RPM within 11 seconds during start number 623 at 1005 hours. High differential pressure across the fuel oil pump strainers and oil filters prompted the issuance of Standing Work Requests 5402, 5404, 6921, and 9004. The strainers and filters for D/G 1A were replaced by 1500 hours on that day. This is the third Valid Failure in the last 100 Valid Starts on D/G 1A and the first in the last 20 Valid Starts. The surveillance interval remained at 31 days following this Valid Failure, which is in accordance with Technical Specifications Surveillance 4.8.1.1.2.

Invalid Test Start numbers 624, 625, and 626 were performed to troubleshoot Start number 623.

Valid Failure Start number 627 was performed on March 7, 1988, at 1955 hours to verify operability by loading the D/G. The D/G started properly and loaded to 5700 KW but tripped on overcurrent protection after exhibiting varying excitation voltage. Invalid Failure Start numbers 628 and 629 were performed to troubleshoot the overcurrent trip on Start number 627. The D/G started but would not load due to loss of generator excitation. Work Request 27213 OPS was initiated and identified a shorted rectifier diode (CR6) in the excitation circuit which was subsequently replaced.

Valid Success Start number 630 was performed on March 8, 1988, at 1535 hours following replacement of the rectifier diode. D/G 1A was unavailable for 29 hours, 30 minutes as a result of these problems. Unit 1 was in Power Operation during the period D/G 1A was unavailable. D/G 1B was verified operable as well as offsite power as required by Technical Specifications.