

ENCLOSURE 5

BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
NRC DOCKETS 50-325 & 50-324
OPERATING LICENSES DPR-71 & DPR-62
REQUEST FOR LICENSE AMENDMENT

UNIT 1 TECHNICAL SPECIFICATION PAGES

8807260115 880919
PDR ADOCK 05000324
P PDC

CONTAINMENT SYSTEMS3/4.6.4 VACUUM RELIEFDRYWELL - SUPPRESSION CHAMBER VACUUM BREAKERSLIMITING CONDITION FOR OPERATION

3.6.4.1 All drywell-suppression chamber vacuum breakers shall be OPERABLE and in the closed position with:

- a. The position indicator OPERABLE, and
- b. An opening set point of less than or equal to 0.5 psid.

APPLICABILITY: OPERATIONAL CONDITICNS 1, 2, and 3.

ACTION:

- a. With no more than 2 drywell-suppression chamber vacuum breakers inoperable for opening but known to be in the closed position, the provisions of Specification 3.0.4 are not applicable and operation may continue until the next COLD SHUTDOWN provided the surveillance requirements of Specification 4.6.4.1.a are performed on the OPERABLE vacuum breakers within 4 hours and at least once per 15 days thereafter, until the inoperable vacuum breakers are restored to OPERABLE status; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With one drywell-suppression chamber vacuum breaker in the open position, as indicated by the position indicating system, the provisions of Specification 3.0.4 are not applicable and operation may continue provided the surveillance requirements of Specification 4.6.4.1.a are performed on the OPERABLE vacuum breakers, and the surveillance requirements of Specification 4.6.4.1.b are performed within 8 hours and at least once per 72 hours thereafter, until the inoperable vacuum breaker is restored to the closed position; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- c. With the position indicator of any drywell-suppression chamber vacuum breaker inoperable, the provisions of Specification 3.0.4 are not applicable, and operation may continue provided the surveillance requirements of Specification 4.6.4.1.b are performed within 8 hours and at least once per 72 hours thereafter, until the inoperable position indicator is returned to OPERABLE status; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

ENCLOSURE 6

BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2
NRC DOCKETS 50-325 & 50-324
OPERATING LICENSES DPR-71 & DPR-62
REQUEST FOR LICENSE AMENDMENT

UNIT 2 TECHNICAL SPECIFICATION PAGES

CONTAINMENT SYSTEMS3/4.6.4 VACUUM RELIEFDRYWELL - SUPPRESSION CHAMBER VACUUM BREAKERSLIMITING CONDITION FOR OPERATION

3.6.4.1 All drywell-suppression chamber vacuum breakers shall be OPERABLE and in the closed position with:

- a. The position indicator OPERABLE, and
- b. An opening setpoint of less than or equal to 0.5 psid.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

- a. With no more than 2 drywell-suppression chamber vacuum breakers inoperable for opening but known to be in the closed position, the provisions of Specification 3.0.4 are not applicable and operation may continue until the next COLD SHUTDOWN provided the surveillance requirements of Specification 4.6.4.1.a are performed on the OPERABLE vacuum breakers within 4 hours and at least once per 15 days thereafter until the inoperable vacuum breakers are restored to OPERABLE status; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With one drywell-suppression chamber vacuum breaker in the open position, as indicated by the position indicating system, the provisions of Specification 3.0.4 are not applicable and operation may continue provided the surveillance requirements of Specification 4.6.4.1.a are performed on the OPERABLE vacuum breakers and the surveillance requirements of Specification 4.6.4.1.b are performed within 8 hours and at least once per 72 hours thereafter until the inoperable vacuum breaker is restored to the closed position; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- c. With the position indicator of any drywell-suppression chamber vacuum breaker inoperable, the provisions of Specification 3.0.4 are not applicable and operation may continue, provided the surveillance requirements of Specification 4.6.4.1.b are performed within 8 hours and at least once per 72 hours thereafter until the inoperable position indicator is returned to OPERABLE status; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.