

May 19, 1988

Docket No. 50-341

Mr. B. Ralph Sylvia
Group Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

DISTRIBUTION

<u>Docket File</u>	JPartlow
NRC & Local PDRs	JCraig
PD31 Plant Gray	ACRS (10)
GHolahan	LMarsh
TQuay	RIngram
EJordan	

Dear Mr. Sylvia:

SUBJECT: MODIFICATION OF ACCEPTANCE CRITERIA FOR SURVEILLANCE LEAKAGE TESTS
ON DRYWELL PURGE AND VENT VALVES WITH RESILIENT SEALS (TAC 65810)

On July 30, 1986, Detroit Edison Company (DECo) requested modification to Section AT-8 (and its associated acceptance criteria) of the Inservice Testing Program for pumps and valves via replacing the current 120% of the previous Type-C test result criteria with that of ASME Section XI, 1980 Edition, Winter 1980 Addenda, paragraph IWV-3427(b).

The 120% value stemmed from a DECo commitment that was reflected on page 6-3 of Supplement Number 1 of the Fermi-2 SER dated September 1981. The staff has reviewed your request and has determined that the 20% increase criterion was not a staff requirement but was in response to a staff request to establish replacement criteria for the seals on the purge and vent valves. We concur that this value may be overly restrictive; therefore, the staff finds your requested modification accomplishes the original purpose without imposing unnecessary seal replacement. Consequently, the staff finds your proposal acceptable and considers TAC 65810 closed.

Sincerely,

Theodore R. Quay

Theodore R. Quay, Project Manager
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects

cc: See next page

LA/PD31:DRSP	PM/PD31:DRSP	D/PD31:DRSP	DEST/EMEB	DEST/PSB
RIngram/ln	TQuay:rl	DMuller	LMarsh	JCraig
5/12/88	5/12/88	5/13/88	5/16/88	5/19/88

OFFICIAL RECORD COPY

8805310219 880519
PDR ADOCK 05000341
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

May 19, 1988

Docket No. 50-341

Mr. B. Ralph Sylvia
Group Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Sylvia:

SUBJECT: MODIFICATION OF ACCEPTANCE CRITERIA FOR SURVEILLANCE LEAKAGE TESTS
ON DRYWELL PURGE AND VENT VALVES WITH RESILIENT SEALS (TAC 65810)

On July 30, 1986, Detroit Edison Company (DECo) requested modification to Section AT-8 (and its associated acceptance criteria) of the Inservice Testing Program for pumps and valves via replacing the current 120% of the previous Type-C test result criteria with that of ASME Section XI, 1980 Edition, Winter 1980 Addenda, paragraph IWV-3427(b).

The 120% value stemmed from a DECo commitment that was reflected on page 6-3 of Supplement Number 1 of the Fermi-2 SER dated September 1981. The staff has reviewed your request and has determined that the 20% increase criterion was not a staff requirement but was in response to a staff request to establish replacement criteria for the seals on the purge and vent valves. We concur that this value may be overly restrictive; therefore, the staff finds your requested modification accomplishes the original purpose without imposing unnecessary seal replacement. Consequently, the staff finds your proposal acceptable and considers TAC 65810 closed.

Sincerely,

Theodore R. Quay

Theodore R. Quay, Project Manager
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects

cc: See next page

Mr. B. Ralph Sylvia
Detroit Edison Company

Fermi-2 Facility

cc:

Mr. Ronald C. Callen
Adv. Planning Review Section
Michigan Public Service Commission
6545 Mercantile Way
P. O. Box 30221
Lansing, Michigan 48909

Ms. Lynn Goodman
Supervisor - Licensing
Detroit Edison Company
Fermi Unit 2
6400 North Dixie Highway
Newport, Michigan 48166

John Flynn, Esq.
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
P. O. Box 30035
Lansing, Michigan 48909

Mr. Thomas Randazzo
Director, Regulatory Affairs
Detroit Edison Company
Fermi Unit 2
6400 North Dixie Highway
Newport, Michigan 48166

Mr. Walt Rogers
U.S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Office of Civil
Preparedness
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137