

McGUIRE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

August 1998

1. Personnel Exposure -

The total station liquid release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

Revision 1

DOCKET: 50 - 369

UNIT: McGuire 1

Date: 09/15/98

NARRATIVE SUMMARY

MONTH: August, 1998

McGuire Unit 1 began the month of August operating at 100% full power. On 08/28/98 at 2029 the unit began decreasing and held at 20% power from 08/29/98 at 0500 to 1038 to repair "1B" feedwater pump bearings and perform ice condenser inspection due to glycol leak. The unit began increasing power and held at 45% power from 08/29/98 at 1249 until 08/31/98 at 2400 to repair "1B" feedwater pump bearings. The unit ended the month operating at 45% full power.

Prepared by: R. A. Williams
Telephone: (704) - 382-5346