

CATAWBA NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

August 1998

1. Personnel Exposure -

The total station liquid release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

Revision 1

DOCKET: 50 - 414

UNIT: Catawba 2

Date: 09/15/98

#### NARRATIVE SUMMARY

MONTH: August, 1998

Catawba Unit 2 began the month of August operating at 100% full power. The unit began core coastdown to end-of-cycle 09 refueling outage on 08/24/98 at 0224. The unit ended the month holding at 94% power due to core coastdown to end-of-cycle 09 refueling outage.

Prepared by: R. A. Williams  
Telephone: (704) - 382-5346