

Lew W. Myers
Vice President

440-280-5915
Fax: 440-280-8029

October 13, 1998
PY-CEI/OEPA-0301L

Ohio Environmental Protection Agency
Division of Water Pollution Control
Enforcement Section, ES/MOR
P. O. Box 1049
Columbus, Ohio 43216-1049


Ladies and Gentlemen:

Enclosed are the NPDES monthly report forms for the month of September, 1998.

No violations occurred during this time period.

If you have questions or require additional information, please contact Ms. Donna Tizzano at (440) 280-5514.

Very truly yours,



DGT

Enclosures

cc: NRC Region III
NRC Resident Inspector
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

1/1
IE25

9810200069 980930
PDR ADOCK 05000440
R PDR

Perry Nuclear Power Plant

3IB00016601 SEP 1998

1 1 10/06/98

0063461

10 Center Rd.
Perry

44081 Lake

601 Discharge from Regenerate Neutralization Pits

FORM

Perry-SB312

D. G. Tizzano

	1 999	1 999	3 000	3 001	3 001	
	CONDUI FLOW MGD	PH (MAX) S.U.	PH (MIN) S.U.	RESIDU TOT NF MG/L	OIL GR TOTAL MG/L	
	50050	00401	00402	00530	00550	
01	.018	7.9	7.2	13	AA	
02	.018	7.0	7.0			
03	AH	AH	AH			
04	AH	AH	AH			
05	AH	AH	AH			
06	AH	AH	AH			
07	AH	AH	AH			
08	.017	7.6	7.1	4	AA	
09	.017	6.8	6.8			
10	AH	AH	AH			
11	AH	AH	AH			
12	AH	AH	AH			
13	AH	AH	AH			
14	AH	AH	AH			
15	AH	AH	AH			
16	.018	8.7	8	2	AA	
17	AH	AH	AH			
18	AH	AH	AH			
19	AH	AH	AH			
20	.017	7.5	7.2			
21	AH	AH	AH			
22	AH	AH	AH			
23	.025	7.0	6.8	1	AA	
24	AH	AH	AH			
25	AH	AH	AH			
26	AH	AH	AH			
27	AH	AH	AH			
28	AH	AH	AH			
29	AH	AH	AH			
30	AH	AH	AH			
31						
	0.1300	52.500	50.100	20.000	AA	
	0.0186	7.5000	7.1571	5.0000	AA	
	0.0250	8.7000	8.0000	13.000	AA	
	0.0170	6.8000	6.8000	1.0000	AA	

AA-Below Detectable Limit (5 mg/L for O&G and
2.5 mg/L for Residue
AH-Sample Not Taken. No Discharge Performed this Date.

REPORTER

10/12/98

[Signature]

[Signature]

Perry Nuclear Power Plant

3IB00016602 SEP 1998

1 1 10/06/98

0063461

10 Center Rd.
Perry

44081 Lake

602 Discharge from Chemical Cleaning Lagoon

FORM

Perry-SB312

D. G. Tizzano

1 999	1 999	3 000	3 001	3 001	3 001
CONDUI FLOW MGD	PH S.U.	RESIDU TOT NF MG/L	COPPER CU,TOT UG/L	IRON TOTAL UG/L	OIL GR TOTAL MG/L
50050	00400	00530	01042	01045	00550

01
02
03
04
05
06
07
08
09
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

No Discharge Occurred During the Month.

REPORTER

10/12/98

Le... ..

v P Nuclear

Perry Nuclear Power Plant

3IB00016004 SEP 1998

1 1 10/06/98

0063461

10 Center Rd.
Perry

44081 Lake

004 POINT REP OF DISCHARGE PRIOR TO TUNNEL ENTRY

FORM

Perry-SB312

D. G. Tizzano

1 999	1 999	3 000	3 001	3 001
WATER TEMP. F	CONDUIT FLOW MGD	CHLORINE FREE A MG/L	PH S.U.	PHOSPHORUS P-WET MG/L
00011	50050	50064	00400	00665

01	82	72.7	0	8.1	
02	82	72.0	0		
03	81	70.4	0		
04	81	70.7	0	8.0	
05	82	66.6	0		
06	83	65.4	0		
07	82	69.5	0		.21
08	81	67.2	0	8.1	
09	80	65.8	0		
10	80	58.1	0		
11	80	64.3	0	8.1	
12	78	83.9	0		
13	79	84.2	0		
14	80	78.2	0		.07
15	81	80.6	0	7.9	
16	81	73.0	0		
17	80	75.3	0		
18	80	68.4	0	8.1	
19	81	72.7	0		
20	80	82.0	0		
21	80	83.9	0		.11
22	78	84.9	0	8.1	
23	78	68.2	0		
24	77	66.0	0		
25	77	74.7	0	8.1	
26	80	66.9	0		
27	81	65.2	0		
28	79	61.6	0		.19
29	80	57.6	0	8.2	
30	75	111.9	0		
31					

2399.0	2181.9	0.0000	72.700	0.5800
79.967	72.730	0.0000	8.0778	0.1450
83.000	111.90	0.0000	8.2000	0.2100
75.000	57.600	0.0000	7.9000	0.0700

None

REPORTER

10/13/98

[Signature]

[Signature]

Perry Nuclear Power Plant

3IB00016800 SEP 1998

1 1 10/06/98

0063461

10 Center Rd.
Perry

44081 Lake

800 INTAKE WATER TO PLANT FROM LAKE ERIE

FORM

Perry-SB312

D. G. Tizzano

1
999

WATER
TEMP.
F

00011

01	77
02	76
03	75
04	75
05	75
06	75
07	75
08	74
09	72
10	72
11	72
12	72
13	72
14	73
15	73
16	73
17	73
18	73
19	73
20	73
21	73
22	73
23	71
24	70
25	69
26	70
27	71
28	71
29	71
30	70
31	

2182.0
72.733
77.000
69.000

none

REPORTER

10/13/98

[Handwritten signature]

JP Nuclear