



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236
Nuclear Business Unit

OCT 13 1998
LR-N980484

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

HOPE CREEK GENERATING STATION
DOCKET NO. 50-354
UNIT NO. 1
LICENSEE EVENT REPORT NO. 98-006-00

Dear Sir:

This Licensee Event Report (LER) entitled "Inadequate Performance of Primary Containment Integrity Verification" is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(i)(B).

Commitments being made by Public Service Electric & Gas Company in connection with this LER are listed in the attachment.

Sincerely,

[Handwritten Signature] FOR M. BEZILLA

Mark Bezilla
General Manager
Hope Creek Operations

[Handwritten Initials]

PRD/
Attachment

C Distribution
LER File
9810200086 981013
PDR ADOCK 03000354
S PDR

The power is in your hands.

Document Control Desk
LR-N980484

Attachment 1

PSE&G is making the following commitment to the NRC in connection with LER 354/98-006-00:

1. The surveillance procedure for PRIMARY CONTAINMENT INTEGRITY verification will be revised to ensure current area radiological conditions are assessed in determining when field verification of valve position is required. This activity will be completed by October 15, 1998.