

Docket Nos.: 50-498
and 50-499

MAR 07 1986

Mr. J. H. Goldberg
Group Vice President - Nuclear
Houston Lighting and Power Company
Post Office Box 1700
Houston, Texas 77001

Dear Mr. Goldberg:

SUBJECT: CONFORMANCE OF THE SOUTH TEXAS PROJECT, UNITS 1 AND 2
TO THE SALEM ATWS FOLLOW-UP ACTIONS IN GENERIC LETTER 83-28

This letter is to acquaint you with the status of conformance to the items in the Generic Letter 83-28 for South Texas, and indicate what actions remain to be taken so that the Project can be brought into conformance in this area. The Enclosure 1 is a tabulation of each of the items contained in the Generic Letter showing either the status or referring to a subsequent Enclosure which provides an evaluation. As shown in the tabulation, several of the items remain open, either due to incomplete NRC staff review or because additional information is needed from you.

The action requested of you by this letter is to provide the additional information as indicated in the Enclosures. Subsequent requests for additional information may be forthcoming as the staff complete the reviews. Please call me at 301-492-7272, if you have any questions.

Sincerely,

N. P. Kadambi, Project Manager
PWR Project Directorate #5
Division of PWR Licensing-A

Enclosures:

1. G. L. 83-28 Items Summary
2. SAIC TER on Item 1.2
3. NRC Staff SER on Item 4.3

cc: See next page

Distribution:

<u>Docket file</u>	E. Jordan
NRC PDR	B. Grimes
Local PDR	J. Partlow
PD#5 Reading Files	P. Kadambi
T. Novak	M. Rushbrook
OELD	ACRS (10)

OFC : PD#5	NPK	:	:	:	:	:	:
NAME : NPKadambi	:	:	:	:	:	:	:
DATE : 3/7/86	:	:	:	:	:	:	:

Mr. J. H. Goldberg
Houston Lighting and Power Company

South Texas Project

cc:

Brian Berwick, Esq.
Assistant Attorney General
Environmental Protection Division
P.O. Box 12548
Capitol Station
Austin, Texas 78711

Resident Inspector/South Texas
Project
c/o U. S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, Texas 77414

Mr. J. T. Westermeir
Manager, South Texas Project
Houston Lighting and Power Company
P. O. Box 1700
Houston, Texas 77001

Mr. Jonathan Davis
Assistant City Attorney
City of Austin
P. O. Box 1088
Austin, Texas 78767

Mr. H. L. Peterson
Mr. G. Porkorny
City of Austin
P. O. Box 1088
Austin, Texas 78767

Ms. Pat Coy
Citizens Concerned About Nuclear
Power
5106 Casa Oro
San Antonio, Texas 78233

Mr. J. B. Poston
Mr. A. Von Rosenberg
City Public Service Board
P. O. Box 1771
San Antonio, Texas 78296

Mr. Mark R. Wisenberg
Manager, Nuclear Licensing
Houston, Lighting and Power Company
P. O. Box 1700
Houston, Texas 77001

Jack R. Newman, Esq.
Newman & Holtzinger, P. C.
1615 I Street, NW
Washington, D. C. 20036

Mr. Charles Halligan
Mr. Burton L. Ilex
Bechtel Corporation
P. O. Box 2166
Houston, Texas 77001

Melbert Schwartz, Jr., Esq.
Baker & Botts
One Shell Plaza
Houston, Texas 77002

Mr. E. R. Brooks
Mr. R. L. Range
Central Power and Light Company
P. O. Box 2122
Corpus Christi, Texas 78403

Mrs. Peggy Buchorn
Executive Director
Citizens for Equitable Utilities, Inc.
Route 1, Box 1684
Brazoria, Texas 77422

cc:
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Lanny Sinkin
Council for Intervenor
Citizens Concerned about Nuclear Power, Inc.
Christic Institute
1324 North Capitol Street
Washington, D. C. 20002

Mr. S. Head, Representative
Houston Lighting and Power Company
Suite 1309
7910 Woodmont Avenue
Bethesda, Maryland 20814

ENCLOSURE 1

GENERIC LETTER 83-28 ITEMS STATUS SUMMARY

<u>G. L. ITEM NUMBER</u>	<u>STATUS</u>	<u>ACTION, COMMENT OR REFERENCE</u>
1.1	Open	NRC review to be completed.
1.2	Open	Additional information required as shown in TER provided as Enclosure 2 herewith.
2.1	Open	NRC review to be completed.
2.2	Open	NRC review to be completed.
3.1.1	Open	NRC review to be completed.
3.1.2	Open	NRC review to be completed.
3.1.3	Open	NRC review to be completed.
3.2.1	Open	NRC review to be completed.
3.2.2	Open	NRC review to be completed.
3.2.3	Open	NRC review to be completed.
4.1	Closed	Letter to Goldberg, October 30, 1985
4.2.1	Closed	Letter to Goldberg, October 30, 1985
4.2.2	Closed	Letter to Goldberg, October 30, 1985
4.2.3	Open	Pending WOG submittal
4.2.4	Open	Pending WOG submittal
4.3	Partially Open	Enclosure 3 provides the SER and points out the open item regarding Tech. Specs.
4.4	Not Applicable	Applies only to B & W plants.
4.5.1	Open	NRC review to be completed.
4.5.2	Open	NRC review to be completed.
4.5.3	Open	NRC review to be completed.

SAIC-85/3092

REVIEW OF LICENSEE AND APPLICANT RESPONSES
TO NRC GENERIC LETTER 83-28
(Required Actions Based on Generic Implications of
Salem ATWS Events), Item 1.2
"POST-TRIP REVIEW: DATA AND INFORMATION CAPABILITIES" FOR
SOUTH TEXAS PROJECT, UNITS 1 AND 2 (50-498, 50-499)

October 2, 1985

Technical Evaluation Report

Prepared by

Science Applications International Corporation
1710 Goodridge Drive
McLean, Virginia 22102

Prepared for

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Contract No. NRC-03-82-096

851070199
14 pp

FOREWORD

This report contains the technical evaluation of the South Texas Project Units 1 and 2 response to Generic Letter 83-28 (Required Actions Based on Generic Implications of Salem ATWS Events), Item 1.2 "Post Trip Review: Data and Information Capabilities." This report supercedes report number SAIC-85/1516 part 4, dated July 10, 1985. This report contains an evaluation of material received by SAIC after July 10, 1985.

For the purposes of this evaluation, the review criteria, presented in part 2 of this report, were divided into five separate categories. These are:

1. The parameters monitored by the sequence of events and the time history recorders,
2. The performance characteristics of the sequence of events recorders,
3. The performance characteristics of the time history recorders,
4. The data output format, and
5. The long-term data retention capability for post-trip review material.

All available responses to Generic Letter 83-28 were evaluated. The plant for which this report is applicable was found to have adequately responded to, and met, categories 2, 3 and 4.

The report describes the specific methods used to determine the categorization of the responses to Generic Letter 83-28. Since this evaluation report was intended to apply to more than one nuclear power plant specifics regarding how each plant met (or failed to meet) the review criteria are not presented. Instead, the evaluation presents a categorization of the responses according to which categories of review criteria are satisfied and which are not. The evaluations are based on specific criteria (Section 2) derived from the requirements as stated in the generic letter.

TABLE OF CONTENTS

Section	Page
Introduction.	1
1. Background.	2
2. Review Criteria	3
3. Evaluation.	8
4. Conclusion.	9
5. References.	10

INTRODUCTION

SAIC has reviewed the utility's response to Generic Letter 83-28, item 1.2 "Post-Trip Review: Data and Information Capability." The response (see references) contained sufficient information to determine that the data and information capabilities at this plant are acceptable in the following areas.

- The sequence-of-events recorder(s) performance characteristics.
- The time history recorder(s) performance characteristics.
- The output format of the recorded data.

However, the data and information capabilities, as described in the submittal, either fail to meet the review criteria or provide insufficient information to allow determination of the adequacy of the data and information capabilities in the following areas.

- The parameters monitored by both the sequence-of-events and time history recorders.
- The long-term data retention, record keeping, capability.

1. Background

On February 25, 1984, both of the scram circuit breakers at Unit 1 of the Salem Nuclear Power Plant failed to open upon an automatic reactor trip signal from the reactor protection system. This incident occurred during the plant startup and the reactor was tripped manually by the operator about 30 seconds after the initiation of the automatic trip signal. The failure of the circuit breakers has been determined to be related to the sticking of the under voltage trip attachment. Prior to this incident; on February 22, 1983; at Unit 1 of the Salem Nuclear Power Plant an automatic trip signal was generated based on steam generator low-low level during plant startup. In this case the reactor was tripped manually by the operator almost coincidentally with the automatic trip. At that time, because the utility did not have a requirement for the systematic evaluation of the reactor trip, no investigation was performed to determine whether the reactor was tripped automatically as expected or manually. The utilities' written procedures required only that the cause of the trip be determined and identified the responsible personnel that could authorize a restart if the cause of the trip is known. Following the second trip which clearly indicated the problem with the trip breakers, the question was raised on whether the circuit breakers had functioned properly during the earlier incident. The most useful source of information in this case, namely the sequence of events printout which would have indicated whether the reactor was tripped automatically or manually during the February 22 incident, was not retained after the incident. Thus, no judgment on the proper functioning of the trip system during the earlier incident could be made.

Following these incidents; on February 28, 1983; the NRC Executive Director for Operations (EDO), directed the staff to investigate and report on the generic implications of these occurrences at Unit 1 of the Salem Nuclear Power Plant. The results of the staff's inquiry into the generic implications of the Salem Unit incidents is reported in NUREG-1000, "Generic Implications of ATWS Events at the Salem Nuclear Power Plant." Based on the results of this study, a set of required actions were developed and included in Generic Letter 83-28 which was issued on July 8, 1983 and sent to all licensees of operating reactors, applicants for operating license, and construction permit holders. The required actions in this generic letter consist of four categories. These are: (1) Post-Trip Review, (2) Equipment

Classification and Vender Interface, (3) Post Maintenance Testing, and (4) Reactor Trip System Reliability Improvements.

The first required action of the generic letter, Post-Trip Review, is the subject of this TER and consists of action item 1.1 "Program Description and Procedure" and action item 1.2 "Data and Information Capability." In the next section the review criteria used to assess the adequacy of the utilities' responses to the requirements of action item 1.2 will be discussed.

2. Review Criteria

The intent of the Post Trip Review requirements of Generic Letter 83-28 is to ensure that the licensee has adequate procedures and data and information sources to understand the cause(s) and progression of a reactor trip. This understanding should go beyond a simple identification of the course of the event. It should include the capability to determine the root cause of the reactor trip and to determine whether safety limits have been exceeded and if so to what extent. Sufficient information about the reactor trip event should be available so that a decision on the acceptability of a reactor restart can be made.

The following are the review criteria developed for the requirements of Generic Letter 83-28, action item 1.2:

The equipment that provides the digital sequence of events (SOE) record and the analog time history records of an unscheduled shutdown should provide a reliable source of the necessary information to be used in the post trip review. Each plant variable which is necessary to determine the cause(s) and progression of the event(s) following a plant trip should be monitored by at least one recorder [such as a sequence-of-events recorder or a plant process computer for digital parameters; and strip charts, a plant process computer or analog recorder for analog (time history) variables]. Each device used to record an analog or digital plant variable should be described in sufficient detail so that a determination can be made as to whether the following performance characteristics are met:

- Each sequence-of-events recorder should be capable of detecting and recording the sequence of events with a sufficient time discrimination capability to ensure that the time responses associated with each monitored safety-related system can be ascertained, and that a determination can be made as to whether the time response is within acceptable limits based on FSAR Chapter 15 Accident Analyses. The recommended guideline for the SOE time discrimination is approximately 100 msec. If current SOE recorders do not have this time discrimination capability the licensee or applicant should show that the current time discrimination capability is sufficient for an adequate reconstruction of the course of the reactor trip. As a minimum this should include the ability to adequately reconstruct the accident scenarios presented in Chapter 15 of the plant FSAR.
- Each analog time history data recorder should have a sample interval small enough so that the incident can be accurately reconstructed following a reactor trip. As a minimum, the licensee or applicant should be able to reconstruct the course of the accident sequences evaluated in the accident analysis of the plant FSAR (Chapter 15). The recommended guideline for the sample interval is 10 sec. If the time history equipment does not meet this guideline, the licensee or applicant should show that the current time history capability is sufficient to accurately reconstruct the accident sequences presented in Chapter 15 of the FSAR.
- To support the post trip analysis of the cause of the trip and the proper functioning of involved safety related equipment, each analog time history data recorder should be capable of updating and retaining information from approximately five minutes prior to the trip until at least ten minutes after the trip.
- The information gathered by the sequence-of-events and time history data collectors should be stored in a manner that will allow for retrieval and analysis. The data may be retained in either hardcopy (computer printout, strip chart output, etc.) or in an accessible memory (magnetic disc or tape). This information should be presented in a readable and meaningful format, taking

into consideration good human factors practices (such as those outlined in NUREG-0700).

- All equipment used to record sequence of events and time history information should be powered from a reliable and non-interruptible power source. The power source used need not be safety related.

The sequence of events and time history recording equipment should monitor sufficient digital and analog parameters, respectively, to assure that the course of the reactor trip can be reconstructed. The parameters monitored should provide sufficient information to determine the root cause of the reactor trip, the progression of the reactor trip, and the response of the plant parameters and systems to the reactor trip. Specifically, all input parameters associated with reactor trips, safety injections and other safety-related systems as well as output parameters sufficient to record the proper functioning of these systems should be recorded for use in the post trip review. The parameters deemed necessary, as a minimum, to perform a post-trip review (one that would determine if the plant remained within its design envelope) are presented on Tables 1.2-1 and 1.2-2. If the applicants' or licensees' SOE recorders and time history recorders do not monitor all of the parameters suggested in these tables the applicant or licensee should show that the existing set of monitored parameters are sufficient to establish that the plant remained within the design envelope for the appropriate accident conditions; such as those analyzed in Chapter 15 of the plant Safety Analysis Report.

Information gathered during the post trip review is required input for future post trip reviews. Data from all unscheduled shutdowns provides a valuable reference source for the determination of the acceptability of the plant vital parameter and equipment response to future unscheduled shutdowns. It is therefore necessary that information gathered during all post trip reviews be maintained in an accessible manner for the life of the plant.

Table 1.2-1. PWR Parameter List

<u>SOE Recorder</u>	<u>Time History Recorder</u>	<u>Parameter / Signal</u>
x		Reactor Trip
(1) x		Safety Injection
x		Containment Isolation
(1) x		Turbine Trip
x		Control Rod Position
(1) x	x	Neutron Flux, Power
x	x	Containment Pressure
(2)		Containment Radiation
	x	Containment Sump Level
(1) x	x	Primary System Pressure
(1) x	x	Primary System Temperature
(1) x		Pressurizer Level
(1) x		Reactor Coolant Pump Status
(1) x	x	Primary System Flow
(3)		Safety Inj.; Flow, Pump/Valve Status
x		MSIV Position
x	x	Steam Generator Pressure
(1) x	x	Steam Generator Level
(1) x	x	Feedwater Flow
(1) x	x	Steam Flow
(3)		Auxiliary Feedwater System; Flow, Pump/Value Status
x		AC and DC System Status (Bus Voltage)
x		Diesel Generator Status (Start/Stop, On/Off)
x		PORV Position

(1): Trip parameters

(2): Parameter may be monitored by either an SOE or time history recorder.

(3): Acceptable recorder options are: (a) system flow recorded on an SOE recorder, (b) system flow recorded on a time history recorder, or (c) equipment status recorded on an SOE recorder.

Table 1.2-2. BWR Parameter List

<u>SOE Recorder</u>	<u>Time History Recorder</u>	<u>Parameter / Signal</u>
x		Reactor Trip
x		Safety Injection
x		Containment Isolation
x		Turbine Trip
x		Control Rod Position
x (1)	x	Neutron Flux, Power
x (1)		Main Steam Radiation
(2)		Containment (Dry Well) Radiation
x (1)	x	Drywell Pressure (Containment Pressure)
(2)		Suppression Pool Temperature
x (1)	x	Primary System Pressure
x (1)	x	Primary System Level
x		MSIV Position
x (1)		Turbine Stop Valve/Control Valve Position
x		Turbine Bypass Valve Position
	x	Feedwater Flow
	x	Steam Flow
(3)		Recirculation; Flow, Pump Status
x (1)		Scram Discharge Level
x (1)		Condenser Vacuum
x		AC and DC System Status (Bus Voltage)
(3)(4)		Safety Injection; Flow, Pump/Valve Status
x		Diesel Generator Status (On/Off, Start/Stop)

(1): Trip parameters.

(2): Parameter may be recorded by either an SOE or time history recorder.

(3): Acceptable recorder options are: (a) system flow recorded on an SOE recorder, (b) system flow recorded on a time history recorder, or (c) equipment status recorded on an SOE recorder.

(4): Includes recording of parameters for all applicable systems from the following: HPCI, LPCI, LPCS, IC, RCIC.

3. Evaluation

The parameters identified in part 2 of this report as a part of the review criteria are those deemed necessary to perform an adequate post-trip review. The recording of these parameters on equipment that meets the guidelines of the review criteria will result in a source of information that can be used to determine the cause of the reactor trip and the plant response to the trip, including the responses of important plant systems. The parameters identified in this submittal as being recorded by the sequence of events and time history recorders do not correspond to the parameters specified in part 2 of this report.

The information provided in the submittal indicates that the equipment used to monitor the digital and analog parameters meets the minimal requirements set forth in part 2 of this report. The sequence of events and analog time history recorders are powered from a non-interruptable power supply. The monitoring characteristics are all within the guidelines of the review criteria.

The data and information recorded for use in the post-trip review should be output in a format that allows for ease of identification and use of the data to meet the review criterion that calls for information in a readable and meaningful format. The information contained in this submittal indicates that this criterion is met.

The data and information used during a post-trip review should be retained as part of the plant files. This information could prove useful during future post-trip reviews. Therefore one criterion presented in part 2 of this report is that information used during a post-trip review be maintained in an accessible manner for the life of the plant. Information contained within this submittal does not indicate that this criterion will be met.

4. Conclusion

The information supplied in response to Generic Letter 83-28 indicates that the current post-trip review data and information capabilities are adequate in the following areas:

1. The SOE recorders meet the minimum performance characteristics.
2. The time history recorders meet the minimum performance characteristics.
3. The recorded data is output in a readable and meaningful format.

The information supplied in response to Generic Letter 83-28 does not indicate that the post-trip review data and information capabilities are adequate in the following areas:

1. As described in the submittal, sufficient analog and digital parameters are not recorded for use in the post-trip review.
2. The data retention procedures, as described in the submittal, may not ensure that the information recorded for the post-trip review is maintained in an accessible manner for the life of the plant.

It is possible that the current data and information capabilities at this nuclear power plant are adequate to meet the intent of these review criteria, but were not completely described. Under these circumstances, the licensee should provide an updated, more complete, description to show in more detail the data and information capabilities at this nuclear power plant. If the information provided accurately represents all current data and information capabilities, then the licensee should either show that the current post trip review data and information capabilities are adequate to meet the intent of the criteria in part 2 of this report, or detail future modifications that would enable the licensee to meet the intent of the evaluation criteria.

REFERENCES

NRC Generic Letter 83-28. "Letter to all licensees of operating reactors, applicants for operating license, and holders of construction permits regarding Required Actions Based on Generic Implications of Salem ATWS Events." July 8, 1983.

NUREG-1000, Generic Implications of ATWS Events at the Salem Nuclear Power Plant, April 1983.

Letter from J.H. Goldberg, Houston Lighting and Power, to D.G. Eisenhut, NRC, dated November 3, 1983, Accession Number 8311210275 in response to Generic Letter 83-28 of July 8, 1983, with attachment.

Letter from J.G. Dewease, Houston Lighting & Power, to H.L. Thompson, NRC, dated February 26, 1985, Accession Number 8503050319 providing partial response to Generic Letter 83-28.

Letter from J.H. Goldberg, Houston Lighting and Power, to H.L. Thompson USNRC, dated June 28, 1985, Accession Number 8507150281, providing additional response to Generic Letter 83-28 of July 8, 1983, for South Texas Project, Units 1 and 2.

SUPPORTING DOCUMENT FOR TELECON

South Texas Project

1. Parameters recorded: **Unsatisfactory**

No parameter lists were provided. However basis described for the selection of parameters would appear to include most, if not all, of the desirable parameters.

2. SOE recorders performance characteristics: **Satisfactory**

Plant computer: 4msec time discrimination with a non Class 1E uninterruptible power supply

3. Time history recorders performance characteristics: **Satisfactory**

Plant computer: Data sampled at 10 secs intervals for the period from ten minutes prior to the trip to ten minutes after the trip

ERFDADS: Data sampled at 0.5 sec intervals from the time of the trip until 10 min post trip

4. Data output format: **Satisfactory**

SOE data output includes time of event, sensor ID, and parameter/event descriptor

Analog data output includes time and parameter name and value

5. Data retention capability: **Unsatisfactory**

The length of time the data is retained is not specified.