

MAY 24 1988

Docket No. 50-352

Philadelphia Electric Company  
ATTN: Mr. C. A. McNeill  
Executive Vice President  
Nuclear  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Gentlemen:

Subject: Inspection No. 50-352/88-07

This refers to the routine safety inspection of your Inservice Testing (IST) activities conducted by Mr. Harold I. Gregg of this office on March 14-15, 1988, March 17, 1988, and March 21-24, 1988, at the Limerick Generating Station, Unit 1. Mr. Gregg also visited your corporate engineering office on March 16, 1988. Mr. Gregg discussed the inspection findings with Mr. P. Duca and other members of your staff at the conclusion of the inspection.

Areas examined during this Inservice Testing implementation inspection are described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection reviewed background data, organization, the engineering interface, and performed selective examinations of procedures, representative records, interviews with personnel, observations of equipment, and test witnessing.

Within the scope of this inspection, no violations were observed, however, four inspection findings were categorized as unresolved items and warrant your attention. The first unresolved item (50-352/88-07-01) groups four concerns that are being addressed by your staff. These concerns relate to your IST program control, organizational procedure, general valve stroke time limits, and time limits for valves with stroke times less than 10 seconds. The other three unresolved items relate to: 1) controls on lubricating a valve stem to enable a stroke time to be met; 2) pump acceptance criteria ranges; and, 3) seismic calculations for an air operated valve.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:

Jacque P. Durr  
Chief, Engineering Branch  
Division of Reactor Safety

Enclosure: NRC Region I Inspection Report Number 50-352/88-07  
OFFICIAL RECORD COPY IR LIM1 88-07 - 0001.0.0  
05/16/88

8806010213 880524  
PFR ADOCK 05000352  
R DCD

IEO  
11


cc w/encl:


John S. Kemper, Sr., Senior Vice President - Nuclear  
E. C. Kistner, Chairman, Nuclear Review Board  
Graham M. Leitch, Vice President, Limerick Generating Station  
J. W. Gallagher, Vice President - Nuclear  
Troy B. Conner, Jr., Esquire  
Eugene J. Bradley, Esquire, Assistant General Counsel  
W. M. Alden, Director, Licensing Section  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania

bcc w/encl:


Region I Docket Room (with concurrences)  
Management Assistant, DRMA (w/o encl)  
Section Chief, DRP  
Robert J. Bores, DRSS

RI:DRS  
Gregg/tlm/rw

  
5/17/88

  
RI:DRS  
Eapen

5/19/88

  
RI:DRS  
Durr

5/17/88

OFFICIAL RECORD COPY

IR LIM1 88-07 - 0001.1.0  
05/04/88