

Attachment A  
Monthly Operating Report for July 1988

Consolidated Edison Company of New York, Inc.  
Indian Point Unit No. 2  
Docket No. 50-247  
September 13, 1988

BB09290032 BB0915  
PDR ADOCK 05000247  
R PNU

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-247  
 UNIT NAME IP Unit No. 2  
 DATE 8/9/88  
 COMPLETED BY K. Krieger  
 TELEPHONE (914) 526-5155

REPORT MONTH July 1988

(REVISED)

| No. | Date   | Type <sup>1</sup> | Duration (Hours) | Reason <sup>2</sup> | Method of Shutting Down Reactor <sup>3</sup> | Licensee Event Report # | System Code <sup>4</sup> | Component Code <sup>5</sup> | Cause & Corrective Action to Prevent Recurrence |
|-----|--------|-------------------|------------------|---------------------|--|-------------------------|--------------------------|-----------------------------|---|
| 6   | 880707 | F                 | 42508            | A                   | 1  | - NA -                  | CH                       | HTEXCH                      | 22 Steam Generator Tube Leak                    |

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

<sup>4</sup>  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-6161)

<sup>5</sup>  
 Exhibit I - Same Source