

ILLINOIS POWER COMPANY



CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

DPH-0481-88  
May 27, 1988

Docket No. 50-461

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555


Subject: Clinton Power Station  
Response to NRC Bulletin 85-03, Supplement 1

Dear Sir:

This letter is in response to the Nuclear Regulatory Commission's (NRC) Bulletin No. 85-03, Supplement 1, "Motor-Operated Valve Common Mode Failures During Plant Transients Due to Improper Switch Settings." The scope of the previous Illinois Power Company (IP) responses to bulletin 85-03 covered all safety related Motor Operated Valves (MOV) in the High Pressure Core Spray (HPCS) and Reactor Core Isolation Cooling (RCIC) systems and their operability. Therefore, no additional actions are required of IP as a result of this supplement.

I hereby affirm that the information in this letter is correct to the best of my knowledge.

Sincerely yours,

  
D. P. Hall  
Vice President

DPH/bjq

cc: Regional Administrator, Region III, USNRC  
NRC Clinton Licensing Project Manager  
NRC Resident Inspector  
Illinois Department of Nuclear Safety

1E11  
1/0