

ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATION CHANGE

SEQUOYAH NUCLEAR PLANT UNIT 2

DOCKET NO. 50-328

(TVA-SQN-TS-88-02)

LIST OF AFFECTED PAGES

Unit 2

3/4 7-5

B 3/4 7-2

PLANT SYSTEMS

AUXILIARY FEEDWATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.1.2 At least three independent steam generator auxiliary feedwater pumps and associated flow paths shall be OPERABLE with:

- a. Two motor-driven auxiliary feedwater pumps, each capable of being powered from separate shutdown boards, and
- b. One turbine-driven auxiliary feedwater pump capable of being powered from an OPERABLE steam supply system.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

- a. With one auxiliary feedwater pump inoperable, restore the required auxiliary feedwater pumps to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With two auxiliary feedwater pumps inoperable, be in at least HOT STANDBY within 6 hours and in HOT SHUTDOWN within the following 6 hours.
- c. With three auxiliary feedwater pumps inoperable, immediately initiate corrective action to restore at least one auxiliary feedwater pump to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

4.7.1.2 In addition to the requirements of Specification 4.0.5 each auxiliary feedwater pump shall be demonstrated OPERABLE by:

- a. Verifying that:
 - 1. each motor-driven pump develops a differential pressure of greater than or equal to ~~1397~~ psid on recirculation flow.
the values indicated below
 - 2. the steam-turbine driven pump develops a differential pressure of greater than or equal to ~~1183~~ psid on recirculation flow when the secondary steam supply pressure is greater than 842 psig. The provisions of Specification 4.0.4 are not applicable for entry into MODE 3. *1165*

R2

SEQUOYAH - UNIT 2

[2A-A greater than or equal to 1490 psid
2B-B greater than or equal to 1432 psid] ~~Amendment 2~~
3/4 7-5 ~~9/15/81~~

PLANT SYSTEMS

BASES

SAFETY VALUES (Continued)

- 109 = Power Range Neutron Flux-High Trip Setpoint for 4 loop operation
- 76 = Maximum percent of RATED THERMAL POWER permissible by P-8 Setpoint for 3 loop operation.
- X = Total relieving capacity of all safety valves per steam line in lbs/hour, 4.75×10^6 lbs/hr at 1170 psig
- Y = Maximum relieving capacity of any one safety valve in lbs/hour, 9.5×10^5 lbs/hr at 1170 psig.

3/4.7.1.2 AUXILIARY FEEDWATER SYSTEM

The OPERABILITY of the auxiliary feedwater system ensures that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions in the event of a total loss of off-site power.

The steam driven auxiliary feedwater pump is capable of delivering 880 gpm (total feedwater flow) and each of the electric driven auxiliary feedwater pumps are capable of delivering 440 gpm (total feedwater flow) to the entrance of the steam generators at steam generator pressures less than 1133 psia. At 1133 psia the open steam generator safety valve(s) are capable of relieving at least 11% nominal steam flow. A total feedwater flow of 440 gpm at pressures less than 1133 psia is sufficient to ensure that adequate feedwater flow is available to remove decay heat and reduce the Reactor Coolant System temperature to less than 350°F where the Residual Heat Removal System may be placed into operation. *The surveillance differential pressure test values ensure that each pump will provide at least 440 gpm plus pump recirculation flow against a steam generator pressure of 1100 psia.*

3/4.7.1.3 CONDENSATE STORAGE TANK

The OPERABILITY of the condensate storage tank with the minimum water volume ensures that sufficient water is available to maintain the RCS at HOT STANDBY conditions for 2 hours with steam discharge to the atmosphere concurrent with total loss of off-site power. The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.

3/4.7.1.4 ACTIVITY

The limitations on secondary system specific activity ensure that the resultant off-site radiation dose will be limited to a small fraction of 10 CFR Part 100 limits in the event of a steam line rupture. This dose also includes the effects of a coincident 1.0 GPM primary to secondary tube leak in the steam generator of the affected steam line. These values are consistent with the assumptions used in the accident analyses.

ENCLOSURE 2

PROPOSED TECHNICAL SPECIFICATION CHANGE

SEQUOYAH NUCLEAR PLANT UNIT 2

DOCKET NO. 50-328

(TVA-SQN-TS-88-02)

DESCRIPTION AND JUSTIFICATION FOR
REVISING SURVEILLANCE REQUIREMENT 4.7.1.2.a

ENCLOSURE 2

Description of Change

TVA proposes to modify the Sequoyah Nuclear Plant unit 2 technical specifications to revise SR 4.7.1.2.a to add pump-specific, differential pressure test values for each auxiliary feedwater (AFW) pump. The associated bases section is revised to clarify the AFW technical specification requirements.

Reason for Change

By letter dated June 26, 1987, TVA provided information to NRC that detailed the need for a revision to the differential pressure test values specified in SR 4.7.1.2.a. The revision to the motor-driven (MD) AFW pump differential pressure test values is necessary because of the replacement of MD pump discharge pressure control valves (PCVs) with cavitating venturis. This modification increased the system resistance of the MDAFW flow paths and thus increased the differential pressure developed by the MDAFW pumps necessary to provide adequate flow to the steam generators. In this letter, TVA indicated that testing would be performed during unit 2 heatup to regenerate as necessary the system resistance curves.

In a September 24, 1987 letter to NRC, additional information was provided on the issue of MDAFW pump operability. This letter indicated that the element of the 2A-A MDAFW pump had been replaced to increase available margin. Because of the replacement of the pump's element, a new pump curve was required for the 2A-A MDAFW pump. This letter detailed how the new pump curve would be used in conjunction with the system resistance curves to establish the new SR differential pressure test values. A safety evaluation report (SER) dated November 2, 1987, was received from NRC that provided NRC concurrence with TVA's methodology for developing the new SR test values. The revisions to the MDAFW pump differential pressure test values are made based on calculations generated from the test data accumulated during unit 2 heatup. This is in accordance with the commitments made in the two TVA letters and recognized in the NRC SER.

As the result of a revised pump curve and more conservative assumptions in calculating the necessary head to ensure adequate flow to the steam generator, a revision is being made to the differential pressure test value of the turbine-driven (TD) AFW pump.

To provide clarification of the AFW technical specification requirements, a revision to the bases is being made and is included for information.

Justification for Change

The Division of Nuclear Engineering (DNE) calculation B25 880430 807 (attachment 1) determines the new AFW pump differential pressure test values. A summary of the calculation results is provided on page 1 of the calculation package. The differential test pressures are determined by two methods. Method one is based on the calculated system resistances generated by DNE calculation B25 880430 806 (attachment 2), whereas

method two utilizes system resistances developed from plant test data. The differential pressure test values that are added to SR 4.7.1.2.a for the MDAFW pumps are those calculated by method two to avoid being overly conservative.

The required head to produce 465 gallons per minute (gal/min) (440 gal/min to the steam generators and 25 gal/min recirculation flow) against a steam generator pressure of 1,100 pounds per square inch absolute (psia) is calculated on sheet 5 of attachment 1 for the MDAFW pumps. The available pump head is obtained from pump-specific head curves. The difference in these two values is the allowable degradation of the pumps, assuming uniform degradation of the pumps. The allowable values are found on page 9 of attachment 1.

Because the pumps are tested on recirculation, a minimum head value at recirculation must be calculated. The allowable degradation value is subtracted from the available pump head at recirculation flow. The remaining value is the minimum acceptable head at recirculation flow. These results are also found on page 9 of attachment 1. As shown on page 9 and the summary sheet, the minimum acceptable differential pressure test value of the 2A-A MDAFW pump is 3,439.8 feet (1,490 pounds per square inch differential [psid]). For the 2B-B MDAFW pump, the test value is 3,305.9 feet (1,432 psid).

The same methodology was used to calculate the minimum acceptable head for the TDAFW pump. As shown on page 12 of attachment 1, a differential pressure test value of 2,689.3 feet (1,165 psid) ensures the TDAFW pump's ability to deliver 490 gal/min (440 gal/min to the steam generators and 50 gal/min recirculation flow) against a steam generator pressure of 1,100 psia.

The pump-specific, differential pressure values added to SR 4.7.1.2.a contain no allowance for test instrument error. This is consistent with other safety-related pump flow and pressure test values contained in the technical specifications.

In summary, the proposed revision to SR 4.7.1.2.a provides specific differential pressure test values. The individual pump values merely reflect the different pump curves and different flow paths associated with the individual pumps. The values added to SR 4.7.1.2.a ensure that the pumps will deliver at least 440 gal/min plus recirculation flow at steam generator pressures of 1,100 psia. This ensures that plant operation is bounded by the assumptions for AFW flow in the various Final Safety Analysis Report (FSAR) analyses described in FSAR section 10.4.7.2.

The revision made to section 3/4.7.1.2 of the bases is made to clarify the technical specification requirements for AFW. The change is an enhancement and is included for information.

TVA 10697 (DNE 6-86)

DNE CALCULATIONS

TITLE MINIMUM HEAD REQUIRED FOR THE TURBINE - DRIVEN AND MOTOR-DRIVEN AUXILIARY FEEDWATER (AFW) PUMPS				PLANT/UNIT SEQUOYAH / UNITS 1&2
PREPARING ORGANIZATION DNE - MEB		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) PUMPS, HEAD, FEEDWATER		
BRANCH/PROJECT IDENTIFIERS 2219280000		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in. Rev (for RIMS' use) RIMS accession number		
APPLICABLE DESIGN DOCUMENT(S) DESIGN CRITERIA SGN - DC - V - 13.9.B		RO 830603E0074	MEB ' 830527 301	
SAR SECTION(S) 10.4.7.2		RIMS accession number 871229F0009 39 B25 871222 800 B25 880430 807		
UNID SYSTEM(S) 03B		INFORMATION ONLY		
Revision 0	3PB	R23	R24	R35
ECN No. (or indicate Not Applicable) N/A		Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
Prepared J. W. WARREN	Checked J. W. ADERHOLDT			Statement of Problem TECH. SPEC. REQUIRES THAT THE MOTOR AND TURBINE DRIVEN AUX. FW PUMPS BE PERIODICALLY TESTED TO DETERMINE IF THE HEAD DEVELOPED BY THE PUMP IS ADEQUATE TO PERFORM ITS SAFETY FUNCTION. DETERMINE THIS MINIMUM DEVELOPED HEAD FOR THE MOTOR - DRIVEN AND TURBINE - DRIVEN AFW PUMPS.
Reviewed J. W. WARREN	Approved L. W. BOYD			
Date 5-25-83	21 Dec '87 30 April '88			
List all pages added by this revision.	3, 3a, 4, 4a, 5a-5h, D1			
List all pages deleted by this revision.	2, 3, 3a-3c, 4, 5a, 5c-5f, 6-12, 5h			
List all pages changed by this revision.	1, 1a, 5, 6a, 2-5, 7-9, 11, 12			
Abstract				
These calculations contain an unverified assumption(s) that must be verified later. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>				
A CALCULATION WAS PERFORMED TO DETERMINE THE MINIMUM TOTAL DEVELOPED HEAD (TDH) THAT THE MOTOR - DRIVEN AND TURBINE - DRIVEN AFW PUMPS MUST DEVELOP AT RECIRCULATION (TEST) CONDITIONS TO ASSURE THAT THE PUMPS WILL DEVELOP ADEQUATE TDH AT DESIGN FLOW CONDITIONS. THE RESULTS OF THE CALCULATIONS WERE :				
<u>Minimum TDH</u>				
MOTOR - DRIVEN AFW PUMPS -		1A-A : (later) psid		
		1B-B : (later) psid		
		2A-A : 1511 psid		
		2B-B : 1450 psid		
TURBINE - DRIVEN AFW PUMPS -		1A-S TDAFWPs : 1201 psid		
		2A-S TDAFWP : 1165 psid		
<input type="checkbox"/> Microfilm and store calculations in RIMS Service Center.		<input type="checkbox"/> Microfilm and destroy.		
<input checked="" type="checkbox"/> Microfilm and return calculations to: J. P. BARTLEMAN		Address: DSC - C7, SEQUOYAH		

EN DES CALCULATIONS QA Record

TITLE MINIMUM HEAD REQUIRED FOR TURBINE DRIVEN AND MOTOR DRIVEN AUX. FW PUMPS		UNID SYSTEM(S) —	PLANT/UNIT SQN-1 & 2 SAR SECTION(S)
DRAWING ORGANIZATION ICG-1		REV (FOR MEDS USE)	
APPLICABLE DESIGN DOCUMENTS		MEDS ACCESSION NUMBER	
BRANCH/PROJECT IDENTIFIERS 2219280000		R0 800603E007L (13) MEB '83 0527 301	R1 850627F0021 (28) B44 '85 0620 013
		R2 870420F0008 (30) B44 '87 0409 006	
KEY NOUNS PUMPS, HEAD, FEEDWATER		R0 <i>gfb</i>	See New Cover Sheet
REV	R0	R1	R2
DATE 5-25-83		4/8/87	10-17-87
PREPARED			
<i>g.w. Warren</i>	<i>L.C. Smith</i>	<i>R.K. Freeman</i>	<i>R.C. Carbonell</i>
CHECKED			
<i>J.W. Adenholdt</i>	<i>J.D. Hubble</i>	<i>B. York</i>	<i>J.P. Bartleman</i>
SUBMITTED			
<i>J.W. Warren</i>	<i>C.F. Bowman</i>	<i>J.P. Boyd</i>	<i>J.D. Johnson</i>
<i>J.W. Boyd</i>	<i>H.R. Corbett</i>	<i>H.R. Corbett</i>	<i>K.C. Daniels</i>
ATTACHMENTS MICROFILMED:			
LIST ALL PAGES * ADDED BY THIS REV:	1, 2a, 2b, 3a, 3b, 3c, 3d, A1, A2, B1-B3, C1, C2	1a, 6a	5a to 5h, 3a, 3b, 3c, 3d, 4 D1 to D5
* ALL PAGES * STED BY THIS REV:			2, 3b, 3d, 3e
LIST ALL PAGES * CHANGED BY THIS REV:	1, 2, 4, 12	1, 2a, 5, 6, 7, 9, 11	5, 2a, 2b, 3, 3b, 2, 1a, 6a

STATEMENT OF PROBLEM

TECH. SPEC. REQUIRES THAT M-D AND T-D AUX. FW PUMPS BE PERIODICALLY TESTED TO DETERMINE IF THE HEAD DEVELOPED BY THE PUMP IS ADEQUATE TO PERFORM ITS SAFETY FUNCTION. DETERMINE THIS MINIMUM DEVELOPED HEAD FOR THE M-D AND T-D AUX. FW PUMPS.

ABSTRACT

A CALCULATION WAS DONE TO DETERMINE THE MINIMUM TOTAL DEVELOPED HEAD (TDH) THAT THE T-D AND M-D AUX. FW PUMPS MUST DEVELOP AT RECIRC. CONDITIONS (TEST CONDITIONS) TO ASSURE THAT THE PUMPS WILL DEVELOP ADEQUATE TDH AT DESIGN FLOW CONDITIONS. THE RESULTS OF THE CALCULATIONS WERE:

MINIMUM TDH -	M-D PUMP -	- 1399 PSIG	R1
MINIMUM TDH -	T-D PUMP -	- 1183 1187.5 PSIG	R3

* @ TURBINE STEAM SUPPLY PRESSURE ≥ 842 PSIG

There are no unverified assumptions in this calculation | R2

Please return originals to *C.F. Bowman* WTA32C
 J.P. BARTLEMAN DSC - C7 SEQUOYAH

CALCULATION INDEPENDENT REVIEW VERIFICATION FORM

2219280000
Calculation No.

R4
Revision

Method of independent review used (check one or more):

- 1. Alternate calculation method _____
- 2. Testing method _____
- 3. Other method X

Justification (explain below):

Method 1: Identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 2: Identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Method 3: Justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

THE DESIGN APPROACH USED IN THIS CALCULATION IS
TECHNICALLY ADEQUATE BECAUSE IT IS SIMILAR TO PREVIOUS
REVISIONS OF THE CALCULATION AS WELL AS OTHER CALCULATIONS
AND IS, IN PART, BASED ON ACCEPTED TEXTBOOK METHODS.
REFERENCED IN THE CALCULATION

Robert V. Daves
Design Verifier
(Independent Reviewer)

4/30/88
Date

CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

2219280000
Calculation No.

R3
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

The calculation was performed based on accepted methods for determining Minimum Total Developed Head - Previous Calc + Field ^{test} data were utilized to generate this calc. See references, Section A, page 1 of 12. Review has determined this calc. is technically adequate.

R. M. Callahan 2/20/87
Design Verifier Date
(Independent Reviewer)

SQN -
 "Minimum Head Required For Turbine Driven
 Title: And Motor Driven Aux. Feedwater Pumps

REVISION LOG

Revision No.	DESCRIPTION OF REVISION	Date Approved
1	<p>This revision incorporates the increase in system resistance due to the removal of the pressure control valves and the installation of cavitating venturis in their place. The increased system resistance reduces the allowable pump degradation and thus raises the minimum acceptable pump head during surveillance testing.</p> <p>This revision also takes credit for the USQD written during the performance of PMT-53 on unit 2, which justifies a reduction in required flow for the 2A-A pump from 440 gpm to the steam generators to 400 gpm. Accordingly, min. acceptable pump head is determined on an individual pump basis to account for the different requirements.</p>	
2	<p>Added references to the Mainsteam and AFWT Design Criteria. Explained the differences between the DC's and the data used in this Calc.</p> <p>This revision completes part of the corrective action for PIR MEM 8786. ALSO ADDED BRANCH ID # TO ALL PAGES.</p>	

TVA

2219280000

SN
 MINIMUM HEAD REQUIRED FOR TURBINE
 Title: DRIVEN & MOTOR DRIVEN AUX. FEEDWATER PUMPS

REVISION LOG

Revision No.	DESCRIPTION OF REVISION	Date Approved
3	<p>REVISED CALCULATION FOR DETERMINING THE MINIMUM TOTAL DYNAMIC HEAD OF THE TURBINE DRIVEN AUXILIARY FEED WATER PUMP IN SECTIONS C.2.a AND C.2.b .</p> <p>ALSO REVISED CALCULATION FOR DETERMINING THE MINIMUM TOTAL DYNAMIC HEAD OF THE MOTOR DRIVEN AUXILIARY FEEDWATER PUMPS IN SECTIONS C.1.a THRU C.1.c . INCORPORATED FIELD PUMP DATA FOR 2A-A AND 2B-B , AND REVISED CALCULATIONS TO REFLECT NEW PUMP CURVES GENERATED FROM DATA. ADDED REFERENCE OF TVA MECHANICAL DESIGN STANDARD. INCORPORATED TEST INSTRUMENT ERROR / INACCURACY FOR THE MOTOR - DRIVEN AUX. FEEDWATER PUMPS. ALSO TO ACCOUNT FOR THE APPENDIXES : APPENDIX A - 2 SHEETS , APPENDIX B - 3 SHEETS , APPENDIX C - 2 SHEETS , AND APPENDIX D - 1 SHEET .</p>	12/21/87
4	<p>Incorporated pump data for 2A-S (TDAFWP) and revised calc. to reflect new pump curve generated from data. Incorporated new system resistance values for AFW system. Calculated new minimum required head(s) for the AFW pumps. Revised TDAFWP (c.2) section for calculating minimum head required. Added, deleted, and changed references. Added "Purpose" section and relettered other sections. Renumbered pages of calc. and added Appendixes E, F, + G.</p>	

CALCULATION ID <u>221928000</u>		Sheet <u>1</u> of <u>12</u>	
SQN - AFW System		Prepared by <u>JPB</u> Date <u>4/30/58</u>	
PROJECT <u>SEQUOYAH NUCLEAR PLANT</u>		Checked by <u>JW</u> Date <u>4/30/58</u>	
SUBJECT <u>Minimum Head Required for Motor-Driven and</u> <u>Turbine-Driven Auxiliary Feedwater Pumps</u>			

SUMMARY OF RESULTS

Equation used to find minimum acceptable head at recirc. flow for surveillance test on Motor-Driven AFW Pumps : Minimum acceptable head at recirc. flow for the Motor Driven AFW Pumps * Pump head at recirc. flow (based on pump curves) - Pump head at 465 gpm - Required TDH at 465 gpm + Allowance for Testing Instrument Error (TIE)

MOTOR-DRIVEN AUXILIARY FEEDWATER PUMPS

	Pump No.	1A-A	1B-B	2A-A	2B-B
	Serial No.	117168	117169	117171	117170
Head at 465 gpm per pump curve (ref.10)		(later) ft.	(later) ft.	3029.4 ft.	2883.8 ft.
Required head at 465 gpm (see sheet 5)		- 2678.7 ft.	- 2691.6 ft.	- 2686.1 ft.	- 2681.6 ft.
Allowable degradation		(later) ft.	(later) ft.	343.3 ft.	202.2 ft.
Available head at recirc. flow (75 gpm) per pump curve (ref.10)		(later) ft.	(later) ft.	3783.1 ft.	3508.1 ft.
Minimum pump head at recirc. flow		(later) ft.	(later) ft.	3439.8 ft.	3305.9 ft.
Allowance for TIE (see sheet 7)		+ (later) ft.	+ (later) ft.	+ 48.7 ft.	+ 42.3 ft.
Minimum acceptable pump head at recirc. - or -		(later) ft.	(later) ft.	3488.5 ft.	3348.2 ft.
Minimum acceptable pump head for SI		(later) psid	(later) psid	1511 psid	1450 psid

Equation used to find minimum acceptable head at recirc. flow for surveillance test on Turbine-Driven AFW Pumps : Minimum acceptable head at recirc. flow for the T-D AFW Pumps * Pump head at recirc. flow (from pump curves) - Pump head at 490 gpm - Required TDH at 490 gpm

TURBINE-DRIVEN AUXILIARY FEEDWATER PUMPS

	Pump No.	1A-S	2A-S
	Serial No.	127182	127183
Head at 490 gpm per pump curve (ref. 3 + 10)		2800.0 ft.	2766.1 ft.
Required head at 490 gpm (see sheet 12)		- 2600.6 ft.	- 2600.6 ft.
Allowable degradation		199.4 ft.	165.5 ft.
Available head at recirc. flow (50 gpm) per pump curve (ref 3 + 10)		2972.0 ft.	2855.8 ft.
Minimum acceptable pump head at recirc. - or -		2772.6 ft.	2689.3 ft.
Minimum acceptable pump head for SI		1201 psid	1165 psid

NOTE :
No Testing Instrument Error was added to the minimum acceptable pump head for the Turbine-Driven AFW Pumps (see sheet 8).

MINIMUM HEAD REQUIRED FOR THE TURBINE - DRIVEN SHEET 1 OF 12
AND MOTOR - DRIVEN AFW PUMPS 2219280000

COMPUTED *gpb* DATE 4/27/88
CHECKED *ju* DATE 4/30/88

A) PURPOSE

This calculation determines the minimum required head that the AFW pumps must develop to assure that the pumps can meet their minimum flow design requirement. The minimum head that is determined in this calculation is used in Technical Specification Requirements 4.7.1.2 for the AFW pumps.

B) ASSUMPTIONS - listed in body of calculation.

R4 GPE 4/30/88

COMPUTED GPE DATE 12/19/87

JW 4/30/88

CHECKED JW DATE 12/19/87

C) REFERENCES

- 1) AFW System Pressure Drop Calculation - SNP1-a-CA-D053 0-HCG-JWW-082274 (B25 880430 806)
- 2) JWW's Calc. 1/9/87 (attached)
- 3) Pump Test Curve Data (see AFW Pump Calc. Book)
 - Contract 72C30 - 72610 NAM-10
 - Pump Test Curves IA-A
 - for Motor - IB-B
 - Driven Pumps 2A-A see reference 10
 - 2B-B see reference 10
 - Pump Test Curves for N-530 for pump # 127182 (IA-S)
 - Turbine-Driven Pumps 2A-S see reference 10
- 4) Bingham Wilhometzte test of $1\frac{1}{2}$ Venturi (NEB 831017 639)
- 5) SQN AFW Flowrates During MSLB Calc. no. SQN-CA-D053 0-HCG-LCS-031285 (B44 850606 006)
- 6) Design Criteria for the Main Steam System SQN-DC-V-4.1.1 RO
- 7) Design Criteria for the AFW System SQN-DC-V-13.9.8 RO & DIMS 1,2,3
- 8) Post Modification Test (PMT) - S3 for Units 1+2 AFW Cavitating Venturi (see Appendix G)
- 9)
- 10) Analysis of AFW Pump Head Test Data Calculation no. SQN-CSS-021 Rev. 1 (B25 88 0429 331)
- 11) Letter from H.L. Jones to R.E. Daniels dated 12/8/87 (B25 871208 016)
- 12) Work Plan (WP) 12195 for 2A-A Motor-Driven AFW Pump Cavitating Venturi (see Appendix F)

MINIMUM HEAD REQUIRED FOR THE TURBINE - DRIVEN SHEET 3 OF 12

AND MOTOR - DRIVEN AFW PUMPS 2519230000

COMPUTED CFB DATE 4/29/88
CHECKED Jw DATE 4/30/88

13) Bingham - Willamette (Rocky Mountain Nuclear Cavitating Venturi Test P0638-3) Test of 2A-A MDAFWP Cavitating Venturi (S/N 02) - Contract No. BSP-JG-453044 (see Appendix D)

14) TYA Mechanical Piping Drawings:

<u>Drawing No.</u>	<u>Rev.</u>	<u>Unit</u>	<u>Description</u>
47W401-4	D	0	Feedwater Piping
47W420-10	R	0	Condensate Piping
47W427-1	E	1+a	AFW Piping
47W427-7	I/I	1/a	AFW Piping

15) FSAR Section 10.4.7.2 - Auxiliary Feedwater System - Amendment 4

COMPUTED *SPB* DATE 4/23/88
 CHECKED *Jur* DATE 4/30/88

D) CALCULATIONS

1) MOTOR - DRIVEN AFW Pumps (MDAFWP)

d.1.a

With the cavitating venturis installed and the Steam Generator (SG) pressure at 1085 psig (ref. 6+7) find the required pump Total Developed Head (TDH_r) at the required flow of 465 gpm (440 gpm to the SGs + 25 gpm recirc. flow) (ref. 7) by two methods:

- i) Calculate the TDH_r by using the SG pressure, static head, calculated system resistance (ref. 1), and the cavitating venturis ΔP's. Use PMT-53 (ref. 8) and manufacture lab test values (ref. 4 + 13) for venturi ΔP losses.
- ii) Use the actual field measured system resistance values from PMT - 53 (ref. 8) and WP 12195 (ref. 12).

Method 1 - Find required TDH using calculated system resistance at a MDAFWP flow of 465 gpm.

$$\text{Required TDH (TDH}_r\text{)} = \text{SG Pressure} + \text{Static Head} + \text{Calculated System Resistance (SR}_c\text{)} + \text{Cavitating Venturi } \Delta P$$

$$\text{SG Pressure} + \text{Static Head} + \text{SR}_c = K = \frac{1085}{0.433} + \underbrace{\left(\frac{1.742 \cdot 34' - 705.5' \right)}{0.433}}_{\text{(sheet 11)}} + \frac{23.74}{0.433} \quad \text{(ref. 1)}$$

$$K = 2597.44 \text{ ft.} \quad \text{TDH}_r = K + \text{Cavitating Venturi } \Delta P$$

Now add the venturi ΔP's and calculate the TDH_r for each MDAFWP.

Loop	1A-A	1B-B	2A-A	2B-B
Venturi ΔP's :	70 psid	78 psid	48 psid	55 psid
	(ref. 4)	PMT - 53 (ref. 8)	Appendix D (ref. 13)	PMT - 53 (ref. 8)
Note:	Scott Long (test engr.) confirmed that venturi S/N 1 with insert, which was tested by the vendor, is installed in loop 1A-A.	data and ref. 5, sheet 14.		test # a Appendix A

$$48 \left(\frac{440}{4104} \right)^2 = 55.2$$

MINIMUM HEAD REQUIRED FOR THE TURBINE - DRIVEN AND MOTOR - DRIVEN AFW PUMPS 2219280000

COMPUTED *gpe* DATE 4/28/88
 CHECKED *ju* DATE 4/30/88

Method 1 Results

TDH_r with venturis installed (based on tested venturi losses & calculated losses for the rest of system)

	LOOP			
	1A-A	1B-B	2A-A	2B-B
K =	2597.44 ft			
+ (70 / 0.433)		+ (78 / 0.433)	+ (48 / 0.433)	+ (55 / 0.433)
	2759.1 ft	2777.6 ft	2708.3 ft	2724.5 ft

Note: Actual Pump Flow = 465 gpm (440 gpm to SG + 25 gpm recirc.)

Method 2 - Find TDH_r using system resistance from PMT-53 (ref. 8) and WP12195 (ref. 12) at a pump flow = 465 gpm (440 gpm to SG + 25 gpm recirc.)

Required TDH (TDH_r) = SG Pressure + Static Head + Measured System Resistance (SR_m)

TDH_r = $\frac{1085}{0.433} + (El. 742.34' - 705.5') + SR_m = 2542.6 \text{ ft} + SR_m$

$SR_m = \left[\left(\frac{\text{Pump discharge pressure (w/ LCV's full open)}}{\text{SG pressure}} - \text{Static Head from pump discharge to SG inlet} \right) \left(\frac{Q_{440}}{Q_{PMT-53}} \right)^2 \right]$

$(742.34' - 692.08') = 50.26'$ (sheet 11) TDH_r

Loop * 1A-A TDH_r = 2542.6 ft + $\left[\left(\frac{1128 - 1005}{0.433} - 50.26 \right) \left(\frac{440}{576.6} \right)^2 \right] \text{ ft} = 2678.7 \text{ ft}$

** 1B-B TDH_r = 2542.6 ft + $\left[\left(\frac{1128 - 1005}{0.433} - 50.26 \right) \left(\frac{440}{551.2} \right)^2 \right] \text{ ft} = 2691.6 \text{ ft}$

Δ 2A-A TDH_r = 2542.6 ft + $\left[\left(\frac{1112.4 - 990}{0.433} - 50.26 \right) \left(\frac{440}{360} \right)^2 \right] \text{ ft} = 2686.1 \text{ ft}$

ΔΔ 2B-B TDH_r = 2542.6 ft + $\left[\left(\frac{1117 - 1002}{0.433} - 50.26 \right) \left(\frac{440}{547.6} \right)^2 \right] \text{ ft} = 2681.6 \text{ ft}$

* See page x-d-18 of PMT-53 (ref. 8)

Δ See page x-a-36 & 37 of WP 12195 (ref. 12)

** See page x-d-21 of PMT-53 (ref. 8)

ΔΔ See page x-a-51 of PMT-53 (ref. 8)

MINIMUM HEAD REQUIRED FOR THE TURBINE - DRIVEN AND
 MOTOR - DRIVEN AFW PUMPS 2219280000

COMPUTED JCB DATE 4/29/88

CHECKED Jv DATE 4/30/88

The SG pressure used in determining the SR_m for 2A-A and 2B-B Motor-Driven AFW Pumps was derived from taking the average of the appropriate SG pressure just before starting the pump and just after stopping the pump.

Method 2 will be used in determining the minimum required head for the motor-driven AFW pumps for the following reasons:

- 1) The values used in determining the TDHr are based on actual field/plant test data which truly represents the system resistance for each particular pump.
- a) There is some conservatism factored into determining the minimum required head, and they are as follows:
 - a) The 440 gpm AFW flow requirement comes from a maximum reactor power of 102% of the ESD rating and no AFW (cooling) flow to the SG for 10 minutes (ref. 15), and
 - b) Testing Instrument Error (TIE), which accounts for instrument inaccuracies, is also being added to the minimum required head for extra assurance that the minimum head calculated is conservative.

Method 2 does not account for the actual friction loss/dP for the MDAFWP suction piping because its value is negligible when compared to the conservatism that is factored into the minimum required head value. The difference between the suction pressure measured and actual head from a CST level of 23.5 ft (ref. 12) is 0.08 psi for a flow rate of 465 gpm.

d.1.b

Testing Instrument Error (TIE) is calculated using ref. 10

Reference 10 uses actual field tested pump data and then develops a computer generated pump curve by means of curve fit equation/program. The ref. 10 calc. incorporates instrument inaccuracy data and a min./max. pump curve based on the +/- of instrument inaccuracies applied to the nominal pump curve (generated from actual field test data).

The TIE used in this calc. is the average of differences, in head, between the min. + nominal and max. + nominal pump curves (generated in ref. 10) at a flow of 465 gpm.

Pump	⇒	2981.3	Min. Head Expected	}	48.1 ft	} Differences
2A-A	⇒	3029.4	Nominal Head Expected		49.2 ft	
@ 465 gpm		3078.6	Max. Head Expected			

$$2A-A \text{ TIE} = \frac{48.1 + 49.2}{2} = 48.65 \text{ ft} \quad \text{or } \underline{48.7 \text{ ft}}$$


Pump	⇒	2841.9	Min. Head Expected	}	41.9 ft	} Differences
2B-B	⇒	2883.8	Nominal Head Expected		42.7 ft	
@ 465 gpm		2926.5	Max. Head Expected			

$$2B-B \text{ TIE} = \frac{41.9 + 42.7}{2} = \underline{42.3 \text{ ft}}$$

Pump	⇒	(later)	Min. Head Expected	}	(later)	} Differences
1A-A	⇒	↓	Nominal Head Expected		(later)	
@ 465 gpm		↓	Max. Head Expected		(later)	

$$1A-A \text{ TIE} = \frac{(later)}{2} = -$$

R4 gpb 4/30/88 COMPUTED gpb DATE 12/19/87
 ju 4/30/88 CHECKED ju DATE 12/19/87



The TIE for the Motor - Driven AFW Pumps incorporates instrument error from both flow and pressure (head) instrumentation inaccuracies. The total error is determined by using the "Square Root of the Sum of the Squares" $[\sqrt{()^2 + ()^2 + \dots}]$ of all the inaccuracies.

The TIE term based only on pressure / head was 10 psig (or 23.1 ft). Therefore, if the Surveillance Instruction (SI) which tests the M-D AFW Pumps (satisfying Tech Spec requirements) can measure the pump head with an error of less than or equal to 10 psi, (i.e. the 10 psi error can be met by using a 2000 psig discharge pressure gauge which has an accuracy of $\frac{1}{2}$ %, and a 60 psig suction pressure gauge which has an accuracy of $\frac{1}{2}$ %) then no further inaccuracies need to be accounted for. ICF 87-2419 will incorporate the use of the specified gauges above in SI-130.2.

There is no TIE applied to the Turbine - Driven AFW Pumps since the pump is only required to supply a minimum of 440 gpm to the Steam Generators and the pump is capable of a nominal flow of 880 gpm. Since this provides approximately 100% reserve margin for the pump, the instrument inaccuracies are negligible when compared to the excess pump capacity. (See ref. 11)

MINIMUM HEAD REQUIRED FOR THE TURBINE-DRIVEN AND MOTOR-DRIVEN AFW PUMPS 2219280000

COMPUTED *gpb* DATE 4/20/88
 CHECKED *Ju* DATE 4/30/88

d.l.c

Since method 2 (sheet 5) yields the actual system resistance per AFW pump, the allowable pump degradation will be based on method 2.

Using the same technique as RO of this calc., the minimum acceptable head when testing at recirc. flow is given by:

$$\text{Min. acceptable head at recirc. flow} = \text{Pump head @ recirc. flow (based on pump curves)} - \left(\text{Pump head @ 465 gpm (based on pump curves)} - \text{Required TDH @ 465 gpm} \right) + \text{Allowance for Testing Instrument Error}$$

AFW Motor-Driven Pumps


Minimum Acceptable Head @ Recirc. (\approx 25 gpm)

Pump	1A-A	1B-B	2A-A	2B-B
Head @ 465 gpm per pump curve	(later) ft	(later) ft	3029.4 ft	2883.8 ft
Required Head @ 465 gpm (from sheet 2b)	<u>2678.7 ft</u>	<u>2691.6 ft</u>	<u>2686.1 ft</u>	<u>2681.6 ft</u>
Allowable degradation	(later) ft	(later) ft	343.3 ft	202.2 ft
Head @ Recirc. flow per pump curve	(later) ft	(later) ft	3783.1 ft	3508.1 ft
Min. Acceptable Head @ Recirc. flow (w/o TIE)	(later) ft	(later) ft	3439.8 ft	3305.9 ft
Allowance for Testing Instrument Error (from sheet 3)	<u>(later) ft</u>	<u>(later) ft</u>	<u>48.7 ft</u>	<u>42.3 ft</u>
Min. Acceptable Head w/TIE @ Recirc flow	<u>(later) ft</u> or <u>(later) psid</u>	<u>(later) ft</u> or <u>(later) psid</u>	<u>3488.5 ft</u> or <u>1511 psid</u>	<u>3348.2 ft</u> or <u>1450 psid</u>
Maximum Allowable Degradation, %	(later) %	(later) %	7.8 %	4.6 %

$$\text{Degradation \%} = \left[\text{Pump Recirc. Head (H}_r\text{)} - \text{Min. Acceptable Head at Recirc. w/TIE} \right] \text{ Divided by } H_r \times 100\%$$

POST MAINTENANCE TEST - WP 12195
 SEQUOYAH NUCLEAR PLANT
 UNIT 2
 MOTOR-DRIVEN AFW PUMP 2A-A SYSTEM DATA ANALYSIS

2219850100



The venturi was designed to limit flow below 630 gpm to no more (approx. 625 gpm total pump flow).

The latest 2A-A Pump Curve, Optimized Venturi, New Pump Impeller

The venturi limits the maximum flow rate to 630 gpm at normal conditions.

988 10/30/87
 MAC 10/24/87

Sheet 10 of 18

C.A. Hixley 10/15/87

MINIMUM HEAD REQUIRED FOR TURBINE
AND MOTOR DRIVEN AUXILIARY FEED-
WATER PUMPS


SHEET 11 OF 12

R4 ~~SPB~~ 4/30/88 COMPUTED REC DATE 10-17-87
JW 4/30/88 CHECKED JDW DATE 10-17-87

D) CALCULATIONS

ASSUME BOTTOM OF THE TANK =
THE MINIMUM WATER LEVEL FOR DETERMINING
THE STATIC HEAD

CONDENSATE STORAGE
TANK (CST)




(ref. 14)
BOTTOM OF
TANK EL. 705.5'

EL. 742' - 4 1/16"
(ref. 14)



STEAM
GEN.

EL. 692' 1" MDAFWP
EL. 691' 3 3/4" TDAFWP
(ref. 14)



AFW PUMP

SH = ELEVATION (POINT OF CONNECTION AT THE SG)
MINUS MINIMUM WATER LEVEL (CONDENSATE
STORAGE TANK)

$$= (742' - 4 \frac{1}{16}'') - 705.5' = 36.84'$$

R4 GFB 4/30/88 COMPUTED GFB DATE 12/19/87
 JW 4/30/88 CHECKED JW DATE 12/19/87

a) T-D Pumps

d.a. Assumptions

According to Westinghouse and refs. 6, 7, + 11; only 440 gpm (+50 gpm recirc. flow) is required to the SGs at a pressure of 1085 psig in order to meet its safety function. Use this as the basis to estimate the tech specs requirement.

Find minimum required TDH (TDH_r) for the Turbine - Driven AFW Pump (TDAFWP) at the minimum required AFW flow of 440 gpm to the SGs.

$$TDH_r = \underset{\text{(ref. 7)}}{SG \text{ Pressure}} + \text{Static Head} + \underset{\text{(ref. 1)}}{\text{System Resistance (calculated)}}$$

$$TDH_r = \frac{1085}{0.433} + (El. 742.34' - 705.5') + \frac{25.12}{0.433} = 2600.6$$

TDAFWP Data	H _{rc}	H _s		
Pump No.	Head from pump curve at 490 gpm (in feet)	Recirc Head (ft) from pump curve (50 gpm)	Minimum Acceptable Head @ Recirc	Degradation Percentage
1A-S	2800 (note 1)	2972 (note 1)	1200.5 psi	93.3 %
2A-S	2766.1 (ref. 10)	2854.8 (ref. 10)	1164.5 psi	94.2 %

Note 1 - Pump test curve from Ingersoll - Rand at 3970 rpm (dated 4-11-73), Pump no. 127182 (Serial No. N-530) (ref. 3)

Degradation % = $\frac{\text{Recirc. / Shut-off Head (H}_s) - [\text{Head from pump test curve at 490 gpm (H}_{rc}) - TDH_r]}{H_s} \times 100\%$

Minimum Acceptable Head @ Recirc = $[H_s - (H_{rc} - TDH_r)] \times 0.433 \text{ (psi)}$

PROJECT PAT-53 RCDIST # 2
 DATE 5/1/85
 CHECKED BY
 DATE

VIA HT	SUCTN PRESSURE	DISCHRG PRESSURE (G.A.M.T)	DISCHRG MEASURE (FEET)	VENTURE HIGH	VENTURE LOW	SYSTEM PRESSURE LOOP 1	SYSTEM PRESSURE LOOP 2	CHECK VALUE DP	VENTURE DP	VENTURE (OP)	PIPING DP LOOP 1	PIPING DP LOOP 2	TOTAL HEAD	FLOW TO SG # 1	FLOW TO SG # 2	TOTAL FLOW TO SG # 1 + SG # 2
1	17.3	1450	-	1426	1399	1387	1387	24	27	5.20	9.6	12	3305	120.0	125.5	245.5
2	17.25	1375	-	1351	1307	1295	1295	24	44	6.63	10.2	12	3132	154.3	154.1	313.4
3	17.1	1260	-	1237	1162	1150	1150	23	75	8.66	9.1	12	2867	209.1	199.7	408.8
4	17.0	1150	-	1133	1028	1014	1014	17	105	10.25	11.0	14	2614	241.7	242.5	484.2
5	16.8	1070	-	1053	911	898	898	17	142	11.92	10.9	13	2390 2430	254.5	236.6	531.1
6	17.25	1345	1322	1321	1269	1259.3	-	24 (-)	52	7.21	9.7	-	3010 3063	171.4	167.7	339.1
7	17.1	1210	1190	1192	1104	1094.1	-	18 (-2)	88	9.38	9.9	-	2700 2752	221.3	219.0	440.3
8	17.0	1160	1140	1136	1032	1021.0	-	24 (-4)	104	10.20	11.0	-	2587 2637	242.1	238.4	480.5

INFORMATION ONLY INFORMATION ONLY

600 SERIES/700 SERIES
STAINLESS STEEL BOURDON TUBE
ALLOY STEEL/STAINLESS STEEL
SOCKET



ACRAGAGE®
SOLID FRONT GAGES

INFORMATION ONLY

For use on any media not corrosive to gage system materials. (See pages 12-13.)

NOTE: 600 Series: Alloy steel socket; 700 Series: 316 Stainless Steel socket.

MOVEMENTS: Add suffix letter to catalog number to designate movement. (B: stainless steel; D: Delrin.) Complete description of movements on page 6.

For ordering information, see page 39.

Standard - AISI 316-L stainless steel, ranges 0-15 thru 0-5000 psi. Type 403 stainless steel, ranges 0-7500 thru 0-20,000 psi.

4 1/2" and 6": Available with Aluminum case, styles 13, 14 and 67; and Phenol case, style 75. See Catalog No. tabulation, this page, and case descriptions, page 11.

Standard: White with black figures. Optional: Black with white figures.

600 Series: Carbon steel. 700 Series: AISI 316 stainless steel.

Pressures up to 1000 psi: 1/4" and 1/2" NPT male. Pressures over 1000 psi: 1/2" NPT male.

NOTE: Custom connections available.

Acrapointer, balanced adjustable design.

Standard: Double-strength glass. Optional: Safety glass or plastic.

Suffix B: Geared stainless steel. Stainless pinion; gear and bushings.

Suffix D: Delrin bushed and geared. Delrin sector and bushings; stainless pinion.

Within 1/2 of 1% of full range.

See pages 36-37.

See page 38.

See pages 32-35.

Gages on this page available with special features shown on pages 7 and 8.

Models 675/775 only also available with fluid fill. See Page 19.

CATALOG NO.	CASE	RING	MOUNTING
613/713	Aluminum	Screwed	Wall, Flush or Stem
614/714	Aluminum	Screwed	Stem only
667/767	Aluminum	Hinged	Flush only
675/775	Phenol	Polypropylene	Wall or Stem

PRESSURE RANGES - PSI

TOTAL GRADUATIONS	FIGURE INTERVALS	MINOR SUBDIVISIONS
0-15	1	.1
0-30	3	.2
0-60	5	.5
0-100	10	1
0-160	20	2
0-200	20	2
0-250	50	2
0-300	30	2
0-400	50	5
0-500	50	5
0-600	50	5
0-800	100	10
0-1000	100	10
0-1500	200	10
0-2000	200	20
0-2500	500	20
0-3000	500	20
0-5000	500	50
0-7500	1000	50
0-10,000	1000	100
0-15,000	2000	100
0-20,000	2000	200

COMPOUND RANGES
(Inches HG, VAC, and PSI)

TOTAL GRADUATIONS	FIGURE INTERVALS	MINOR SUBDIVISIONS
30"-0- 15	5" & 3	5" & .2
30"-0- 30	10" & 5	1" & .5
30"-0- 60	10" & 10	1" & 1
30"-0-100	30" & 10	2" & 1
30"-0-150	30" & 30	5" & 2
30"-0-200	30" & 20	5" & 2
30"-0-300	30" & 50	5" & 2

VACUUM RANGE

0-30" Vac.	3"	.2"
------------	----	-----

Also available in equivalent metric ranges.

Purchase Requisition

B2

Commodity Code: _____ Requisition number: **337850**
 Requisition Date: **Oct. 4, 1982**

Account Number	Location	Sub-pro.	Org.	Activity
6000	056	12	80	

Acct. Office: **Power** 02

Location: Sequoyah Nuclear Plant

Project: Power Stores
 Organization: Power 5040800000
 Requisitioner Ref. No. _____

Ship To: Tennessee Valley Authority 5800
ATTN: C. E. Brannon, Power Stores
Sequoyah Nuclear Plant near Daisy,
 Shipping Notice To: P.O. Box 2000, Daisy, TN 3
 Ship By: UPS 02 Date Wanted: 10/20

ITEM NO 105-2

ARTICLES OR SERVICES
Give Complete Description or Catalog Number

QUANTITY	UNIT	UNIT PRICE	AMOUNT
----------	------	------------	--------

INITIAL STOCK

1.	Gauge, pressure, Robertshaw catalog <u>0767-B-4 1/2"</u> , C-2000 psi, 1/2" NPT back connection	5	EA	100.00	50
----	--	---	----	--------	----

Seg
Robertshaw Div. CISC-1-F-2
Tic # Aym 438K
Bin 10318-2

FOR: Various Non-CSSC Systems
(3-PI-3-122B & 3-PI-3-132B)

REF: Robertshaw Controls Co.
2318 Kingston Pike, S.W.
Knoxville, TN 37901

INFORMATION ONLY

THIS CONTRACT WILL BE PAID WITH: (REFER TO ACCOUNTING MEMORANDUM 144)

POWER FUNDS 100% APPROPRIATED FUNDS 0% OTHER FUNDS 0%

Quality Assurance Requirements are required and included are not required

Is TO CFR Part 21 notice required? Yes No *QA 10-10-5-82*

*If not estimated price, price used on previous Contract No. _____

C. E. Brannon

G. E. Brannon
131-4-24

Validated by _____

E. W. Mansfield

Approved by _____

WP 11010
 PAGE IX-1 OF 14

389000 250 11020 KNOX WASH. (T) (2) 80 20 2219280000 B3

ROBERTSHAW CONTROLS COMPANY
FULTON SYLPHON DIVISION
 P. O. BOX 400 - KNOXVILLE, TENNESSEE 37901
 PAGE #8 OF 26

INVOICE
 D.U.N.S. 00-337-4683

CHANGE #1
 1/26/73

OUR ORDER NO. 39301	DATE 9/18/72	CUSTOMER'S ORDER NO. AND/OR DATE 73C-38-83530-3 SCHEDULE 1
WOLFE & MANN MFG. CO. 28TH AND SISSON STREETS BALTIMORE, MD 21211 MARK: FOR SHOP ORDER 16285		CUSTOMER'S REQUISITION CASE NO.
SHIPPING INSTRUCTIONS ROADWAY - PPD. & CHG. 150 865		SHIPMENT REQUESTED ASAP
SOLD TO TENNESSEE VALLEY AUTHORITY CONSTRUCTION ACCOUNTING BRANCH KNOXVILLE, TENNESSEE		TRAFFIC CONTROL BRANCH ORDER NO.
COMPLETE OR PARTIAL NET 30 DAYS F O B. KNOXVILLE, TENN.	PRIORITY RATING	MTL. CERT. REQUIRED RENEGOTIABLE GOVERNMENT INSPECTION

INVOICE NUMBER
19904
5-18-73

WHEN REMITTING PLEASE ENCLOSE THE YELLOW COPY OF THIS INVOICE, OR REFER TO YOUR "CUSTOMER ACCOUNT NUMBER" OR YOUR REMITTANCE ADVISE.

QUANTITY THIS SHIPMENT	QUAN ORDERED OR BALANCE DUE	PART NO. SIZE AND DESCRIPTION	PART CODE NUMBER	UNIT PRICE	GROSS AMOUNT	NET AMOUNT - PAY LAST AMOUNT - IN THIS COLUMN
10	10	FACTORY ITEM #8 80164-A31-(767-8) AC RAGAGE 4 1/2" 0-30 PSI 1/4" NPT BACK CONN. AL. TAG (1 EA.) 1-PI-3-127, 1-PI-3-117, 1-PI-6-188, 1-PI-6-189 0-PI-78-23, 0-PI-78-24 2-PI-3-127, 2-PI-3-117, 2-PI-6-188, 2-PI-6-189 CHANGE TAGGING system 78 QA.		23.73	237.30	6691.86
					6989.16	767

INFORMATION ONLY



MISSISSIPPI VALLEY AUTHORITY
 DIVISION OF PURCHASING
 Chattanooga, Tennessee 37401
 Telephone -- Area Code 615/265-3651
 TWX No. 810 575 5274

Appendix C 2219280000

to be completed by bidder No. 1

State or Country Code (29) - 148
 Vendor Code (34) - 38,635
 (05) - 110,074
 Buying Code L.A.
 Commodity Code
 Account Number IN2 139
 Requisitioner NEM 10
 Ref. No.
 Project Sequoyah Nuclear Project
 TVA Reference No. CONTRACT 720 30-926
 Contract Date July 9, 1971
 Total Amount \$ 296,931
 Performance Date May 1, 1972

INVITATION, BID, AND ACCEPTANCE

Date May 4, 1971

A quotation IN DUPLICATE is requested on the items listed, subject to the conditions herein. Quotations will be received at this office until 10 a.m. EST, June 3, 1971* and will be opened and read in public. Bids not physically received by the time stated will be returned unopened to the bidder.

MISSISSIPPI VALLEY AUTHORITY, By M. W. Thomas
 Purchasing Agent

BID -- Date 6/9/71 Bidder's Reference Number ATL-2090

In compliance with the invitation for bids, and subject to all the conditions thereof, the bidder offers, and agrees if this bid be accepted within _____ days (30 days unless otherwise specified) from the date of the opening, to furnish the services and/or sell and deliver the articles any or all of the items at the price quoted opposite each. Bids may not be withdrawn or opening without the consent of the Contracting Officer.

Discounts will be allowed for payments as follows: None
 Unless otherwise qualified by the bidder on this form: (1) discounts will be deducted from contract price; and (2) time in connection with discounts offered will be computed from delivery of the supplies at destination, or from date of receipt of correct bill, whichever is later.

The bidder represents:
 That he is _____, is not a small business concern as defined in Code of Federal Regulations Title 13, Chapter I, Part 121, Section 121.3-8. In connection with supply contracts, if he is a nonmanufacturer, he also represents that the products to be furnished hereunder will not be produced by a small business concern. In construction and construction nonpersonal service contracts, the preceding sentence is not applicable.

(Complete only when the aggregate amount of bid is \$10,000 or more)
 That he is a manufacturer of the articles, equipment, material or supplies quoted upon. That he is _____ a regular dealer in, and maintains a stock for sale to the general public of equipment, materials, or supplies of the general character of that or those upon which herein.

(Complete only when (a) the aggregate amount of bid in response to advertising is \$25,000 or more, or (b) the aggregate amount of bid on a negotiated purchase is more than \$10,000)
 That (a) he has _____, has not employed or retained any company or person (other than an employee or bona fide established commercial or selling agencies maintained by the bidder or contractor) for purposes of securing business; to solicit or secure this contract; and (b) he has not _____, paid or agreed to pay any company or person (other than bona fide established commercial or selling agencies maintained by the bidder or contractor for purposes of securing business) any fee, commission, percentage, or brokerage fee, or anything requested by the Contracting Officer.

ARTICLES OR SERVICES AND ATTACHMENTS WHICH FORM PART OF CONTRACT

Local time at Chattanooga, Tennessee
 STEAM-TURBINE-DRIVEN AND ELECTRIC-MOTOR-DRIVEN AUXILIARY FEED WATER PUMPING UNITS

APPROVED:
 James L. Williams, Jr.
 7/9/71

- Schedule of Prices
- Delivery and Shipping Data
- Guaranteed Data
- Equipment Data
- Experience Data

Foreign Bidder Conditions (Forms 9499 and 9699A)

- Special Conditions
- General Conditions (form 5052)
- Cash-Healey Act
- Equal Opportunity (forms 9923 and 9925)

TVA Specification No. 9955

System Tabulation

Flow Diagram No. 47A

REC'D - 112070
 JUL 19 1971
 MECHANICAL DESIGN
 INGERSOLL-RAND COMPANY

Spec	NI	NI	Name	NI	NI	Name	NI
Bonine 4			RHD			BSM	
CAB			DRP				
TB			RMS			REL	
PAB							
Sherrod						JIG	

INGERSOLL-RAND COMPANY
 Ingersoll-Rand Drive
 Columbus, Georgia 30341
 Person authorized to sign bid - Name and title (print or type) and signature
 R. Unkles, Jr. Dist. Mgr. *S.R. Unkles, Jr.*

ACCEPTANCE -- Accepted only as to: Items 1 and 2, and if required by TVA, item 3, including overtime rates when applicable. F.O.B. Cars, Daisy, Tennessee (CNO & TP Railway), for switch delivery to Sequoyah Plant Site.

CONSIGN TO -- TENNESSEE VALLEY AUTHORITY
 Daisy, Tennessee (CNO & TP Ry.), for switch delivery to Sequoyah Nuclear Plant Site
 MARK: Contract 72030-92610
 for: Sequoyah Units 1 and 2
 Attn: Chief Storekeeper

PAGE 1A IS MADE A PART OF THIS CONTRACT.
 (*See note on page 1A).

MAIL INVOICE IN DUPLICATE TO --
 TENNESSEE VALLEY AUTHORITY
 Construction Accounting Branch
 400 Northshore Building
 Knoxville, TN 37902

MISSISSIPPI VALLEY AUTHORITY, By M. W. Thomas, Purchasing Agent

Invoices must show contract number, discount or terms of payment applicable, number, description of article or service, quantity, unit price, and total amount.

IVA USE ONLY
 I certify that the articles or services listed above have been received in quantity and quality specified herein as noted.
 TVA 5050 (12-7-70)

Person receiving material _____
 Date Material Received _____
 G.B.L. _____
 Truck _____
 Vendor IVA _____
 Express _____
 Carrier's Charges: Paid \$ _____ Collect \$ _____
 No. _____
 Common Carrier _____
 Purchase Cost _____
 Cash Discount _____
 Carrier's Charges _____

EQUIPMENT DATA (Continued)**INFORMATION ONLY**

Impellers

- a. Type and material Same as turbine unit
- b. Diameter 9-5/8
- c. Number of stages 9

7. Wearing rings

- a. Type, method of fastening, and material of rings Casing Rings
Type 410 SS, Set Screwed

8. Shaft and sleeves

- a. Material and method of fastening 316 SS Coated, Keyed to Shaft
- P/Bb. Diameter at impellers, bearings, and stuffing boxes 2 1/2", 2.12", & 3"
- c. Brinell hardness number of shaft sleeves 578 Min. (Coating)

9. Stuffing boxes

- P/Ba. Type, size, and materials Packed 4 1/8" OD 13% Chrome

10. Base plate

- a. Material and construction Fabricated Carbon Steel

11. Couplings

- a. Make, type, and size Fast B Flexible, #2

12. Flanges

- P/Ba. Size and length of suction and discharge nozzles from centerline
Std of shaft Suction 300# RF 16"
Discharge 900# RF 16"

- b. Materials Same as Casing

- c. Limiting allowable pump nozzle forces and moments

13. Minimum flow

- a. Minimum recommended flow from pump discharge to prevent overheating and/or provide for operational stability 25 GPM

Bingham-Willamette Company

A Division of Guy F. Atkinson Company

VENTURI SN 03 D41
 TVA REF 85P-JG 453044 898
 15 of 3
 APPENDIX D 898
~~221902~~ 898 10/19/87
 2219280000

ROCKY MOUNTAIN NUCLEAR CAVITATING VENTURI TEST--P0638-3

RUN NO.	CAPACITY GPM	INLET PRESSURE PSI	OUTLET PRESSURE PSI	DIFFERENTIAL PRESSURE PSI	LOOP TEMPERATURE °F
1	603	983	802	181	93
2	500	763	702	61	98
3	440	877	829	48	97
4	400	731	692	39	99
5	300	737	715	22	97
6	203	847	837	10	94
7	606	987	21	966	95
8	566	863	735	128	94
9	529	840	768	72	93

INSTRUMENTATION USED:

CAPACITY.....4" VENTURI METER
 INLET PRESSURE.....0-1500 PSI GAGE
 OUTLET PRESSURE.....0-60 PSI GAGE
 0-1000 PSI GAGE

INFORMATION ONLY

WITNESS TESTED @ PORTLAND, OREGON 8/1/85
 FOR ROCKY MOUNTAIN NUCLEAR
 FOR TENNESSEE VALLEY AUTH.

Jack L. Poe
Steven Scott Long

CERTIFIED CORRECT BY:
O.C. Smith FOR BINGHAM-WILLAMETTE CO.



Bingham-Willamette Company
 A DIVISION OF GUY F. ATKINSON COMPANY

CHRIS A. WRIGHT
 MANAGER
 PORTLAND SERVICE CENTER

2200 NORTHWEST FRONT AVENUE
 P. O. BOX 10247
 PORTLAND, OREGON 97210

(503) 226-5203
 (24 HOURS)

ROCKY MOUNTAIN NUCLEAR
 Q.A APPROVED
 By *Jack L. Poe*
 Date 8-8-85

2219280000

R2 RKF 3/25/87

COMPUTED JWW DATE 1/9/79

Rcy 3/27/87

CHECKED JAW DATE 1-29-79

BACKGROUND / MISC. INFO.

1) ADDITIONAL REFERENCES

1) W ^{written} comments (see Spike Pothol's 6/22/77 '45 and notes on 7/12/77 telegram.

2) Crosby letter dated 1/12/72 on S.G. safety values for Sequoyah

3) Crosby Catalog 402, pg 19.

4) Safety Value (Contract) Setpoint tolerance for popping is ± 1 percent of setpoint per PG-72.3 (1968 Ed. of Section I).

5) TVA-1918 letter from W ^{NSSS} (SQN), dated 8/11/71

2) ADDITIONAL ASSUMPTIONS AND GIVEN INFO.

1) 1st S.V. setpoint is 1064 psig. \checkmark ref 6
2nd S.V. setpoint is 1077 psig. \checkmark ref 6

2) From Reference #1, W states that 440 gpm ^{M.D.} per aux. feedpump is satisfactory \checkmark at least to an 1133 psia if the open safety valves can relieve at least 11 percent of nominal steam flow at that pressure.

In Ref. 5, W states that the max. flow that the NSSS can deliver @ 1100 psia is assumed to be max. calculated load flow times 1.02. Max. Calc. load flow is 15,481,500 #/hr per TVA HB 17X1110-1.

3) Assume 11 percent of nominal flow is
 $0.11 \times 1.02 \times 15,481,500 = 1,737,024.3$ #/HR total
or 434,256,075 #/HR. per S.G. \checkmark

4) Select 1085 psig ^(\approx 1100 psia) as ^(ref 6) min. pressure for aux. feedwater pumps per B(2) above. R2
Verify below by calculation that S.V. relieving capacity is sufficient.

APPENDIX E

SHEET E2 OF 8

Minimum Head Required for Turbine-
Driven and Motor-Driven Aux FVW Pumps

R3 QPB 10/20/87
RCC 10/20/87

2219280000

COMPUTED RKJ DATE 3-25-87

(THIS PAGE ADDED IN REV. 2)

CHECKED Boy DATE 3/27/87

ADDITIONAL REFERENCES (Continued)

6. Design Criteria for Main Steam System
SON-DC-V-4.1.1 RO

7. Design Criteria for Auxillary Feedwater System
SON-DC-V-13.9.8 RO & DIMS 1, 2, 3

8. AFW Pump Contract	72C30-72G10	N2M-10
Pumptest Curves	Curve No. N-509	for pump # 117169
for Motor-	N-510	117171
driven Pumps	N-511	117771
	N-524	117168
Pumptest Curves	N-530	127182
for Turbine	N-531	127183
driven Pumps		

Note

The current steam design flow is 3.73×10^6 lb/hr per SG, or 14.92×10^6 lb/hr total (ref 6). The maximum capacity of a safety valve is 890,000 lb/hr^(ref 6). Since this calculation used 15,481,500 lb/hr steam flow rate and 617,848.9 lb/hr for safety valve capacity, the results are still within the current plant design. The steam flow used is greater than the design point and the safety valve capacity less than the design point are both conservative. The greater flow means the need for more steam relieving capability. The lower safety valve capacity means the current design has greater relieving margin than that used in this calc. Since the results of this calc was acceptable the current design is also acceptable. There is no need to revise this calc since these difference do not change the results of this calculation.

Min Required Head for AFW Pumps

R2: RKF 3-25-87

COMPUTED DATE

2219280000

Rcy 3/27/87

CHECKED NA DATE 1-29-79

3) ADDITIONAL CALCULATIONS

$$\checkmark A = 16 \text{ sq. in.}$$

$$\checkmark P = 1085 + 14.7 \text{ psia}$$

$$\checkmark W = 51.45 A \cdot P \cdot K \quad (100\% \text{ rated capacity})$$

$$\checkmark K = 0.975$$

$$W = 51.45 \cdot 16 \cdot 1099.7 \cdot 0.975 \checkmark$$

$$= 882,641.2 \text{ \#/HR} \quad (100\% \text{ theoretical capacity})$$

$$(\quad) \times .9$$

$$= 794,377.09 \quad (90\% \text{ theoretical capacity})$$

$$[\downarrow]$$

see pg 19A for typical
capacities @ pressures
1 to 2 percent above set pressure


$$= 617,848.9 \text{ \#/HR} \quad (70\% \text{ theoretical capacity})$$

Since 617,848.9 is greater than 434,256.1 \#/HR
1st Safety Values can relieve greater than 11 percent of
nominal steam flow. Thus okay to have 1085 psig
as minimum test pressure requirement for aux. feedwater
pumps in Tech Specs.

See Note pg 6A

/R2

7 x 10 INCHES
 MADE IN U.S.A.
 KUPFFEL & ESSER CO.



no effects compared
 test curve 4

MOTOR DRIVEN - TEST

APPENDIX E

Min Required Head for AFM Pumps.

RZ RK3 3/25/87

COMPUTED DATE


By 3/27/87

CHECKED DATE

2219280000

	BHP					N ₂	NPSH				
					AVG						AVG
0	310	195	288	270	266	400	11	11.5	11.0	11.0	11.1
200	355	345	349	350	350	500	14.5	14.5	14.5	14.5	14.5
400	446	450	452	450	450	600	19.1	19.0	19.0	19.0	19.0
600	521	527	524	526	525	650	22.0	21.6	22.0	21.9	21.9
750	551	560	560	560	558	700					
	EFF						HEAD				
					AVG						AVG
0	0	0	0	0	0	3500	3530	3550	3500	3520	
200	47.5	51.2	48.8	49.0	49.1	3390	3430	3450	3440	3478	
400	68.9	68.8	69.3	68.0	68.8	3060	3100	3100	3050	3078	
600	72.0	73.0	72.0	71.0	72.0	2480	2570	2520	2465	2509	
750	68.0	71.0	68.4	-	69.1	1900	2080	1980	-	1985	

2219280000



ME 10 X 10 TO 1/2 INCH 46 1320
7 X 10 INCHES MADE IN U.S.A.
KEUFFEL & ESSER CO.

SEQUOYAH NUCLEAR PLANT
UNITS 1&2
TURBINE DRIVEN AUXILIARY
FEED PUMPS
COMPOSITE OF TWO TEST CURVES
PUMP TEST SPEED = 3970 RPM
SNP 57731

TURBINE DRIVEN - TEST

APPENDIX E

Min. Required Head For AF VI Pumps

R2 RKF 3/25/87
 Bcy 3/27/87

COMPUTED _____ DATE _____

CHECKED _____ DATE _____

2219280000

BHP				NPSH			
			Avg				
0	480	485	483	600	12	12	12
400	590	500	545	800	15	15	15
800	732	745	738	1000	19	19	19
1200	870	875	873	1200	24.5	23.3	23.9
1480	930	935	933	1400	32	30.7	31.3
EFF				HEAD			
			Avg.				
0	0	0	0	3000	2960	2980	
					2970	2965	
400	47.0	46.0	47.5	2900	2830	2890	
					2800	2850	
800	72.0	74.3	73.2	2730	2690	2710	
					2650	2705	
1200	80.0	81.5	80.8	2340	2340	2340	✓
1480	77.8			2000	1975	1988	✓
1660	77.3	81.0	78.9				
200	60.0						

(From Ref 3)

1R2

JLW
 1/12/79

10% correction

2x slope
 0-GPM 2664 (296) 2688 (298)

400-GPM 2800-295=2505 2865-298=2567

and to give 400+40

Min Required Head for AFM Pumps

2219280000

APPENDIX E

COMPUTED JWW DATE 1/29/79

CHECKED JWW DATE 1-29-79

JWW 2/21/79

RL 6/13/85

JWH 6/14/85

Revise 4.7.1.2.a (1.) and (2.) as follows:

(1.) Verifying that each motor driven pump develops a differential pressure greater than or equal to ~~1397 psid~~ ^{1183.5 psid} that shown in the summary of results (sh. i) on recirculation flow.

(2.) Verifying that the steam turbine driven pump develops a differential pressure greater than or equal to ~~1183 psid~~ ^{1183.5 psid} on recirculation flow with the secondary steam supply pressure greater than or equal to 842 psig.

R3

Calc. ID. No. 2219280000

WP12195
Data Sheet 3
Page 1 of 2
12/03/86

DATA SHEET 3

AFW SYSTEM
MDAFW 2A-A Pump Test

S/G Pressure At Approximately 1,005 psig
Unit 2

WCN 12195-262
HFK
2/9/88

CA 4
4/6/87

PARAMETER	INSTRUMENT	STEP 5.4.16 DATA	STEP 5.4.24 DATA	SUGGESTED VALUE
S/G No. 1 Level	IR-3-43A LI-3-164	<u>26</u> %	<u>34</u> %	Info 25-30%
S/G No. 2 Level	IR-3-43A LI-3-156	<u>28</u> %	<u>34</u> %	Info 25-30%
S/G No. 1 Pressure	PI-1-2A OR RTDTS	<u>1005</u> psig	<u>990</u> psig	apprx. 1,005 psig
S/G No. 2 Pressure	PI-1-9A OR RTDTS	<u>985</u> psig	<u>970</u> psig	apprx. 1,005 psig
CST Level	LI-2-230D or LI-2-233D	<u>28 1/2</u> ft	<u>28 1/2</u> ft	>15.8 ft

Recorded By John O'Neil 3-17-88

ICF 87-162
CA 4 9-12-87

STEP NO.	PARAMETER	INSTRUMENT	DATA	SUGGESTED VALUE
5.4.21	Pump Motor Current	2-EI-3-119XB	<u>40</u> amps	<40 amps
5.4.21	Pump speed	Strobotac	<u>3568</u> rpm	Info
5.4.21	AFW temperature to S/G No. 1	Log T2425A or Contact Pyrometer	<u>57.6</u> °F	Info
5.4.21	AFW temperature to S/G No. 2	Log T2426A or Contact Pyrometer	<u>57.6</u> °F	Info

~~* indicate narrow (NR) or wide range (WR)~~

* APPLIES ONLY TO STEP 5.4.16

WCN 12195-262
HFK
2/9/88

Recorded by John O'Neil 3-17-88

WP 12195

PAGE X-a-36 OF

Calc. ID. No. 2219280000

WP12195
Data Sheet 3
Page 2 of 2
12/29/86

DATA SHEET 3

AFW SYSTEM
MDAFP 2A-A Pump Test
S/G Pressure at Approximately 1,005 psig
Unit 2

STEP NO.	MEASUREMENT	INSTRUMENT	DATA WITH UNITS
5.4.20	Flow Rate to S/G No. 1	2-FT-3-163 (Auto Data 10)	<u>297.98</u>
5.4.20	Flow Rate to S/G No. 2	2-FT-3-155 (Auto Data 10)	<u>260.05</u>
5.4.20	MDAFP 2A-A Recirculation Flow Rate	Ultrasonic Meter	<u>23.7 gpm</u>
5.4.20	Suction Pressure (Corrected for Water Leg)	Temporary PT at 2-PI-3-117 (Auto Data 10)	<u>18.26</u>
5.4.20	Discharge Pressure (Corrected for Water Leg)	2-PT-3-122A (Auto Data 10)	<u>1112.39</u>
5.4.25 *	Time to Reach 460 gpm from a MDAFW 2A-A Pump Start Signal (Flow to S/G Nos. 1 and 2)	RTDTS	3.2 secs

See Chron Log 3-17-88, 2355
Lob 3-17-88
3-17-88 Lob ~~8.0 secs~~ *

DN-12
HPK
2/17/88

INITIAL
HPK
3/18/88

Recorded by Jenni Obed 13-17-88

*The allowable time must be less than 21.75 seconds. 60 seconds (response time from BO signal to full flow) minus 28.25 seconds (actual load sequence delay time from the latest SI-247.900 run on December 12, 1984) minus 10 seconds (maximum D/G start and bus reenergization) equals 21.75 seconds.

↑
need to add
flow error to 15 gpm
time to 475 gpm

Drawing
45N 603-3 K
needs to be
revised to eq.
500 to 400 psia

0243E/bh

2219280000

PMT-53

ATTACHMENT III

CALCULATION SHEET

Sheet 1 of 3

Test PMT 53 SG Pressure 1005 PSIG Date April 16, 1984
 Pump 1A-A Calculated by Rich Mann
 Checked by Craig A. Hilley

I. Miscellaneous Data Transferred from Data Sheets and the RTDTS Plots

Total flow to SGs from pump 551.6 gpm
 Suction pressure 16.08 psig; Discharge pressure 1128 psig
 Barometric pressure at M-D pump 29.04 in. Hg
 Auxiliary feedwater temperature 69.0 °F

II. Miscellaneous Information

Radius at suction 3.03 in.; Radius at discharge 2.75 in.
 Water leg at suction -0.71 ft.
 (Elevation difference between gage and pump centerline, position if gage is above ϵ and NEG if gage is below ϵ .)
 Water leg at discharge 0 ft.
 Approximate local air temperature near M-D pumps 78 °F

III. Available Net Positive Suction Head, NPSH

A. $P_{atm} = \text{Barometric Pressure, in. Hg} \times 0.491 \text{ psi/in. Hg}$
 $= 29.04 \text{ in. Hg} \times 0.491$
 $= 14.26 \text{ psia}$

B. $P_v = \text{Vapor Pressure of Water, psia at AFW Temperature}$
 $= 0.35 \text{ psia at } 69 \text{ °F}$

C. $\text{Water Leg at Suction, psi} = \text{Water Leg at Suction, ft.} \times \text{Density of Water, lbm/ft}^3 \text{ at Local Air Temperature}$
 $= 0.71 \text{ ft} \times 62.27 \text{ lbm/ft}^3$
 $= 0.31 \text{ psi}$

D. $\text{Corrected Suction Pressure}$
 $= \text{Suction-Pressure, psig plus or minus the-water leg at suction, psi}$
 $= 16.08 \text{ psig} - 0.31 \text{ psi}$
 $= 15.77 \text{ psig}$

E. $W_{in} = \text{Specific Weight of Water, lb/ft}^3 \text{ at AFW Temperature}$
 $= 62.3 \text{ lb/ft}^3 \text{ at } 69 \text{ °F}$

F. $\text{Total Pump Flow, gpm} = \text{flow to SGs, gpm} + 25 \text{ gpm}$
 $= 576.6 \text{ gpm}$

WP 10920

PAGE x-d-16 OF x-d-21

PMT-53

ATTACHMENT III

CALCULATION SHEET

Sheet 2 of 3

Test PMT 53 SG Pressure 1005 PSIGDate April 16, 1984Pump 1A-ACalculated by Rob ShawChecked by Craig A. HildleyG. Inlet Velocity, V_{in}

$$V_{in} = \frac{(\text{Total Pump Flow, gpm}) \times (144 \text{ in}^2/\text{ft}^2)}{\pi (\text{radius, in})^2 \times 7.48 \text{ gal}/\text{ft}^3 \times 60 \text{ sec}/\text{min}}$$

$$= \frac{(576.6) \times 144}{3.1416 \times (3.03)^2 \times 7.48 \times 60}$$

$$= (576.6) \times 0.011124$$

$$= \underline{6.41} \text{ ft/sec}$$

H. Suction Head, H_s

$$H_s, \text{ ft H}_2\text{O} = \left[(\text{Corrected Suction Pressure, psig}) \times \frac{144}{(W_{in})} \right] + \frac{V_{in}^2}{2g}$$

$$= \left(\frac{15.77}{62.3} \right) \times 144 + \frac{(6.41)^2}{64.348}$$

$$= \underline{37.09} \text{ ft of H}_2\text{O}$$

$$\begin{aligned} \text{I. Available NPSH} &= \left[[(\text{Patm, psia}) - (\text{Pv, psia})] \times \frac{144}{(W_{in})} \right] + (H_s, \text{ ft of H}_2\text{O}) \\ &= \left[[(14.26) - (0.35)] \times 144 / (62.3) \right] + (37.09) \\ &= \underline{69.24} \text{ ft of H}_2\text{O} \end{aligned}$$

IV. Total Head, H

$$\begin{aligned} \text{A. } W_{out} &= \text{Specific Weight of Water, lb}/\text{ft}^3 \text{ at AFW Temperature} \\ &= \underline{62.3} \text{ lb}/\text{ft}^3 \text{ at } \underline{69} \text{ }^\circ\text{F} \end{aligned}$$

$$\begin{aligned} \text{B. Water Leg at Discharge, psi} &= \text{Water Leg at Discharge, ft} \times \text{Density of Water} \\ &\quad \text{lbm}/\text{ft}^3 \text{ at Local Air Temperature} \\ &= \underline{0} \text{ ft} \times \underline{62.3} \text{ lbm}/\text{ft}^3 \\ &= \underline{0} \text{ psi} \end{aligned}$$

10920

X-d-17-07 x-d-21

PMT-53

ATTACHMENT III

CALCULATION SHEET

Sheet 3 of 3

Test PMT 53 SG Pressure 1005 PSIG Date April 16, 1984Pump 1A-A Calculated by Rich BrownChecked by Craig A. Hildley

C. Corrected Discharge Pressure = Discharge Pressure, psig plus or minus the Water Leg at Discharge, psi

$$= \frac{1128}{1128} \text{ psig} \pm \frac{0}{0} \text{ psi}$$

$$= \underline{1128} \text{ psig}$$

D. Outlet Velocity, V_{out}

$$V_{out} = \frac{(\text{Total Pump Flow, gpm}) \times (144 \text{ in}^2/\text{ft}^2)}{\pi (\text{radius, in})^2 \times 7.48 \text{ gal}/\text{ft}^3 \times 60 \text{ sec}/\text{min}}$$

$$= \frac{(576.6) \times 144}{3.1416 \times (2.75)^2 \times 7.48 \times 60}$$

$$= \underline{7.79} \text{ ft/sec.}$$

E. Discharge Head, H_d

$$H_d, \text{ ft. H}_2\text{O} = [(\text{Corrected Discharge Pressure, psig}) \times \frac{144}{(W_{out})}] + \frac{V_{out}^2}{2g}$$

$$= \left(\frac{1128}{62.3} \right) \times 144 + \frac{(7.79)^2}{64.348}$$

$$= \underline{2608.2} \text{ ft of H}_2\text{O}$$

F. $H = H_d - H_s = \frac{2571.1}{576.6} \text{ ft of H}_2\text{O}$ at a total pump flow rate of $\frac{576.6}{576.6} \text{ gpm.}$

CAG:JLR
01/20/84
B5236.MC

WP 10920PAGE x-d-18 OF x-d-21

PMT-53

2219280000

ATTACHMENT III

CALCULATION SHEET

Sheet 1 of 3

Test PMT-53 SG Pressure 1005 psig Date April 16, 1984
 Pump 1B-B Calculated by Rich Mann
 Checked by Craig Hildley

I. Miscellaneous Data Transferred from Data Sheets and the RTDTS Plots

Total flow to SGs from pump 526.2 gpm
 Suction pressure 16.05 psig; Discharge pressure 1128 psig
 Barometric pressure at M-D pump 29.04 in. Hg
 Auxiliary feedwater temperature 75.3 °F

II. Miscellaneous Information

Radius at suction 3.03 in.; Radius at discharge 2.75 in.
 Water leg at suction 0.71 ft.
 (Elevation difference between gage and pump centerline, position if gage is above ϵ and NEG if gage is below ϵ .)
 Water leg at discharge 0 ft.
 Approximate local air temperature near M-D pumps 78 °F

III. Available Net Positive Suction Head, NPSH

A. Patm = Barometric Pressure, in. Hg x 0.491 psi/in. Hg.
 = 29.04 in. Hg x 0.491
 = 14.26 psia

B. Pv = Vapor Pressure of Water, psia at AFW Temperature
 = 0.43 psia at 75.3 °F

C. Water Leg at Suction, psi = Water Leg at Suction, ft. x Density of Water,
 lbm/ft³ at Local Air Temperature
 = 0.71 ft x 62.27 lbm/ft³
 = 0.31 psi

D. Corrected Suction Pressure

= Suction Pressure, psig plus or minus the water leg at suction, psi
 = 16.05 psig \pm 0.31 psi
 = 15.74 psig

E. Win = Specific Weight of Water, lb/ft³ at AFW Temperature
 = 62.3 lb/ft³ at 75.3 °F

F. Total Pump Flow, gpm = flow to SGs, gpm + 25 gpm
 = 551.2 gpm

WF 10920

PMT-53

ATTACHMENT III

CALCULATION SHEET

Sheet 2 of 3

Test PMT 53 SG Pressure 1005 psig Date April 16, 1984
 Pump 1B-B Calculated by Rick Hsu
 Checked by Craig A. Hilley

G. Inlet Velocity, V_{in}

$$V_{in} = \frac{(\text{Total Pump Flow, gpm}) \times (144 \text{ in}^2/\text{ft}^2)}{\pi (\text{radius, in})^2 \times 7.48 \text{ gal}/\text{ft}^3 \times 60 \text{ sec}/\text{min}}$$

$$= \frac{(551.2) \times 144}{3.1416 \times (3.03)^2 \times 7.48 \times 60}$$

$$= (551.2) \times 0.011124$$

$$= \underline{6.13} \text{ ft}/\text{sec}$$

H. Suction Head, H_s

$$H_s, \text{ ft H}_2\text{O} = [(\text{Corrected Suction Pressure, psig}) \times \frac{144}{(W_{in})}] + \frac{V_{in}^2}{2g}$$

$$= \left(\frac{15.74}{62.3} \right) \times 144 + \frac{(6.13)^2}{64.348}$$

$$= \underline{36.96} \text{ ft of H}_2\text{O}$$

$$\text{I. Available NPSH} = \left[\frac{[(P_{atm, psia}) - (P_v, psia)] \times \frac{144}{W_{in}}}{144/(62.3)} \right] + (H_s, \text{ ft of H}_2\text{O})$$

$$= \left[\frac{[(14.26) - (0.43)] \times \frac{144}{62.3}}{144/(62.3)} \right] + (36.96)$$

$$= \underline{68.93} \text{ ft of H}_2\text{O}$$

IV. Total Head, H

$$\text{A. } W_{out} = \text{Specific Weight of Water, lb}/\text{ft}^3 \text{ at Air Temperature}$$

$$= \underline{62.3} \text{ lb}/\text{ft}^3 \text{ at } \underline{75.3} \text{ } ^\circ\text{F}$$

$$\text{B. Water Leg at Discharge, psi} = \text{Water Leg at Discharge, ft} \times \text{Density of Water}$$

$$\text{lbm}/\text{ft}^3 \text{ at Local Air Temperature}$$

$$= \underline{62.30} \text{ ft} \times \underline{62.3} \text{ lbm}/\text{ft}^3$$

$$= \underline{0} \text{ psi}$$

CMS
4/16/84

WR 10920PAGE x-d-20 OF x-d-21

PMT-53

ATTACHMENT III

CALCULATION SHEET

Sheet 3 of 3

Test PMT 53 SG Pressure 109.5 psig Date April 16, 1984
 Pump 1B-B Calculated by Rich Houn
 Checked by Craig A. Hildley

C. Corrected Discharge Pressure = Discharge Pressure, psig plus or minus the Water Leg at Discharge, psi
 = 1128 psig + 0 psi
 = 1128 psig

D. Outlet Velocity, V_{out}

$$V_{out} = \frac{(\text{Total Pump Flow, gpm}) \times (144 \text{ in}^2/\text{ft}^2)}{\pi (\text{radius, in})^2 \times 7.48 \text{ gal}/\text{ft}^3 \times 60 \text{ sec}/\text{min}}$$

$$= \frac{(551.2) \times 144}{3.1416 \times (2.75)^2 \times 7.48 \times 60}$$

$$= \underline{7.44} \text{ ft}/\text{sec.}$$

E. Discharge Head, H_d

$$H_d, \text{ ft. H}_2\text{O} = [(\text{Corrected Discharge Pressure, psig}) \times \frac{144}{(W_{out})}] + \frac{V_{out}^2}{2g}$$

$$= \left(\frac{1128}{62.3} \right) \times 144 + \frac{(7.44)^2}{64.348}$$

$$= \underline{2608.1} \text{ ft of H}_2\text{O}$$

F. $H = H_d - H_s = \frac{2571.1}{551.2} \text{ ft of H}_2\text{O at a total pump flow rate of gpm.}$

CAG:JLR
 01/20/84
 B5236.MC

WP 10920PAGE X-d-21 OF X-d-21

PMT-53
AFW System

2219280000

Data Sheet 8.3.1
Page 1 of 3

Unit 2
Two-Pump Start Test
(2A-A and 2B-B AFWP)

Step	Measurement	Instrument	Data W/Units	Suggested Value	Recorded by/Date
8.3.1.8.2 (Before pump start)	SG No. 1 Pressure	PI-1-2A	1013.3 psig	≈ 1005 psig	Scott Long / 12/17/84
	SG No. 2 Pressure	PI-1-9A	1013.3 psig	≈ 1005 psig	
	SG No. 3 Pressure	PI-1-20A	1015.4 psig	≈ 1005 psig	
	SG No. 4 Pressure	PI-1-27A	1009.6 psig	≈ 1005 psig	
	SG No. 1 Level	LR-3-43	28.5 %	Info	
	SG No. 2 Level	LR-3-43	23.1 %	Info	
	SG No. 3 Level	LR-3-98	27.1 %	Info	
	SG No. 4 Level	LR-3-98	24.9 %	Info	
CST Levels		LI-2-230D/	25.4 ft.	Info	Scott Long / 12/17/84
		LI-2-233D	25.8 ft.	Info	
8.3.1.11.1 (After pump has stopped)	SG No. 1 Pressure	PI-1-2A	993.5 psig	≈ 1005 psig	Scott Long / 12/17/84
	SG No. 2 Pressure	PI-1-9A	993.5 psig	≈ 1005 psig	
	SG No. 3 Pressure	PI-1-20A	992.8 psig	≈ 1005 psig	
	SG No. 4 Pressure	PI-1-27AB	990.5 psig	≈ 1005 psig	
	SG No. 1 Level	LR-3-43	36.3 %	Info	
	SG No. 2 Level	LR-3-43	29.3 %	Info	
	SG No. 3 Level	LR-3-98	34.1 %	Info	
	SG No. 4 Level	LR-3-98	34.0 %	Info	
CST Levels		LI-2-230D/	25.0 ft.	Info	Scott Long / 12/17/84
		LI-2-233D	25.5 ft.	Info	
8.3.1.10.1	2 A-S AFWP Suction	PS-3-121A	27.7 psig (A.D. 10) 9 sec 12/19/84	> 12.9 psig	See log entry on 9/15/85 for clarification 12/19/85 for explanation 9/17/85 Scott Long / 12/17/84
	2A-A M-D AFWP Suction	PS-3-139A	16.238 psig (A.D. 10) 9 sec 12/19/84	> 1.25 psig	
	2B-B M-D AFW Suction	PS-3-144A	16.248 psig (A.D. 18) 9 sec 12/19/84	> 1.25 psig	
	T-D AFWP Suction Pressure Below 12.9 psig		< 2 sec.	< 5.5 sec.	
	2A-A AFWP Suction Pressure Below 1.25 psig		< 2 sec.	< 4.0 sec.	
	2B-B AFWP Suction Pressure Below 1.25 psig		< 2 sec.	< 4.0 sec.	
	2A-A Discharge Pressure	PT-3-122A	1168 psig (RTDTS)	Info	
	2B-B Discharge Pressure	PT-3-132A	1117 psig (RTDTS)	Info	
	2A-A Recirc. Flowrate		N/A gpm	Info	
	2B-B Recirc. Flowrate		N/A gpm	Info	

PMT-53
AFW System

2219280000

Data Sheet 8.3.1 (Continued)
Page 2 of 3

Unit 2
Two-Pump Start Test
(2A-A and 2B-B AFWP)

Step	Measurement	Instrument	Data W/Units	Suggested Value	Recorded by/Date
8.3.1.10.2	Flow to SG 1	2-FI-3-163A	251.6 gpm	Info	
	Flow to SG 2	2-FI-3-155A	220.3 gpm	Info	
	Total Flow from pump 2A-A to SG 1 and 2		471.9 gpm	> 500 gpm	460 TC-86-1109 Rmm 9/20/84
	Flow to SG 3	2-FI-3-147A	224.6 gpm	Info	
	Flow to SG 4	2-FI-3-170A	323.0 gpm	Info	
	Total Flow from pump 2B-B to SG 3 and 4		547.6 gpm	> 500 gpm	
	Time to reach 500 gpm from pump 2A-A (Flow to SG Nos. 1 and 2)		4.6 / 6.8 sec.	< *23.75 sec.	① Time for sum of 2 loop flow to equal flowrate (i.e. 460 or 500)
	Time to reach 500 gpm from pump 2B-B (Flow to SG Nos. 3 and 4)		3.8 / 8.6 sec.	< *23.75 sec.	② Time to steady-state flowrates.
8.3.1.10.3	Barometric pressure at M-D pumps		29.48 In. Hg.	Info	
8.3.1.3	AFW temperature to SG No. 1	log T2425	69.6 °F	Info	* Avg. values during 2 minute data interval
	AFW temperature to SG No. 2	log T2426	66.45 °F	Info	
	AFW temperature to SG No. 3	log T2427	67.25 °F	Info	** AFW temp for loop 4 did not trend on P250. Value used is that for loop 3.
	AFW temperature to SG No. 4	log T2428	67.25 °F	Info	
8.3.1.2	2A-A pump speed	Strobe	3490 rpm	Info	
	2B-B pump speed	Strobe	3490 rpm	Info	

*This time criteria was calculated as follows:

Sixty seconds (response time from Bo signal to full flow) minus 26.25 seconds (maximum load sequence delay time) minus 10 seconds (maximum diesel generator start and bus regeneration) equals 23.75 seconds.

WP 11243

TVA 10697 (DNE 6-86)

DNE CALCULATIONS

TITLE AUXILIARY FEEDWATER SYSTEM PRESSURE DROP CALCULATION				PLANT/UNIT SEQUOYAH / UNIT 1 & 2		
PREPARING ORGANIZATION MEB - HCG		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) AFW, PRESSURE DROP, SYSTEM RESISTANCE				
BRANCH/PROJECT IDENTIFIERS SNP 1-2-CA-0053 0-HCG-JWW-082274		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in. Rev (for RIMS' use) RIMS accession number				
APPLICABLE DESIGN DOCUMENT(S) DESIGN CRITERIA SQN-DC-V-13.9.B		R0	830512B0008	MEB '830509 301		
		R1	870331E0004	B25 870324 804		
		R2	B25 880430 806			
SAR SECTION(S) 10.4.7.2		UNID SYSTEM(S) 03B	R- INFORMATION ONLY (Not Original Copy)			
Revision 0		R1	R2	R3	Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
ECN No. (or indicate Not Applicable)		N/A			Statement of Problem	
Prepared J.W. Aderholdt		J.P. Hahn	John Bartleman			Determine the pressure drop (dP) in the Auxiliary Feedwater (AFW) system piping; first in the discharge of the Motor-Driven AFW Pumps (MDAFWP) and Turbine-Driven AFW Pumps (TDAFWP), and then in the suction piping for these pumps.
Checked E.W. Scheinhausser		H.V. Garreth	M.H. Laid			
Reviewed for R.K. Sood		R.W. Bond	J.D. Whinnery			
Approved for H.R. Corbett		J.E. Pilgrim	J.E. Pilgrim			
Date 8/23/74		3/23/87	27 April 88			
Use form TVA 10534 if more space required	List all pages added by this revision.	Revision Log	1-16			
	List all pages deleted by this revision.		Attachment A 1-20A of previous rev.			
	List all pages changed by this revision.	1				
Abstract						
These calculations contain an unverified assumption(s) that must be verified later. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>						
<p>An analysis of the pressure drop (dP) in the discharge and suction piping of the AFW pumps is performed to show the total dP for the AFW system. The AFW pump flow path chosen to represent the dP for the pump discharge is the flow path to Steam Generator (S/G) No. 3, and for the pump suction it is the 1A-A MDAFWP and 1A-S TDAFWP. These paths were chosen because the dP results obtained are conservative.</p>						
<input type="checkbox"/> Microfilm and store calculations in RIMS Service Center. <input checked="" type="checkbox"/> Microfilm and return calculations to: J.E. PILGRIM - SEQUOYAH			Microfilm and destroy. <input type="checkbox"/> Address: DSC - C3			

QA Record EN DES CALCULATIONS ORIGINAL

SEGUOYAH NUCLEAR PLANT
 AUX. FEEDWATER SYSTEM
 PRESSURE DROP CALCULATION

UNID SYSTEM(S) CA
 PLANT/UNIT SQN 152
 SAR SECTION(S)

PREPARING ORGANIZATION MEB - HCG		REV	(FOR MEDS USE)	MEDS ACCESSION NUMBER	
APPLICABLE DESIGN DOCUMENTS APPLICABLE	BRANCH/PROJECT IDENTIFIERS SNPI-2-CA-D053 0-HCG-JWW-082274	R0	830512B00008	33 MEB	'830509 301
		R1	870331E00004	35 B25	870324 804
		R2			
KEY NOUNS AFW, PRESSURE DROP		R3			

REV	R0	R1	R2	R3	STATEMENT OF PROBLEM
DATE	8/23/74	03/23/87			Determine the pressure drop in the AFW system piping, first in the discharge of the motor driven and turbine driven pumps, and then in the suction piping of those pumps.
PREPARED	J. W. Aderholdt	J. P. Hahn			
CHECKED	P. W. Steinkaus	Robert V. Sandiford			
SUBMITTED	For R. K. SOOD	For [Signature]			
APPROVED	For H. R. CORBETT	[Signature]			
ATTACHMENTS MICROFILMED:					
LIST ALL PAGES * ADDED BY THIS REV:		REVISION LOG			
LIST ALL PAGES * DELETED BY THIS REV:					
LIST ALL PAGES * CHANGED BY THIS REV:		1			

SEE NEW COVER SHEET

ABSTRACT

An analysis of the pressure drop in the discharge piping of the AFW system motor driven pump and turbine driven pump is performed. The pressure drop in the ^{pumps} suction piping is then determined.

Return original to ~~L. C. Smith W7A34 C-100~~ ^{24 MAR}
 H V Garrett SQN DSC D5

CALCULATION INDEPENDENT REVIEW VERIFICATION FORM

SNP 1-2 - CA - 0053

0-HCG - JWW - 082274

Calculation No.

R2

Revision

Method of independent review used (check one or more):

- 1. Alternate calculation method _____
- 2. Testing method _____
- 3. Other method X

Justification (explain below):

Method 1: Identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 2: Identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

Method 3: Justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

CALCULATION IS TECHNICALLY ADEQUATE BECAUSE IT IS BASED
ON ACCEPTED HANDBOOK METHODS AND DESIGN GUIDES. THESE
REFERENCES ARE IDENTIFIED WITHIN THE CALCULATION.

Robert V. Dancy
Design Verifier
(Independent Reviewer)

4/27/88
Date

Title: AUXILIARY FEEDWATER SYSTEM PRESSURE DROP CALCULATION

Revision No.	DESCRIPTION OF REVISION	Date Approved
0	INITIAL ISSUE	
1	RESPONSE TO MEMO FROM D.W. WILSON TO G.B. KIRK (RIMS B25 B7C109027). EXPLANATION OF ASSUMPTION ADDED. REVISION LOG ADDED. NO ECN IS INVOLVED	
2	REVISED ENTIRE CALCULATION TO DOCUMENT REFERENCES AND ACCEPTABLE METHOD(S) TO DETERMINE PRESSURE DROPS FOR AFW SYSTEM. ADDED APPENDIX A, 7 SHEETS.	

A) PURPOSE

This calculation determines the pressure drop (ΔP) across the AFW system piping, fittings, valves, etc. The total calculated ΔP for the AFW system can be used to determine the total required head that an AFW pump must develop in order to assure that the pump can meet its design function.

B) ASSUMPTIONS - listed in body of calculation.

c) REFERENCES -

- 1) TVA Mechanical Design Guide DG-MA.8.5 Rev. 3
- 2) CRANE Technical Paper No. 410 - Flow of Fluids Through Valves, Fittings, and Pipe. 1986
- 3) AFW Bill of Materials - 47BM427 Series
- 4) AFW System Design Criteria SON-DC-V-13.9.8 Rev. R0
- 5) Mechanical AFW Piping Drawings:

<u>DRAWING</u>	<u>REVISION</u>	<u>UNIT</u>
47W420-5	H/G	1/2
47W427-1	E	1+2
47W427-2	F	1+2
47W427-3	B/E	1/2
47W427-4	F/G	1/2
47W427-5	B	1
47W427-6	A/C	1/2
47W427-7	I/I	1/2
47W427-8	E	1+2
47W420-10	R	0

- 6) Condensate Bill of Materials - 47BM420 Series
- 7) AFW Pumps Minimum Head Required Calc. - 221928000 Rev. R4
(B2E 880430 807)
- 8) Vendor Drawings:

<u>DRAWING</u>	<u>CONTRACT</u>	<u>REVISION</u>	<u>UNIT</u>	<u>EQUIPMENT ID</u>
A-32500-134	83520-7	1	1+2	FE-3-142
A-32500-135	83520-1	1	1+2	FE-3-147

- 9) Contract file #73024 83577 for AFW Level Control Valves. (see Attachment A)


FLOW RATES

③	to	②	- 440 GPM
②	to	⑦	- 220
①	to	①	- 220
④	to	⑤	- 880
⑤	to	⑥	- 440
⑥	to	⑦	- 220
⑦	to	①	- 220


D. CALCULATIONS

ASSUMPTION:

The pressure drops for the paths that were analyzed can be used as conservative result for the other paths.



--- CALCULATED
 △ to △ and △ to △



MOTOR - DRIVEN
 AFW PUMPS
 (MDAFWP)





TURBINE
 DRIVEN
 AFW PUMP
 (TDAFWP)

NOTE: △ - PIPING JUNCTION LOCATION SYMBOL


DESIGN CRITERIA DIAGRAM OF Aux. FEEDWATER SYSTEM
PUMP DISCHARGE PIPING - UNIT 1 (UNIT 2 SIMILAR)

Start at the intersection point (7) of the MDAFWP and TDAFWP and work back to the discharge of the E MDAFWP (point 3). (see reference 5)

4" PIPE SIZE



6" PIPE SIZE



3 Discharge Flange of MDAFWP (1B-B)

UNIT 1 - AS SHOWN
UNIT 2 - SIMILAR

PRESSURE DROP CALCULATION SHEET

Sheet 6 of 16

SYSTEM AUXILIARY FEEDWATER (*03B)
 CALC ID SNP 1-2-CA-D053
2-HCG-JWW-082274

Computed by gpc Date 4-21-82
 Checked by WJ Date 4-21-82


Line Identification		<u>4²⁰5</u>	<u>5²⁰6</u>	<u>6²⁰7</u>	<u>7²⁰1</u>	<u>8²⁰2</u>	<u>8²⁰7</u>	
Nominal Dia, In. (ref. 5)	D	<u>6</u>	<u>6</u>	<u>4</u>	<u>4</u>	<u>6</u>	<u>4</u>	
Schedule (ref. 3)		<u>120</u>	<u>120</u>	<u>120</u>	<u>120</u>	<u>120</u>	<u>120</u>	
Internal Dia, In. (ref. 2)	d	<u>5.501</u>	<u>5.501</u>	<u>3.624</u>	<u>3.624</u>	<u>5.501</u>	<u>3.624</u>	
Pressure, psia (ref. 4)	P	<u>1100</u>	<u>1100</u>	<u>1100</u>	<u>1100</u>	<u>1100</u>	<u>1100</u>	
Temperature, °F (ref. 4)	T	<u>40</u>	<u>40</u>	<u>40</u>	<u>40</u>	<u>40</u>	<u>40</u>	
Spec Volume, Ft ³ /Lb (ref. 2)	v	<u>0.01602</u>	<u>0.01602</u>	<u>0.01602</u>	<u>0.01602</u>	<u>0.01602</u>	<u>0.01602</u>	
Viscosity, Centipoise (ref. 1)	u	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	
Flow, gpm (ref. 4)	Q	<u>880</u>	<u>440</u>	<u>220</u>	<u>220</u>	<u>440</u>	<u>220</u>	
Flow, Lb/Hr (8.02Q/v)	W	<u>440.549</u>	<u>220.275</u>	<u>110.137</u>	<u>110.137</u>	<u>220.275</u>	<u>110.137</u>	
Velocity, Ft/Sec (0.0509Wv/d ²)	V	<u>11.87</u>	<u>5.94</u>	<u>6.84</u>	<u>6.84</u>	<u>5.94</u>	<u>6.34</u>	
Reynolds No. (6.31W/du)	Re	<u>315,836</u>	<u>157,918</u>	<u>119,855</u>	<u>119,855</u>	<u>157,918</u>	<u>119,855</u>	
Friction Factor (ref. 1)	f	<u>0.0172</u>	<u>0.0185</u>	<u>0.0204</u>	<u>0.0204</u>	<u>0.0185</u>	<u>0.0204</u>	
dP/100' (0.000336W ² vf/d ⁵)		<u>3.57</u>	<u>0.96</u>	<u>2.13</u>	<u>2.13</u>	<u>0.96</u>	<u>2.13</u>	
L/D 90° Welding Elbow (ref. 5)	13	<u>91(9)</u>	<u>—</u>	<u>26(2)</u>	<u>117(9)</u>	<u>78(6)</u>	<u>117(9)</u>	
L/D 45° Welding Elbow (ref. 5)	8.5	<u>—</u>	<u>—</u>	<u>—</u>	<u>8.5(1)</u>	<u>—</u>	<u>8.5(1)</u>	
L/D Tee (Thru run) (ref. 5)	20	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>20(1)</u>	<u>20(2)</u>	
L/D Tee (Thru branch) (ref. 5)	60	<u>60(1)</u>	<u>60(1)</u>	<u>60(1)</u>	<u>—</u>	<u>60(1)</u>	<u>—</u>	
L/D 45° Lateral (Thru branch)	30	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	
L/D Reducer/Enlarger (ref. 1+5)		<u>—</u>	<u>9.9(1)</u>	<u>7.7(1)</u>	<u>—</u>	<u>18.7(1)</u>	<u>12.2(2)</u>	
L/D Gate Valve* (ref. 5)	10	<u>—</u>	<u>—</u>	<u>20(2)</u>	<u>—</u>	<u>—</u>	<u>20(2)</u>	
L/D Globe Valve*	340	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	
L/D Swing Check Valve* (ref. 5)	80	<u>80(1)</u>	<u>—</u>	<u>80(1)</u>	<u>160(2)</u>	<u>80(1)</u>	<u>80(1)</u>	
Total Fitting L/D		<u>221</u>	<u>69.9</u>	<u>200.8</u>	<u>285.5</u>	<u>270.5</u>	<u>285.5</u>	
Fitting Equiv. Length, Ft(L/D)(d/12)		<u>105.9</u>	<u>25.0</u>	<u>60.6</u>	<u>26.2</u>	<u>124.0</u>	<u>26.2</u>	
Piping Length, Ft (ref. 5)		<u>27.2</u>	<u>6.25</u>	<u>5.1</u>	<u>227.3</u>	<u>24.1</u>	<u>22.1</u>	
Total Equiv. Length, Ft L		<u>133.1</u>	<u>31.2</u>	<u>65.7</u>	<u>420.2</u>	<u>148.1</u>	<u>126.3</u>	
Orifice Plate dP, psi (see c.1)		<u>8.72</u>	<u>—</u>	<u>—</u>	<u>2.84</u>	<u>—</u>	<u>—</u>	
Pressure Drop, psi (dP/100')(L/100)		<u>6.97</u>	<u>0.37</u>	<u>1.40</u>	<u>8.95</u>	<u>1.73</u>	<u>2.76</u>	

*L/D for valves are in the fully open position.

D. CALCULATIONS

ASSUMPTIONS:

1) Maximum total required flow for one unit = $4 \times 465 = 1860 \text{ gpm}$



--- CALCULATED $\triangle 11$ to $\triangle 18$ and $\triangle 11$ to $\triangle 19$

NOTE: \triangle - PIPING JUNCTION LOCATION SYMBOL

DESIGN CRITERIA DIAGRAM OF AUX. FEEDWATER SYSTEM
PUMP SUCTION PIPING - UNIT 1&2


PIPING LENGTHS AND COMPONENTS BETWEEN NODAL POINTS ON DESIGN CRITERIA DIAGRAM (Sheet) FOR AFW PUMPS SUCTION PIPING.


Longest Piping run is to 1A-A MDAFWP and 1A-S TDAFWP from the B CST. Tabulate pipe lengths and fittings from CST to AFW Pumps in order to calculate a pipe friction loss. All components are the same size as the pipe, unless otherwise noted. (see reference 5)



12" PIPE SIZE

- 11 2.9' - Pipe el. 702'-7 $\frac{1}{2}$ "
- 1- 90° Elbow
- 14.5' - Pipe
- 1- 90° Elbow
- 80' - Pipe
- 1- 90° Elbow
- 21.25' - Pipe
- 1- 90° Elbow
- 15.3' - Pipe
- 1- Gate Valve



12a 16" PIPE SIZE

- 1- Tee (16" x 12" x 16") 
- 2.2' - Pipe
- 8.25' - Pipe
- 1- 90° Elbow
- 1- 45° Elbow (approx.)
- 9.25' - Pipe el. 700'-9"
- 1- 90° Elbow
- 53.5' - Pipe
- 1- 45° Elbow
- 14.15' - Pipe
- 1- 45° Elbow
- 15' - Pipe
- 1- Gate Valve
- 30.5' - Pipe
- 1- 90° Elbow
- 4.25' - Pipe





- 14 40.3' - Pipe (approx.)
- 1- Tee (16" x 8" x 16") 
- 12' - Pipe 
- 15 1- Tee (16" x 8" x 16")
- 3' - Pipe (approx.)
- 1- Reducer (16" x 10")

10" PIPE SIZE

- 66.5' - Pipe (approx.)
- 1- 90° Elbow
- 8' - Pipe
- 1- 90° Elbow
- 8' - Pipe
- 1- 90° Elbow
- 8' - Pipe
- 1- 90° Elbow
- 8' - Pipe
- 1- 90° Elbow
- 63' - Pipe (approx.)
- 16 1- Tee (10" x 8" x 10") 
- 12' - Pipe
- 17 1- Tee (10" x 8" x 10") 
- 1- Reducer (10" x 8")

8" PIPE SIZE

- 4' - Pipe (approx.)
- 1- 90° Elbow
- 8.9' - Pipe el. 692'-0 $\frac{15}{16}$ "
- 1- 90° Elbow
- 1- Gate Valve
- 1- Check Valve 
- 1- Standard Tee
- 5' - Pipe
- 1- 90° Elbow



CALCULATION

SNP 1-2-CA-0053


O-HCG-JWW-082274

COMPUTED *JPR* DATE 4-21-88


CHECKED *MH* DATE 4-26-88

Start at the intersection point ($\triangle 17$) of the CST supply to the MDAFWP (IA-A) and TDAFWP (IA-S) and work to the suction of the TDAFWP (IA-S).
(see reference 5)

10" PIPE SIZE



- 1- Tee (10" x 8" x 10")
- 43.5' - Pipe (approx.)
- 1- 90° Elbow
- 6' - Pipe el. 700' - 11 5/8"
- 1- 90° Elbow
- 4' - Pipe el. 687' - 0"
- 1- 90° Elbow
- 3.9' - Pipe
- 1- 90° Elbow
- 25' - Pipe
- 1- 90° Elbow
- 10' - Pipe el. 677' - 0"
- 1- 90° Elbow
- 1- Gate Valve
- 1- 90° Elbow
- 1- Check Valve



- 1- Standard Tee
- 5.75' - Pipe
- 1- 90° Elbow
- 6.8' - Pipe
- 1- Reducer (10" x 8")
- 1- 90° Elbow

$\triangle 19$ Suction Flange of TDAFWP (IA-S)

PRESSURE DROP CALCULATION SHEET

Sheet 10 of 16

SYSTEM AUXILIARY FEEDWATER (#03B)
 CALC ID SNP 1-2-CA-D053
0-HCG-JWW-082274

Computed by SRC Date 4-21-92
 Checked by MJE Date 4-26-92

Line Identification		$\Delta 11^{20}/13$	$\Delta 12^{20}/13$	$\Delta 13^{20}/14$	$\Delta 14^{20}/15$	$\Delta 15^{20}/16$	$\Delta 16^{20}/17$	
Nominal Dia, In. (ref. 5)	D	<u>12</u>	<u>16</u>	<u>16</u>	<u>16</u>	<u>10/16</u>	<u>10</u>	
Schedule (ref. 3+6)		<u>STD</u>	<u>30</u>	<u>30</u>	<u>30</u>	<u>40/30</u>	<u>40</u>	
Internal Dia, In. (ref. a)	d	<u>12.00</u>	<u>15.25</u>	<u>15.25</u>	<u>15.25</u>	<u>10.02/15.65</u>	<u>10.02</u>	
Pressure, psia (ref. 3+6)	P	<u>65</u>	<u>65</u>	<u>65</u>	<u>65</u>	<u>65</u>	<u>65</u>	
Temperature, °F (ref. 4)	T	<u>STD</u>	<u>40</u>	<u>40</u>	<u>40</u>	<u>40</u>	<u>40</u>	
Spec Volume, Ft ³ /Lb (ref. a)	v	<u>0.01602</u>	<u>0.01602</u>	<u>0.01602</u>	<u>0.01602</u>	<u>0.01602</u>	<u>0.01602</u>	
Viscosity, Centipoise (ref. 1)	u	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	
Flow, gpm (ref. 4)	Q	<u>3720</u>	<u>3720</u>	<u>2790</u>	<u>2285</u>	<u>1860</u>	<u>1395</u>	
Flow, Lb/Hr (8.02Q/v)	W	<u>1,863,322</u>	<u>1,862,322</u>	<u>1,396,742</u>	<u>1,163,951</u>	<u>931,161</u>	<u>698,371</u>	
Velocity, Ft/Sec (0.0509Wv/d ²)	V	<u>10.55</u>	<u>6.52</u>	<u>4.90</u>	<u>4.09</u>	<u>7.56/3.82</u>	<u>5.67</u>	
Reynolds No. (6.31W/du)	Re	<u>612,044</u>	<u>481,609</u>	<u>361,207</u>	<u>301,025</u>	<u>366,474/0.01602</u>	<u>374,970</u>	
Friction Factor (ref. 1)	f	<u>0.0149</u>	<u>0.0149</u>	<u>0.0155</u>	<u>0.0158</u>	<u>0.0161</u>	<u>0.0165</u>	
dP/100' (0.000336W ² vf/d ⁵)		<u>1.12</u>	<u>0.34</u>	<u>0.20</u>	<u>0.14</u>	<u>0.74/2.09</u>	<u>0.42</u>	
L/D 90° Welding Elbow (ref. 5)	13	<u>52(4)</u>	<u>29(2)</u>	—	—	<u>52(4)</u>	—	
L/D 45° Welding Elbow (ref. 5)	8.5	—	<u>25.5(2)</u>	—	—	—	—	
L/D Tee (Thru run) (ref. 5)	20	—	<u>20(1)</u>	<u>20(1)</u>	<u>20(1)</u>	<u>20(1)</u>	<u>20(1)</u>	
L/D Tee (Thru branch) (ref. 5)	60	—	—	—	—	—	—	
L/D 45° Lateral (Thru branch)	30	—	—	—	—	—	—	
L/D Reducer/Enlarger (ref. 1+5)		<u>5.2(1)</u>	—	—	—	<u>10(1)</u>	—	
L/D Gate Valve* (ref. 5)	10	<u>10(1)</u>	<u>10(1)</u>	—	—	—	—	
L/D Globe Valve*	340	—	—	—	—	—	—	
L/D Swing Check Valve* (ref. 5)	80	—	—	—	—	—	—	
Total Fitting L/D		<u>67.2</u>	<u>94.5</u>	<u>20</u>	<u>20</u>	<u>52/30</u>	<u>20</u>	
Fitting Equiv. Length, Ft(L/D)(d/12)		<u>67.2</u>	<u>120.1</u>	<u>25.4</u>	<u>25.4</u>	<u>43.4/37.1</u>	<u>16.7</u>	
Piping Length, Ft (ref. 5)		<u>134</u>	<u>137.1</u>	<u>40.2</u>	<u>12</u>	<u>153.5/2</u>	<u>12</u>	
Total Equiv. Length, Ft L		<u>201.2</u>	<u>257.6</u>	<u>65.7</u>	<u>37.4</u>	<u>196.9/21.1</u>	<u>28.7</u>	
Orifice Plate dP, psi		—	—	—	—	—	—	
Pressure Drop, psi (dP/100')(L/100)		<u>2.25</u>	<u>0.27</u>	<u>0.13</u>	<u>0.05</u>	<u>1.46/0.04</u>	<u>0.12</u>	
						<u>1.50</u>		

*L/D for valves are in the fully open position.

PRESSURE DROP CALCULATION SHEET

Sheet 11 of 16

SYSTEM AUXILIARY FEEDWATER (*03B)

CALC ID SNP 1-2-CA-D053

Computed by gob Date 4-21-95

0-HCG-JWW-082274

Checked by MTT Date 4-21-95

Line Identification		$\Delta T_{17}^{\circ} / \Delta T_{18}^{\circ}$	$\Delta T_{18}^{\circ} / \Delta T_{19}^{\circ}$					
Nominal Dia, In	(ref. 5) D	<u>8</u>	<u>10</u>					
Schedule	(ref. 3)	<u>40</u>	<u>40</u>					
Internal Dia, In.	(ref. 2) d	<u>7.981</u>	<u>10.02</u>					
Pressure, psia	(ref. 3) P	<u>*</u>	<u>*</u>					
Temperature, °F	(ref. 4) T	<u>40</u>	<u>40</u>					
Spec Volume, Ft ³ /Lb	(ref. 2) v	<u>0.01602</u>	<u>0.01602</u>					
Viscosity, Centipoise	(ref. 1) u	<u>1.6</u>	<u>1.6</u>					
Flow, gpm	(ref. 4) Q	<u>465</u>	<u>930</u>					
Flow, Lb/Hr (8.02Q/v)	W	<u>232,790</u>	<u>465,581</u>					
Velocity, Ft/Sec (0.0509Wv/d ²)	V	<u>2.98</u>	<u>3.78</u>					
Reynolds No. (6.31W/du)	Re	<u>115,021</u>	<u>183,247</u>					
Friction Factor (ref. 1)	f	<u>0.0189</u>	<u>0.0175</u>					
dP/100' (0.000336W ² vf/d ⁵)		<u>0.17</u>	<u>0.20</u>					
L/D 90° Welding Elbow (ref. 5)	13	<u>29(3)</u>	<u>117(9)</u>					
L/D 45° Welding Elbow	8.5	<u>—</u>	<u>—</u>					
L/D Tee (Thru run) (ref. 5)	20	<u>20(1)</u>	<u>20(1)</u>					
L/D Tee (Thru branch) (ref. 5)	60	<u>60(1)</u>	<u>60(1)</u>					
L/D 45° Lateral (Thru branch)	30	<u>—</u>	<u>—</u>					
L/D Reducer/Enlarger (ref. 1+5)		<u>5.4(1)</u>	<u>5.4(1)</u>					
L/D Gate Valve* (ref. 5)	10	<u>10(1)</u>	<u>10(1)</u>					
L/D Globe Valve*	340	<u>—</u>	<u>—</u>					
L/D Swing Check Valve* (ref. 5)	80	<u>80(1)</u>	<u>80(1)</u>					
Total Fitting L/D		<u>214.4</u>	<u>292.4</u>					
Fitting Equiv. Length, Ft(L/D)(d/12)		<u>142.6</u>	<u>244.8</u>					
Piping Length, Ft (ref. 5)		<u>17.9</u>	<u>10.5</u>					
Total Equiv. Length, Ft L		<u>160.5</u>	<u>349.8</u>					
Orifice Plate dP, psi		<u>—</u>	<u>—</u>					
Pressure Drop, psi (dP/100')(L/100)		<u>0.27</u>	<u>0.70</u>					

*L/D for valves are in the fully open position.

* Pressure is 65 psia up to the check valves, and 16E psia between the check valves and the pump.

CALCULATION

SNF. 1-2 - CA - D053

O-HCG-JWW-082274

COMPUTED SPB DATE 4-21-88CHECKED WVA DATE 4-26-88D. CALCULATIONS

1) Orifice Plates

Compute the ΔP for the orifice plates installed in the AFW piping.

$$Q = 236 d_o^2 C \sqrt{\frac{\Delta P}{\rho}} \quad (\text{ref. 2})$$

Q = flow in gpm ; d_o = orifice plate hole diameter in inches ;
 C = flow coefficient ; ΔP = pressure drop in psi ; ρ = weight density

$$\Delta P = \rho \left(\frac{Q}{236 d_o^2 C} \right)^2$$

Find ΔP for FE-3-142

$Q = 880$ gpm ; $d_o = 3.8028$ in (ref. 8) ; $C = 0.69$; $\rho = 62.426$ (@ 40°F)

$$\Delta P = 62.426 \left(\frac{880}{236 (0.69)(3.8028)^2} \right)^2 = \underline{8.72 \text{ psi}}$$

Find ΔP for FE-3-147

$Q = 220$ gpm ; $d_o = 2.55027$ in (ref. 8) ; $C = 0.672$; $\rho = 62.426$

$$\Delta P = 62.426 \left(\frac{220}{236 (0.672)(2.55027)^2} \right)^2 = \underline{2.84 \text{ psi}}$$

PRESSURE DROP CALCULATION SHEET

Sheet 13 of 16

SYSTEM AUXILIARY FEEDWATER - #038
 CALC ID SNP 1-2-CA-D053
Q-HCQ-JWW-082274

Computed by CPB Date 4-21-88
 Checked by WJL Date 4-21-88


SUBJECT PRESSURE DROP ACROSS THE AFW LEVEL CONTROL VALVES ON THE DISCHARGE OF THE TURBINE-DRIVEN AFW PUMP - 3" LCV-3-172, 173, 174, + 175

D. CALCULATIONS

CONTROL VALVE

2) LCV's

d.2 Compute dP for LCV-3-172



Liquid Sizing Coeff.
 $C_v = \underline{155}$ (ref. 9)

$$C_v = Q \sqrt{\frac{G}{\Delta P}}$$

$$Q = C_v \sqrt{\frac{\Delta P}{G}} \quad (\text{ref. 9})$$

$$\frac{C_v}{Q} = \sqrt{\frac{G}{\Delta P}}$$

$$\left(\frac{C_v}{Q}\right)^2 = \frac{G}{\Delta P}$$

$$\Delta P = G \left(\frac{Q}{C_v}\right)^2$$

G = SP. GR. = 1.001

Q = Flow Rate = 220 gpm

C_v = Flow Coeff. = 155

$$\Delta P = \frac{(1.001)(220)^2}{(155)^2}$$

$$= \frac{(1.001)(48,400)}{(24,025)}$$

$\Delta P = \underline{2.02}$ psi

ΔP = Press. Drop = _____ psi

Q = Flow Rate = _____ gpm

G = Specific Gravity = _____

$$Q = \text{---} \sqrt{\text{---}}$$

$$= \text{---} \sqrt{\text{---}}$$

$$= (\quad) (\quad)$$

Q = _____ gpm

PRESSURE DROP CALCULATION SHEET

Sheet 14 of 16

SYSTEM AUXILIARY FEEDWATER - #038
 CALC ID SNP 1-a-CA-D053
Q-HCG-JWW-082274

Computed by GPB Date 4-21-88
 Checked by /// Date 4-21-88

SUBJECT PRESSURE DROP ACROSS THE AFW LEVEL CONTROL VALVES ON THE DISCHARGE OF THE MOTOR-DRIVEN AFW PUMPS - 4" LCY-3-148, 156, 164, & 171


D. CALCULATIONS

CONTROL VALVE

a) LCY's

d.2

Compute dP for LCY-3-148



Liquid Sizing Coeff.
 $C_v = \underline{195}$ (ref. 9)

$$C_v = Q \sqrt{\frac{G}{\Delta P}}$$

$$Q = C_v \sqrt{\frac{\Delta P}{G}} \quad (\text{ref. 2})$$

$$\frac{C_v}{Q} = \sqrt{\frac{G}{\Delta P}}$$

$$\left(\frac{C_v}{Q}\right)^2 = \frac{G}{\Delta P}$$

$$\Delta P = G \left(\frac{Q}{C_v}\right)^2$$

G = SP. GR. = 1.001

Q = Flow Rate = 337 gpm

C_v = Flow Coeff. = 195

$$\Delta P = \frac{(1.001) (337)^2}{(195)^2}$$

$$= \frac{(1.001) (48,800)}{(38,025)}$$

$\Delta P = \underline{1.27}$ psi

ΔP = Press. Drop = _____ psi

Q = Flow Rate = _____ gpm

G = Specific Gravity = _____

$$Q = \frac{C_v}{\sqrt{\frac{\Delta P}{G}}}$$

$$= \frac{C_v \sqrt{G}}{\sqrt{\Delta P}}$$

$$= \frac{C_v \sqrt{G}}{\sqrt{\Delta P}}$$

Q = _____ gpm

CALCULATION

SNP 1-2-CA-D053

O-HCG-JWW-082274

COMPUTED *JPB* DATE 4-21-88CHECKED *MHT* DATE 4-26-88

D. CALCULATIONS

3) MDAFWP

3.3 Compute the total pressure drop (dP) for the MDAFWP (piping, valves, and fittings) at the minimum required flow of 440 gpm to two steam generators (S/G).

$$\text{MDAFWP } dP = (\triangle 3 \text{ to } \triangle 1) + (\triangle 11 \text{ to } \triangle 18) + \text{LCV} + \text{Orifice Plate}$$

$$dP_M = dP_{3-2} + dP_{2-7} + dP_{7-11} + dP_{11-12} + dP_{12-13} + dP_{13-14} + dP_{14-15} \\ + dP_{15-16} + dP_{16-17} + dP_{17-18} + dP_{\text{LCV}-2-148} + dP_{\text{OE}-3-147}$$

(see d.2) (see d.1)

$$dP_M = 1.73 + 3.76 + 8.95 + 2.25 + 0.87 + 0.13 + 0.05 + 1.50 + 0.12 \\ + 0.27 + 1.27 + 2.84$$

$$\underline{dP_M = 23.74 \text{ psi}}$$

NOTE: This MDAFWP dP value does not include the dP value for the Cavitating Venturi (on the pump discharge). The cavitating venturi dP is accounted for in reference # 7.

3.4 4) TDAFWP - Compute the total dP for the TDAFWP (piping, valves, and fittings) at the minimum required flow of 440 gpm to two S/G.

$$\text{TDAFWP } dP = (\triangle 4 \text{ to } \triangle 1) + (\triangle 11 \text{ to } \triangle 19) + \text{LCV} + \text{Orifice Plates}$$

$$dP_T = (dP_{4-5}) \left(\frac{440 \text{ gpm}}{880 \text{ gpm}} \right)^2 + dP_{5-6} + dP_{6-7} + dP_{7-11} + dP_{11-12} + dP_{12-13} \\ + dP_{13-14} + dP_{14-15} + dP_{15-16} + dP_{16-17} + dP_{17-19} + dP_{\text{LCV}-3-142} + dP_{\text{OE}-3-147} \\ + dP_{\text{OE}-3-142} \left(\frac{440 \text{ gpm}}{880 \text{ gpm}} \right)^2$$

(see d.1) (see d.2) (see d.1)

$$dP_T = 6.97 (0.25) + 0.37 + 1.40 + 8.95 + 2.25 + 0.87 + 0.12 + 0.05 + 1.50 \\ + 0.12 + 0.70 + 2.02 + 2.84 + 8.72 (0.25)$$

$$\underline{dP_T = 25.12 \text{ psi}}$$

The dP values used for the MDAFWP and TDAFWP suction piping assumes a TDAFWP flow of 880 gpm which is greater than the minimum required flow of 440 gpm. Therefore, the total pump suction piping dP value used is conservative, even though the difference between dP values for a TDAFWP flow of 880 and 440 gpm are small. Also, the flow through the suction piping is higher than that of the specific pump being considered because it is assumed that all six AFW pumps are running simultaneously. This approach is conservative since the total dP for the suction piping is higher.

The flow rates for the AFW pumps suction piping includes the pump circ. flow of 25 gpm per MDAFWP and 50 gpm per TDAFWP.

The pressure drop (dP) through the main feedwater line from the AFW p. tie in to the steam generator is negligible since it is a short run of pipe and the dP for 220 gpm through a 16" pipe is very small.

SNP 1-2-CA-D053
 O-HCG-JWW-082274
 R-1

I&C F-014 RIO/73

REQUISITION NO. 83577

		ITEM NO.	23	MFR DATA (IF APP)
GENERAL	1	ITEM NO.	23	
	2	QUANTITY	8	X
	3	INSTRUMENT NO.	LCV-3-148, 156, 164, 171	
	4	DRAWING		
	5	REFERENCE	SPEC 1643	
	6	MANUFACTURER & MODEL	MASONELLAN MS	X
	7	UNIT PRICE/UNIT WT		X
	8	SERVICE	AUX FW	
	9	TVA CLASS/SEISMIC	C F	
	10	ACTION/INPUT SIGNAL	MODULATE 10-SOMA	X
DESIGN	11	LINE SIZE SCHEDULE	4" 120	
	12	MAX LINE PRESS. (PSIA)	1650	
	13	MAX ΔP (VLV CLOSED)	1305	
	14	MAX INLET TEMP (F)	100	
BODY	15	SIZE/STYLE	Globe	X
	16	ANSI RATING/MATERIAL	900 CARBON STEEL	X
	17	END CONNECTIONS	FLANGED	X
	18	BONNET TYPE	MS	X
	19	PACKING	MS	X
	20	LEAKOFF CONNECTIONS	NA	X
TRIM	21			
	22	PLUG FORM	MS	X
	23	MATERIAL	STAINLESS STEEL	X
	24	NO. OF PORTS/PORT SIZE	1 MS	X
	25	GUIDING	MS	X
	26	SPECIAL TRIM	HARDENED FACE	X
	27			
ACT.	28	TYPE	MS	X
	29	SIZE & STROKE	MS MS	X
	30	AIR SUPPLY	70-100 PSIG	X
	31	FAILURE POSITION	OPEN	X
ACCESSORIES POS'NER	32	MANUFACTURER & MODEL	MASONELLAN 8012	X
	33	BYPASS/GAUGES	MS MS	X
	34	FOR INPUT OF	10 MA 50 MA	X
	35	OUTPUT SHALL BE	3 PSIG 15 PSIG	X
	36	FILTER-REG TYPE	67FR-35 FISHER	X
ACCESSORIES	37	LIMIT SWITCHES (EA LIMIT)	DPDT	X
	38	L. S. CONTACT RATING	PAR 21.2.3	X
	39	SOLENOID VALVE (SEE NOTE 2)	3 WAY (PARA 21.2.6)	X
	40	S.V. COIL VOLTAGE	125 VDC	X
	41			
OPER COND	42			
	43	FLOWING MEDIUM	WATER	
	44	SIZING CONDITIONS	MAX MIN MAX MIN	
	45	FLOW RATE	550 GPM NA	
	46	PRESSURE (PSIA)	1110 NA	
	47	TEMPERATURE (F)	100 NA	
	48	ΔP (PSI)	20 NA	
	49	CY (CALC) (1)		X
	50	CY (ACTUAL)		X

X---DATA BY BIDDER
 #---OR EQUAL
 NA--NOT APPLICABLE
 MS--MFR STANDARD

NOTES: (1) USE FOR 80% TO 90% OF VALVE OPERATOR STROKE.

(2) TAG SOLENOID VALVES
 LSV-3-148, 156, 164, 171

M-6; DATE:
 H-5; DATE:

SPECIFICATION NO. 1643

SNP-1-a-CA-D053

O-HCG-JWW-082274

R-2

I&C F-014 R10/73

REQUISITION NO. 83577

R-2

R-2
R-2
R-2
R-2

R-2

GENERAL	DESIGN	BODY	TRIM	ACT.	POS'NER	ACCESSORIES	OPER COND
1 ITEM NO.	2 QUANTITY	3 INSTRUMENT NO.	4 DRAWING	5 REFERENCE	6 MANUFACTURER & MODEL	7 UNIT PRICE/UNIT WT	8 SERVICE
9 TYA CLASS/SEISMIC	10 ACTION/INPUT SIGNAL	11 LINE SIZE SCHEDULE	12 MAX LINE PRESS. (PSIA)	13 MAX ΔP (VLY CLOSED)	14 MAX INLET TEMP (F)	15 SIZE/STYLE	16 ANSI RATING/MATERIAL
17 END CONNECTIONS	18 BONNET TYPE	19 PACKING	20 LEAKOFF CONNECTIONS	21	22 PLUG FORM	23 MATERIAL	24 NO. OF PORTS/PORT SIZE
25 GUIDING	26 SPECIAL TRIM	27	28 TYPE	29 SIZE & STROKE	30 AIR SUPPLY	31 FAILURE POSITION	32 MANUFACTURER & MODEL
33 BYPASS/GAUGES	34 FOR INPUT OF	35 OUTPUT SHALL BE	36 FILTER-REG TYPE	37 LIMIT SWITCHES	38 L.S. CONTACT RATING	39 SOLENOID VALVE	40 S.V. COIL VOLTAGE
41 HAND WHEEL	42	43 FLOWING MEDIUM	44 SIZING CONDITIONS	45 FLOW RATE	46 PRESSURE (PSIA)	47 TEMPERATURE (F)	48 ΔP (PSI)
49 CV (CALC) (I)	50 CV (ACTUAL)						

X---DATA BY BIDDER
 *---OR EQUAL
 MA--NOT APPLICABLE
 MS--MFR STANDARD

NOTES: (1) USE FOR 80% TO 90% OF VALVE OPERATOR STROKE.
 (2) TAG LSV-3-172,173,174,175

M-6; DATE:
 M-5; DATE:
 EMGR: JES DATE: 5 8 74

SPECIFICATION NO. 1645

PLANT: SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2

CONTROL VALVES
 DATA SHEET NO. 71

CUSTOMER TVA
REFERENCE Contract 73074-23577
Plant-Water - Unit 1E2

Masonite International, Inc.
Norwood, Massachusetts 02062
Montebello, California 90030

SNP 1-2-CA
O-HCG - JWW

QUOTE 2073-Add PAGE 3
- D053
- 082274
DATE 7-30-73 BY RHM

ATTACHMENT A
CONTROL VALVE SPECIFICATION

- Equipment Tagging -
(Aluminum Tags)

<u>Quote Item</u>	<u>Control Valve</u>	<u>Solenoid Valve</u>
	<u>SG Flowdown Tool Vlv</u>	
	1-FCV-1-181 Flow	1-FSV-1-181
	2-FCV-1-181	2-FSV-1-181
	1-FCV-1-182	1-FSV-1-182
<u>21. Tag one each</u>	2-FCV-1-182	2-FSV-1-182
	1-FCV-1-183	1-FSV-1-183
	2-FCV-1-183	2-FSV-1-183
	1-FCV-1-184	1-FSV-1-184
	2-FCV-1-184	2-FSV-1-184

Aux F.W. Pump Back Trans Control

	1-PCV-3-122 Pressure	
	2-PCV-3-122	
<u>22. Tag one each</u>	1-PCV-3-132	(none)
	2-PCV-3-132	

Aux Feedwater Tank

	1-LCV-3-143 Level	1-LSV-3-143
	2-LCV-3-143	2-LSV-3-143
	1-LCV-3-156	1-LSV-3-156
<u>23. Tag one each</u>	2-LCV-3-156	2-LSV-3-156
	1-LCV-3-164	1-LSV-3-164
	2-LCV-3-164	2-LSV-3-164
	1-LCV-3-171	1-LSV-3-171
	2-LCV-3-171	2-LSV-3-171

Aux Feedwater Tank

	1-LCV-3-172 Level	1-LSV-3-172
	2-LCV-3-172	2-LSV-3-172
	1-LCV-3-173	1-LSV-3-173
<u>24. Tag one each</u>	2-LCV-3-173	2-LSV-3-173
	1-LCV-3-174	1-LSV-3-174
	2-LCV-3-174	2-LSV-3-174
	1-LCV-3-175	1-LSV-3-175
	2-LCV-3-175	2-LSV-3-175

ATTACHMENT A

TENNESSEE VALLEY AUTHORITY

KNOXVILLE, TENNESSEE 37002

WBC126 Commercial Realty Management Building
400 Commerce Avenue

SNP 1-2-CA-D053

O-HCG-JWW-082274

DEC 79 1 27 922

December 21, 1979

Masoneilan International, Incorporated
63 Nahatan Street
Holwood, Massachusetts 02062

Attention: Mr. Edward J. Canniff, Certified Print Department

Gentlemen:

SEQUOYAH AND WATTS BAR NUCLEAR PLANTS UNITS 1 AND 2
VALVES AND CONTROLS - NUCLEAR
CONTRACT 73C34-83577
REF ROOTS7 AND ROOT38

**RECEIVED
SEQUOYAH
JAN 3 1980
DIV. OF CONSTR.**

We have your transmittal letters dated September 17, 1979 (EEB 790920 029), October 9, 1979 (EEB 791015 028), and followup letter dated November 6, 1979 (EEB 791113 002), submitting drawings as listed below. We are returning two prints each of drawings marked (A) "Approved." We are returning one print and the sepia of each drawing marked (N) "Approved With Correction as Noted." Please make the necessary corrections on those marked (N) and resubmit.

<u>Status</u>	<u>Item No.</u>	<u>Ref. or Serial No.</u>	<u>Plant</u>	<u>Dwg. No.</u>	<u>Rev Date</u>	<u>Title</u>
A	23	N-00137-12	SQN	CP1-9-175	B	Control Valve 4" 20,000 Series ANSI CL 900
A	24	N-00137-27	SQN	CP40-8-98	A	Control Valve 3" 40,000 Series 900 ANSI
A	24	N-00138-23	WBN	CP40-8-195	9/14/79	Control Valve 3" 40,000 Series
N	39	N-00238-1	SQN & WBN	CP1-3-293	10/4/79	Control Valve 1" 20,000 Series
N	40	N-00238-2	SQN & WBN	CP1-3-293	10/4/79	Control Valve 1" 20,000 Series
N	41	N-00238-3	SQN & WBN	CP1-3-293	10/4/79	Control Valve 1" 20,000 Series
N	42	N-00238-4	SQN & WBN	CP1-5-172	10/4/79	Control Valve 1-1/2" 20,000 Series
N	43	N-00238-5	SQN & WBN	CP1-5-172	10/4/79	Control Valve 1-1/2" 20,000 Series
N	44	N-00238-6	SQN & WBN	CP1-5-172	10/4/79	Control Valve 1-1/2" 20,000 Series
N	45	N-00238-7	SQN & WBN	CP1-5-172	10/4/79	Control Valve 1-1/2" 20,000 Series
N	46	N-00238-8	SQN & WBN	CP1-5-172	10/4/79	Control Valve 1-1/2" 20,000 Series

ATTACHMENT A

Masonellon International, Inc.
 Norwood, Massachusetts 02062
 Montebello, California 90690

SNP 1-2-CA-0053
 O-HCG-JWW-082274

QUOTE 2073-AJ, PAGE 9-Rev A1
 Rev. 1.

DATE 7-23-74 BY RNM

PAGE A5

CUSTOMER: **TVA**
 REFERENCE: **Plant-Seguoyah, Units 1&2**
TVA Piping Class

CONTROL VALVE SPECIFICATION

ITEM	22-R1	23-R1
1 TAG	See Page 1-Cont.	
2 QUANTITY	4	8
3 SIZE	4"	4"
4 MODEL	58-20721	37-20721 (1)
5 TYPE	Diaphragm Press Globe 1650 PSIA	
6 MATERIAL	ASME SA-216 Gr. WCB	
7 RATING	900 lb.	
8 CONN.	R.F. Flanged	
9 TYPE Material	Std. Bolted Same as Body	
10 GUIDE Bushing	#440-C St. St.	
11 PACKING	Crane 2CRJ	
12 Packing Box	Oversize	
13 SIZE	Full - 4"	Full - 4"
14 TYPE	Equal Percent Contoured	
15 PLUG MATERIAL	ASME SA-479, Ty. 316 (U)	
16 RING(S) MATERIAL	ASTM A276, Ty. 316 (U)	
17 FLOW TO	AIR TO	
18 RANGE	Open n/a	Close
19 TYPE 2	ME A Electrohydraulic	Diaph. - Spring
20 SIZE	Model No. 2-19K-6-C No. 2 (w/HL Comp.) 19,000 lbs. Stall Thrust	No. 24 (Direct)
21 Stroke	2"	2"
22 MODEL	n/a	8012 E/P
23 INPUT	10-50ma D.C.	10-50ma D.C.
24 SUPPLY	120V, 60cy AC	60 PSIG
25 AIRSET	n/a	No. 77-41 w/Gauge
26 FLUID	Water	
27 LINE SIZE	SCHED. 6" 120	4" 120
28 SP. GR. @ 60°	TEMP 1.0	0.9926 @ 180° 0.9938 @ 120°
29 ΔP SIZING	MAX. 1105 psi	20 psi 1305 psi
30 TEMP	MAX. 120° (R-1)	100°
31 QTY	MAX MIN 550 GPH 550 GPH	550 GPH (w. 1/2" str)
32 INLET	OUTLET 1110	1110 1090
33 VAPOR	CRIT. 3206.2	0.7492 3206.2
34 CF FACTOR	0.9	0.9
35 REQ'D CV	122.485	122.485
36 RATED CV	195	195
37 Net Unit Price	No. Change in Contract	446,200.00 (w. 14,323 cc)
38 Unit Shipping Weight - lbs.	760	735
39 NOTES: Nuclear Class	3	3
40 Service Class	E	E
41 Coating Quality Factor	1.00	1.00
42 Valve Action	Back Press. Control	Modulates (2) (R-1)
43 Allowable Seat Leakage	10.5 cc/hr H ₂ O	4 cc/hr. H ₂ O
44 Body Face - b. Face Dia.	18 1/4"	18 1/4"
45 Order Reference See	1b, 2c, 6, 7, 9, 11 thru 19, 21, 22, 23, 24a, 26, 27, 28b, 30 thru 33.	1b, 2d, 3c, 4, 6, 7, 9, 11 thru 19, 21, 22, 23, 24b, 26, 27, 28a, 30 thru 33.
46 Accessories: See	A	A, E-1, H, R ¹ & S.
47 Order Note: See	334E A ME A	334E
48 User to provide Controller		

(1) Hard. Inland Sealing Surface.
 (2) Changed from "On-Off" (3) Changed from Model No. 37-20761.

Note: Soft Seal for tight shut-off on Item 22-R1 is not available for 1305 max. shut-off ΔP; 500 - 550 psi is max. for soft seal construction.

ATTACHMENT A

SNP 1-3-CA-D053
O-HCG-JWW-082274

R-2
R-1 PAGE A6

I & C F-014

REQUISITION NO. 83577

GENERAL		DESIGN		BODY		TRIM		ACT.		POS'NER		ACCESSORIES		OPER COND	
1	TITLE NO.	2, 3													
2	QUANTITY	8													
3	INSTRUMENT NO.	LCV-3-172, 173, 174, 175													
4	DRAWING														
5	REFERENCE														
6	MANUFACTURER & MODEL	SPEC. 1648 Masonilan (2000)													
7	UNIT PRICE/UNIT WT														
8	SERVICE	AUX. F.W.													
9	TYA CLASS/SEISMIC	CLASS 1													
10	ACTION	ON / OFF													
11	LINE SIZE/SCHEDULE	4" / 120													
12	MAX LINE PRESS. (PSIA)	1650													
13	MAX LP (VLV CLOSED)	1250													
14	MAX INLET TEMP (F)	100°													
15	SIZE/STYLE	MS / MS													
16	ANSI RATING/MATERIAL	900 lb / 900 lb													
17	END CONNECTIONS	FLANGED													
18	END MET TYPE	MS													
19	PACKING	MS													
20	LEAKOFF CONNECTIONS	NA													
21															
22	PLUG FORM	MS													
23	MATERIAL	STAINLESS STEEL													
24	NO. OF PORTS/PORT SIZE	SINGLE / MS													
25	GUIDING	MS													
26	SPECIAL TRIM	HARDENED FACE													
27	Rep's Cost Leak/Sec/Air/Inch of valve size (mm/hr)														
28	TYPE	DIRTY/DIRTY													
29	SIZE & STROKE	MS / MS													
30	AIR SUPPLY	70-100 PSIG													
31	FAILURE POSITION	CLOSE													
32	MANUFACTURER & MODEL	NA / NA													
33	BYPASS/GAUGES	NA / NA													
34	FOR INPUT OF	NA / NA													
35	OUTPUT SHALL BE	NA / NA													
36	FILTER-REG TYPE	67 FR-55 FILTERS													
37	LIMIT SWITCHES	DPDT													
38	L.S. CONTACT RATING	15A/20VAC 12, 1/2, 1/20													
39	SOLENOID VALVE	3 WAY (100/2)													
40	S.V. COIL VOLTAGE	125 VAC													
41	HANDWHEEL	YES / SIDE MOUNTED													
42															
43	FLOWING MEDIUM	WATER													
44	SIZING CONDITIONS	MAX / MIN													
45	FLOW RATE (GPM)	440 / 0													
46	PRESSURE (PSIA)	1250 / 1250													
47	TEMPERATURE (F)	100° / 80°													
48	LP (PSI)	1250 / 20													
49	CV (CALC) (1)														
50	CV (ACTUAL)														

X---DATA BY RIDDER
P---OR EQUAL
NA--NOT APPLICABLE
MS--MFR STANDARD

NOTES: (1) USE FOR 80% TO 90% OF VALVE OPERATOR STROKE.
(2) TAG MSV-3-172, 173, 174, 175

H-5: DATE:
ENGR: JES DATE: 2-12-74 (RWH 1/14/74)

SPECIFICATION NO. 1648

PLANT: SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2

CONTROL VALVES

R-2

R-2
R-2
R-2

R-1

ENCLOSURE 3

PROPOSED TECHNICAL SPECIFICATION CHANGES

SEQUOYAH NUCLEAR PLANT UNIT 2

DOCKET NO. 50-328

(TVA-SQN-TS-88-02)

DETERMINATION OF NO SIGNIFICANT HAZARDS CONSIDERATIONS

Significant Hazards Evaluation

TVA has evaluated the proposed technical specification change and determined that it does not represent a significant hazards consideration based on criteria established in 10 CFR 50.92(c). Operation of SQN in accordance with the proposed amendment will not:

- (1) involve a significant increase in the probability or consequences of an accident previously evaluated. As described in section 10.4.7.2 of the SQN FSAR, the AFW system is an engineered safety features system designed, constructed, and operated to serve as a backup to the main feedwater system to provide feedwater to the steam generator in the event that main feedwater is not available. This maintains the heat sink capabilities of the steam generators. The AFW system is directly relied upon to prevent core damage and system overpressurization in the event of transients, such as a loss of normal feedwater or a secondary system pipe rupture, and to provide a means for plant cooldown following any plant transient.

The proposed change to SR 4.7.1.2.a adds pump-specific, differential pressure test values for each AFW pump. The new test values ensure that each AFW pump will provide a flow of at least 440 gal/min plus pump recirculation flow. This flow satisfies the FSAR assumptions concerning 440 gal/min AFW flow to two intact steam generators. The addition of pump-specific test values merely reflects the performance characteristics of different pumps. Because the revised SR ensures conformance with the FSAR accident analysis assumptions, the probability or consequences of an accident previously evaluated remain unchanged.

- (2) create the possibility of a new or different kind of accident from any previously analyzed. As described above, the proposed technical specification change to SR 4.7.1.2.a adds pump-specific, differential pressure requirements for the testing of the AFW system. The revised requirements ensure that the AFW pumps will satisfy the assumptions of the FSAR AFW analyses. No changes, other than those to the testing values, are made to the AFW system. As such, the possibility of a new or different kind of accident from any previously analyzed is not created by this change.
- (3) involve a significant reduction in a margin of safety. The proposed changes to SR 4.7.1.2.a add pump-specific, differential pressure test values for each AFW pump. The new test values ensure that each AFW pump will provide a flow of at least 440 gal/min plus recirculation flow. This flow ensures that plant operation is bounded by the FSAR analyses assumptions that 440-gal/min AFW flow is available to the steam generators. Because operation remains bounded by the FSAR analyses, there is no reduction in the margin of safety.