

March 7, 1986

Docket No. 50-336

Mr. John F. Opeka, Senior Vice President
Nuclear Engineering and Operations
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: PREVENTIVE MAINTENANCE AND SURVEILLANCE PROGRAM FOR REACTOR
TRIP BREAKERS FOR MILLSTONE-2 (ITEMS 4.2.1 AND 4.2.2 OF
GENERIC LETTER 83-28)

By letters dated November 8, 1983 and June 25, 1985 you provided responses to Items 4.2.1 and 4.2.2 of Generic Letter 83-28 concerning your preventive maintenance and surveillance programs for reactor trip breakers at Millstone Unit 2. We find your programs acceptable provided that the following conditions are met.

1. Measurement of the UVT device roller rivet armature clearance is done with the UVT armature in the energized position.
2. Inspection and adjustment of the trip latch engagement is performed in accordance with the applicable GE instruction manual.

We request that you confirm within 30 days that the above conditions will be met.

Enclosed is our Safety Evaluation which used technical input from Idaho National Engineering Laboratory.

Sincerely,

Ashok C. Thadani, Project Director
Division of PWR Licensing-B

Enclosure:
As stated

cc: See next page

DISTRIBUTION:
~~DOCKET FILE~~ ACRS (10)
NRC PDR
Local PDR
PD#8 Rdg.
ACThadani
OELD
EJordan
BGrimes
JPartlow
DOsborne
PMKreutzer

PD#8:
PMKreutzer
2/4/86

PD#8:
DOsborne: dd
3/7/86

PD#8: AT
ACThadani
3/7/86

8603140461 860307
PDR ADOCK 05000336
P PDR

Mr. John F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit No. 2

cc:
Gerald Garfield, Esq.
Day, Berry & Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

Mr. Wayne D. Romberg
Superintendent
Millstone Nuclear Power Station
P. O. Box 128
Waterford, Connecticut 06385

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
Office of Executive Director for
Operations
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Edward J. Mrocza
Vice President, Nuclear Operations
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Mr. Charles Brinkman, Manager
Washington Nuclear Operations
C-E Power Systems
Combustion Engineering, Inc.
7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Lawrence Bettencourt, First Selectman
Town of Waterford
Hall of Records - 200 Boston Post Road
Waterford, Connecticut 06385

Northeast Utilities Service Company
ATTN: Mr. Richard R. Laudenat, Manager
Generation Facilities Licensing
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental
Protection
State Office Building
Hartford, Connecticut 06106

Mr. John Shedlosky
Resident Inspector/Millstone
Box 811
Niantic, Connecticut 06357

Office of Policy & Management
ATTN: Under Secretary Energy
Division
80 Washington Street
Hartford, Connecticut 06106