

Georgia Power Company
Post Office Box 282
Waynesboro, Georgia 30830
Telephone 404 554-9961
404 724-8114

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011



Vogtle Project

September 20, 1988

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

File: X7BC35
Log: GN-1490

NRC DOCKET NUMBER 50-425
CONSTRUCTION PERMIT NUMBER CPPR-109
VOGTLE ELECTRIC GENERATING PLANT - UNIT 2
CONFIRMATORY ITEM 36: TDI DIESEL GENERATORS

Section 9.5.4.1.6 of supplement 5 to the Vogtle Safety Evaluation Report concluded that confirmatory Item 36 regarding the incorporation of generic and plant specific recommendations for TDI diesel generators was fully resolved for Vogtle Unit 1. However the program to verify and enhance the reliability of the Vogtle Unit 2 diesel generators by implementing the maintenance/ surveillance program recommended by the TDI Diesel Generator Owners Group was not complete.

The maintenance/surveillance program has also been implemented on Unit 2 as stated on page 8.3.1-22 of the Vogtle FSAR. All Phase I & II inspections have been performed on Unit 2 with the exception of the items listed below.

The remaining Phase I & II inspections are scheduled for completion by November 21, 1988. These inspections are consistent with all inspection requirements for Unit 1.

Train A

- 1) Report on connecting rod bolt eddy current test.
- 2) Eddy current on fuel injection lines.
- 3) Report on torsigraph test.
- 4) Turbocharger bearing inspection.
- 5) Turbocharger nozzle ring inspection.
- 6) Perform engine vibration survey.

Train B

- 1) Eddy current test on connecting rod bolt.
- 2) Eddy current on fuel injection lines.
- 3) Report on torsigraph test.
- 4) Turbocharger bearing inspection.
- 5) Turbocharger nozzle ring inspection.

8809290127 880920
PDR ADOCK 05000425
Q PDC

Boo1
1/0

If your staff should require additional information, please do not hesitate to contact me.

Sincerely,

J. A. Bailey

J. A. Bailey
Project Licensing Manager

JBA/sem

xc: NRC Regional Administrator	J. B. Hopkins (2)
NRC Resident Inspector	G. Bockhold, Jr.
P. D. Rice	J. E. Joiner, Esquire
J. P. Kane	R. J. Goddard, Esquire
R. A. Thomas	R. W. McManus
B. W. Churchill, Esquire	Vogtle Project File

jb009