



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 19, 1998

MEMORANDUM FOR:

Docket File

FROM:

Peter S. Tam, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

SUBJECT:

CATAWBA NUCLEAR STATION, UNITS 1 AND 2 -
IMPLEMENTATION OF AMENDMENTS 172 and 163 TO
OPERATING LICENSES (TAC MA3280 AND MA3281)

The attached document, transmitted by fax from Duke Energy Corporation, signifies the implementation of operating license Amendment Nos. 172 (for Unit 1) and 163 (for Unit 2) on October 7, 1998.

Docket Numbers 50-413
and 50-414

1/1

Distribution
Docket file
PUBLIC
H. Berkow

DF01

9810210227 981019
PDR ADOCK 05000413
P PDR

010044

NRC FILE CENTER COPY

APPENDIX D. 221. FACILITY OPERATING LICENSE/TECHNICAL SPECIFICATIONS AMENDMENT IMPLEMENTATION SHEET

FACILITY OPERATING LICENSE/TECHNICAL SPECIFICATIONS AMENDMENT IMPLEMENTATION SHEET

CNS MNS ONS UNIT NO. 1 2 3

TS NO. 4.6.5.1.5.2 DATE RECEIVED 9/14/98

AMENDMENT NO. 172/163 DESCRIPTION Extend SR frequency for NF lower inlet plenum/turning vanes from 9 to 18 months

1. IMPLEMENTATION DATES

A. NRC ISSUE DATE (Date of NRC Cover Letter): 9/10/98

B. NRC EFFECTIVE DATE (From Text of NRC letter): 9/10/98

C. STATION IMPLEMENTATION DATE (No later than NRC Effective Date): 10/10/98

2. PLANT NOTIFICATION

initials date
mc 9/15/98 Via E-Mail Distribution; Include Site Technical Contacts

3. RGC TECHNICAL CONTENT REVIEW CRITERIA

- A. All Discrepancies Have Been Resolved Via NRC Interface.
- B. No Inadvertent Changes Were Made To TS Sheets Involved.
- C. TS Change Was Issued As Requested By DPC.

TECHNICAL REVIEWER: [Signature] 9/15/98
(List Discrepancies On Attached Page) Date

CHECKED BY: Margaret Chernoff 9/15/98
(List Discrepancies On Attached Page) Date

4. PIP NUMBER (If generated): 0-C98-3400

*all
require
vbrn
complete 10/7/98.*

5. ALL APPLICABLE CORRECTIVE ACTIONS FROM ASSIGNED PIP COMPLETED

VERIFIED BY: [Signature] 10/7/98
Regulatory Compliance Date

6. ALL PRE-IMPLEMENTATION ITEMS (ITEMS 1-5) COMPLETED

VERIFIED BY: [Signature] 10/7/98
Regulatory Compliance Date

7. FINAL IMPLEMENTATION APPROVAL

• N/A N/A
Manager, Regulatory Compliance Date

• N/A N/A
Manager, Safety Assurance Date