

*Official*

SEP 16 1988

Docket Nos.: 50-327 and 50-328  
License Nos.: DPR-77 and DPR-79

Mr. S. A. White  
Senior Vice President, Nuclear Power  
Tennessee Valley Authority  
6N 38A Lookout Place  
1101 Market Square  
Chattanooga, TN 37402-2801

Dear Mr. White:

SUBJECT: NOTICE OF VIOLATION  
(NRC INSPECTION REPORT NOS. 50-327/88-36 AND 50-328/88-36)

This refers to the routine Nuclear Regulatory Commission (NRC) resident inspection conducted by P. Harmon on July 12 - August 5, 1988. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

The inspection findings indicate that certain activities appeared to violate NRC requirements. The violation identified involves the failure to adequately test certain containment isolation valves in the containment spray system per the requirements of 10 CFR 50 Appendix J. The violation, references to pertinent requirements, and elements to be included in your response are described in the enclosed Notice of Violation.

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2 Title 10, Code of Federal Regulations, a copy of this letter, its enclosures, and any reply will be placed in the NRC's Public Document Room.

The responses directed by this letter and its enclosures are not subjected to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

8809290325 880916  
PDR ADDCK 05000327  
G PNU

11  
IE01

SEP 16 1988

Tennessee Valley Authority

2

Should you have any questions concerning this letter, please contact us.

Sincerely,

ORIGINAL SIGNED BY  
FRANK R. McCOY

Frank R. McCoy, Assistant Director  
for TVA Inspection Programs  
TVA Projects Division  
Office of Special Projects

Enclosures:

1. Notice of Violation
2. NRC Inspection Report

cc w/encls:

J. A. Kirkebo, Vice President,  
Nuclear Engineering  
J. L. LaPoint, Acting Site Director  
Sequoyah Nuclear Plant  
R. L. Gridley, Director  
Nuclear Safety and Licensing  
M. J. Ray, Acting Site Licensing  
Manager  
TVA Representative, Rockville  
Office  
General Counsel, TVA  
State of Tennessee

bcc w/encls:

J. G. Partlow, OSP  
S. D. Richardson, OSP  
S. C. Black, OSP  
B. D. Liaw, OSP  
K. P. Barr, OSP/RII  
J. B. Brady, OSP/RII  
J. Rutberg, OGC  
NRC Resident Inspector  
DRS Technical Assistant  
NRC Document Control Desk

OSP/RII

*B*  
Brady  
9/15/88

OSP/RII

*K. Barr*  
K. Barr  
9/15/88

OSP/RII

*K. Barr*  
K. Barr  
9/15/88