

ENCLOSURE 1

NOTICE OF VIOLATION

Tennessee Valley Authority
Sequoyah

Docket Nos. 50-327, 50-328
License Nos. DPR-77, DPR-79

During the Nuclear Regulatory Commission (NRC) inspection conducted July 12 - August 5, 1988, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1988), the violation is listed below:

° 10 CFR 50 Appendix J states that:

II.H.3 Type C testing is required for those valves that, " Are required to operate intermittently under postaccident conditions..."

III.C.1 "Type C tests shall be performed by local pressurization. The pressure shall be applied in the same direction as that when the valve would be required to perform its safety function..."

III.C.2 "Valves, which are sealed with fluid from a seal system shall be pressurized with that fluid to a pressure not less than 1.10 Pa."

Contrary to the above, the containment spray and RHR spray inboard containment isolation valves have not been type C tested for the life of the plant.

This is a Severity Level IV violation (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Tennessee Valley Authority is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Director, Office of Special Projects, and a copy to the NRC Resident Inspector, Sequoyah, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include [for each violation]: (1) admission or denial of the violation, (2) the reason for the violation if admitted, (3) the corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the

date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

FOR THE NUCLEAR REGULATORY COMMISSION



Frank R. McCoy, Assistant Director
for TVA Inspection Programs
TVA Projects Division
Office of Special Projects

Dated at,
this 16th day of September 1988