

MAR 14 1986

Docket No. 50-412

Mr. J. J. Carey, Vice President  
Duquesne Light Company  
Nuclear Group  
Post Office Box 4  
Shippingport, PA 15077

DISTRIBUTION

<u>Docket File</u>	J. Partlow
NRC PDR	P. Tam
Local PDR	I. Lee
PAD#2 Rdg	ACRS (10)
T. Novak	Tech Branch
OELD	Gray File
E. Jordan	
B. Grimes	

Dear Mr. Carey:

Subject: Beaver Valley Unit 2 - Steam Leakage Collection System

By letter dated August 19, 1985, you submitted a letter to withdraw your original commitment to provide a steam leakage collection system around certain steam valves. Your request was based on the fact that expected radiological dose contribution due to steam leakage will be small.

We have approved your request. Details of our review are presented in the enclosed safety evaluation.

Sincerely,

Peter S. Tam, Project Manager  
PWR Project Directorate #2  
Division of PWR Licensing-A  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc: See next page

PM:PAD#2  
PTam:hc  
3/13/86

D:PAD#2  
LRubenstein  
3/14/86

8603200012 860314  
PDR ADOCK 05000412  
A PDR