

MAR 17 1986

Docket Nos.: 50-266  
and 50-301

Mr. C. W. Fay, Vice President  
Nuclear Power Department  
Wisconsin Electric Power Company  
231 W. Michigan Street, Room 308  
Milwaukee, Wisconsin 53201

Dear Mr. Fay:

SUBJECT: FIRE PROTECTION REQUIREMENTS 4160 VOLT SWITCHGEAR ROOM  
POINT BEACH NUCLEAR UNITS 1 AND 2

We have received your February 7, 1986 letter on the above subject. With regard to the dedicated shutdown system for the 4160 volt switchgear room described in your submittal, we have determined that we will need the additional information identified in the enclosure. As discussed with and agreed to by your staff, we request that your response be submitted within 30 days receipt of this letter in order for our review to remain on schedule. An advance copy of the enclosure has been transmitted to your staff via telecopy.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

If you have any questions, please contact me at (301) 492-9787.

Sincerely,

*TS*  
Timothy G. Colburn, Project Manager  
Project Directorate #1  
Division of PWR Licensing-A

Enclosure:  
Request for Additional  
Information

cc: See next page

\*See original concurrence.

Office: LA/PAD#1

PM/PAD#1

PD/PAD#1

PSB-A *JWS*

Surname:\* PShuttleworth

\*TColburn/tg

GLear *for*

D. Milhoan

Date: 03/ /86

03/ /86

03/13/86

03/11/86

8603200015 860317  
PDR ADOCK 05000266  
F PDR

MAR 17 1986

Docket Nos.: 50-266  
and 50-301

Mr. C. W. Fay, Vice President  
Nuclear Power Department  
Wisconsin Electric Power Company  
231 W. Michigan Street, Room 308  
Milwaukee, Wisconsin 53201

Dear Mr. Fay:

SUBJECT: FIRE PROTECTION REQUIREMENTS 4160 VOLT SWITCHGEAR ROOM  
POINT BEACH NUCLEAR UNITS 1 AND 2

We have received your February 7, 1986 letter on the above subject. With regard to the dedicated shutdown system for the 4160 volt switchgear room described in your submittal, we have determined that we will need the additional information identified in the enclosure in order to continue our review. As discussed with and agreed to by your staff, in order for our review to remain on schedule we request that your response be submitted within 30 days receipt of this letter. An advance copy of the enclosure has been transmitted to your staff via telecopy.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

If you have any questions, please contact me at (301) 492-9787.

Sincerely,

Timothy G. Colburn, Project Manager  
Project Directorate #1  
Division of PWR Licensing-A

Enclosure:  
Request for Additional  
Information

cc: See next page

Office:	LA/PAD#1 <i>MLL</i>	PM/PAD#1 <i>TG</i>	PD/PAD#1
Surname:	PShuttleworth	TColburn/tg	GLear
Date:	03/5/86	03/5/86	03/ /86

Mr. C. W. Fay  
Wisconsin Electric Power Company

Point Beach Nuclear Plant  
Units 1 and 2

cc:

Mr. Bruce Churchill, Esq.  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, DC 20036

Mr. James J. Zach, Manager  
Point Beach Nuclear Plant  
Wisconsin Electric Power Company  
6610 Nuclear Road  
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha  
Town Chairman  
Town of Two Creeks  
Route 3  
Two Rivers, Wisconsin 54241

Chairman  
Public Service Commission  
of Wisconsin  
Hills Farms State Office Building  
Madison, Wisconsin 53702

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
Office of Executive Director  
for Operations  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Resident Inspector's Office  
U.S. Nuclear Regulatory Commission  
6612 Nuclear Road  
Two Rivers, Wisconsin 54241

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION

DEDICATED SHUTDOWN SYSTEM FOR THE 4160 VOLT  
SWITCHGEAR ROOM AT THE POINT BEACH NUCLEAR PLANT

1. Describe instrumentation associated with the proposed dedicated shutdown system including its function, physical location and independence from the 4160 volt switchgear room. Include instrumentation necessary for the functioning, monitoring and processing of variables with respect to the new system.
2. Provide details of your associated circuits analysis with respect to the new system.
3. Provide details of the physical location of major components of the new system (both existing equipment and new equipment) including cable routing, location of power supplies, location of major switchgear, electrical isolations, etc.

MAR 17 1986

50-266

DISTRIBUTION:

Docket Files

NRC PDR

Local PDR

G. Lear

T. Colburn

P. Shuttleworth

L. Harmon

E. Jordan

B. Grimes

J. Partlow

T. Barnhart (4)

ACRS (10)

OPA

PAD#1 r/f

PAD#1 s/f