



South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

October 15, 1998
NOC-AE-000297
File No.: G021.02.01,
G03.16
10CFR50
STI: 30713270

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

South Texas Project
Units 1 and 2
Docket Nos. STN 50-498, STN 50-499
Response to Staff Questions on Proposed Amendment to Technical Specifications for
Spent Fuel Storage Pool Rack Criticality Analysis with Soluble Boron Credit

Reference: Letter from T. H. Cloninger, South Texas Project, to the Nuclear Regulatory Commission dated July 7, 1998 (NOC-AE-000178)

In response to NRC staff questions on the referenced letter regarding the proposed Amendment to Technical Specifications for Spent Fuel Storage Pool Rack Criticality Analysis with Soluble Boron Credit, the STP Nuclear Operating Company hereby submits the requested information. The questions and answers are attached.

Should you have any questions in regard to this response, please contact Mr. D. F. Hoppes at (512) 972-8132 or me at (512) 972-7795.

D. A. Leazar
Manager,
Nuclear Fuels and Analysis

KAW

Attachment

9810220098 981015
PDR ADOCK 05000498
P PDR

11
A001

Ellis W. Merschhoff
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Thomas W. Alexion
Project Manager, Mail Code 13H3
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Cornelius F. O'Keefe
Sr. Resident Inspector
c/o U. S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77404-0910

J. R. Newman, Esquire
Morgan, Lewis & Bockius
1800 M. Street, N.W.
Washington, DC 20036-5869

M. T. Hardt/W. C. Gunst
City Public Service
P. O. Box 1771
San Antonio, TX 78296

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Jon C. Wood
Matthews & Branscomb
One Alamo Center
106 S. St. Mary's Street, Suite 700
San Antonio, TX 78205-3692

Institute of Nuclear Power
Operations - Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

D. G. Tees/R. L. Balcom
Houston Lighting & Power Co.
P. O. Box 1700
Houston, TX 77251

Central Power and Light Company
ATTN: G. E. Vaughn/C. A. Johnson
P. O. Box 289, Mail Code: N5012
Wadsworth, TX 77483

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

Question #1) What neutron cross-section libraries were used with KENO and PHOENIX?

Answer #1) A 227 energy group cross-section library is the common starting point for all cross sections used for the benchmarks of KENO calculations. This cross-section library is generated from ENDF/B-V data.

The transport theory computer code PHOENIX-P is a depletable, two-dimensional, multigroup, discrete theory code which utilizes a 42 energy group nuclear data library from ENDF/B-V data.

For more information see Chapter 2 of WCAP-14416-P, the Westinghouse topical for Spent Fuel Rack Criticality Analysis Methodology.

Question #2) Explain the difference between the 1.7 w/o U-235 Categories 5 and 6, and 1.4 w/o categories 8,9,10.

Answer #2) For both Category 5 and Category 6 fuel, with no burnup, 1.7 w/o U235 will satisfy the criticality requirements for the configurations in which they are allowed. When considering burnup credit reactivity equivalencing (higher initial enrichments with associated burnup), differences arise between the Category 5 and Category 6 allowed enrichments for a given burnup. For example, at an initial 4.0 w/o the Category 5 minimum allowable burnup is 27,839 MWD/MTU while the Category 6 minimum allowable burnup is 30,965 MWD/MTU.

The reason for this difference is that the two configurations are neutronicly different, and the burned assembly (with built-in plutonium) has different reactivity effects in the two configurations. The configuration for Category 5 fuel is a three-out-of-four loading of all Category 5 assemblies in a Region 2 (closer packed) cell array. The configuration for Category 6 fuel is a four-out-of-four loading of Category 1, 4, 6, and 10 fuel in a Region 1 cell array.

The same type of configuration differences applies to the three different configurations in which the Category 8, 9 and 10 fuel are allowed.

Question # 3) Where RCCAs are required to be in the loaded fuel assemblies, how is the presence of the RCCA in the initial loading assured?

Answer #3) The South Texas Project is preparing to shuffle the fuel in each Spent Fuel Pool (SFP), including any required RCCA moves, to ensure the storage configurations match the Technical Specification submittal. After approval of the proposed Technical Specification amendment, fuel stored in the SFP will be reconfigured to comply with the approved storage configurations; this is the reason for the 90-day implementation period. This activity will involve categorizing all of the fuel in the SFP, moving fuel into new checkerboard configurations, and moving RCCAs into applicable assemblies.

Question #4) Credit for added absorber (rod, plates, or other configurations) has been allowed by the NRC provided it can be clearly demonstrated that design features prevent such absorbers from being removed, either inadvertently or intentionally, without unusual effort such as the necessity for special equipment maintained under positive administrative controls. Although the postulated misload accident for the RCCA #1 and #2 checkerboard configurations accounts for the replacement of an RCCA-contained fuel assembly by an unrodded assembly, specify the controls that are in place to prevent removal of an RCCA from an assembly.

Answer #4) STP procedures require a move sheet to move fuel or core components stored in the Spent Fuel Pool (SFP). These move sheets are prepared and verified to ensure that required fuel storage configurations are maintained in accordance with Technical Specifications. Correct preparation and execution of these move sheets are the primary methods to control fuel storage configurations. In addition, dual verification methods are used during physical movement of fuel or core components in the SFP. The RCCA top fixtures are readily seen from the fuel handling machine bridge when the RCCAs are contained in fuel assemblies seated in spent fuel pool rack cells. Senior Reactor Operator (Shift/Unit Supervisor) approval is required prior to moving items in the SFP. The procedures used to control preparation of the move sheets will be revised to ensure RCCAs are not moved if they are needed to satisfy a fuel storage configuration.

In order to move RCCAs in the SFP, special equipment, i.e., the RCCA Change Tool, is required to perform the operation. Operation of this tool requires a unique electrical power cord and an instrument air line with regulator. Authorization to use this equipment is controlled by the Core Loading Supervisor during refueling outages, or by the Shift Supervisor at all other times.

The referenced RCCA checkerboard configurations are applicable only to the Region 2 spent fuel storage racks. These racks are typically used for storage of fuel not intended for reuse in the core. During refuelings, the freshly offloaded fuel assemblies are typically stored only in the Region 1 spent fuel storage racks and thus do not require RCCAs for meeting fuel storage configurations. In addition, RCCA movements in the SFP are performed infrequently at STP. This is due to a reactor vessel feature which enables the RCCAs to be left in the upper internals during rapid refueling outages (typically outages other than those requiring a 10-year inservice inspection).