

May 27, 1988

Docket No. 50-354

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric & Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: REQUEST FOR INFORMATION TO SUPPORT THE NRC MARK I
CONTAINMENT ENHANCEMENT PROGRAM

RE: HOPE CREEK

The NRC staff is planning to present to the Commission proposals for Mark I containment improvements. To assist us in presenting realistic, plant specific features in support of our recommendations, we request that you provide the information delineated in the enclosure, as it pertains to the Hope Creek facility. This enclosure was previously transmitted to you on May 18, 1988 via telecopy.

To meet our schedule for preparation of these proposals, we ask that your response be received by June 6, 1988. Should you have any questions regarding this request, please call me.

This letter is covered by Office of Management and Budget, Clearance Number 3150-0011.

Sincerely,

/S/

George W. Rivenbark, Project Manager
Project Directorate I-2
Division of Reactor Projects I/II

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
MO'Brien
PDI-2 Reading
EJordan/JPartlow

PDI-2/PM
GRivenbark:tr
5/27/88

NRC PDR/LPDR
OGC
WButler
GPA/PA

~~PDI-2/LA~~
~~MO'Brien~~
1/1/88

SVarga/BBoger
ACRS (10)
GRivenbark/SBrown

PDI-2/D
WButler
5/27/88

8806030140 880527
PDR ADOCK 05000354
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 27, 1988

Docket No. 50-354

Mr. Steven E. Miltenberger
Vice President and Chief Nuclear
Officer
Public Service Electric & Gas Company
Post Office Box 236
Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: REQUEST FOR INFORMATION TO SUPPORT THE NRC MARK I
CONTAINMENT ENHANCEMENT PROGRAM

RE: HOPE CREEK

The NRC staff is planning to present to the Commission proposals for Mark I containment improvements. To assist us in presenting realistic, plant specific features in support of our recommendations, we request that you provide the information delineated in the enclosure, as it pertains to the Hope Creek facility. This enclosure was previously transmitted to you on May 18, 1988 via telecopy.

To meet our schedule for preparation of these proposals, we ask that your response be received by June 6, 1988. Should you have any questions regarding this request, please call me.

This letter is covered by Office of Management and Budget, Clearance Number 3150-0011.

Sincerely,

A handwritten signature in cursive script that reads "George W. Rivenbark".

George W. Rivenbark, Project Manager
Project Directorate I-2
Division of Reactor Projects I/II

Enclosure:
As stated

cc w/enclosures:
See next page

Mr. Steven E. Miltenberger
Public Service Electric & Gas Co.

Hope Creek Generating Station

cc:

M. J. Wetterhahn, Esquire
Conner & Wetterhahn
Suite 1050
1747 Pennsylvania Avenue
Washington, D.C. 20006

R. Fryling, Jr., Esquire
Law Department - Tower 5E
80 Park Place
Newark, New Jersey 07101

Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 241
Hancocks Bridge, New Jersey 08038

Mr. S. LaBruna
General Manager - Hope Creek Operations
Hope Creek Generating Station
P.O. Box 118
Hancocks Bridge, New Jersey 08038

Mr. B. A. Preston, Manager
Licensing and Regulation
Nuclear Department
P.O. Box 236
Hancocks Bridge, New Jersey 08038

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. David M. Scott, Chief
Bureau of Nuclear Engineering
Division of Environmental Quality
Department of Environmental Protection
State of New Jersey
CN 411
Trenton, New Jersey 08625

Office of Management and Budget
Clearance Number 3150-0011*

DATA BASE FOR MARK I CONTAINMENT
ENHANCEMENTS EVALUATION

A. ALTERNATE WATER INJECTION CAPABILITY

Identify and list all significant water sources which can be injected into the reactor vessel and/or containment under severe accident environments. For each source listed, provide a description of the pathway including the following information:

1. Power source for injection;
2. Rated flow and delivery pressure;
3. Where will the injection water be drawn from?;
4. Valve operator power source (AC/DC/Air/other)
5. If manual valve, describe its accessibility in postulated severe accident environments; and
6. List containment connections provided for water source hook up

B. ALTERNATE POWER SUPPLIES WHICH COULD BE MOBILIZED IN SEVERE ACCIDENT CONDITIONS

Identify and list all alternate power supplies which could be hooked up to the plant systems and can substitute for failed power in severe accident situations. For each identified source, provide the following information:

1. Fuel required to generate the alternate power;
2. Estimate the time it will take to align the alternate power supply with the plant systems; and
3. Estimate the duration of time the alternate power source would be operable in severe accident environment (at the rated power).

C. EMERGENCY VENTING CAPABILITY

Identify and list the vent paths which are suitable for emergency venting under severe accidents to achieve pressure control, hydrogen control and/or otherwise mitigate against the potential for containment failure. For each vent path provide the following information:

1. Size of the vent path (controlling size);
2. List the equipment which is likely to fail or otherwise made unavailable if the vent pipe or duct fails;
3. Vent path critical pressure, and expected flow rate of vented materials;
4. Power supply needed for vent operation (Air/Electrical/manual/other);

*This request is covered by Office of Management and Budget, Clearance Number 3150-0011 which expires December 31, 1989. Comments on burden and duplication may be directed to the Office of Management and Budget, Room 3208, New Executive Office Building, Washington, DC 20503.

5. Maximum operable pressure for containment isolation valves in the vent path;
6. Total length of the vent path;
7. Height of the vent release point for release to the atmosphere; and
8. Expected impacts of vent operation (e.g. contamination of control structure, exposures to the operators).

D. PRIMARY CONTAINMENT SPRAY NOZZLES

In the event of a severe accident, alternate water sources can be routed to the containment spray system to suppress the pressure rise in the containment, and to scrub the fission products released in the case of core damaging accidents. Provide the following information for the containment sprays:

- a. Drywell Sprays
 1. Number of spray nozzles,
 2. Nozzle diameter,
 3. Spray Design (single nozzles or nozzle clusters), and
 4. Spray capacity (flow rate); and
- b. Wetwell Sprays
 1. Number of spray nozzles,
 2. Nozzle diameter,
 3. Spray Design, and
 4. Spray Capacity.

E. SECONDARY CONTAINMENT FIRE SUPPRESSION SYSTEM

Secondary containment fire spray system can provide a useful function of scrubbing the fission products, should the primary containment fail as a result of a core damage accident and release of radioactive materials to the secondary containment. Provide the following information on the fire suppression spray capability:

1. Location of the fire suppression spray;
2. Flow capacity of the fire protection water supply to the fire spray system;
3. Fire suppression power supply type and distance from the fire equipment; and
4. How can the fire suppression system be hooked up to the ECCS?

F. SURVIVABILITY OF AUTOMATIC DEPRESSURIZATION SYSTEM (ADS) FOLLOWING SEVERE ACCIDENTS

The ADS is an important safety system which must function in a severe accident environment and permit easy depressurization of the vessel, such that low pressure water supplies can be injected in the vessel. Provide the following information relative to ADS survivability:

1. ADS valve manufacturer;
2. ADS power source (Air/Electric/other);
3. Maximum containment pressure at which ADS will still be operable;
4. Back up operating sources, such as accumulators/bottles; and
5. Qualification of ADS operating cables for the harsh post-severe-accident environments.