

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel: 815/654-2241



SVP-98-325

October 15, 1998

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-265, DPR-30, Unit Two

Enclosed is Licensee Event Report (LER) 98-006, Revision 30, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(B). The licensee shall report any event or condition that could have prevented the removal of residual heat.

ComEd is committing to the following actions:

1. Prior to performing the next required surveillance (due November 15, 1998), QCIS 0200-06 will be revised to allow setting the Volt-Ohmeter (VOM) for measuring proper resistance (ohms).
2. Tailgate this event with the Maintenance Departments by November 11, 1998, stressing the importance of the Technical Specification (TS) short duration time clock allowance.

Any other actions described in the submittal represent intended or planned actions by ComEd. They are described for the NRC's information and are not regulatory commitments.


9810220138 981015
PDR ADDCK 05000265
S PDR

11
IE22

October 15, 1998

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Assurance Manager at 309-654-2241, ext. 3609.

Sincerely,



Joel P. Dimmette, Jr.
Site Vice President
Quad Cities Nuclear Power Station

JPD/CP/

Enclosure

cc: Regional Administrator - NRC Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
INPO Records Center
Office of Nuclear Facility Safety, IDNS
Bob Ganser, IDNS, Quad Cities
Stanley P. Focht, American Nuclear Insurers