



LOUISIANA
POWER & LIGHT

317 BARONNE STREET • P. O. BOX 60340
NEW ORLEANS, LOUISIANA 70160 • (504) 595-3100

MIDDLE SOUTH
UTILITIES SYSTEM

September 23, 1988

W3P88-1807
A4.05
QA

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
NRC Bulletin No. 88-05

Reference: Letter W3P88-1285 dated September 9, 1988 to NRC, Document
Control Desk from R.F. Burski

In the referenced letter, LP&L submitted a report in response to the information requested in NRC Bulletin 88-05, "Nonconforming Materials Supplied by Piping Supplies, Inc. at Folsom, New Jersey and West Jersey Manufacturing Company at Williamstown, New Jersey". Following the submittal, Louisiana Power and Light Company discovered that the report inadvertently failed to identify certain flanges as being supplied by Piping Supplies, Inc. (PSI). Eight (8) of the 534 carbon steel flanges discussed in the subject report were manufactured by PSI and were satisfactorily tested and evaluated during the Waterford 3 testing program. Therefore, please find attached Revision 1 to the report entitled "Actions Completed by Louisiana Power & Light in Response to NRC Bulletin 88-05."

Should you require additional information, please feel free to contact me or L.W. Laughlin, Site Licensing Support Supervisor, at (504) 464-3499.

Very truly yours,

R.F. Burski, Manager
Nuclear Safety & Regulatory Affairs

RFB:DDG:ssf

Enclosure

cc: R.D. Martin, NPC Region IV
J.A. Calvo, NRC-NRR
D.L. Wigginton, NRC-NRR
NRC Resident Inspectors Office
E.L. Blake
W.M. Stevenson

NS41486NSR

"AN EQUAL OPPORTUNITY EMPLOYER"

8809300136 880923
PDR ADOCK 05000382
PDC