



GPU Nuclear Corporation
One Upper Pond Road
Parsippany, New Jersey 07054
201-316-7000
TELEX 136-482
Writer's Direct Dial Number:

September 20, 1988
C311-88-2127

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Three Mile Island Nuclear Generating Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Response to Generic Letter 88-11

NRC Generic Letter 88-11, "NRC Position on Radiation Embrittlement of Reactor Vessel Materials and Its Impact on Plant Operations", dated July 12, 1988, requires analysis be performed to determine the impact of using Regulatory Guide 1.99, Revision 2 methodology on Technical Specification pressure-temperature limits.

The present TMI-1 Technical Specification for reactor coolant system pressure-temperature limits were calculated using the procedures and methodology defined in Regulatory Guide 1.99, Revision 2. These Technical Specification limits were approved and issued by NRC Amendment No. 134, dated November 18, 1987, and are applicable through ten effective full power years. All related procedural changes have been fully implemented and no further actions are required at this time.

If any further information is required, please contact us.

Sincerely,

H. D. Hukill
Vice President & Director, TMI-1

HDH/DD/fk

cc: J. Stolz, USNRC
R. Hernan, USNRC
W. Russell, USNRC, Region I
R. Conte, USNRC, TMI-1

7239f/0169f

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

8809300 157 060920
PDR ADOCK 05000289
FDC

Acad
1/0