

MAR 11 1986

Docket Nos.: 50-443
and 50-444

Mr. Robert J. Harrison
President & Chief Executive Officer
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Dear Mr. Harrison:

Subject: Request for Additional Information Concerning the Safety Parameter
Display System for Seabrook Station

The staff has reviewed your submittal of January 6, 1986 concerning the Safety Parameter Display System and concluded that insufficient information was provided to complete our evaluation. The information needed by the staff to continue the evaluation is defined in the enclosure. I request that you provide me your response by March 18, 1986. If this is not possible, please notify me.

An on-site pre-implementation audit will be required to complete the evaluation, and I expect that this audit will be accomplished within approximately one month following receipt of the additional information requested above.

Sincerely,

151

Victor Nerses, Project Manager
PWR Project Directorate No. 5
Division of PWR Licensing-A

Enclosure:
As stated

cc: See next page

DISTRIBUTION

Docket File

NRC PDR	Rossi
LPDR	BStevens
JPartlow	EJordan
PWR5 Reading	VNerses
BGrimes	Attorney, ELD
VNoonan	MRushbrook

PWR5
VNerses
3/11/86

~~DIR: PWR5
VNoonan
3/11/86~~

8603200268 860311
PDR ADOCK 05000443
A PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 11 1986

Docket Nos.: 50-443
and 50-444

Mr. Robert J. Harrison
President & Chief Executive Officer
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Dear Mr. Harrison:

Subject: Request for Additional Information Concerning the Safety Parameter Display System for Seabrook Station

The staff has reviewed your submittal of January 6, 1986 concerning the Safety Parameter Display System and concluded that insufficient information was provided to complete our evaluation. The information needed by the staff to continue the evaluation is defined in the enclosure. I request that you provide me your response by March 13, 1986. If this is not possible, please notify me.

An on-site pre-implementation audit will be required to complete the evaluation, and I expect that this audit will be accomplished within approximately one month following receipt of the additional information requested above.

Sincerely,

A handwritten signature in cursive script that reads "Victor Nerses".

Victor Nerses, Project Manager
PWR Project Directorate No. 5
Division of PWR Licensing-A

Enclosure:
As stated

cc: See next page

Mr. Robert J. Harrison
Public Service Company of New Hampshire

Seabrook Nuclear Power Station

cc:

Thomas Dignan, Esq.
John A. Ritscher, Esq.
Ropes and Gray
225 Franklin Street
Boston, Massachusetts 02110

E. Tupper Kinder, Esq.
G. Dana Bisbee, Esq.
Assistant Attorney General
Office of Attorney General
208 State House Annex
Concord New Hampshire

Mr. Bruce Beckley, Project Manager
Public Service Company of New Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Resident Inspector
Seabrook Nuclear Power Station
c/o U.S. Nuclear Regulatory Comm.
Post Office Box 700
Seabrook, New Hampshire 03874

Dr. Murray Tye, President
Sun Valley Association
209 Summer Street
Haverhill, Massachusetts 08139

Mr. John DeVincentis, Director
Engineering and Licensing
Yankee Atomic Electric Company
1671 Worcester Road
Framingham, Massachusetts 01701

Robert A. Backus, Esq.
O'Neil, Backus and Spielman
116 Lowell Street
Manchester, New Hampshire 03105

Mr. A.M. Ebner, Project Manager
United Engineers & Constructors
30 South 17th Street
Post Office Box 8223
Philadelphia, Pennsylvania 19101

Mr. Phillip Ahrens, Esq.
Assistant Attorney General
State House, Station #6
Augusta, Maine 04333

William S. Jordan, III
Diane Curran
Harmon, Weiss & Jordan
20001 S. street, NW
Suite 430
Washington, D.C. 20009

Mr. Warren Hall
Public Service Company of
New Hampshire
Post Office Box 300
Seabrook, New Hampshire 03874

Jo Ann Shotwell, Esq.
Office of the Assistant Attorney
General
Environmental Protection Division
One Ashburton Place
Boston, Massachusetts 02108

Seacoast Anti-Pollution League
Ms. Jane Doughty
5 Market Street
Portsmouth, New Hampshire 03801

Ms. Diana P. Randall
70 Collins Street
Seabrook, New Hampshire 03874

D. Pierre G. Cameron, Jr., Esq.
General Counsel
Public Service Company of New
Hampshire
Post Office Box 330
Manchester, New Hampshire 03105

Richard Hampe, Esq.
New Hampshire Civil Defense Agency
107 Pleasant Street
Concord, New Hampshire 03301

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Public Service Company of
New Hampshire

-2-

Seabrook Nuclear Power Station

cc:

Mr. Calvin A. Canney, City Manager
City Hall
126 Daniel Street
Portsmouth, New Hampshire 03801

Mr. Alfred V. Sargent,
Chairman
Board of Selectmen
Town of Salisbury, MA 01950

Ms. Letty Hett
Town of Brentwood
RFD Dalton Road
Brentwood, New Hampshire

Senator Gordon J. Humphrey
ATTN: Tom Burack
U. S. Senate
Washington, D.C. 20510

Ms. Roberta C. Pevear
Town of Hampton Falls, New Hampshire
Drinkwater Road
Hampton Falls, New Hampshire 03844

Ms. Sandra Gavutis
Town of Kensington, New Hampshire
RDF 1
East Kingston, New Hampshire 03827

Mr. Owen B. Durgin, Chairman
Durham Board of Selectmen
Town of Durham
Durham, New Hampshire 03824

Ms. Anne Verga
Chairman, Board of Selectmen
Town Hall
South Hampton, New Hampshire 03827

Charles Cross, Esq.
Shaines, Mardrigan and
McEaschern
25 Maplewood Avenue
Post Office Box 366
Portsmouth, New Hampshire 03801

Mr. Angie Machiros, Chairman
Board of Selectmen
for the Town of Newbury
Newbury, Massachusetts 01950

Mr. Guy Chichester, Chairman
Rye Nuclear Intervention Committee
c/o Rye Town Hall
10 Central Road
Rye, New Hampshire 03870

Ms. Rosemary Cashman, Chairman
Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, Massachusetts 01913

Jane Spector
Federal Energy Regulatory
Commission
825 North Capitol Street, N.E.
Room 8105
Washington, D.C. 20426

Honorable Richard E. Sullivan
Mayor, City of Newburyport
Office of the Mayor
City Hall
Newburyport, Massachusetts 01950

Mr. R. Sweeney
New Hampshire Yankee Division
Public Service Company of New
Hampshire
7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Donald E. Chick, Town Manager
Town of Exeter
10 Front Street
Exeter, New Hampshire 03823

Mr. William B. Derrickson
Senior Vice President
Public Service Company of
New Hampshire
Post Office Box 700, Route 1
Seabrook, New Hampshire 03874

REQUEST FOR ADDITIONAL INFORMATION
CONCERNING THE
SEABROOK STATION
SAFETY PARAMETER DISPLAY SYSTEM

Each operating reactor shall be provided with a Safety Parameter Display System (SPDS). The Commission approved requirements for an SPDS are defined in NUREG-0737, Supplement 1. In the Regional workshops on Generic Letter 82-33 held during March 1983, the NRC discussed these requirements and the staff's review of the SPDS.

The staff reviewed the SPDS safety analysis provided by Public Service of New Hampshire dated January 6, 1986 (Reference 1). The staff was unable to complete the review because of insufficient information. The following additional information is required to continue the review:

Isolation Devices

Provide the following:

- a. For the type of device used to accomplish electrical isolation, describe the specific testing performed to demonstrate that the device is acceptable for its application(s). This description should include elementary diagrams when necessary to indicate the test configuration and how the maximum credible faults were applied to the devices.
- b. Data to verify that the maximum credible faults applied during the test were the maximum voltage/current to which the device could be exposed, and define how the maximum voltage/current was determined.

- c. Data to verify that the maximum credible fault was applied to the output of the device in the transverse mode (between signal and return) and other faults were considered (i.e., open and short circuits).
- d. Define the pass/fail acceptance criteria for each type of device.
- e. Provide a commitment that the isolation devices comply with the environment qualifications (10CFR 50.49) and with the seismic qualifications which were the basis for plant licensing.
- f. Provide a description of the measures taken to protect the safety systems from electrical interference (i.e., Electrostatic Coupling, EMI, Common Mode and Crosstalk) that may be generated by the SPDS.
- g. Provide information to verify that the Class 1E isolation is powered from a Class 1E source.

Human Factors Engineering

a. Human Factors Program

Provide a description of the display system, its human factored design, and the methods used and results from a human factors program to ensure that the displayed information can be readily perceived and comprehended so as not to mislead the operator.

b. Data Validation

Describe method used to validate data displayed on the SPDS and how "conservative substitute values" are calculated. Also describe how "conservative substitute values" are made known to the operator.

c. Verification and Validation Program

The SPDS report describes the validation program for the Westinghouse Owner's Group (WOG) Emergency Response Guidelines (ERGs). It does not describe the Verification and Validation Program used in the development of the SPDS. This program needs to be described along with a description of results to date and the corrective actions taken to address identified design deficiencies.

d. Unreviewed Safety Questions

Provide conclusions regarding unreviewed safety questions or changes to technical specifications.

e. Implementation Plan

Provide a schedule for full implementation of the SPDS including hardware, software, operator training, procedures and user manuals.

Parameter Selection

As a result of its review, the staff noted that the following variables are not proposed for the Seabrook SPDS:

1. RHR Flow
2. Steam Generator (or steamline) Radiation
3. Stack Monitor
4. Containment Isolation
5. Containment Hydrogen Concentration

During RHR and ECCS modes of cooling when steam generators are not available, RHR flow is a key indicator to monitor the viability of the heat removal system.

Steamline (or steam generator) radiation, in conjunction with containment radiation and reactor stack radiation, gives a rapid assessment of radiation status for the most likely radioactive release paths to accomplish the "Radioactivity Control" safety function. For a rapid assessment of Radioactivity control, the applicant has not demonstrated how radiation in the secondary system (steam generators and steamlines) is monitored by SPDS when the steam generators and/or their steamlines are isolated. The analysis should be expanded to include this discussion.

Containment isolation is an important parameter for use in making a rapid assessment of "Containment Conditions." In particular, a determination that known process pathways through containment have been secured provides significant additional assurance of containment integrity.

Containment hydrogen concentration is a key parameter used in the emergency guidelines to monitor combustible gas control and to indicate a compromise of the "Containment Conditions" safety function.

The above variables do, for given scenarios, provide unique inputs to the determinations of status for their respective Critical Safety Functions (CSFs), which have not been discussed by the applicant as being satisfied by other variables in the proposed Seabrook SPDS list. The applicant should address these variables and their functions by: (1) adding the variables to the Seabrook SPDS, (2) providing alternate added variables along with justifications that these alternates accomplish the same safety functions for all scenarios, or (3) providing justification that variables currently on the Seabrook SPDS do in fact accomplish the same safety functions for all scenarios.

Reference

Letter to V. Noonan from J. DeVincentis, SBN-920, dated January 6, 1986, "NUREG-0737 Task I.D.2, Plant Safety Parameter Display Console."