

May 26, 1988

Docket No. 50-341

Mr. B Ralph Sylvia
Group Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

DISTRIBUTION

Docket File
NRC & Local PDRs
PD31 Plant Gray
EJordan
RIngram

JPartlow
GHolahan
ACRS (10)
TQuay


Dear Mr. Sylvia:

SUBJECT: NRC BULLETIN NO. 87-02, SUPPLEMENT 1: FASTENER TESTING TO DETERMINE CONFORMANCE WITH APPLICABLE MATERIAL SPECIFICATIONS

NRC has been notified by Lynn Goodman of your staff that a copy of the subject NRC Bulletin has not been received by Detroit Edison. Apparently Detroit Edison became aware that other utilities had received the Supplement.

Enclosed is a copy of the Supplement for your action.

Sincerely,



Theodore R. Quay, Project Manager
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects

cc w/enclosure:
See next page

LA/PD31:DRSP	PM/PD31:DRSP	D/PD31:DRSP
RIngram	TQuay: rTRQ	DMuller
5/25/88	5/25/88	5/26/88

OFFICIAL RECORD COPY

8806030339	880526
PDR ADOCK	05000341
Q	PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

May 26, 1988

Docket No. 50-341

Mr. B. Ralph Sylvia
Group Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Sylvia:

SUBJECT: NRC BULLETIN NO. 87-02, SUPPLEMENT 1: FASTENER TESTING TO DETERMINE
CONFORMANCE WITH APPLICABLE MATERIAL SPECIFICATIONS

NRC has been notified by Lynn Goodman of your staff that a copy of the subject
NRC Bulletin has not been received by Detroit Edison. Apparently Detroit
Edison became aware that other utilities had received the Supplement.

Enclosed is a copy of the Supplement for your action.

Sincerely,

Theodore R. Quay

Theodore R. Quay, Project Manager
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects

cc w/enclosure:
See next page

Mr. B. Ralph Sylvia
Detroit Edison Company

Fermi-2 Facility

cc:

Mr. Ronald C. Callen
Adv. Planning Review Section
Michigan Public Service Commission
6545 Mercantile Way
P. O. Box 30221
Lansing, Michigan 48909

Ms. Lynn Goodman
Supervisor - Licensing
Detroit Edison Company
Fermi Unit 2
6400 North Dixie Highway
Newport, Michigan 48166

John Flynn, Esq.
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
P. O. Box 30035
Lansing, Michigan 48909

Mr. Thomas Randazzo
Director, Regulatory Affairs
Detroit Edison Company
Fermi Unit 2
6400 North Dixie Highway
Newport, Michigan 48166

Mr. Walt Rogers
U.S. Nuclear Regulatory Commission
Resident Inspector's Office
6-50 W. Dixie Highway
Newport, Michigan 48166

Monroe County Office of Civil
Preparedness
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REACTOR REGULATION
WASHINGTON, D.C. 20555

April 22, 1988

NRC BULLETIN NO. 87-02, SUPPLEMENT 1: FASTENER TESTING TO DETERMINE
CONFORMANCE WITH APPLICABLE
MATERIAL SPECIFICATIONS

Addressees:

All holders of operating licenses or construction permits for nuclear power reactors.

Purpose:

The purpose of this supplement is to require addressees to submit additional information on the source of fasteners purchased for use in nuclear power plants.

Description of Circumstances:

Item 5 of NRC Compliance Bulletin 87-02 requested that all holders of operating licenses or construction permits for nuclear power reactors submit information regarding the identity of the suppliers and manufacturers of the safety-related and non-safety-related fasteners selected for testing. After further consideration, the NRC has determined that it needs information regarding the identity of all vendors from which safety-related and non-safety-related fasteners have been obtained within the past 10 years, a reasonable period which will not put undue burden on addressees. This information will assist the NRC in determining whether nuclear facility fasteners in use have been supplied in accordance with their intended use. In addition, this information is needed so that the NRC can properly coordinate information with other government agencies concerned with problems identified in the quality of fasteners.

Action Required:

Within 90 days from the receipt of this supplemental bulletin, addressees shall provide the following information concerning the procurement of fasteners within the past 10 years:

1. A list of the suppliers and manufacturers from which safety-related fasteners have been purchased, including addresses, and the type of fasteners purchased (i.e., the material specifications). For those fastener purchases made from fastener suppliers and/or original equipment manufacturers, any available information concerning the manufacturer or sub-tier supplier of the fastener also should be provided.

2. For non-safety-related fasteners the same information as requested in item 1.

The written reports requested above shall be addressed to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20535, under oath or affirmation under the provisions of Section 182a, Atomic Energy Act of 1954, as amended. In addition, a copy shall be submitted to the appropriate Regional Administrator.

This requirement for information was approved by the Office of Management and Budget under a blanket clearance number 3150-0011. Comments on burden and duplication may be directed to the Office of Management and Budget, Reports Management, Room 3208, New Executive Office Building, Washington, D.C. 20503.

If you have any questions about this matter, please contact one of the technical contacts listed below or the Regional Administrator of the appropriate regional office.

Charles E. Rossi
Charles E. Rossi, Director
Division of Operational Events Assessment
Office of Nuclear Reactor Regulation

Technical Contacts: J. T. Conway, MPR
(301) 492-0978

E. T. Baker, NRR
(301) 492-3221

Attachment: List of Recently Issued NRC Bulletins

Attachment
NRCB 87-02, Supplement 1
April 22, 1988

LIST OF RECENTLY ISSUED
NRC BULLETINS

Bulletin No.	Subject	Date of Issuance	Issued to
88-03	Inadequate Latch Engagement in HFA Type Latching Relays Manufactured by General Electric (GE) Company	3/10/88	All holders of OLs or CPs for nuclear power reactors.
88-02	Rapidly Propagating Fatigue Cracks in Steam Generator Tubes	2/5/88	All holders of OLs or CPs for W-designed nuclear power reactors with steam generators having carbon steel support plates.
88-01	Defects in Westinghouse Circuit Breakers	2/5/88	All holders of OLs or CPs for nuclear power reactors.
87-02	Fastener Testing to Determine Conformance with Applicable Material Specifications	11/6/87	All holders of OLs or CPs for nuclear power reactors.
87-01	Thinning of Pipe Walls in Nuclear Power Plants	7/9/87	All licensees for nuclear power plants holding an OL or CP.
86-04	Defective Teletherapy Timer That May Not Terminate Dose	10/29/86	All NRC licensees authorized to use cobalt-60 teletherapy units.
86-03	Potential Failure of Multiple ECCS Pumps Due to Single Failure of Air-Operated Valve in Minimum Flow Recirculation Line	10/8/86	All facilities holding an OL or CP.
86-02	Static "O" Ring Differential Pressure Switches	7/18/86	All power reactor facilities holding an OL or CP.
86-01	Minimum Flow Logic Problems That Could Disable RHR Pumps	5/23/86	All GE BWR facilities holding an OL or CP.

OL = Operating License
CP = Construction Permit