

USARC, GERMANTOWN, MARYLAND  
J. C. DELANEY  
CHIEF, NUCLEAR MATERIALS BRANCH  
DIVISION OF LICENSING AND REGULATION

SUSQUEHANNA-WESTERN, INC.  
TWX 144  
FALLS CITY, TEXAS  
ATTENTION: MR. G. H. BRYANT

COLLECT

APRIL 6, 1961

THIS CONFIRMS OUR TELEPHONE CONVERSATION OF APRIL 6, 1961, DURING WHICH YOU WERE ADVISED THAT FURTHER CONSIDERATION WILL NOT BE GIVEN TO YOUR REQUEST FOR LICENSE UNTIL YOU HAVE ADVISED US THAT ALL VENTILATION EQUIPMENT DESCRIBED IN THE APPLICATION HAS BEEN INSTALLED AND IS OPERABLE AND UNTIL THE INSTALLATION HAS BEEN EXAMINED BY AEC PERSONNEL. THIS VENTILATION EQUIPMENT INCLUDES THE AAF TYPE N ROTO CLOWE AND THE HOODING, DUCTWORK AND FANS FOR THE SCALE BUILDING AS DESCRIBED TO MR. CUNNINGHAM ON APRIL 3, 1961. REFERENCE YOUR ENGINEERING DRAWINGS 19-M 24, AND 19-M25, SCALE BUILDING FOR HOODING.  
REFERENCE L&R:JCD DOCKET 40-5939

Delaney/jc  
3:00 p.m.  
4593  
C-151

9810220346 610406  
PDR ADOCK 04005939  
C PDR