

SEP 27 1988

Docket/License: 50-336/DPR-65

Northeast Nuclear Energy Company
ATTN: Mr. Edward J. Mroczka
Senior Vice President - Nuclear
Engineering and Operations Group
P.O. Box 270
Hartford, Connecticut 06101-0270

Gentlemen:

Subject: Millstone 2 Routine Inspection 50-336/88-19 (7/30/88 - 9/12/88)


This forwards our report of the routine resident inspection from July 30 through September 12, 1988 at Millstone 2. The results of the inspection were discussed with Mr. Scace of your staff at the conclusion of the inspection.

In May 1988, your Quality Services Department audited Consolidated Controls Corporation and found the seismic qualification of Engineered Safeguards Actuation Systems power supplies to be in question. The Engineering/Operations groups initiated further evaluation about three months later, and that delay indicates that associated interfaces could be improved.

No violations were identified during this inspection and no reply to this letter is required.

Thank you for your cooperation.

Sincerely, ORIGINAL SIGNED BY


Lee H. Bettenhausen, Chief
Projects Branch No. 1
Division of Reactor Projects

Enclosure: NRC Region I Inspection Report 50-336/88-19

cc w/encl:

W. D. Romberg, Vice President, Nuclear Operations
R. M. Kacich, Manager, Generation Facilities Licensing
D. O. Nordquist, Director of Quality Services
S. E. Scace, Station Superintendent
Gerald Garfield, Esquire
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Senior Resident Inspector
State of Connecticut

OFFICIAL RECORD COPY

DL50-336/88-19 - 0001.0.0
09/20/88

8810030082 880927
PDR ADOCK 05000336
FDC

1001

bcc w/encl:
 Region I Docket Room (with concurrences)
 Management Assistant, DRMA (w/o enclosures)
 DRP Section Chief
 J. Shediowsky, SRI, Haddam Neck
 W. Raymond, SRI, Millstone 1,2 & 3
 D. Jaffe, LPM, NRR
 R. Bores, DRSS
 R Keimig, DRSS
 C. Anderson, DRS (see Detail 5.2)

RI:DRP
EV
 Habighorst/meo
 9/20/88
10

RI:DRP
MC
 McCabe
9/20

RI:DRP
MC
 Bettenhausen
9/27

OFFICIAL RECORD COPY

DL50-336/88-19 - 0002.0.0
 09/20/88