

SEP 19 1988

MEMORANDUM FOR: Christopher I. Grimes
Comanche Peak Project
Division Director


FROM: Thomas T. Martin, Director
Division of Reactor Safety
Region I

SUBJECT: NDE INSPECTION REPORT

Transmitted herewith is the inspection report resulting from our inspection activities at the Comanche Peak Unit 1 facility. This inspection focused on selected safety related piping weldments in the Safety Injection, Core Spray and Service Water Systems. The results of our inspection identified deficiencies in the licensee reviews of their contractor programs and licensee quality assurance overviews.


We hope that this independent measurement inspection activity and documentation satisfies your needs and we offer our services to you in the future. We solicit your comments in the mobile NDE program to better serve NRC needs.

ORIGINAL SIGNED BY
WILLIAM V. JOHNSTON

 Thomas T. Martin, Director
Division of Reactor Safety

cc w/attachment:
C. Y. Cheng, NRR
H. H. Livermore (Comanche Peak)
S. Phillips, (Comanche Peak)
H. Kerch, RI
J. Strosnider, RI

 RI:DRS
Kerch/rw
9/9/88

 RI:DRS
Strosnider
9/9/88

 RI:DRS
Durr
9/14/88

OFFICIAL RECORD COPY

MEMO IR TU 88-48/43 - 0001.0.0
09/07/88

8810030107 880919
PDR ADOCK 05000446
Q PDC

IE:01