

U.S. NUCLEAR REGULATORY COMMISSION

REGION III

Report No. 50-305/88017(DRSS)

Docket No. 50-305

License No. DPR-43

Licensee: Wisconsin Public Service Corporation
Post Office Box 1200
Green Bay, WI 54305

Facility Name: Kewaunee Nuclear Power Plant

Inspection At: Kewaunee Site, Kewaunee, Wisconsin

Inspection Conducted: July 25-28, 1988

Date of Last Physical Security Inspection: April 4-7, and 15, 1988

Type of Inspection: Routine Physical Security Inspection

Inspector: J. Belanger for
T. J. Madeda
Physical Security Inspector

9-21-88
Date

Approved By: James R. Creed
James R. Creed, Chief
Safeguards Section

9/21/88
Date

Inspection Summary

Inspection on July 25-28, 1988 (Report No. 50-305/88017(DRSS))

Areas Inspected: Management Effectiveness; Security Organization; Security Program Audit; Records and Reports; Testing and Maintenance; Locks; Keys, and Combinations; Physical Barriers - Protected and Vital Areas; Lighting; Compensatory Measures; Assessment Aids; Access Control - Personnel, Packages and Vehicles; Detection Aids - Protected and Vital Areas; Alarm Stations; Communications; Personnel Training and Qualifications; Safeguards Information and Contingency Plan Implementation Review. In addition, a followup on Regulatory Effectiveness Review Findings was conducted.

Results: The licensee was found to be in compliance with NRC requirements, excepted as noted below:

BB10030155 880927
PDR ADOCK 05000305
Q PNU

Enclosure Contains
SAFEGUARDS INFORMATION
Upon Separation This
Page is Decontrolled

Assessment Aids: Lack of effectiveness as it related to the licensee's
CCTV.

Additionally, one open item was noted regarding a weakness in the licensee's
program to categorize Safeguards Information. Implementation of the licensee's
security program was determined to be adequate.
(DETAILS - UNCLASSIFIED SAFEGUARDS INFORMATION)