

NUREG-0020  
Vol. 12, No. 8  
August 1988

---

---

# LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT

DATA AS OF 07-31-88

---

---

UNITED STATES NUCLEAR REGULATORY COMMISSION



BB10030170 880930  
PDR NUREG  
0020 PDR

Available from

NRC/GPO Sales Program

Superintendent of Documents  
Government Printing Office  
Washington, D. C. 20402

A year's subscription consists of 12 issues for  
this publication.

Single copies of this publication  
are available from National Technical  
Information Service, Springfield, VA 22161

Microfiche of single copies are  
available from NRC/GPO Sales Program  
Washington, D. C. 20555

NUREG-0020  
Vol. 12, No. 8  
August 1988

---

---

# LICENSED OPERATING REACTORS

## STATUS SUMMARY REPORT

DATA AS OF 07-31-88

---

---

Manuscript Completed: September 1988  
Date Published: September 1988

OFFICE OF ADMINISTRATION AND RESOURCES MANAGEMENT  
U.S. NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555



#### STATEMENT OF PURPOSE

The U.S. Nuclear Regulatory Commission's monthly LICENSED OPERATING REACTORS Status Summary Report provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Information Resources Management, from the Headquarters Staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. Since all of the data concerning operation of the units is provided by the utility operators less than two weeks after the end of the month, necessary corrections to published information are shown on the ERRATA page.

This report is divided into three sections: the first contains monthly highlights and statistics for commercial operating units, and errata from previously reported data; the second is a compilation of detailed information on each unit, provided by NRC Regional Offices, IE Headquarters and the Utilities; and the third section is an appendix for miscellaneous information such as spent fuel storage capability, reactor years of experience and non-power reactors in the United States.

The percentage computations, Items 20 through 24 in Section 2, the vendor capacity factors on page 1-7, and actual vs. potential energy production on Page 1-2 are computed using actual data for the period of consideration. The percentages listed in power generation on Page 1-2 are computed as an arithmetic average. The factors for the life-span of each unit (the "Cumulative" column) are reported by the utility and are not entirely re-computed by NRC. Utility power production data is checked for consistency with previously submitted statistics.

It is hoped this status report proves informative and helpful to all agencies and individuals interested in analyzing trends in the nuclear industry which might have safety implications, or in maintaining an awareness of the U.S. energy situation as a whole.

## T A B L E O F C O N T E N T S

	PAGE
GLOSSARY	ii
INDEX TO LICENSED UNITS	vii
<u>SECTION 1 - CURRENT DATA SUMMARIES</u>	
MONTHLY HIGHLIGHTS OF COMMERCIAL NUCLEAR POWER UNITS	1-2
Licensed Power Reactors	1-2
Power Generation	1-2
Actual vs. Potential Energy Production	1-2
Outage Data	1-2
Reasons for Shutdown	1-3
Derated Units	1-3
Shutdowns Greater Than 72 Hours Each	1-3
UNIT AVAILABILITY, CAPACITY, AND FORCED OUTAGE RATE PLOT	1-4
AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIAL OPERATING UNITS	1-5
AVERAGE CAPACITY FACTORS BY VENDOR	
Vendor Plot	1-6
Statistics	1-7
MEMORANDA - SPECIAL INFORMATION	1-8
ERRATA - CORRECTIONS TO PREVIOUSLY REPORTED DATA	1-9
<u>SECTION 2 - OPERATING POWER REACTORS</u>	
ARKANSAS 1 THROUGH ZION 2	2-002 through 2-483
For each reactor:	
Operating Status	
Average Daily Power Level (MWe) Plot	
Unit Shutdowns/Reductions Summary	
Facility Data	
Inspection Status	
Licensee Reports	
<u>SECTION 3 - APPENDIX</u>	
STATUS OF SPENT FUEL STORAGE CAPABILITY	3-2
REACTOR-YEARS OF OPERATION	3-6
NON-POWER REACTORS IN THE U.S.	3-7

## G L O S S A R Y

AVERAGE DAILY POWER LEVEL (MWe)	The net electrical energy generated during the day (measured from 0001 to 2400 hours inclusive) in megawatts hours, divided by 24 hours.
LICENSED THERMAL POWER (Mwt)	The maximum thermal power of the reactor authorized by the NRC, expressed in megawatts.
DATE OF COMMERCIAL OPERATION	Date unit was declared by utility owner to be available for the regular production of electricity; usually related to satisfactory completion of qualification tests as specified in the purchase contract and to accounting policies and practices of utility.
DESIGN ELECTRICAL RATING (DER) (NET MWe)	The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.
FORCED OUTAGE	An outage required to be initiated no later than the weekend following discovery of an offnormal condition.
FORCED OUTAGE HOURS	The clock hours during the report period that a unit is unavailable due to forced outages.
GROSS ELECTRICAL ENERGY GENERATED (MWH)	Electrical output of the unit during the report period as measured at the output terminals of the turbine generator, in megawatts hours.
GROSS HOURS	The clock hours from the beginning of a specified situation until its end. For outage durations, the clock hours during which the unit is not in power production.
GROSS THERMAL ENERGY GENERATED (MWH)	The thermal energy produced by the unit during the report period as measured or computed by the licensee in megawatt hours.
HOURS GENERATOR ON-LINE	Also, "Unit Service Hours." The total clock hours in the report period during which the unit operated with breakers closed to the station bus. These hours added to the total outage hours experienced by the unit during the report period, shall equal the hours in the report period.
HOURS IN REPORTING PERIOD	For units in power ascension at the end of the period, the gross hours from the beginning of the period or the first electrical production, whichever comes last, to the end of the period.  For units in commercial operation at the end of the period, the gross hours from the beginning of the period or of commercial operation, whichever comes last, to the end of the period or decommissioning, whichever comes first.

## G L O S S A R Y (continued)

HOURS REACTOR CRITICAL	The total clock hours in the report period during which the reactor sustained a controlled chain reaction.
MAXIMUM DEPENDABLE CAPACITY (GROSS) (MDC Gross) (Gross MWe)	Dependable main-unit gross capacity, winter or summer, whichever is smaller. The dependable capacity varies because the unit efficiency varies during the year due to cooling water temperature variations. It is the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions (usually summer).
MAXIMUM DEPENDABLE CAPACITY (NET) (MDC Net) (Net MWe)	Maximum Dependable Capacity (Gross) less the normal station service loads.
NAMEPLATE RATING (Gross MWe)	The nameplate power designation of the generator in megavolt amperes (MVA) times the nameplate power factor of the generator. NOTE: The nameplate rating of the generator may not be indicative of the maximum or dependable capacity, since some other item of equipment of a lesser rating (e.g., turbine) may limit unit output.
NET ELECTRICAL ENERGY GENERATED	Gross electrical output of the unit measured at the output terminals of the turbine generator during the reporting period, minus the normal station service electrical energy utilization. If this quantity is less than zero, a negative number should be recorded.
OUTAGE	A situation in which no electrical production takes place.
OUTAGE DATE	As reported on Appendix D of Reg. Guide 1.16, the date of the start of the outage. If continued from a previous month, report the same outage date but change "Method of Shutting Down Reactor" to "4 (continuations)" and add a note: "Continued from previous month."
OUTAGE DURATION	The Total clock hours of the outage measured from the beginning of the report period or the outage, whichever comes last, to the end of the report period or the outage, whichever comes first.
OUTAGE NUMBER	A number unique to the outage assigned by the licensee. The same number is reported each month in which the outage is in progress. One format is "76-05" for the fifth outage to occur in 1976.
PERIOD HOURS	See "Hours in Reporting Period."
POWER REDUCTION	A reduction in the Average Daily Power Level of more than 20% from the previous day. All power reductions are defined as outage of zero hours durations for the purpose of computing unit service and availability factors, and forced outage rate.

G L O S S A R Y (continued)

REACTOR AVAILABLE HOURS	The Total clock hours in the report period during which the reactor was critical or was capable of being made critical. (Reactor Reserve Shutdown Hours + Hours Reactor Critical.)
REACTOR AVAILABILITY FACTOR	$\frac{\text{Reactor Available Hours} \times 100}{\text{Period Hours}}$
REACTOR RESERVE SHUTDOWN	The cessation of criticality in the reactor for administrative or other similar reasons when operation could have been continued.
REACTOR RESERVE SHUTDOWN HOURS	The total clock hours in the report period that the reactor is in reserve shutdown mode. NOTE: No credit is given for NRC imposed shutdowns.
REACTOR SERVICE FACTOR	$\frac{\text{Hours Reactor Critical} \times 100}{\text{Period Hours}}$
REPORT PERIOD	Usually, the preceding calendar month. Can also be the preceding calendar year, (Year-to-Date), or the life-span of a unit (cumulative).
RESTRICTED POWER LEVEL	Maximum net electrical generation to which the unit is restricted during the report period due to the state of equipment, external conditions, administrative reasons, or a direction by NRC.
SCHEDULED OUTAGE	Planned removal of a unit from service for refueling, inspection, training, or maintenance. Those outages which do not fit the definition of "Forced Outage" perforce are "Scheduled Outages."
STARTUP AND POWER ASCENSION TEST PHASE	Period following initial criticality during which the unit is tested at successively higher levels, culminating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the utility generally considers the unit to be available for commercial operation.
UNIT	The set of equipment uniquely associated with the reactor, including turbine generators, and ancillary equipment, considered as a single electrical energy production facility.
UNIT AVAILABLE HOURS	The total clock hours in the report period during which the unit operated on-line or was capable of such operation. (Unit Reserve Shutdown Hours + Hours Generator On-Line.)



G L O S S A R Y (continued)

UNIT AVAILABILITY FACTOR	$\frac{\text{Unit Available Hours} \times 100}{\text{Period Hours}}$
UNIT CAPACITY FACTORS	
- Using Licensed Thermal Power	$\frac{\text{Gross Thermal Energy Generated} \times 100}{\text{Period Hours} \times \text{Lic. Thermal Power}}$
- Using Nameplate Rating	$\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{Nameplate Rating}}$
- Using DER	$\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{DER}}$
- Using MDC Gross	$\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Gross}}$
- Using MDC Net	$\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Net}}$

NOTE: if MDC GROSS and/or MDC NET have not been determined, the DER is substituted for this quantity for Unit Capacity Factor calculations.

UNIT FORCED OUTAGE RATE	$\frac{\text{Forced Outage Hours} \times 100}{\text{Unit Service Hours} + \text{Forced Outage Hours}}$
-------------------------	--

UNIT RESERVE SHUTDOWN      The removal of the unit from on-line operation for economic or other similar reasons when operation could have been continued.

UNIT RESERVE SHUTDOWN HOURS      The total clock hours in the report period during which the unit was in reserve shutdown mode.

UNIT SERVICE FACTOR	$\frac{\text{Unit Service Hours} \times 100}{\text{Period Hours}}$
---------------------	--

UNIT SERVICE HOURS      See "Hours Generator On-Line."

NOTE:

At the end of each statement in the Enforcement Summary for any given facility may be found numbers in parentheses. These numbers are related to the inspection, e.g., 8111 (the 11th inspection of the plant in 1981); and the severity level, e.g., 4 (severity level IV). Violations are ranked by severity levels from I through V with level I being the most serious. The severity level is used in the determination of any resulting enforcement action. Gray Book lists severity level by Arabic numbers corresponding to the Roman numerals. Details on the various severity levels and enforcement actions can be found in Appendix C to 10 CFR Part 2 published in the Federal Register of March 9, 1982 pages 9987 through 9995, and as corrected April 14, 1982.

INDEX TO OPERATING POWER REACTORS

	PAGE		PAGE
ARKANSAS 1	2-002	MILLSTONE 3	2-246
ARKANSAS 2	2-006	MONTICELLO	2-250
BEAVER VALLEY 1	2-010	NINE MILE POINT 1	2-256
BEAVER VALLEY 2	2-014	NINE MILE POINT 2	2-260
BIG ROCK POINT 1	2-018	NORTH ANNA 1	2-264
BRAIDWOOD 1	2-022	NORTH ANNA 2	2-268
BRAIDWOOD 2	2-026	OCONEE 1	2-272
BROWNS FERRY 1	2-030	OCONEE 2	2-276
BROWNS FERRY 2	2-036	OCONEE 3	2-280
BROWNS FERRY 3	2-042	OYSTER CREEK 1	2-284
BRUNSWICK 1	2-048	PALISADES	2-288
BRUNSWICK 2	2-054	PALO VERDE 1	2-292
BYRON 1	2-058	PALO VERDE 2	2-298
BYRON 2	2-062	PALO VERDE 3	2-302
CALLAWAY 1	2-066	PEACH BOTTOM 2	2-306
CALVERT CLIFFS 1	2-070	PEACH BOTTOM 3	2-310
CALVERT CLIFFS 2	2-074	PERRY 1	2-314
CATAWBA 1	2-078	PILGRIM 1	2-318
CATAWBA 2	2-082	POINT BEACH 1	2-322
CLINTON 1	2-086	POINT BEACH 2	2-328
COOK 1	2-090	PRAIRIE ISLAND 1	2-334
COOK 2	2-096	PRAIRIE ISLAND 2	2-340
COOPER STATION	2-100	QUAD CITIES 1	2-344
CRYSTAL RIVER 3	2-104	QUAD CITIES 2	2-350
DAVIS-BESSE 1	2-108	RANCHO SECO 1	2-354
DIABLO CANYON 1	2-112	RIVER BEND 1	2-360
DIABLO CANYON 2	2-118	ROBINSON 2	2-364
DRESDEN 2	2-122	SALEM 1	2-370
DRESDEN 3	2-128	SALEM 2	2-374
DUANE ARNOLD	2-134	SAN ONOFRE 1	2-378
FARLEY 1	2-140	SAN ONOFRE 2	2-382
FARLEY 2	2-146	SAN ONOFRE 3	2-386
FERMI 2	2-152	SEQUOYAH 1	2-390
FITZPATRICK	2-156	SEQUOYAH 2	2-394
FORT CALHOUN 1	2-160	SOUTH TEXAS 1	2-398
FORT ST VRAIN	2-166	ST LUCIE 1	2-402
GINNA	2-170	ST LUCIE 2	2-406
GRAND GULF 1	2-174	SUMMER 1	2-410
HADDAM NECK	2-178	SURRY 1	2-414
HARRIS 1	2-182	SURRY 2	2-418
HATCH 1	2-186	SUSQUEHANNA 1	2-422
HATCH 2	2-190	SUSQUEHANNA 2	2-426
HOPE CREEK 1	2-194	THREE MILE ISLAND 1	2-430
INDIAN POINT 2	2-198	TROJAN	2-434
INDIAN POINT 3	2-202	TURKEY POINT 3	2-440
KEWAUNEE	2-206	TURKEY POINT 4	2-446
LASALLE 1	2-210	VERMONT YANKEE 1	2-450
LASALLE 2	2-214	VOGTLE 1	2-454
LIMERICK 1	2-218	WASHINGTON NUCLEAR 2	2-458
MAINE YANKEE	2-222	WATERFORD 3	2-464
MCGUIRE 1	2-226	WOLF CREEK 1	2-468
MCGUIRE 2	2-232	YANKEE-ROWE 1	2-472
MILLSTONE 1	2-238	ZION 1	2-476
MILLSTONE 2	2-242	ZION 2	2-480

**SECTION 1**

**CURRENT  
DATA  
SUMMARIES**

MONTHLY HIGHLIGHTS

\*\*\*\*\* 106 IN COMMERCIAL OPERATION . . . . . 92,499 CAPACITY MWe (Net) --Based upon maximum dependable  
 \* LICENSED \* (a) 2 IN POWER ASCENSION. . . . . 2,370 capacity; design elec. rating  
 \* POWER \* used if MDC not determined  
 \* REACTORS \* (b) 108 LICENSED TO OPERATE . . . . . 94,869 TOTAL  
 \*\*\*\*\* (c) 1 LICENSED FOR FUEL LOADING  
 AND LOW POWER TESTING

	MDC NET		DER	DATE	DER
(a) BRAIDWOOD 2	1120	(b) Excludes these plants	1. DRESDEN 1.....200	07/03/85	820
SOUTH TEXAS 1	1250	licensed for operation	2. HUMBOLDT BAY.....65		
		which are shut down	3. TMI 2.....906		
		indefinitely or	4. LACROSSE.....50		
		permanently			

		REPORT MONTH	PREVIOUS MONTH	YEAR-TO-DATE
*****	1. GROSS ELECTRICAL (MWHE)	50,900,833	45,489,135	317,889,679
* POWER *	2. NET ELECTRICAL (MWHE)	48,358,042	43,196,547	302,066,026
* GENERATION *	3. AVG. UNIT SERVICE FACTOR (%)	78.1	72.1	70.3
*****	4. AVG. UNIT AVAILABILITY FACTOR (%)	78.1	72.1	70.3
	5. AVG. UNIT CAPACITY FACTOR (MDC) (%)	71.9	67.3	66.1
	6. AVG. UNIT CAPACITY FACTOR (DER) (%)	70.2	65.6	64.5
	7. FORCED OUTAGE RATE (%)	9.0	8.6	10.6

			% OF POTENTIAL PRODUCTION
*****	1. ENERGY ACTUALLY PRODUCED DURING THIS REPORT PERIOD.	48,358,042 NET	71.1
* ACTUAL VS. *	2. ENERGY NOT PRODUCED DUE TO SCHEDULED OUTAGES (NET).	8,669,560 MWe	12.7
* POTENTIAL *	3. ENERGY NOT PRODUCED DUE TO FORCED OUTAGES (NET)	6,803,054 MWe	10.0
* ENERGY *	4. ENERGY NOT PRODUCED FOR OTHER REASONS (NET)	4,218,376 MWe	6.2
* PRODUCTION *	POTENTIAL ENERGY PRODUCTION IN THIS PERIOD BY UNITS IN COMMERCIAL OPERATION	68,049,032 MWe	100.0% TOTAL
*****	(Using Maximum Dependable Capacity Net)		
	5. ENERGY NOT PRODUCED DUE TO NRC-REQUIRED OUTAGES	MWe	
	6. ENERGY NOT PRODUCED DUE TO NRC RESTRICTED POWER LEVELS.	MWe	3 UNIT(S) WITH NRC RESTRICTION

		NUMBER	HOURS	PERCENT OF CLOCK TIME	MWHE LOST PRODUCTION
*****	1. FORCED OUTAGES DURING REPORT PERIOD	43	6,996.0	8.9	6,803,054
* OUTAGE *	2. SCHEDULED OUTAGES DURING REPORT PERIOD.	27	10,307.6	13.2	8,669,560
* DATA *					
*****	TOTAL	70	17,303.6	22.1	15,472,614

MWHE LOST PRODUCTION = Down time X maximum dependable capacity net

MONTHLY HIGHLIGHTS


		NUMBER	HOURS LOST
*****	A - Equipment Failure . . . . .	30	3,757.1
* REASONS *	B - Maintenance or Test . . . . .	10	602.8
* FOR *	C - Refueling . . . . .	16	8,367.1
* SHUTDOWNS *	D - Regulatory Restriction . . . . .	0	0.0
*****	E - Operator Training & License Examination . . . . .	0	6.0
	F - Administrative . . . . .	4	2,976.0
	G - Operational Error . . . . .	1	19.0
	H - Other . . . . .	9	1,581.6
	TOTAL	70	17,303.6

	MDC (MWe Net)	POWER LIMIT (MWe Net)	TYPE
* DERATED *	BYRON 1 1105	1097	Self-imposed
* UNITS *	BYRON 2 1105	1055	Self-imposed
*****	COOK 1 1020	920	Self-imposed
	FORT ST VRAIN 330	271	NRC Restriction
	LIMERICK 1 1055	915	Self-imposed
	PEACH BOTTOM 2 1051	0	NRC Restriction
	PEACH BOTTOM 3 1035	0	NRC Restriction
	SAN ONOFRE 1 436	390	Self-imposed

	UNIT	REASON	UNIT	REASON	UNIT	REASON	UNIT	REASON
* SHUTDOWNS *	ARKANSAS 2	A	BIG ROCK POINT 1	A	BROWNS FERRY 1	F	BROWNS FERRY 2	F
* GREATER *	BROWNS FERRY 3	F	BRUNSWICK 1	A	BRUNSWICK 2	B	CATAWBA 2	A
* THAN 72 HRS *	COOK 2	C	DAVIS-BESSE 1	C	DIABLO CANYON 1	C	DIABLO CANYON 2	A
* EACH *	FERMI 2	A	FORT ST VRAIN	H	INDIAN POINT 2	A	LASALLE 1	B,C
*****	MCGUIRE 2	C	NINE MILE POINT 1	C	OCONEE 2	A	OYSTER CREEK 1	A
	PALO VERDE 1	A	PEACH BOTTOM 2	C	PEACH BOTTOM 3	C	PILGRIM 1	C
	QUAD CITIES 2	A	SAN ONOFRE 1	H	SAN ONOFRE 3	C	SEQUOYAH 1	F
	ST LUCIE 1	C	SURRY 1	C	SUSQUEHANNA 2	A	THREE MILE ISLAND 1	C
	TROJAN	C	VERMONT YANKEE 1	B	ZION 1	H		

# Unit Availability, Capacity, Forced Outage

Avg. Unit Percentage as of July 1988



## AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIALY OPERATING UNITS

This chart depicts the average daily power level for the units in commercial operation during the month.

The straight line on the graph labelled "SUM OF MDC" is plotted at the value shown by summing the separate maximum dependable capacities of the commercially operating units (in Net MWe). The plot shown below the line is calculated by summing the separate average daily power levels of the same units for each day of the month.


The scale on the left vertical axis runs in 1,000 MWe increments from 0 to 55,000 MWe (Net). The right vertical axis shows the percentage in 10% increments, up to 100% of the "SUM OF MDC".

It should be recognized that the 100% line would be obtainable only if all of the commercially operating units operated at 100% capacity, 24 hours per day, for the entire month. In other words, since any power generator must occasionally shut down to refuel and/or perform needed maintenance, and also since 100% capacity production is not always required by power demands, the 100% line is a theoretical goal and not a practical one.

THE AVERAGE POWER LEVEL CHART  
IS NOT AVAILABLE THIS REPORT  
PERIOD DUE TO SOFTWARE PROBLEMS

# Vendor Average Capacity Factors

07/31/88



## Legend

- x General Electric
- o Westinghouse
- Combustion Engineering
- △ Babcock & Wilcox

July 1988

NOTE: This display of average capacity factors provides a general performance comparison of plants supplied by the four nuclear steam supply system vendors. One must be careful when drawing conclusions regarding the reasons for the performance levels indicated, since plant performance may be affected by unspecified factors such as: (1) various plant designs and models are included for each vendor; (2) turbine/generators and (3) different architect/engineers are also involved.



AVERAGE CAPACITY FACTORS BY VENDORS

***** * GENERAL * * ELECTRIC * *****	CFMDC 0.0 BROWNS FERRY 1 65.0 BRUNSWICK 2 76.3 DRESDEN 3 100.7 GRAND GULF 1 28.8 LASALLE 1 90.9 MONTICELLO 0.0 PEACH BOTTOM 2 74.6 QUAD CITIES 1 81.4 SUSQUEHANNA 2	CFMDC 0.0 BROWNS FERRY 2 84.1 CLINTON 1 85.1 DUANE ARNOLD 95.8 HATCH 1 75.6 LASALLE 2 0.0 NINE MILE POINT 1 0.0 PEACH BOTTOM 3 49.7 QUAD CITIES 2 64.2 VERMONT YANKEE 1	CFMDC 0.0 BROWNS FERRY 3 87.8 COOPER STATION 64.9 FERMI 2 96.9 HATCH 2 81.4 LIMERICK 1 77.7 NINE MILE POINT 2 90.9 PERRY 1 98.3 RIVER BEND 1 93.9 WASHINGTON NUCLEAR 2	CFMDC 60.5 BRUNSWICK 1 71.1 DRESDEN 2 95.4 FITZPATRICK 95.6 HOPE CREEK 1 98.9 MILLSTONE 1 25.8 OYSTER CREEK 1 0.0 PILGRIM 1 98.4 SUSQUEHANNA 1
---	--	--	---	--

***** * BABCOCK & * * WILCOX * *****	CFMDC 82.4 ARKANSAS 1 66.6 OCONEE 2	CFMDC 97.4 CRYSTAL RIVER 3 98.1 OCONEE 3	CFMDC 0.0 DAVIS-BESSE 1 59.9 RANCHO SECO 1	CFMDC 90.9 OCONEE 1 0.0 THREE MILE ISLAND 1
---	---	--	--	---

***** * COMBUSTION * * ENGINEERING * *****	CFMDC 78.0 ARKANSAS 2 96.5 MAINE YANKEE 101.2 PALO VERDE 2 29.7 ST LUCIE 1	CFMDC 73.5 CALVERT CLIFFS 1 100.2 MILLSTONE 2 100.5 PALO VERDE 3 100.5 ST LUCIE 2	CFMDC 102.0 CALVERT CLIFFS 2 98.8 PALISADES 100.3 SAN ONOFRE 2 90.3 WATERFORD 3	CFMDC 86.9 FORT CALHOUN 1 17.4 PALO VERDE 1 0.0 SAN ONOFRE 3
---	--	---	---	---

***** * WESTINGHOUSE * *****	CFMDC 97.2 BEAVER VALLEY 1 78.8 BYRON 2 87.9 COOK 1 100.2 FARLEY 1 81.4 HARRIS 1 95.1 MCGUIRE 1 98.9 NORTH ANNA 2 99.3 PRAIRIE ISLAND 2 0.0 SAN ONOFRE 1 38.0 SURRY 1 99.2 TURKEY POINT 4 64.9 ZION 1	CFMDC 90.6 BEAVER VALLEY 2 101.8 CALLAWAY 1 0.0 COOK 2 100.0 FARLEY 2 39.9 INDIAN POINT 2 5.0 MCGUIRE 2 101.6 POINT BEACH 1 104.1 ROBINSON 2 0.0 SEQUOYAH 1 92.9 SURRY 2 85.3 VOGTLE 1 98.6 ZION 2	CFMDC 95.2 BRAIDWOOD 1 97.2 CATAHBA 1 32.4 DIABLO CANYON 1 94.0 GINNA 96.8 INDIAN POINT 3 98.9 MILLSTONE 3 101.7 POINT BEACH 2 97.9 SALEM 1 76.7 SEQUOYAH 2 58.9 TROJAN 99.7 WOLF CREEK 1	CFMDC 89.3 BYRON 1 73.4 CATAHBA 2 45.7 DIABLO CANYON 2 97.3 HADDAM NECK 102.1 KEWAUNEE 97.2 NORTH ANNA 1 84.0 PRAIRIE ISLAND 1 90.1 SALEM 2 89.8 SUMMER 1 99.8 TURKEY POINT 3 98.2 YANKEE-ROWE 1
------------------------------------	---	--	--	---

\*\*\*\*\*  
\* OTHER INFO \*  
\*\*\*\*\*  
Units excluded are:  
BIG ROCK POINT  
DRESDEN 1  
FORT ST VRAIN  
HUMBOLDT BAY  
LACROSSE  
THREE MILE ISLAND 2

Capacity factor in this page, denoted as CFMDC, is a function of the net maximum dependable capacity. See the corresponding definition in the glossary. The vendor averages are computed by the formula:

$$\frac{\text{Net Electrical Energy Produced by Vendor}}{\text{Potential Electrical Production by Vendor in this Month}} \times 100\%$$

	GE BHRs	West PHRs	Comb PHRs	B&W PHRs	ALL PHRs
NET ELECTRICAL PRODUCTION.....	14,389,908	22,845,847	7,962,719	3,104,991	33,913,557
MDC NET.....	30,858	40,583	13,955	6,704	61,242
CFMDC.....	62.7	77.6	75.7	62.3	75.7

MEMORANDA

THE FOLLOWING UNITS USE WEIGHTED AVERAGES TO CALCULATE CAPACITY FACTORS:

ITEM 22

BIG ROCK POINT 1  
FARLEY 1  
FITZPATRICK  
FORT CALHOUN 1  
INDIAN POINT 2\*  
KEWAUNEE  
OYSTER CREEK 1  
POINT BEACH 1 & 2  
THREE MILE ISLAND 1  
TURKEY POINT 3 & 4

ITEM 22 & 23

GINNA  
HADDAM NECK (CONNECTICUT YANKEE)  
MAINE YANKEE  
MILLSTONE 2  
OCONEE 1, 2, & 3  
YANKEE-ROWE 1

\*COMPUTED SINCE 7/1/74, THE DATE OF COMPLETION OF A 100 DAY - 100% POWER OPERATION TEST.

THE FOLLOWING UNITS USE THE DATE OF FIRST ELECTRICAL GENERATION INSTEAD OF COMMERCIAL OPERATION,  
FOR THEIR CUMULATIVE DATA:

ITEMS 20 THROUGH 24

COOK 1 & 2  
RIVER BEND  
SAN ONOFRE 1

ITEM 24 ONLY

BIG ROCK POINT 1

ERRATA  
CORRECTIONS TO PREVIOUSLY REPORTED DATA

NOTE: THESE CHANGES ARE REFLECTED IN THE DATA CONTAINED IN THE CURRENT REPORT

REVISED MONTHLY HIGHLIGHTS

N O N E  
N O N E  
N G N E  
N O N E

**SECTION 2**

**OPERATING  
POWER  
REACTORS**

1. Docket: 50-313      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: J. N. GOBELL (501) 964-3251

4. Licensed Thermal Power (Mwt):      2568

5. Nameplate Rating (Gross MWe):      1003 X 0.9 = 903

6. Design Electrical Rating (Net MWe):      850

7. Maximum Dependable Capacity (Gross MWe):      883

8. Maximum Dependable Capacity (Net MWe):      836

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>119,370.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,079.2</u>	<u>84,134.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,044.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,073.6</u>	<u>82,502.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>817.5</u>
17. Gross Therm Ener (MWH)	<u>1,628,430</u>	<u>10,568,811</u>	<u>189,403,818</u>
18. Gross Elec Ener (MWH)	<u>540,335</u>	<u>3,575,610</u>	<u>62,842,740</u>
19. Net Elec Ener (MWH)	<u>512,751</u>	<u>3,391,793</u>	<u>59,781,170</u>
20. Unit Service Factor	<u>100.0</u>	<u>99.3</u>	<u>69.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>99.3</u>	<u>69.8</u>
22. Unit Cap Factor (MDC Net)	<u>82.4</u>	<u>79.4</u>	<u>59.9</u>
23. Unit Cap Factor (DER Net)	<u>81.1</u>	<u>78.1</u>	<u>58.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.7</u>	<u>13.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>37.4</u>	<u>12,435.0</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
REFUELING - 09/02/88 - 71 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                    ARKANSAS                    \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ARKANSAS 1 \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ARKANSAS ONE OPERATED THE ENTIRE MONTH OF JULY AT 85% POWER FOR FUEL CONSERVATION AND INCURRED NO OUTAGES OR SIGNIFICANT LOAD REDUCTIONS.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
X ARKANSAS 1 X  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXX

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ARKANSAS  
COUNTY.....POPE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...6 MI WNW OF  
RUSSELLVILLE, AR  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 6, 1974  
DATE ELEC ENER 1ST GENER...AUGUST 17, 1974  
DATE COMMERCIAL OPERATE...DECEMBER 19, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....DARDANELLE RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ARKANSAS POWER & LIGHT  
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS  
LITTLE ROCK, ARKANSAS 72203  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER .....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....B. JOHNSON  
LICENSING PROJ MANAGER....C. HARBUCK  
DOCKET NUMBER.....50-313  
LICENSE & DATE ISSUANCE...DPR-51, MAY 21, 1974  
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY  
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 31-JUNE 10 (88-17) THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF REVIEW OF THE ADEQUACY OF EMERGENCY OPERATING PROCEDURES FOR UNIT 1. NO INSPECTION OF UNIT 2 WAS CONDUCTED. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ALTHOUGH NUMEROUS TECHNICAL AND HUMAN FACTOR DEFICIENCIES WERE IDENTIFIED, THE EMERGENCY OPERATING PROCEDURES WERE FOUND TO BE ADEQUATE FOR CONTINUED OPERATION OF THE FACILITY. THE LICENSEE COMMITTED TO REVIEW THE DEFICIENCIES AND TAKE PROMPT CORRECTIVE ACTION TO RESOLVE THEM.

INSPECTION CONDUCTED MAY 23-27, 1988 (88-18) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S RADIATION PROTECTION ACTIVITIES ASSOCIATED WITH RADIOACTIVE MATERIAL TRANSPORTATION, LOW LEVEL SOLID RADIOACTIVE WASTE MANAGEMENT, AND GASEOUS AND LIQUID RADIOACTIVE WASTE RELEASES. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 1-30, 1988 (88-20) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, AND TEMPORARY INSTRUCTIONS. WITHIN THE FOUR AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 20-24, 1988 (88-21) ROUTINE, UNANNOUNCED INSPECTION OF LICENSED OPERATOR TRAINING, NON-LICENSED STAFF TRAINING, QUALITY CONTROL TRAINING PROGRAM, AND PLANT TOURS. WITHIN THE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.





1. Docket: 50-368 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: D. F. HARRISON (501) 964-3743  
 4. Licensed Thermal Power (Mwt): 2815  
 5. Nameplate Rating (Gross MWe): 943  
 6. Design Electrical Rating (Net MWe): 912  
 7. Maximum Dependable Capacity (Gross MWe): 897  
 8. Maximum Dependable Capacity (Net MWe): 858  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>73,199.0</u>
13. Hours Reactor Critical	<u>651.6</u>	<u>2,735.6</u>	<u>52,503.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,430.1</u>
15. Hrs Generator On-Line	<u>647.3</u>	<u>2,588.3</u>	<u>50,981.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>75.0</u>
17. Gross Therm Ener (MWH)	<u>1,621,050</u>	<u>6,782,948</u>	<u>131,640,505</u>
18. Gross Elec Ener (MWH)	<u>525,765</u>	<u>2,230,195</u>	<u>43,229,606</u>
19. Net Elec Ener (MWH)	<u>498,106</u>	<u>2,105,095</u>	<u>41,124,592</u>
20. Unit Service Factor	<u>87.0</u>	<u>50.6</u>	<u>69.6</u>
21. Unit Avail Factor	<u>87.0</u>	<u>50.6</u>	<u>69.8</u>
22. Unit Cap Factor (MDC Net)	<u>78.0</u>	<u>48.0</u>	<u>65.5</u>
23. Unit Cap Factor (DER Net)	<u>73.4</u>	<u>45.2</u>	<u>61.6</u>
24. Unit Forced Outage Rate	<u>13.0</u>	<u>4.7</u>	<u>14.2</u>
25. Forced Outage Hours	<u>96.7</u>	<u>127.4</u>	<u>8,463.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* ARKANSAS 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* ARKANSAS 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-03	07/22/88	F	0.0	A	5		AB	PZR	POWER WAS REDUCED TO 20% FOR REPAIR OF FLANGE LEAK AT PRESSURIZER SAFETY VALVE.
88-04	07/24/88	F	96.7	A	1		AB	PZR	UNIT SHUTDOWN TO REPAIR FLANGE LEAK AT PRESSURIZER SAFETY VALVE.
88-05	07/30/88	F	0.0	A	5		TJ	PS	POWER REDUCED FOR WORK ON STATOR WATER COOLING INLET PRESSURE SWITCH.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 ARKANSAS 2 INCURRED ONE FORCED OUTAGE AND 2 FORCED LOAD REDUCTIONS DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ARKANSAS 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....ARKANSAS  
COUNTY.....POPE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...6 MI WNW OF  
RUSSELLVILLE, AR  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...DECEMBER 5, 1978  
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1978  
DATE COMMERCIAL OPERATE...MARCH 26, 1980  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...DARDANELLE RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY  
LICENSEE.....ARKANSAS POWER & LIGHT  
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS  
LITTLE ROCK, ARKANSAS 72203

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....W. JOHNSON  
LICENSING PROJ MANAGER.....C. HARBUCK  
DOCKET NUMBER.....50-368  
LICENSE & DATE ISSUANCE...NPF-6, SEPTEMBER 1, 1978  
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY  
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED FEB 29 - MAR 4, 21-25, APR 4-8, AND JUNE 6-11 (88-19) ROUTINE, ANNOUNCED INSPECTION OF FOLLOWUP TO ISSUES IDENTIFIED IN NRC IN-SPECTION REPORT 50-313/87-23 AND 50-368/87-23 AND THE LICENSEE'S RESPONSE TO NRC GENERIC LETTER 83-28. WITHIN THE AREAS INSPECTED, TWO VIOLATIONS, IN ONE POTENTIAL VIOLATION WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 23-27, 1988 (88-18) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S RADIATION PROTECTION ACTIVITIES ASSOCIATED WITH RADIOACTIVE MATERIAL TRANSPORTATION, LOW LEVEL SOLID RADIOACTIVE WASTE MANAGEMENT, AND GASEOUS AND LIQUID RADIOACTIVE WASTE RELEASES. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. PROFICIENCY OF PERSONNEL IN USING THEM. WITHIN THE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 1-30, 1988 (88-20) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, TEMPORARY INSTRUCTIONS. WITHIN THE FOUR AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 20-24, 1988 (88-21) ROUTINE, UNANNOUNCED INSPECTION OF LICENSED OPERATOR TRAINING, NON-LICENSED STAFF TRAINING, QUALITY CONTROL TRAINING PROGRAM, AND PLANT TOURS. WITHIN THE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    ARKANSAS 2                    \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ONE REACTOR COOLANT PUMP OUT OF SERVICE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 30, 1988

INSPECTION REPORT NO: 50-368/88-20

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE			
=====			

1. Docket: 50-334                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: P.A. SMITH (412) 393-7621

4. Licensed Thermal Power (Mwt):                      2652

5. Nameplate Rating (Gross MWe):                      102' X 0.9 = 923

6. Design Electrical Rating (Net MWe):                      835

7. Maximum Dependable Capacity (Gross MWe):                      860

8. Maximum Dependable Capacity (Net MWe):                      810

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>107,399.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,606.0</u>	<u>62,794.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>4,482.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,539.2</u>	<u>61,193.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2.2</u>
17. Gross Therm Ener (MWH)	<u>1,941,312</u>	<u>9,010,080</u>	<u>145,927,390</u>
18. Gross Elec Ener (MWH)	<u>622,450</u>	<u>2,926,059</u>	<u>46,791,819</u>
19. Net Elec Ener (MWH)	<u>586,000</u>	<u>2,741,707</u>	<u>43,677,310</u>
20. Unit Service Factor	<u>100.0</u>	<u>69.2</u>	<u>59.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>69.2</u>	<u>59.3</u>
22. Unit Cap Factor (MDC Net)	<u>97.2</u>	<u>66.2</u>	<u>53.4</u>
23. Unit Cap Factor (DER Net)	<u>94.3</u>	<u>64.2</u>	<u>51.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.9</u>	<u>18.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>105.9</u>	<u>19,147.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \*                      B E A V E R   V A L L E Y   1                      \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 BEAVER VALLEY 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
18	07/18/88	F	0.0	A	5		HF	PUMPXX	OUTPUT REDUCED TO 75% TO REPAIR A SEAL ON THE 'A' COOLING TOWER PUMP.
19	07/23/88	F	0.0	A	5		HF	PUMPXX	OUTPUT REDUCED TO 90% TO REPAIR A SEAL ON THE 'A' COOLING TOWER PUMP.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BEAVER VALLEY 1 INCURRED TWO POWER REDUCTIONS IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	H-Other		
	E-Operator Training & License Examination		

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....BEAVER  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...SHIPPINGPORT, PENNSYLVANIA

TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 10, 1976  
DATE ELEC ENER 1ST GENER...JUNE 14, 1976  
DATE COMMERCIAL OPERATE...OCTOBER 1, 1976

CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...OHIO RIVER

ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUQUESNE LIGHT  
CORPORATE ADDRESS.....ONE OXFORD CENTRE, 301 GRANT STREET  
PITTSBURGH, PENNSYLVANIA 15279

CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....J. BEALL  
LICENSING PROJ MANAGER.....P. TAM  
DOCKET NUMBER.....50-334  
LICENSE & DATE ISSUANCE...DPR-66, JULY 2, 1976  
PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY  
633 FRANKLIN AVENUE  
ALIQUPPA, PA 15001

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*            BEAVER VALLEY 1            \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====



Docket: 50-412 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: P. A. SMITH (412) 643-1825  
 4. Licensed Thermal Power (Mwt): 2652  
 5. Nameplate Rating (Gross MWe): 923  
 6. Design Electrical Rating (Net MWe): 836  
 7. Maximum Dependable Capacity (Gross MWe): 885  
 8. Maximum Dependable Capacity (Net MWe): 833  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>6,182.0</u>
13. Hours Reactor Critical	<u>725.1</u>	<u>4,672.1</u>	<u>5,637.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>719.9</u>	<u>4,638.0</u>	<u>5,587.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,881,079</u>	<u>12,012,947</u>	<u>14,398,584</u>
18. Gross Elec Ener (MWH)	<u>594,000</u>	<u>3,872,900</u>	<u>4,655,100</u>
19. Net Elec Ener (MWH)	<u>561,406</u>	<u>3,661,567</u>	<u>4,399,671</u>
20. Unit Service Factor	<u>96.8</u>	<u>90.7</u>	<u>90.4</u>
21. Unit Avail Factor	<u>96.8</u>	<u>90.7</u>	<u>90.4</u>
22. Unit Cap Factor (MDC Net)	<u>90.6</u>	<u>86.0</u>	<u>85.4</u>
23. Unit Cap Factor (DER Net)	<u>90.3</u>	<u>85.7</u>	<u>85.1</u>
24. Unit Forced Outage Rate	<u>3.2</u>	<u>2.6</u>	<u>4.2</u>
25. Forced Outage Hours	<u>24.1</u>	<u>126.0</u>	<u>247.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* BEAVER VALLEY 2 \*  
 \*\*\*\*\*

AVERAGE DAILY "R LEVEL (MWe) PLOT

BEAVER VALLEY 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BEAVER VALLEY 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
11	07/16/88	F	0.0	A	5		HC	HTEXCH	UNIT'S OUTPUT WAS REDUCED TO 85% TO IMPROVE CONDENSER VACUUM.
12	07/27/88	F	24.1	A	3	2-88-009	RB	CONROD	THE UNIT TRIPPED INADVERTENTLY WHILE TROUBLESHOOTING A ROD CONTROL PROBLEM.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

BEAVER VALLEY 2 INCURRED ONE FORCED OUTAGE AND ONE FORCED REDUCTION IN POWER IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....BEAVER  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...SHIPPINGPORT, PENNSYLVANIA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 4, 1987  
DATE ELEC ENER 1ST GENER...AUGUST 17, 1987  
DATE COMMERCIAL OPERATE...NOVEMBER 17, 1987  
CONDENSER COOLING METHOD...HNDCT  
CONDENSER COOLING WATER...OHIO RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSE#.....DUQUESNE LIGHT  
CORPORATE ADDRESS.....435 SIXTH AVENUE  
PITTSBURGH, PENNSYLVANIA 15219  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....J. BEALL  
LICENSING PROJ MANAGER.....P. TAM  
DOCKET NUMBER.....50-412  
LICENSE & DATE ISSUANCE...NPF-73, AUGUST 14, 1987  
PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY  
633 FRANKLIN AVENUE  
ALIQUIPPA, PA 15001

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*            BEAVER VALLEY 2            \*  
\*\*\*\*\*

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

INFO. NOT SUPPLIED BY REGION

=====

1. Docket: 50-155 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. R. JOHNSTON (616) 547-6537

4. Licensed Thermal Power (Mwt): 240

5. Nameplate Rating (Gross MWe): 70.6 X 0.85 = 60

6. Design Electrical Rating (Net MWe): 72

7. Maximum Dependable Capacity (Gross MWe): 73

8. Maximum Dependable Capacity (Net MWe): 69

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>222,162.0</u>
13. Hours Reactor Critical	<u>612.1</u>	<u>2,834.7</u>	<u>158,668.4</u>
14. Rx Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>576.4</u>	<u>2,736.1</u>	<u>155,871.0</u>
16. Unit Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>97,188</u>	<u>500,101</u>	<u>29,433,624</u>
18. Gross Elec Ener (MWH)	<u>31,618</u>	<u>162,945</u>	<u>9,334,779</u>
19. Net Elec Ener (MWH)	<u>29,773</u>	<u>153,790</u>	<u>8,827,032</u>
20. Unit Service Factor	<u>77.5</u>	<u>53.5</u>	<u>70.2</u>
21. Unit Avail Factor	<u>77.5</u>	<u>53.5</u>	<u>70.2</u>
22. Unit Cap Factor (MDC Net)	<u>58.0</u>	<u>43.6</u>	<u>59.0*</u>
23. Unit Cap Factor (DER Net)	<u>55.6</u>	<u>41.8</u>	<u>55.2</u>
24. Unit Forced Outage Rate	<u>22.5</u>	<u>12.0</u>	<u>13.6</u>
25. Forced Outage Hours	<u>167.6</u>	<u>372.2</u>	<u>12,478.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
BIG ROCK POINT 1



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BIG ROCK POINT 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
88-10	06/29/88	F	42.6	A	4			DURING POWER ESCALATION, AFTER THE REFUELING OUTAGE, IT WAS FOUND THAT THE NEW WIDE RANGE MONITORING INSTRUMENTS (WRM'S) COULD NOT BE CALIBRATED TO INDICATE ACTUAL REACTOR POWER. AT THAT TIME, POWER ESCALATION WAS STOPPED AND THE PLANT COMMENCED AN ORDERLY SHUTDOWN OF THE REACTOR. THE UNIT WAS REMOVED FROM SERVICE AT 06:50 HRS, 06/29/88. ON 07/01/88, AFTER MODIFICATIONS WERE COMPLETED ON THE WRM'S, THE REACTOR WAS TAKEN CRITICAL AND THE UNIT WAS RETURNED TO SERVICE.
88-11	07/02/88	F	125.0	A	1			THE UNIT WAS SHUTDOWN MANUALLY WHEN THE TURBINE/GENERATOR SEAL OIL SYSTEM COULD NOT BE ESTABLISHED. THE UNIT WAS RETURNED TO SERVICE ON 07/07/88 AT 23:37 AFTER REPAIRS WERE COMPLETE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BIG ROCK POINT ENTERED JULY SHUTDOWN. SUBSEQUENTLY, INCURRED ONE FORCED OUTAGE WHILE RETURNING TO POWER.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
COUNTY.....CHARLEVOIX  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...4 MI NE OF  
CHARLEVOIX, MICH  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 27, 1962  
DATE ELEC ENER 1ST GENER...DECEMBER 8, 1962  
DATE COMMERCIAL OPERATE...MARCH 29, 1963  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONSUMERS POWER  
CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE  
JACKSON, MICHIGAN 49201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....S. GUTHRIE  
LICENSING PROJ MANAGER.....W. SCOTT  
DOCKET NUMBER.....50-155  
LICENSE & DATE ISSUANCE...DPR-6, AUGUST 30, 1962  
PUBLIC DOCUMENT ROOM.....NORTH CENTRAL MICHIGAN COLLEGE  
1515 HOWARD STREET  
PETOSKEY, MICHIGAN 49770

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 20 THROUGH JUNE 1 (88009): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY THE SENIOR RESIDENT INSPECTOR. THE FUNCTIONAL AREAS INSPECTED CONSISTED OF LICENSEE ACTION ON A PREVIOUS INSPECTION FINDING INVOLVING SITE QA STAFFING, OPERATIONAL SAFETY VERIFICATION INVOLVING DAY TO DAY PLANT ACTIVITIES, MAINTENANCE OBSERVATIONS OF WORK PERFORMED ON AN EMERGENCY DIESEL GENERATOR, THREE DIGITAL TEMPERATURE RECORDERS, A CIRCULATING WATER PUMP, AND SEVERAL PRESSURE RELIEF VALVES, SECURITY, LICENSEE ACTION IN RESPONSE TO NRC BULLETIN 88-03, AND LICENSING ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 86 INSPECTOR-HOURS BY TWO NRC INSPECTORS. IN GENERAL, THE LICENSEE HAS DEMONSTRATED A DESIRE TO RESPOND IN A TIMELY MANNER TO ISSUES AND CONCERNS PRESENTED TO THEM BY THE NRC. THE OPERATIONAL SAFETY MAINTENANCE, AND SECURITY PROGRAMS APPEARED ADEQUATE TO ENSURE PUBLIC HEALTH AND SAFETY. TWO OPEN ITEMS WERE IDENTIFIED IN THE MAINTENANCE AREA. BOTH ITEMS INVOLVED SAFETY ISSUES WITH PRESSURE RELIEF VALVES.

INSPECTION ON MAY 23-27 AND JUNE 9 (88012): ROUTINE, ANNOUNCED INSPECTION OF MAINTENANCE ACTIVITIES USING SELECTED PORTIONS OF INSPECTION MODULES 62700, 62702, 62704 AND 62705. MAINTENANCE WAS ACCOMPLISHED, EFFECTIVE, AND SELF-ASSESSED; HOWEVER, MANAGEMENT INVOLVEMENT IS NEEDED TO ASSURE THAT MAINTENANCE PROCEDURES ARE REVIEWED AND EVALUATED FOR TECHNICAL ADEQUACY. MAINTENANCE PROCEDURES NEED TO BE USED FOR ACTIVITIES PERFORMED ON A REGULAR INTERVAL FOR PERFORMANCE CONSISTENCY. CORRECTIVE MAINTENANCE PROCEDURES NEED TO PROVIDE DETAILED STEP BY STEP INSTRUCTIONS ESPECIALLY DURING TASKS REQUIRING DISASSEMBLY AND ASSEMBLY OF EQUIPMENT. THE THRESHOLD FOR PLACING EQUIPMENT PROBLEMS ON MAINTENANCE WORK REQUESTS WAS SUFFICIENT TO MAINTAIN THE MATERIAL CONDITION OF THE PLANT AT AN ACCEPTABLE LEVEL. TRAINING CONDUCTED BEFORE THE INSTALLATION OF THE NEW INTERMEDIATE RANGE NEUTRON CHANNELS WAS CONSIDERED A STRENGTH IN PREPARING MAINTENANCE PERSONNEL FOR OPERATING AND MAINTAINING THE NEW EQUIPMENT. THE QA DEPARTMENT AUDITS AND SURVEILLANCES EVALUATED MAINTENANCE PROCESSES FOR TECHNICAL ADEQUACY AND PROVIDED INPUT TO UPGRADE AND TRACK THE PM PROGRAM. TWO EXAMPLES OF ONE VIOLATION WERE IDENTIFIED.

Report Period JUL 1988

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

RDS VALVES CORROSION PROBLEM

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: 07/21/88

INSPECTION REPORT NO: 88016

REPORTS FROM LICENSEE

```

=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT    REPORT
-----
88-05    062688    071888    REACTOR DEPRESSURIZATION TIMERS OUT OF SPECIFICATION
88-06    070888    080588    SOURCE RANGE MONITOR ANOMALY RESULTING IN TECHNICAL SPECIFICATION VIOLATION
=====

```



1. Docket: 50-456 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 56.3  
 3. Utility Contact: B. M. PEACOCK (815) 458-2801 EXT. 2480  
 4. Licensed Thermal Power (Mwt): 3411  
 5. Nameplate Rating (Gross MWe): \_\_\_\_\_  
 6. Design Electrical Rating (Net MWe): 1120  
 7. Maximum Dependable Capacity (Gross MWe): 1175  
 8. Maximum Dependable Capacity (Net MWe): 1120  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>56.3</u>	<u>56.3</u>	<u>56.3</u>
13. Hours Reactor Critical	<u>56.3</u>	<u>56.3</u>	<u>56.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>56.3</u>	<u>56.3</u>	<u>56.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>183,082</u>	<u>183,082</u>	<u>183,082</u>
18. Gross Elec Ener (MWH)	<u>62,690</u>	<u>62,690</u>	<u>62,690</u>
19. Net Elec Ener (MWH)	<u>60,040</u>	<u>60,040</u>	<u>60,040</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>100.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>100.0</u>
22. Unit Cap Factor (MDC Net)	<u>95.2</u>	<u>95.2</u>	<u>95.2</u>
23. Unit Cap Factor (DER Net)	<u>95.2</u>	<u>95.2</u>	<u>95.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 X BRAIDWOOD 1 X  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRAIDWOOD 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BRAIDWOOD 1 \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BRAIDWOOD 1 COMPLETED ALL REQUIREMENTS FOR COMMERCIAL OPERATION  
ON JULY 29, 1988, AND WAS DECLARED "IN COMMERCIAL OPERATION".

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* BRAIDWOOD 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION:

LOCATION  
STATE.....ILLINOIS  
COUNTY.....WILL  
DIST AND EJECTION FROM  
NEAREST POPULATION CTR...24 MI SSW OF  
JOLIET, ILL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 29, 1987  
DATE ELEC ENER 1ST GENER...JULY 12, 1987  
DATE COMMERCIAL OPERATE....JULY 29, 1988  
CONDENSER COOLING METHOD...CC ART  
CONDENSER COOLING WATER...KANKAKEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER...SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....L. MCGREGOR  
LICENSING PROJ MANAGER.....S. SANDS  
DOCKET NUMBER.....50-456  
LICENSE & DATE ISSUANCE...NPF-72, JULY 2, 1987  
PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN  
GOVERNMENT DOCUMENTS COLLECTION  
WILMINGTON PUBLIC LIBRARY  
201 SOUTH KANKAKEE STREET  
WILMINGTON, ILLINOIS, 60481

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 6-21 (88018; 88018): INCLUDED A REVIEW OF MANAGEMENT EFFECTIVENESS; SECURITY ORGANIZATION; SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; PHYSICAL BARRIERS-PROTECTED AND VITAL AREAS; ASSESSMENT AIDS; ACCESS CONTROL-VEHICLES; DETECTION AIDS-PROTECTED AREA; ALARM STATIONS; COMMUNICATIONS; TRAINING AND QUALIFICATIONS-GENERAL REQUIREMENTS; AND SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW. NO VIOLATIONS WERE IDENTIFIED. ONE OPEN ITEM INVOLVING THE USE OF FORCE WAS IDENTIFIED DURING THIS INSPECTION. LICENSEE PERFORMANCE IN IMPLEMENTING SECURITY PROGRAM REQUIREMENTS IS ADEQUATE.

INSPECTION ON JUNE 20 (88020; 88020): INCLUDED A REVIEW OF COMPENSATORY MEASURES AND ACCESS CONTROL-PERSONNEL AS THEY RELATED TO AN NRC IDENTIFIED INCIDENT INVOLVING AN INATTENTIVENESS TO DUTY ISSUE OF TWO SECURITY OFFICERS. THE LICENSEE WAS FOUND TO BE IN VIOLATION OF NRC REQUIREMENTS NOTED BELOW: COMPENSATORY MEASURES: THE LICENSEE FAILED ON TWO OCCASIONS TO ENSURE ADEQUATE IMPLEMENTATION OF VITAL AREA COMPENSATORY MEASURES. INSPECTION ACTIVITIES SHOWED A DECLINE IN THE LICENSEE'S IMPLEMENTATION OF THEIR SECURITY PROGRAM.

ENFORCEMENT SUMMARY

NONE



1. Docket: 50-457 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 56.3

3. Utility Contact: M. W. PETERSON

4. Licensed Thermal Power (Mht): 3411

5. Nameplate Rating (Gross MWe): \_\_\_\_\_

6. Design Electrical Rating (Net MWe): 1120

7. Maximum Dependable Capacity (Gross MWe): 1175

8. Maximum Dependable Capacity (Net MWe): 1120

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>1,611.4</u>	<u>1,611.4</u>
13. Hours Reactor Critical	<u>679.7</u>	<u>1,367.7</u>	<u>1,367.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>663.4</u>	<u>1,207.6</u>	<u>1,207.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,169,397</u>	<u>1,818,718</u>	<u>1,818,718</u>
18. Gross Elec Ener (MWH)	<u>363,584</u>	<u>518,762</u>	<u>518,762</u>
19. Net Elec Ener (MWH)	<u>339,149</u>	<u>482,829</u>	<u>482,829</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>80.6</u>	<u>204.1</u>	<u>204.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* BRAIDWOOD 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRAIDWOOD 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BRAIDWOOD 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
08	07/02/88	F	55.1	G	3	88-018	JG	PIC	FAILURE OF PRESSURIZER PRESSURE BISTABLE 457C WITH BISTABLE 455C IN A TRIPPED CONDITION DUE TO TESTING. COMPARATOR CARD WAS REPLACED.
09	07/24/88	F	25.5	A	2	88-019	LD	ISV	LOSS OF INSTRUMENT AIR TO HEATER DRAIN VALVES. INSTRUMENT AIR ISOLATION VALVE WAS REPOSITIONED.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BRAIDWOOD 2 INCURRED TWO FORCED OUTAGES DURING JULY WHILE PROCEEDING WITH THE STARTUP TEST PROGRAM.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BRAIDHOOD 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
  
COUNTY.....WILL  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...24 MI SSW OF  
JOLIET, ILL  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...MARCH 8, 1988  
  
DATE ELEC ENER 1ST GENER...MAY 25, 1988  
  
DATE COMMERCIAL OPERATE.....\*\*\*\*\*  
  
CONDENSER COOLING METHOD...CCART  
  
CONDENSER COOLING WATER...KANKAKEE RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....COMMONWEALTH EDISON  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
  
IE RESIDENT INSPECTOR.....L. MCGREGOR  
  
LICENSING PROJ MANAGER....S. SANDS  
DOCKET NUMBER.....50-457  
  
LICENSE & DATE ISSUANCE...NPF-77, MAY 20, 1988  
  
PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN  
GOVERNMENT DOCUMENTS COLLECTION  
WILMINGTON PUBLIC LIBRARY  
201 SOUTH KANKAKEE STREET  
WILMINGTON, ILLINOIS, 60481

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 6-21 (88018; 88018): INCLUDED A REVIEW OF MANAGEMENT EFFECTIVENESS; SECURITY ORGANIZATION; SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; PHYSICAL BARRIERS-PROTECTED AND VITAL AREAS; ASSESSMENT AIDS; ACCESS CONTROL-VEHICLES; DETECTION AIDS-PROTECTED AREA; ALARM STATIONS; COMMUNICATIONS; TRAINING AND QUALIFICATIONS-GENERAL REQUIREMENTS; AND SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW. NO VIOLATIONS WERE IDENTIFIED. ONE OPEN ITEM INVOLVING THE USE OF FORCE WAS IDENTIFIED DURING THIS INSPECTION. LICENSEE PERFORMANCE IN IMPLEMENTING SECURITY PROGRAM REQUIREMENTS IS ADEQUATE.

INSPECTION ON JUNE 20 (88020; 88020): INCLUDED A REVIEW OF COMPENSATORY MEASURES AND ACCESS CONTROL-PERSONNEL AS THEY RELATED TO AN NRC IDENTIFIED INCIDENT INVOLVING AN INATTENTIVENESS TO DUTY ISSUE OF TWO SECURITY OFFICERS. THE LICENSEE WAS FOUND TO BE IN VIOLATION OF NRC REQUIREMENTS NOTED BELOW: COMPENSATORY MEASURES: THE LICENSEE FAILED ON TWO OCCASIONS TO ENSURE ADEQUATE IMPLEMENTATION OF VITAL AREA COMPENSATORY MEASURES. INSPECTION ACTIVITIES SHOWED A DECLINE IN THE LICENSEE'S IMPLEMENTATION OF THEIR SECURITY PROGRAM.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

## SYSTEMS AND COMPONENT PROBLEMS:

NONE

## FACILITY ITEMS (PLANS AND PROCEDURES):

LOW LEVEL OF ROCK RIVER NECESSITATES PERIODIC MONITORING OF RIVER FLOW IN SUPPORT OF ALTERNATE HEAT SINK CONSIDERATIONS.

## MANAGERIAL ITEMS:

NONE

## PLANT STATUS:

OPERATING AT POWER LEVELS UP TO 100%.

LAST IE SITE INSPECTION DATE: 07/18/88

INSPECTION REPORT NO: 88025

## R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-12	062088	070888	REACTOR TRIP DUE TO PHASE B OVERCURRENT PROTECTIVE RELAY CO-7 DEFFECTIVE CURRENT SWITCH
88-13	062188	071888	LOW STEAM GENERATOR LEVEL RESULTS IN REACTOR TRIP DUE TO INADEQUATE PROCEDURE GUIDANCE
88-	062288	071888	UNIT 2 REACTOR TRIP DUE TO LOW WATER LEVEL CAUSED BY ERRATIC OPERATION OF MAIN WATER REGULATING VALVE
88-15	062688	071988	FEEDWATER ISOLATION DUE TO HI-2 STEAM GENERATOR LEVEL CAUSED BY STEAM GENERATOR SENSITIVITY
88-16	062488	071988	UNIT 2 REACTOR TRIP U-2 RX TRIP ON LO-2 2B S/G LEVEL
88-17	062988	072088	MISSED TECHNICAL SPECIFICATION SURVEILLANCE DUE TO CALCULATIONAL ERROR
88-18	070288	072188	REACTOR TRIP DUE TO DEFECTIVE CIRCUIT CARD



1. Docket: 50-259 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: J. D. CRAWFORD (205) 729-2507  
 4. Licensed Thermal Power (MWT): 3293  
 5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152  
 6. Design Electrical Rating (Net MWe): 1065  
 7. Maximum Dependable Capacity (Gross MWe): 1098  
 8. Maximum Dependable Capacity (Net MWe): 1065  
 9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>122,737.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>59,520.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>6,996.8</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>58,276.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>167,963,338</u>
18. Gross Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>55,398,130</u>
19. Net Elec Ener (MWH)	<u>-5,132</u>	<u>-29,019</u>	<u>53,612,464</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>47.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>47.5</u>
22. Unit Cap Factor (IDC Net)	<u>.0</u>	<u>.0</u>	<u>41.0</u>
23. Unit Cap Factor (DLR Net)	<u>.0</u>	<u>.0</u>	<u>41.0</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>44.0</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,111.0</u>	<u>45,809.1</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* BROWNS FERRY 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BROWNS FERRY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
315	06/01/85	F	744.0	F	4			ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BROWNS FERRY 1 REMAINED ON ADMINISTRATIVE HOLD IN JULY IN ORDER TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& license Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BROWNS FERRY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....LIMESTONE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI NW OF  
DECATUR, ALA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 17, 1973  
DATE ELEC ENER 1ST GENER...OCTOBER 15, 1973  
DATE COMMERCIAL OPERATE...AUGUST 1, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...TENNESSEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II  
CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR  
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. PAULK  
LICENSING PROJ MANAGER.....J. GEARS  
DOCKET NUMBER.....50-259  
LICENSE & DATE ISSUANCE....DPR-33, DECEMBER 20, 1973  
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY  
SOUTH AND FORREST  
ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 2-6 (88-12): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF MARK I CONTAINMENT LONG TERM PROGRAM MODIFICATION, IEB 79-02, AND IEB 79-14. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.5.1, THE REQUIREMENTS WERE NOT MET AS FOLLOWS: (1) PLANT MANAGERS INSTRUCTION (PMI) 7.1, PLANT OPERATIONS REVIEW COMMITTEE, IMPROPERLY DESIGNATED THREE ALTERNATE PORC CHAIRMEN. PM 7.1 ALLOWED TWO OF THE UNIT SUPERINTENDENTS AND THE MAINTENANCE SUPERINTENDENT TO BE ALTERNATE PORC CHAIRMAN. (2) THE ACTING MAINTENANCE SUPERINTENDENT WHO IS NEITHER AUTHORIZED BY TECHNICAL SPECIFICATIONS OR PMI 7.1 TO BE AN ALTERNATE CHAIRMAN, CHAIRED AS PORC MEETING ON MARCH 10, 1988. ALSO ON THIS MARCH 10, 1988, PORC MEETING, AN INDIVIDUAL ACTED AS AN ALTERNATE MEMBER FOR THE HEALTH PHYSICS SUPERVISOR WITHOUT BEING APPOINTED IN WRITING IN PMI 7.1. (3) WRITTEN MINUTES OF THE EXPEDITED PORC MEETING CONDUCTED ON MARCH 10, 1988, IN WHICH A DEFICIENT CONDITION WITH THE REACTOR BUILDING OVERHEAD CRANE WAS DISCUSSED WERE NOT MAINTAINED.  
(8800 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V: (1) THE REQUIREMENTS OF SURVEILLANCE INSTRUCTION O-SI-4.7.B.6, STANDBY GAS TREATMENT SYSTEM IODINE REMOVAL EFFICIENCY WERE NOT ADHERED TO FOR THE TEST ON TRAINS B AND C COMPLETED ON JANUARY 12, 1988, AND TRAIN A COMPLETED ON FEBRUARY 16, 1988. ATTACHMENT 5 OF SI 4.7.B.6 REQUIRES THAT THE CHARCOAL SAMPLES BE TESTED IN ACCORDANCE



=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-017	06/04/88	07/01/88	UNPLANNED STANDBY GAS TREATMENT ACTUATION DUE TO PERSONNEL ERROR
88-018	06/05/88	07/05/88	UNPLANNED ENGINEERED SAFETY FEATURE ACTUATION DUE TO CIRCUIT PROTECTOR TRIP CAUSED BY UNSTABLE UNDervOLTAGE RELAY FAILURE
88-019	06/08/88	07/07/88	ENGINEERED SAFETY FEATURE ACTUATIONS OCCURRED DUE TO PERSONNEL ERROR

=====

THIS PAGE INTENTIONALL LFFT BLANK

1. Docket: 50-260 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. CRAWFORD (205) 729-2507

4. Licensed Thermal Power (MWT): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>117,648.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>55,859.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>14,200.4</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>54,338.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>153,245,167</u>
18. Gross Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>50,771,798</u>
19. Net Elec Ener (MWH)	<u>-2,419</u>	<u>-14,526</u>	<u>49,169,307</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>46.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>46.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>39.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>39.2</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>43.5</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,111.0</u>	<u>41,864.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* BROWNS FERRY 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BROWNS FERRY 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
305	09/15/84	F	744.0	F	4			ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BROWNS FERRY 2 REMAINED ON ADMINISTRATIVE HOLD IN JULY TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		



\*\*\*\*\*  
\* BROWNS FERRY 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....LIMESTONE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTN...10 MI NW OF  
DECATUR, ALA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JULY 20, 1974  
DATE ELEC ENER 15; GENER...AUGUST 28, 1974  
DATE COMMERCIAL OPERATE...MARCH 1, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...TENNESSEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II  
CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR  
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. PAULK  
LICENSING PROJ MANAGER.....J. GEARS  
DOCKET NUMBER.....50-260  
LICENSE & DATE ISSUANCE....DPR-52, AUGUST 2, 1974  
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY  
SOUTH AND FORREST  
ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 2-6 (88-12): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF MARK I CONTAINMENT LONG TERM PROGRAM MODIFICATION, IEB 79-02, AND IEB 79-14. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.5.1, THE REQUIREMENTS WERE NOT MET AS FOLLOWS: (1) PLANT MANAGERS INSTRUCTION (PMI) 7.1, PLANT OPERATIONS REVIEW COMMITTEE, IMPROPERLY DESIGNATED THREE ALTERNATE PORC CHAIRMEN. PMI 7.1 ALLOWED TWO OF THE UNIT SUPERINTENDENTS AND THE MAINTENANCE SUPERINTENDENT TO BE ALTERNATE PORC CHAIRMAN. (2) THE ACTING MAINTENANCE SUPERINTENDENT WHO IS NEITHER AUTHORIZED BY TECHNICAL SPECIFICATIONS OR PMI 7.1 TO BE AN ALTERNATE CHAIRMAN, CHAIRED AS PORC MEETING ON MARCH 10, 1988. ALSO ON THIS MARCH 10, 1988, PROC MEETING, AN INDIVIDUAL ACTED AS AN ALTERNATE MEMBER FOR THE HEALTH PHYSICS SUPERVISOR WITHOUT BEING APPOINTED IN WRITING IN PMI 7.1. (3) WRITTEN MINUTES OF THE EXPEDITED PORC MEETING CONDUCTED ON MARCH 10, 1988, IN WHICH A DEFICIENT CONDITION WITH THE REACTOR BUILDING OVERHEAD CRANE WAS DISCUSSED WERE NOT MAINTAINED. CONTRARY TO 10 CFR, APPENDIX B, CRITERION X, THE REQUIREMENT WAS NOT MET ON NOVEMBER 20, 1987 WHEN A CHECK VALVE IN THE EMERGENCY EQUIPMENT COOLING WATER SYSTEM (EECW) WAS IMPROPERLY INSTALLED DURING THE PERFORMANCE OF MAINTENANCE REQUEST (MR) NUMBER 792717. VALVE NUMBER 2-67-659 WAS FOUND TO BE INSTALLED BACKWARDS ON MARCH 15, 1988. RESEARCH INDICATED THAT THE LAST ACTIVITY PERFORMED ON THE VALVE WAS MR-792717. NO INSPECTION WAS PERFORMED AND DOCUMENTED TO VERIFY PROPER ORIENTATION OF THE CHECK VALVE FOLLOWING THE MAINTENANCE ACTIVITY. WORK INSTRUCTIONS OF THE MR EXPLICITLY STATED TO REINSTALL THE VALVE IN THE PROPER ORIENTATION. REVERSAL OF THIS CHECK VALVE PREVENTED

ENFORCEMENT SUMMARY

THE SUPPLY OF EECW TO THE RESIDUAL HEAT REMOVAL (RHR) PUMP SEAL COOLER AND THE RHR PUMP ROOM COOLER FROM THE NORTH EECW HEADER. (8800 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V: (1) THE REQUIREMENTS OF SURVEILLANCE INSTRUCTION 0-SI-4.7.B.6, STANDBY GAS TREATMENT SYSTEM IODINE REMOVAL EFFICIENCY WERE NOT ADHERED TO FOR THE TEST ON TRAINS B AND C COMPLETED ON JANUARY 12, 1988, AND TRAIN A COMPLETED ON FEBRUARY 16, 1988. ATTACHMENT 5 OF SI 4.7.B.6 REQUIRES THAT THE CHARCOAL SAMPLES BE TESTED IN ACCORDANCE WITH ASTM D3803, STANDARD TEST METHOD FOR RADIOIODINE TESTING OF NUCLEAR-GRADE GAS-PHASE ADSORBENTS. ASTM D3803 REQUIRES THAT THE FEED PERIOD DURATION AND THE ELUTION PERIOD DURATION BE 60 PLUS OR MINUS 1 MINUTES AND 240 PLUS OR MINUS 1 MINUTES RESPECTIVELY. TEST DATA CONTAINED IN THE COMPLETED SI DATA PACKAGE DOCUMENT THAT THE ACTUAL FEED DURATION WAS 90 MINUTES (THIRTY MINUTES LONGER THAN SPECIFIED) AND THE ACTUAL ELUTION TIME WAS 90 MINUTES (150 MINUTES SHORTER THAN SPECIFIED). IT IS NOTED THAT THIS IS A REPEAT VIOLATION MOST RECENTLY CITED IN INSPECTION REPORTS 50-259, 260, 296/86-11. (2) THE REQUIREMENTS OF PLANT MANAGERS INSTRUCTION 15.4 (UNIQUE REPORTING REQUIREMENTS), WERE NOT ADHERED TO IN THAT NO LICENSEE REPORTABLE EVENT DETERMINATION EVALUATION WAS INITIATED AS REQUIRED TO DETERMINE THE OPERABILITY OF THE UNIT 2 RESIDUAL HEAT REMOVAL SYSTEM LOWER CONTAINMENT SPRAY HEADER AFTER AN INSPECTION (CAQR BFP880052) REVEALED CLOGGED NOZZLES DUE TO RUST ON FEBRUARY 3, 1988. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION VI, REVISION 1 TO TEMPORARY ALTERATION CONTROL FORM (TACF) NUMBER 3-88-001-111 WAS NOT PROPERLY REVIEWED FOR ADEQUACY APPROVED FOR RELEASE, AND PROPERLY DISTRIBUTED. THE ORIGINAL TACF WAS INITIATED ON MARCH 10, 1988 WITH THE MAJORITY OF THE REVIEW AND APPROVAL AUTHORIZATIONS OBTAINED ON MARCH 13, 1988. A REVISION WAS INITIATED ON MARCH 15, 1988; HOWEVER, NOT ALL OF THE APPROVAL SIGNATURES WERE UPDATED TO REFLECT APPROVAL OF THE REVISED INFORMATION. (1) THE OPERATIONS SUPERVISOR'S CONCURRENCE SIGNATURE WAS DATED MARCH 13, 1988. (2) THE SHIFT ENGINEER'S APPROVAL OF THE TACF WAS DATED MARCH 13, 1988. (3) THE FILE CLERK MADE AND DISTRIBUTED COPIES OF THE TACF ON MARCH 15, 1988, ALTHOUGH FOUR SIGNATURES ON THE TACF WERE DATED MARCH 16, 1988. THE ABOVE INFORMATION WAS ONLY AVAILABLE ON THE ORIGINAL TACF FORM MAINTAINED IN THE SHIFT ENGINEER'S OFFICE AND WAS THE CONDITION OF THE TACF ON MARCH 17, 1988. SIMILAR PROBLEMS WERE FOUND WITH THE FOLLOWING TACF'S: 2-85-50-24, 2-84-097-57, 2-84-101-64, AND 2-85-039-064. (8800 5)

OTHER ITEMS

## SYSTEMS AND COMPONENT PROBLEMS:

NONE.

## FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

## MANAGERIAL ITEMS:

+ NONE.

## PLANT STATUS:

SHUTDOWN ON SEPTEMBER 15, 1984 FOR REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: JULY 31, 1988 +

INSPECTION REPORT NO: 50-260/88-21 +

Report Period JUL 1988

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* BROWNS FERRY 2 \*  
\*\*\*\*\*

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
.....			
NONE.			
.....			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-296                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. CRAWFORD (205) 729-2507

4. Licensed Thermal Power (MWT):                      3293

5. Nameplate Rating (Gross MWe):                      1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe):                      1065

7. Maximum Dependable Capacity (Gross MWe):                      1098

8. Maximum Dependable Capacity (Net MWe):                      1065

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>100,103.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>45,306.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,149.4</u>
15. Hrs Generator On-line	<u>.0</u>	<u>.0</u>	<u>44,195.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>131,846,076</u>
18. Gross Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>43,473,760</u>
19. Net Elec Ener (MWH)	<u>-1,833</u>	<u>-15,891</u>	<u>42,026,177</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>44.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>44.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>39.4</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>39.4</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>44.8</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,111.0</u>	<u>35,848.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      BROWNS FERRY 3                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
BROWNS FERRY 3



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BROWNS FERRY 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
157	03/03/85	F	744.0	F	4			ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BROWNS FERRY 3 REMAINED ON ADMINISTRATIVE HOLD IN JULY IN ORDER TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)



ENFORCEMENT SUMMARY

WITH ASTM D3803, STANDARD TEST METHOD FOR RADIOIODINE TESTING OF NUCLEAR-GRADE GAS-PHASE ADSORBENTS. ASTM D3803 REQUIRES THAT THE FEED PERIOD DURATION AND THE ELUTION PERIOD DURATION BE 60 PLUS OR MINUS 1 MINUTES AND 240 PLUS OR MINUS 1 MINUTES RESPECTIVELY. TEST DATA CONTAINED IN THE COMPLETED SI DATA PACKAGE DOCUMENT THAT THE ACTUAL FEED DURATION WAS 90 MINUTES (THIRTY MINUTES LONGER THAN SPECIFIED) AND THE ACTUAL ELUTION TIME WAS 90 MINUTES (150 MINUTES SHORTER THAN SPECIFIED). IT IS NOTED THAT THIS IS A REPEAT VIOLATION MOST RECENTLY CITED IN INSPECTION REPORTS 50-259, 260, 296/86-11. (2) THE REQUIREMENTS OF PLANT MANAGERS INSTRUCTION 15.4 (UNIQUE REPORTING REQUIREMENTS), WERE NOT ADHERED TO IN THAT NO LICENSEE REPORTABLE EVENT DETERMINATION EVALUATION WAS INITIATED AS REQUIRED TO DETERMINE THE OPERABILITY OF THE UNIT 2 RESIDUAL HEAT REMOVAL SYSTEM LOWER CONTAINMENT SPRAY HEADER AFTER AN INSPECTION (CAQR BFP880052) REVEALED CLOGGED NOZZLES DUE TO RUST ON FEBRUARY 3, 1988. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION VI, REVISION 1 TO TEMPORARY ALTERATION CONTROL FORM (TACF) NUMBER 3-82-001-111 WAS NOT PROPERLY REVIEWED FOR ADEQUACY APPROVED FOR RELEASE, AND PROPERLY DISTRIBUTED. THE ORIGINAL TACF WAS INITIATED ON MARCH 10, 1988 WITH THE MAJORITY OF THE REVIEW AND APPROVAL AUTHORIZATIONS OBTAINED ON MARCH 13, 1988. A REVISION WAS INITIATED ON MARCH 15, 1988; HOWEVER, NOT ALL OF THE APPROVAL SIGNATURES WERE UPDATED TO REFLECT APPROVAL OF THE REVISED INFORMATION. (1) THE OPERATIONS SUPERVISOR'S CONCURRENCE SIGNATURE WAS DATED MARCH 13, 1988. (2) THE SHIFT ENGINEER'S APPROVAL OF THE TACF WAS DATED MARCH 13, 1988. (3) THE FILE CLERK MADE AND DISTRIBUTED COPIES OF THE TACF ON MARCH 15, 1988, ALTHOUGH FOUR SIGNATURES ON THE TACF WERE DATED MARCH 16, 1988. THE ABOVE INFORMATION WAS ONLY AVAILABLE ON THE ORIGINAL TACF FORM MAINTAINED IN THE SHIFT ENGINEER'S OFFICE AND WAS THE CONDITION OF THE TACF ON MARCH 17, 1988. SIMILAR PROBLEMS WERE FOUND WITH THE FOLLOWING TACF'S: 2-85-50-24, 2-84-097-57, 2-84-101-64, AND 2-85-039-064.  
(8800 5)

OTHER ITEMS

## SYSTEMS AND COMPONENT PROBLEMS:

LICENSEE EVALUATING CAUSE OF REACTOR VESSEL WATER LEVEL INDICATION PROBLEMS.

## FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

## MANAGERIAL ITEMS:

+ NONE.

## PLANT STATUS:

SHUTDOWN ON MARCH 9, 1985.

LAST IE SITE INSPECTION DATE: JULY 31, 1988 +

INSPECTION REPORT NO: 50-296/88-21 +



Report Period JUL 1988

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* BROWNS FERRY 3 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-001	06/05/88	07/01/88	DESIGN DEFICIENCY IN DIESEL GENERATOR BREAKER LOGIC PREVENTS THREE DGS FROM CONNECTING TO SHUTDOWN BOARDS DURING LOSS OF COOLANT/LOSS OF POWER TEST

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-325 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-2756

4. Licensed Thermal Power (MWT): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>99,696.0</u>
13. Hours Reactor Critical	<u>566.9</u>	<u>4,254.5</u>	<u>65,172.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,647.1</u>
15. Hrs Generator On-Line	<u>544.3</u>	<u>4,124.5</u>	<u>61,985.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,165,287</u>	<u>9,553,666</u>	<u>131,533,202</u>
18. Gross Elec Ener (MWH)	<u>371,000</u>	<u>3,129,640</u>	<u>43,239,187</u>
19. Net Elec Ener (MWH)	<u>355,311</u>	<u>3,026,417</u>	<u>41,605,549</u>
20. Unit Service Factor	<u>75.2</u>	<u>80.7</u>	<u>62.2</u>
21. Unit Avail Factor	<u>75.2</u>	<u>80.7</u>	<u>62.2</u>
22. Unit Cap Factor (MDC Net)	<u>60.5</u>	<u>75.0</u>	<u>52.8</u>
23. Unit Cap Factor (LER Net)	<u>58.2</u>	<u>72.1</u>	<u>50.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>14.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>10,619.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* BRUNSWICK 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRUNSWICK 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BRUNSWICK 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
88055	07/02/88	F	0.0	A	5			POWER REDUCTION TO PERFORM WATERBOX WORK ON MAIN CONDENSER.
88056	07/05/88	F	0.0	A	5			POWER REDUCTION FOR REPAIR OF TRANSMISSION LINE.
88057	07/10/88	S	0.0	B	5			ROD IMPROVEMENT.
88059	07/13/88	S	199.7	A	1	1-88-017		UNIT SHUT DOWN DUE TO FAILURE OF HPCI VALVE 1-E41-F001.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BRUNSWICK 1 INCURRED THREE REDUCTIONS IN POWER AND ONE OUTAGE IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

\*\*\*\*\*  
\* BRUNSWICK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
COUNTY.....BRUNSWICK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3 MI N OF  
SOUTHPORT, NC  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...OCTOBER 8, 1976  
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1976  
DATE COMMERCIAL OPERATE...MARCH 18, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...CAPE FEAR RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CAROLINA POWER & LIGHT  
CORPORATE ADDRESS.....P. O. BOX 1551  
RALEIGH, NORTH CAROLINA 27602  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BROWN & ROOT  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. RULAND  
LICENSING PROJ MANAGER.....B. BUCKLEY  
DOCKET NUMBER.....50-325  
LICENSE & DATE ISSUANCE...DPR-71, NOVEMBER 12, 1976  
PUBLIC DOCUMENT ROOM.....RANDALL LIBRARY  
UNIV OF N.C. AT WILMINGTON  
601 S. COLLEGE ROAD  
WILMINGTON, N. C. 28405

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 14-17 (88-22): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF THE SNUBBER SURVEILLANCE PROGRAM AND IEB 80-11. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING THE ADEQUACY OF QC INSPECTION PROCEDURES AND RECORDS RELATING TO PLANT MODIFICATIONS.

INSPECTION JUNE 20-24 (88-23): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF RADIATION PROTECTION INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS; TRAINING AND QUALIFICATIONS; INTERNAL EXPOSURE CONTROL; CONTROL OF RADIOACTIVE MATERIAL; SLID WASTE; TRANSPORTATION, AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE LICENSEE'S RADIATION PROTECTION PROGRAM WAS ASSESSED TO BE ADEQUATE IN THE AREAS COVERED DURING THE INSPECTION. A POSITIVE LICENSEE INITIATIVE WAS NOTED DEALING WITH THE INSTALLATION OF RADIATION MONITORING SYSTEMS BEYOND MINIMUM NRC REQUIREMENTS. THE SYSTEMS, WHICH ARE INTENDED TO REDUCE RADIATION EXPOSURE, FEATURE REMOTE RADIATION MONITORS LOCATED IN AREAS OF HIGH RADIATION BACKGROUND WHICH READ OUT AT A CENTRAL LOCATION IN AN AREA WITH LOW BACKGROUND. LICENSEE PERSONNEL CAN CHECK RADIATION LEVELS IN MONITORED AREAS BEFORE ENTERING FOR TOURS OR WORK.

ENFORCEMENT SUMMARY

CONTRARY TO TS 3.4.6, SURVEILLANCE REQUIREMENT 4.4.6.1.1, REACTOR VESSEL PRESSURE AND SHELL TEMPERATURE WERE NOT DETERMINED TO BE

ENFORCEMENT SUMMARY

WITHIN LIMITS ONCE PER 30 MINUTES DURING SYSTEM HEATUP. ON JANUARY 25, 1988, FROM 2:45 A.M. TO 4:30 A.M., A REACTOR COOLANT SYSTEM HEATUP OF ABOUT 90 DEGREES F OCCURRED WITH NO DETERMINATION AT THAT TIME THAT REACTOR VESSEL PRESSURE AND SHELL TEMPERATURES WERE WITHIN LIMITS.

CONTRARY TO 10 CFR 50.59(A)(1) AND 10 CFR 50.59(B)(1), A WRITTEN SAFETY EVALUATION PROVIDING THE BASIS FOR THE DETERMINATION THAT A CHANGE DID NOT INVOLVE AN UNREVIEWED SAFETY QUESTION WAS NOT PERFORMED. THE LICENSEE RECEIVED INFORMATION PRIOR TO UNIT 1 STARTUP ON FEBRUARY 20, 1988, THAT, WITH CERTAIN SINGLE FAILURES, NUCLEAR SERVICE WATER FLOW TO THE REACTOR BUILDING CCM HEAT EXCHANGERS WOULD NOT BE ZERO GALLONS PER MINUTE DURING THE FIRST 10 MINUTES OF A LOSS OF COOLANT ACCIDENT. A WRITTEN SAFETY EVALUATION WAS NOT COMPLETED UNTIL MARCH 22, 1988, SUBSEQUENT TO THE INSPECTION.  
(8801 4)

CONTRARY TO TS 4.6.6.2.A.2, THE CAD SYSTEM WAS NOT DEMONSTRATED TO BE OPERABLE BY VERIFYING EACH MANUAL VALVE IN THE FLOW PATH NOT LOCKED WAS IN THE CORRECT POSITION. VALVE 1-CAC-V168, A FLOW PATH VALVE, WAS OPEN AND NOT LOCKED ON AND BEFORE FEBRUARY 26, 1988, AND REQUIRED TO BE OPEN BUT NOT LOCKED BY 1-OP-24, REV. 22, CONTAINMENT ATMOSPHERE CONTROL SYSTEM OPERATING PROCEDURE. V168 WAS NOT VERIFIED IN ITS CORRECT POSITION (OPEN) BY PT-10.1, REV. 12.  
(8801 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ PLANT OPERATION AT 95% POWER.

LAST IE SITE INSPECTION DATE: JULY 31, 1988 +

INSPECTION REPORT NO: 50-325/88-24 +

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-014	06/06/88	07/06/88	NONCONSERVATIVE SETPOINTS OF STEAM LEAK DETECTION INSTRUMENTATION FOR THE RCIC SYSTEMS OF UNITS 1 AND 2 AND THE HPCI SYSTEM OF UNIT 2
88-015	06/12/88	07/08/88	AUTOMATIC ISOLATION OF UNITS 1 AND 2 COMMON CONTROL BUILDING HEATING, VENTILATING, AIR CONDITIONING SYSTEM AND EMERGENCY AIR FILTRATION SYSTEM

.....

THIS PAGE INTENTIONALLY LEFT BLANK



1. Docket: 50-324                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-2756

4. Licensed Thermal Power (MWT):                      2436

5. Nameplate Rating (Gross MWe):                      963 X 0.9 = 867

6. Design: Electrical Rating (Net MWe):                      821

7. Maximum Dependable Capacity (Gross MWe):                      815

8. Maximum Dependable Capacity (Net MWe):                      790

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>111,720.0</u>
13. Hours Reactor Critical	<u>536.6</u>	<u>2,028.0</u>	<u>69,101.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>531.7</u>	<u>1,770.9</u>	<u>65,017.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,215,057</u>	<u>3,895,000</u>	<u>130,482,479</u>
18. Gross Elec Ener (MWH)	<u>398,215</u>	<u>1,279,205</u>	<u>43,020,737</u>
19. Net Elec Ener (MWH)	<u>381,941</u>	<u>1,208,992</u>	<u>41,251,821</u>
20. Unit Service Factor	<u>71.5</u>	<u>34.6</u>	<u>58.2</u>
21. Unit Avail Factor	<u>71.5</u>	<u>34.6</u>	<u>58.2</u>
22. Unit Cap Factor (MDC Net)	<u>65.0</u>	<u>29.9</u>	<u>46.7</u>
23. Unit Cap Factor (DER Net)	<u>62.5</u>	<u>28.8</u>	<u>45.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>14.7</u>	<u>14.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>304.1</u>	<u>11,763.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      BRUNSWICK 2                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRUNSWICK 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BRUNSWICK 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
88027	07/02/88	S	0.0	B	5			ROD IMPROVEMENT AND ROUTINE VALVE TESTING.
88033	07/15/88	F	0.0	A	5			REDUCE POWER DUE TO LOW CONDENSER VACUUM (2A CIRCULATING WATER PUMP TRIPPED DUE TO CLOGGED INTAKE SCREEN).
88034	07/16/88	F	0.0	B	5			REDUCED POWER FOR PT-14.2.1, SINGLE ROD SCRAM INSERTION TIMES AND CIRCULATING WATER INTAKE TRAVELING SCREEN REPAIR.
88037	07/22/88	S	212.3	B	1			MAINTENANCE OUTAGE TO WORK ON HPCI, REACTOR RECIRCULATION, RHR, AND OTHER MAINTENANCE ITEMS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BRUNSWICK 2 INCURRED THREE POWER REDUCTIONS AND ONE OUTAGE IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
  
COUNTY.....BRUNSWICK  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3 MI N OF  
SOUTHPORT, NC  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...MARCH 20, 1975  
DATE ELEC ENER 1ST GENER...APRIL 29, 1975  
DATE COMMERCIAL OPERATE....NOVEMBER 3, 1975  
  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....CAPE FEAR RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CAROLINA POWER & LIGHT  
  
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET  
RALEIGH, NORTH CAROLINA 27602  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BROWN & ROOT  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. RULAND  
LICENSING PROJ MANAGER.....B. BUCKLEY  
DOC/ET NUMBER.....50-324  
LICENSE & DATE ISSUANCE....DPR-62, DECEMBER 27, 1974  
PUBLIC DOCUMENT ROOM.....RANDALL LIBRARY  
UNIV OF N.C. AT WILMINGTON  
601 S. COLLEGE ROAD  
WILMINGTON, N. C. 28403

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 14-17 (88-22): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF THE SNUBBER SURVEILLANCE PROGRAM AND IEB 80-11. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING THE ADEQUACY OF QC INSPECTION PROCEDURES AND RECORDS RELATING TO PLANT MODIFICATIONS.

INSPECTION JUNE 20-24 (88-25): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF RADIATION PROTECTION INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS; TRAINING AND QUALIFICATIONS; INTERNAL EXPOSURE CONTROL; CONTROL OF RADIOACTIVE MATERIAL; SOLID WASTE; TRANSPORTATION, AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE LICENSEE'S RADIATION PROTECTION PROGRAM WAS ASSESSED TO BE ADEQUATE IN THE AREAS COVERED DURING THE INSPECTION. A POSITIVE LICENSEE INITIATIVE WAS NOTED DEALING WITH THE INSTALLATION OF RADIATION MONITORING SYSTEMS BEYOND MINIMUM NRC REQUIREMENTS. THE SYSTEMS, WHICH ARE INTENDED TO REDUCE RADIATION EXPOSURE, FEATURE REMOTE RADIATION MONITORS LOCATED IN AREAS OF HIGH RADIATION BACKGROUND WHICH READ OUT AT A CENTRAL LOCATION IN AN AREA WITH LOW BACKGROUND. LICENSEE PERSONNEL CAN CHECK RADIATION LEVELS IN MONITORED AREAS BEFORE ENTERING FOR TOURS OR WORK.

ENFORCEMENT SUMMARY

NONE

Report Period JUL 1988

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* BRUNSWICK 2 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

PLANT OPERATION AT 100% POWER.

LAST IE SITE INSPECTION DATE: JULY 31, 1988 +

INSPECTION REPORT NO: 50-324/88-24 +

REPORTS FROM LICENSEE

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
.....			
NONE.			
.....			

1. Docket: 50-454                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: D. J. SPITZER (815) 234-5441 X2023

4. Licensed Thermal Power (MWT):                    3411

5. Nameplate Rating (Gross MWe):                    1175

6. Design Electrical Rating (Net MWe):                    1120

7. Maximum Dependable Capacity (Gross MWe):                    1120

8. Maximum Dependable Capacity (Net MWe):                    1105

9. If Changes Occur Above Since Last Report, Give Reasons:

\*\*\*\*\*  
 \*                    BYRON 1                    \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 BYRON 1

10. Power Level To Which Restricted, If Any (Net MWe): 1097

11. Reasons for Restrictions, If Any: \_\_\_\_\_


STEAM GENERATOR SPLIT FLOW

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>25,200.0</u>
13. Hours Reactor Critical	<u>722.4</u>	<u>4,400.0</u>	<u>19,712.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>37.8</u>
15. Hrs Generator On-Line	<u>712.2</u>	<u>4,376.1</u>	<u>19,337.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,293,717</u>	<u>13,683,531</u>	<u>57,279,382</u>
18. Gross Elec Ener (MWH)	<u>775,163</u>	<u>4,572,595</u>	<u>19,198,372</u>
19. Net Elec Ener (MWH)	<u>734,398</u>	<u>4,314,826</u>	<u>18,054,303</u>
20. Unit Service Factor	<u>95.7</u>	<u>85.6</u>	<u>76.7</u>
21. Unit Avail Factor	<u>95.7</u>	<u>85.6</u>	<u>76.7</u>
22. Unit Cap Factor (MDC Net)	<u>89.3</u>	<u>75.5</u>	<u>64.8</u>
23. Unit Cap Factor (DER Net)	<u>88.1</u>	<u>75.4</u>	<u>64.0</u>
24. Unit Forced Outage Rate	<u>4.3</u>	<u>2.2</u>	<u>5.0</u>
25. Forced Outage Hours	<u>31.8</u>	<u>97.1</u>	<u>1,009.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING - 09/03/88.

27. If Currently Shutdown Estimated Startup Date: N/A



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BYRON 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9	07/16/88	F	31.8	A	3		FW	1BFWPP	1B FW PUMP TRIPPED CAUSING STEAM GENERATOR LEVELS TO GO TO THE LO-LO SETPOINT WHICH CAUSED THE REACTOR TRIP.

\*\*\*\*\* BYRON 1 INCURRED ONE FORCED OUTAGE IN JULY FOR REASONS STATED ABOVE.  
 \* SUMMARY \*  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Prohibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licence Event Report
	& License Examination	9-Other	(LEF (NUREG-0161))

\*\*\*\*\*  
\* BYRON 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....OGLE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI SW OF  
ROCKFORD, ILL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...FEBRUARY 2, 1985  
DATE ELEC ENER 1ST GENER...MARCH 1, 1985  
DATE COMMERCIAL OPERATE...SEPTEMBER 16, 1985  
CONDENSER COOLING METHOD...CC HNDCT  
CONDENSER COOLING WATER...ROCK RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STFAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. HINDS  
LICENSING PROJ MANAGER....L. OLSHAN  
DOCKET NUMBER.....50-454  
LICENSE & DATE ISSUANCE...NPF-37, FEBRUARY 14, 1985  
PUBLIC DOCUMENT ROOM.....LIBRARIAN  
BUSINESS SCIENCE & TECHNOLOGY DEPT.  
ROCKFORD PUBLIC LIBRARY  
215 NORTH WYMAN STREET  
ROCKFORD, ILLINOIS 61101

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION FROM MAY 17 THROUGH JUNE 30 (88009; 88009): ROUTINE, UNANNOUNCED SAFETY INSPECTION BY THE RESIDENT INSPECTORS AND A REGION-BASED INSPECTOR OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; LICENSEE EVENT REPORTS; BULLETINS; GENERIC LETTERS; OPERATIONS SUMMARY; TRAINING; SPENT FUEL STORAGE RACKS; SURVEILLANCE; MAINTENANCE; OPERATIONAL SAFETY; AND EVENT FOLLOWUP. OF THE 10 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 9 AREAS; 2 VIOLATIONS WERE IDENTIFIED IN THE REMAINING AREA (FAILURE TO ESTABLISH AND IMPLEMENT ADEQUATE PROCEDURES FOR THE FIRE PROTECTION PROGRAM; FAILURE TO MAINTAIN AN AUXILIARY FEEDWATER PUMP OPERABLE DURING OPERATIONAL MODE CHANGES. HOWEVER, IN ACCORDANCE WITH 10 CFR 2, APPENDIX C, SECTION V.G.1, A NOTICE OF VIOLATION WAS NOT ISSUED FOR THE SECOND VIOLATION.

INSPECTION BETWEEN JUNE 23 AND JULY 1 (88010; 88010): INCLUDED A REVIEW OF MANAGEMENT EFFECTIVENESS-SECURITY; SECURITY PROGRAM AUDITS; TESTING AND MAINTENANCE; VITAL AREA-BARRIERS AND ALARMS; COMPENSATORY MEASURES; ACCESS CONTROL-PERSONNEL; PACKAGES, AND VEHICLES; COMMUNICATIONS; AND FOLLOWUP ON PREVIOUS INSPECTION FINDINGS. THE EFFECTIVENESS OF THE TRANSITION PROCESS FOR THE CHANGE IN THE CONTRACTOR SECURITY FORCE WAS ALSO REVIEWED. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED, EXCEPT AS NOTED BELOW: ACCESS CONTROL VEHICLES: THE DESIGNATED VEHICLE PROGRAM WAS NOT ADEQUATELY MONITORED.

Report Period JUL 1988

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* BYRON 1 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

LOW LEVEL OF ROCK RIVER NECESSITATES PERIODIC MONITORING TO APPROXIMATELY 75% POWER BECAUSE TOTAL STATION OUTPUT IS LIMITED BY WATER FLOW IN SUPPORT OF ULTIMATE HEAT SINK CONSIDERATIONS. LIMITED DUE TO DISABLED GRID STABILITY TRIPS.

MANAGERIAL ITEMS:

PLANT STATUS:

LAST IE SITE INSPECTION DATE: 07/01/88

INSPECTION REPORT NO: 88010

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-03	061388	072088	ESSENTIAL SERVICE WATER MAKEUP PUMP INOPERABLE GREATER THAN 72 HOURS DUE TO ERRONEOUS ELECTRICAL DISTRIBUTION DATA



1. Docket: 50-455 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: D. J. SPITZER (815)234-5441 X2023  
 4. Licensed Normal Power (MWT): 3411  
 5. Nameplate Rating (Gross MWe): 1175  
 6. Design Electrical Rating (Net MWe): 1120  
 7. Maximum Dependable Capacity (Gross MWe): 1120  
 8. Maximum Dependable Capacity (Net MWe): 1105  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): 1055  
 11. Reasons for Restrictions, If Any:

STEAM GENERATOR SPLIT FLOW

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>8,304.0</u>
13. Hours Reactor Critical	<u>707.3</u>	<u>5,017.9</u>	<u>7,345.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>700.5</u>	<u>4,767.2</u>	<u>7,047.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,041,982</u>	<u>13,802,725</u>	<u>20,274,888</u>
18. Gross Elec Ener (MWH)	<u>686,051</u>	<u>4,634,973</u>	<u>6,739,284</u>
19. Net Elec Ener (MWH)	<u>647,496</u>	<u>4,371,373</u>	<u>6,342,274</u>
20. Unit Service Factor	<u>94.2</u>	<u>93.3</u>	<u>84.9</u>
21. Unit Avail Factor	<u>94.2</u>	<u>93.3</u>	<u>84.9</u>
22. Unit Cap Factor (MDC Net)	<u>78.8</u>	<u>76.5</u>	<u>69.1</u>
23. Unit Cap Factor (DER Net)	<u>77.7</u>	<u>76.4</u>	<u>68.2</u>
24. Unit Forced Outage Rate	<u>5.8</u>	<u>3.2</u>	<u>5.9</u>
25. Forced Outage Hours	<u>43.5</u>	<u>156.2</u>	<u>444.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - 1/7/89

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 X BYRON 2 X  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BYRON 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BYRON 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
12	07/05/88	S	0.0	H	5				UNIT 2 RAMPED DOWN PER SP50.
13	07/14/88	F	22.8	A	3		FW	2CFWPP	REACTOR TRIP DUE TO LOSS OF 2C FW PUMP ON LOSS OF 4KV BUS 243, AF ACTUATION.
14	07/15/88	F	20.7	A	3		FW	2FW039	VALVES FAILED TO OPEN CAUSING STEAM GENERATOR LEVEL TO DECREASE CAUSING REACTOR TRIP AT LO-LO SETPOINT.
15	07/30/88	S	0.0	H	5				LOAD REDUCED TO ALLOW CONDENSER CLEANING.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BYRON 2 INCURRED TWO POWER REDUCTIONS AND TWO FORCED OUTAGES  
 IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BYRON 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....OGLE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI SW OF  
ROCKFORD, ILL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JANUARY 9, 1987  
DATE ELEC ENER 1ST GENER...FEBRUARY 6, 1987  
DATE COMMERCIAL OPERATE...AUGUST 21, 1987  
CONDENSER COOLING METHOD...CCHNDCT  
CONDENSER COOLING WATER...ROCK RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. HINDS  
LICENSING PROJ MANAGER.....L. OLSHAN  
DOCKET NUMBER.....50-455  
LICENSE & DATE ISSUANCE...NPF-66, JANUARY 30, 1987  
PUBLIC DOCUMENT ROOM.....LIBRARIAN  
BUSINESS SCIENCE & TECHNOLOGY DEPT.  
ROCKFORD PUBLIC LIBRARY  
215 NORTH WYMAN STREET  
ROCKFORD, ILLINOIS 61101

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION FROM MAY 17 THROUGH JUNE 30 (88009; 88009): ROUTINE, UNANNOUNCED SAFETY INSPECTION BY THE RESIDENT INSPECTORS AND A REGION-BASED INSPECTOR OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; LICENSEE EVENT REPORTS; BULLETINS; GENERIC LETTERS; OPERATIONS SUMMARY; TRAINING; SPENT FUEL STORAGE RACKS; SURVEILLANCE; MAINTENANCE; OPERATIONAL SAFETY; AND EVENT FOLLOWUP. OF THE 10 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 9 AREAS; 2 VIOLATIONS WERE IDENTIFIED IN THE REMAINING AREA (FAILURE TO ESTABLISH AND IMPLEMENT ADEQUATE PROCEDURES FOR THE FIRE PROTECTION PROGRAM; FAILURE TO MAINTAIN AN AUXILIARY FEEDWATER PUMP OPERABLE DURING OPERATIONAL MODE CHANGES. HOWEVER, IN ACCORDANCE WITH 10 CFR 2, APPENDIX C, SECTION V.G.1, A NOTICE OF VIOLATION WAS NOT ISSUED FOR THE SECOND VIOLATION.

INSPECTION BETWEEN JUNE 23 AND JULY 1 (88010; 88010): INCLUDED A REVIEW OF MANAGEMENT EFFECTIVENESS-SECURITY; SECURITY PROGRAM AUDITS; TESTING AND MAINTENANCE; VITAL AREA-BARRIERS AND ALARMS; COMPENSATORY MEASURES; ACCESS CONTROL-PERSONNEL, PACKAGES, AND VEHICLES; COMMUNICATIONS; AND FOLLOWUP ON PREVIOUS INSPECTION FINDINGS. THE EFFECTIVENESS OF THE TRANSITION PROCESS FOR THE CHANGE IN THE CONTRACTOR SECURITY FORCE WAS ALSO REVIEWED. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED, EXCEPT AS NOTED BELOW: ACCESS CONTROL VEHICLES: THE DESIGNATED VEHICLE PROGRAM WAS NOT ADEQUATELY MONITORED.



1. Docket: 50-483 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: MARY DALY (314) 676-8460

4. Licensed Thermal Power (Mwt): 3565

5. Nameplate Rating (Gross MWe): 1373 X .9 = 1236

6. Design Electrical Rating (Net MWe): 1171

7. Maximum Dependable Capacity (Gross MWe): 1174

8. Maximum Dependable Capacity (Net MWe): 1120

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>31,693.5</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,704.3</u>	<u>26,702.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,651.0</u>	<u>26,106.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,624,336</u>	<u>15,898,058</u>	<u>84,187,838</u>
18. Gross Elec Ener (MWH)	<u>889,139</u>	<u>5,410,093</u>	<u>28,451,813</u>
19. Net Elec Ener (MWH)	<u>848,646</u>	<u>5,149,904</u>	<u>27,039,580</u>
20. Unit Service Factor	<u>100.0</u>	<u>91.0</u>	<u>82.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>91.0</u>	<u>82.4</u>
22. Unit Cap Factor (MDC Net)	<u>101.8</u>	<u>90.0</u>	<u>76.2</u>
23. Unit Cap Factor (DER Net)	<u>97.4</u>	<u>86.0</u>	<u>72.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.9</u>	<u>4.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>240.6</u>	<u>1,144.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* CALLAWAY 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALLAWAY 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* CALLAWAY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
14	07/08/88	F	0.0	A	S				TURBINE RUNBACK DUE TO 'B' CIRCULATING WATER PUMP TRIP ON HIGH STATOR TEMPERATURE.
15	07/21/88	S	0.0	A	S				DERATE TO REPAIR SEAL RETURN LINE ON THE 'B' CONDENSATE PUMP.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
CALLAWAY 1 INCURRED TWO POWER REDUCTIONS IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)



Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
\*                   CALLAWAY 1                   \*  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

LAST IE SITE INSPECTION DATE: 05/25/88

INSPECTION REPORT NO: 88013

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-08	063088	072888	SAMPLING NOT PERFORMED FOR AN INOPERBLE RADIATION MONITOR DUE TO A CIRCUIT BOARD FAILURE THAT PREVENTED DETECTION OF THE CONDITION

=====



1. Docket: 50-317 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: C. BEHNKE (301) 260-4871  
 4. Licensed Thermal Power (MWT): 2700  
 5. Nameplate Rating (Gross MWe): 1020 X 0.9 = 918  
 6. Design Electrical Rating (Net MWe): 880  
 7. Maximum Dependable Capacity (Gross MWe): 860  
 8. Maximum Dependable Capacity (Net MWe): 825  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>116,004.0</u>
13. Hours Reactor Critical	<u>691.8</u>	<u>3,070.1</u>	<u>89,457.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,299.2</u>
15. Hrs Generator On-Line	<u>608.3</u>	<u>2,959.6</u>	<u>87,412.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,443,521</u>	<u>7,543,066</u>	<u>219,617,784</u>
18. Gross Elec Ener (MWH)	<u>474,746</u>	<u>2,526,226</u>	<u>72,741,827</u>
19. Net Elec Ener (MWH)	<u>451,157</u>	<u>2,418,888</u>	<u>69,434,405</u>
20. Unit Service Factor	<u>81.8</u>	<u>57.9</u>	<u>75.4</u>
21. Unit Avail Factor	<u>81.8</u>	<u>57.9</u>	<u>75.4</u>
22. Unit Cap Factor (MDC Net)	<u>73.5</u>	<u>57.4</u>	<u>72.6</u>
23. Unit Cap Factor (DER Net)	<u>68.9</u>	<u>55.0</u>	<u>68.0</u>
24. Unit Forced Outage Rate	<u>10.0</u>	<u>3.1</u>	<u>9.1</u>
25. Forced Outage Hours	<u>67.6</u>	<u>93.2</u>	<u>8,675.4</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* CALVERT CLIFFS 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALVERT CLIFFS 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* CALVERT CLIFFS 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-02	04/09/88	S	65.9	C	4				CONTINUED SHUTDOWN FOR REFUELING OPERATIONS.
88-06	07/03/88	F	13.3	H	9		HA	MECFUN	BREAKER OPENED DUE TO TURBINE BEARING #11 HIGH VIBRATION. CORRECTED BY REMOVING RUBBER SPACERS INSTALLED IN COUPLING PER GENERAL ELECTRIC T.I.L. #815(8/31/76).
88-07	07/04/88	S	2.2	B	1				BREAKER OPENED FOR SCHEDULED TURBINE OVERSPEED TESTING.
88-08	07/15/88	F	54.3	B	3	88-006	HH	INSTRU	TRIP CAUSED BY IMPROPERLY ISOLATED LEVEL SWITCHES ON #12C FEEDWATER HEATER DUE TO UNCLEAR MAINTENANCE PROCEDURE INSTRUCTIONS.
88-09	07/29/88	F	0.0	B	5		WE	HTEXCH	REDUCED POWER TO CLEAN WATERBOXES AND REPAIR OIL LEAKS ON #12 S/G FEED PUMP.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

CALVERT CLIFFS 1 ENTERED JULY SHUTDOWN FOR REFUELING OPERATIONS. SUBSEQUENTLY, RETURNED TO POWER AND INCURRED 3 OUTAGES AND ONE LOAD REDUCTION DURING THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

\*\*\*\*\*  
\* CALVERT CLIFFS 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MARYLAND  
COUNTY.....CALVERT  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI S OF  
ANNAPOLIS, MD  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 7, 1974  
DATE ELEC ENER 1ST GENER...DECEMBER 30, 1974  
DATE COMMERCIAL OPERATE...MAY 8, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...CHESAPEAKE BAY  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....BALTIMORE GAS & ELEC  
CORPORATE ADDRESS.....P.O. BOX 1475  
BALTIMORE, MARYLAND 21203  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....D. TRIMBLE  
LICENSING PROJ MANAGER.....S. MCNEIL  
DOCKET NUMBER.....50-317  
LICENSE & DATE ISSUANCE...DPR-53, JULY 31, 1974  
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY  
FOURTH STREET  
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*            CALVERT CLIFFS 1            \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVLNT	DATE OF REPORT	SUBJECT
-----			
NO INPUT PROVIDED.			

=====

1. Docket: 50-318 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: C. BEHNKE (301) 260-4871

4. Licensed Thermal Power (Mwt): 2700

5. Nameplate Rating (Gross MWe): 1012 X 0.9 = 911

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>99,359.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,154.1</u>	<u>81,997.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,296.8</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,142.2</u>	<u>80,822.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,991,386</u>	<u>10,986,459</u>	<u>204,327,122</u>
18. Gross Elec Ener (MWH)	<u>653,263</u>	<u>3,681,386</u>	<u>67,569,522</u>
19. Net Elec Ener (MWH)	<u>626,084</u>	<u>3,532,669</u>	<u>64,521,566</u>
20. Unit Service Factor	<u>100.0</u>	<u>81.0</u>	<u>81.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>81.0</u>	<u>81.3</u>
22. Unit Cap Factor (MDC Net)	<u>102.0</u>	<u>83.8</u>	<u>78.7</u>
23. Unit Cap Factor (DER Net)	<u>99.6</u>	<u>81.8</u>	<u>76.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.2</u>	<u>5.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>135.1</u>	<u>4,707.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* CALVERT CLIFFS 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALVERT CLIFFS 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* CALVERT CLIFFS 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
CALVERT CLIFFS 2 OPERATED ROUTINELY DURING JULY WITH NO OUTAGES  
OR SIGNIFICANT LOAD REDUCTIONS.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* CALVERT CLIFFS 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MARYLAND  
COUNTY.....CALVERT  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI S OF  
ANNAPOLIS, MD  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 30, 1976  
DATE ELEC ENER 1ST GENER...DECEMBER 7, 1976  
DATE COMMERCIAL OPERATE...APRIL 1, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...CHESAPEAKE BAY  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....BALTIMORE GAS & ELEC  
CORPORATE ADDRESS.....P.O. BOX 1475  
BALTIMORE, MARYLAND 21203  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....D. TRIMBLE  
LICENSING PROJ MANAGER.....S. MCNEIL  
DOCKET NUMBER.....50-318  
LICENSE & DATE ISSUANCE...DPR-69, NOVEMBER 30, 1976  
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY  
FOURTH STREET  
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====



1. Docket: 50-413 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: J. A. REAVIS (704) 373-7567  
 4. Licensed Thermal Power (Mwt): 3411  
 5. Nameplate Rating (Gross MWe): 1305  
 6. Design Electrical Rating (Net MWe): 1145  
 7. Maximum Dependable Capacity (Gross MWe): 1145  
 8. Maximum Dependable Capacity (Net MWe): 1129  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	744.0	5,111.0	27,096.0
13. Hours Reactor Critical	744.0	4,824.8	19,938.8
14. Rx Reserve Shtdwn Hrs	.0	.0	.0
15. Hrs Generator On-Line	744.0	4,781.6	19,380.9
16. Unit Reserve Shtdwn Hrs	.0	.0	.0
17. Gross Therm Ener (MWH)	2,448,271	15,584,778	61,639,642
18. Gross Elec Ener (MWH)	862,849	5,527,202	21,618,324
19. Net Elec Ener (MWH)	816,381	5,220,787	20,221,632
20. Unit Service Factor	100.0	93.6	71.5
21. Unit Avail Factor	100.0	93.6	71.5
22. Unit Cap Factor (MDC Net)	97.2	90.5	66.1
23. Unit Cap Factor (DER Net)	95.8	89.2	65.2
24. Unit Forced Outage Rate	.0	6.4	15.6
25. Forced Outage Hours	.0	328.9	3,588.0

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - NOVEMBER 21, 1988 - 8 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
 X CATAWBA 1 X  
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CATAWBA 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* CATAWBA 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
40-P	07/19/88	F	0.0	F	5		HG	XXXXXX	FEEDWATER SYSTEM CHEMISTRY OUT OF SPEC.
41-P	07/19/88	F	0.0	F	5		HG	XXXXXX	FEEDWATER SYSTEM CHEMISTRY OUT OF SPEC.
42-P	07/19/88	F	0.0	F	5		HG	XXXXXX	FEEDWATER CHEMISTRY OUT OF SPEC.
43-P	07/19/88	F	0.0	H	5		NH	PUMPXX	HOLD POWER TO PLACE '1A' FEEDWATER PUMP IN SERVICE.
44-P	07/19/88	S	0.0	B	5		IF	XXXXXX	ADJUSTMENT OF K' FLUX TRIP SETPOINT.
45-P	07/20/88	S	0.0	B	5		IE	INSTRU	NUCLEAR INSTRUMENTATION ON CALIBRATION.
46-P	07/23/88	F	0.0	A	5		HJ	PUMPXX	REDUCE POWER TO REMOVE '1C2' HEATER DRAIN PUMP FROM SERVICE.
47-P	07/24/88	F	0.0	A	5		HJ	VALVEX	REDUCE POWER DUE TO '1C2' HEATER DRAIN PUMP RECIRC CONTROL VALVE CYCLING.
48-P	07/26/88	F	0.0	A	5		HJ	CKTBKR	REDUCTION DUE TO '1C2' HEATER DRAIN PUMP BREAKER FAILURE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 CATAWBA 1 INCURRED SEVERAL LOAD REDUCTIONS DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* CATAHBA 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....YORK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...6 MI NNW OF  
ROCK HILL, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JANUARY 7, 1985  
DATE ELEC ENER 1ST GENER...JANUARY 22, 1985  
DATE COMMERCIAL OPERATE...JUNE 29, 1985  
CONDENSER COOLING METHOD...MDCT  
CONDENSER COOLING WATER....LAKE WYLIE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE POWER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....P. SKINNER  
LICENSING PROJ MANAGER....K. JABBOUR  
DOCKET NUMBER.....50-413  
LICENSE & DATE ISSUANCE...NPF-35, JANUARY 17, 1985  
PUBLIC DOCUMENT ROOM.....YORK COUNTY LIBRARY  
138 E. BLACK STREET  
ROCK HILL, SOUTH CAROLINA 29730

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 26 - JUNE 25 (88-22): THIS ROUTINE, RESIDENT INSPECTION WAS CONDUCTED ON SITE INSPECTING IN THE AREAS OF REVIEW OF PLANT OPERATIONS; SURVEILLANCE OBSERVATION; MAINTENANCE OBSERVATION; REVIEW OF LICENSEE NONROUTINE EVENT REPORTS; AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. LICENSEE PROGRAMS COVERED BY THIS INSPECTION WERE OBSERVED TO BE ADEQUATE. WITHIN THE AREAS INSPECTED THE FOLLOWING VIOLATION WAS IDENTIFIED: FAILURE TO FOLLOW REQUIREMENTS FOR OVERTIME. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING POTENTIAL INADEQUATE VENTING OF ECCS SYSTEMS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   ~   (CONTINUED)

\*\*\*\*\*  
\*                   CATANBA 1                   \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NONE.

LAST IE SITE INSPECTION DATE: JULY 29, 1988 +

INSPECTION REPORT NO: 50-413/88-28 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			
=====			

1. Docket: 50-414 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: J. A. REAVIS (704) 373-7567  
 4. Licensed Thermal Power (Mwt): 3411  
 5. Nameplate Rating (Gross MWe): 1505  
 6. Design Electrical Rating (Net MWe): 1145  
 7. Maximum Dependable Capacity (Gross MWe): 1145  
 8. Maximum Dependable Capacity (Net MWe): 1129  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>17,112.0</u>
13. Hours Reactor Critical	<u>645.0</u>	<u>2,897.6</u>	<u>11,503.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>608.8</u>	<u>2,734.7</u>	<u>11,079.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,892,358</u>	<u>7,754,761</u>	<u>33,482,254</u>
18. Gross Elec Ener (MWH)	<u>659,346</u>	<u>2,696,799</u>	<u>11,773,827</u>
19. Net Elec Ener (MWH)	<u>616,579</u>	<u>2,474,765</u>	<u>10,941,462</u>
20. Unit Service Factor	<u>81.8</u>	<u>53.5</u>	<u>64.7</u>
21. Unit Avail Factor	<u>81.8</u>	<u>53.5</u>	<u>64.7</u>
22. Unit Cap Factor (MDC Net)	<u>73.4</u>	<u>42.9</u>	<u>56.6</u>
23. Unit Cap Factor (DER Net)	<u>72.4</u>	<u>42.3</u>	<u>55.8</u>
24. Unit Forced Outage Rate	<u>18.2</u>	<u>21.4</u>	<u>27.2</u>
25. Forced Outage Hours	<u>135.2</u>	<u>743.8</u>	<u>4,137.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* CATAWBA 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CATAWBA 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* CATAWBA 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
67-P	07/01/88	F	0.0	A	5		HJ	PUMPXX	REDUCE POWER FOR REMOVAL OF '2C2' HEATER DRAIN PUMP FROM SERVICE FOR REPAIRS.
68-P	07/02/88	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCHER REQUEST
69-P	07/05/88	S	0.0	B	5		IE	INSTRU	NUCLEAR INSTRUMENTATION CALIBRATION.
70-P	07/06/88	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCHER REQUEST.
71-P	07/16/88	F	0.0	A	5		CG	PUMPXX	HYDROGEN BUBBLE IN CENTRIFUGAL CHARGING PUMP '2A'.
16	07/17/88	F	134.6	A	2		CG	PUMPXX	CENTRIFUGAL CHARGING PUMP REPAIR.
17	07/22/88	F	0.6	A	3		EE	CKTBKR	GENERATOR BREAKER TRIP DUE TO SPURIOUS ANTI-MOTING RELAY ACTUATION.
72-P	07/23/88	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCHER REQUEST.
73-P	07/23/88	S	0.0	B	5		IE	INSTRU	HOLDING POWER FOR NUCLEAR INSTRUMENTATION CALIBRATION.
74-P	07/23/88	S	0.0	B	5		HB	VALVEX	HOLDING POWER FOR CONTROL VALVE MOVEMENT TEST.
77-P	07/24/88	F	0.0	A	5		HJ	PUMPXX	REDUCTION DUE TO '2C1' HEATER DRAIN PUMP SEAL REPLACEMENT.
78-P	07/25/88	S	0.0	B	5		HB	VALVEX	POWER REDUCTION DUE TO CONTROL VALVE MOVEMENT TEST.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 CATAWBA 2 INCURRED TWO FORCED OUTAGES AND SEVERAL LOAD REDUCTIONS DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Ma:nt or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....YORK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...6 MI NNW OF  
ROCK HILL, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 8, 1986  
DATE ELEC ENER 1ST GENER...MAY 18, 1986  
DATE COMMERCIAL OPERATE...AUGUST 19, 1986  
CONDENSER COOLING METHOD...HNDCT  
CONDENSER COOLING WATER...LAKE WYLIE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....POWER BLDG., BOX 2178  
CHARLOTTE, NORTH CAROLINA 28201  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE POWER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....P. SKINNER  
LICENSING PROJ MANAGER.....K. JABBOUR  
DOCKET NUMBER.....50-414  
LICENSE & DATE ISSUANCE...NPF-52, MAY 15, 1986  
PUBLIC DOCUMENT ROOM.....YORK COUNTY LIBRARY  
138 E. BLACK STREET  
ROCK HILL, SOUTH CAROLINA 29730

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

\* INSPECTION MAY 26 - JUNE 25 (88-22): THIS ROUTINE, RESIDENT INSPECTION WAS CONDUCTED ON SITE INSPECTING IN THE AREAS OF REVIEW OF PLANT OPERATIONS; SURVEILLANCE OBSERVATION; MAINTENANCE OBSERVATION; REVIEW OF LICENSEE NONROUTINE EVENT REPORTS; AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. LICENSEE PROGRAMS COVERED BY THIS INSPECTION WERE OBSERVED TO BE ADEQUATE. WITHIN THE AREAS INSPECTED THE FOLLOWING VIOLATION WAS IDENTIFIED: FAILURE TO FOLLOW REQUIREMENTS FOR OVERTIME. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING POTENTIAL INADEQUATE VENT. OF ECCS SYSTEMS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.





1. Docket: 50-461 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: F.A. SPANGENBERG (217)935-8881 X3400

4. Licensed Thermal Power (Mwt): 2894

5. Nameplate Rating (Gross MWe): \_\_\_\_\_

6. Design Electrical Rating (Net MWe): 933

7. Maximum Dependable Capacity (Gross MWe): 933

8. Maximum Dependable Capacity (Net MWe): 930

9. If Changes Occur Above Since Last Report, Give Reasons:

\*\*\*\*\*  
 \* CLINTON 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CLINTON 1

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_


NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>6,009.3</u>
13. Hours Reactor Critical	<u>716.5</u>	<u>3,992.0</u>	<u>4,897.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>710.2</u>	<u>3,897.7</u>	<u>4,796.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,870,592</u>	<u>12,414,795</u>	<u>12,560,295</u>
18. Gross Elec Ener (MWH)	<u>611,611</u>	<u>3,450,858</u>	<u>4,167,508</u>
19. Net Elec Ener (MWH)	<u>582,150</u>	<u>3,220,230</u>	<u>3,974,333</u>
20. Unit Service Factor	<u>95.5</u>	<u>76.3</u>	<u>79.8</u>
21. Unit Avail Factor	<u>95.5</u>	<u>76.3</u>	<u>79.8</u>
22. Unit Cap Factor (MDC Net)	<u>84.1</u>	<u>69.2</u>	<u>71.1</u>
23. Unit Cap Factor (DER Net)	<u>83.9</u>	<u>69.0</u>	<u>70.9</u>
24. Unit Forced Outage Rate	<u>4.5</u>	<u>4.4</u>	<u>3.6</u>
25. Forced Outage Hours	<u>33.8</u>	<u>180.8</u>	<u>180.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUEL OUTAGE, 01/03/89, 69 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* CLINTON 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
17	07/12/88	F	33.8	A	2			A FAILURE OF ELECTRICAL COMPONENTS IN THE CONDENSER PIT HIGH WATER LEVEL PUMP TRIP CIRCUIT CAUSED ALL THREE CIRCULATING WATER PUMPS TO TRIP EVEN THOUGH NO HIGH LEVEL EXISTED. THE LOSS OF CIRCULATING WATER TO THE CONDENSER CAUSED CONDENSER VACUUM TO DECREASE RAPIDLY PROMPTING THE REACTOR OPERATOR TO MANUALLY SCRAM THE REACTOR.
18	07/28/88	F	0.0	G	5			LOST FEED WATER HEATERS 1A, 2A, 3A, 4A, 5A, 6A, AND 6B DUE TO ATTEMPTING TO CHANGE LEVEL CONTROL OF FLASH TANK 1A FROM NORMAL TO EMERGENCY CONTROL FOR CONTROL AND INSTRUMENTATION WORK ON THE FLASH TANK VALVE CONTROLLER. REDUCED POWER TO APPROXIMATELY 70% TO COMPENSATE FOR THE REDUCED FEED WATER TEMPERATURE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 CLINTON 1 INCURRED ONE POWER REDUCTION AND ONE FORCED OUTAGE IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

\*\*\*\*\*  
\* CLINTON 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....DE WITT  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...6 MI E OF  
CLINTON, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...FEBRUARY 27, 1987  
DATE ELEC ENER 1ST GENER...APRIL 24, 1987  
DATE COMMERCIAL OPERATE...NOVEMBER 24, 1987  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....SALT CREEK  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ILLINOIS POWER  
CORPORATE ADDRESS.....500 SOUTH 27TH STREET  
DECATUR, ILLINOIS 62525  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BALDWIN ASSOCIATES  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....P. MILAND  
LICENSING PROJ MANAGER.....J. STEVENS  
DOCKET NUMBER.....50-461  
LICENSE & DATE ISSUANCE...NPF-62, APRIL 17, 1987  
PUBLIC DOCUMENT ROOM.....VESPASIAN WARNER PUBLIC LIBRARY  
120 WEST JOHNSON ST.  
CLINTON, IL. 61727

I N S P E C T I O N    S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:



1. Docket: 50-315 OPERATING STATUS
2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: HIRSCH (616) 465-5961
4. Licensed Thermal Power (Mwt): 3250
5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152
6. Design Electrical Rating (Net MWe): 1030
7. Maximum Dependable Capacity (Gross MWe): 1056
8. Maximum Dependable Capacity (Net MWe): 1020
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe): 920
11. Reasons for Restrictions, If Any: \_\_\_\_\_

ADMINISTRATIVE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>119,063.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,058.3</u>	<u>86,895.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>463.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,046.0</u>	<u>85,283.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>321.0</u>
17. Gross Therm Ener (MWH)	<u>2,182,564</u>	<u>14,497,913</u>	<u>247,489,283</u>
18. Gross Elec Ener (MWH)	<u>694,150</u>	<u>4,700,190</u>	<u>80,844,860</u>
19. Net Elec Ener (MWH)	<u>667,090</u>	<u>4,517,257</u>	<u>77,748,255</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.7</u>	<u>72.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.7</u>	<u>72.9</u>
22. Unit Cap Factor (MDC Net)	<u>87.9</u>	<u>86.7</u>	<u>65.1</u>
23. Unit Cap Factor (DER Net)	<u>87.1</u>	<u>85.8</u>	<u>63.0</u>
24. Unit Forced Outage Ratio	<u>.0</u>	<u>.5</u>	<u>7.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>26.5</u>	<u>6,644.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X COOK 1 X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOK 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* COOK 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
COOK 1 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR SIGNIFICANT  
POWER REDUCTIONS WHILE OPERATING AT AN ADMINISTRATIVE POWER  
LIMIT OF 90%.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Main' or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* COOK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
COUNTY.....BERRIEN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI S OF  
BENTON HARBOR, MI  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JANUARY 18, 1975  
DATE ELEC ENER 15% GENER...FEBRUARY 10, 1975  
DATE COMMERCIAL OPERATE...AUGUST 27, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....INDIANA MICHIGAN POWER CO.  
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA  
COLUMBUS, OHIO 43216  
CONTRACTOR  
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....AMERICAN ELEC. POWER SERVICE CORP.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....B. JORGENSEN  
LICENSING PROJ MANAGER.....J. STANG  
DOCKET NUMBER.....50-315  
LICENSE & DATE ISSUANCE...DPR-58, OCTOBER 25, 1974  
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY  
500 MARKET STREET  
ST. JOSEPH, MICHIGAN 49085

INSPECTION STATUS

INSPECTION SUMMARY

RESIDENT INSPECTORS OF: ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS; PLANT OPERATIONS; RADIOLOGICAL CONTROLS; MAINTENANCE; SURVEILLANCE; FIRE PROTECTION; SECURITY; OUTAGES; REPORTABLE EVENTS; BULLETINS AND NOTICES; NRC REGION III REQUESTS; TRAINING AND QUALIFICATION EFFECTIVENESS; MANAGEMENT MEETING; AND MEETING AMONG NRC AND COMMUNITY LEADERS. ONE SAFETY ISSUES MANAGEMENT SYSTEM (SIMS) ITEM (BULLETIN 88-01, MULTI-PLANT ACTION MPA NO. B100) WAS REVIEWED DURING THIS INSPECTION. OF THE 14 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 13 AREAS. ONE VIOLATION WAS IDENTIFIED (FAILURE TO FOLLOW PROCEDURE) IN THE REMAINING AREA. MISCELLANEOUS MAJOR WEAKNESSES WERE NOTED WHICH HAD IN COMMON THE FACT THEY INVOLVED CLEANLY "WRAPPING UP" ACTIVITIES (E.G., COMPLETE/ACCURATE PAPERWORK, JOBSITE CLEANUP AND HURRYING AT STEP-OFF PADS). A STRENGTH NOTED DURING THE INSPECTION WAS TIMELY MANAGEMENT INVOLVEMENT IN ITEMS IDENTIFIED AS PROBLEMS OR POTENTIAL PROBLEMS, SUCH AS ALARA REEXAMINATION OF ONGOING JOBS, THOROUGH UPGRADE OF A WEAK MAINTENANCE PROCEDURE, AND STRONG PURSUIT OF MAINTENANCE OBSERVATIONS (PUMP BEARING/OIL) AND TESTING QUESTIONS (THIMBLE TUBES, SEISMIC MONITORS, AND TREVITEST METHOD).

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION III, AS IMPLEMENTED BY THE D.C. COOK OPERATIONS QUALITY ASSURANCE PROGRAM, REQUIRES THAT DESIGN CONTROL MEASURES BE PROVIDED FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN, INCLUDING DESIGN CHANGES. CONTRARY TO THE ABOVE, THE LICENSEE FAILED TO ENSURE THAT ADEQUATE DESIGN CONTROL MEASURES WERE PROVIDED AS FOLLOWS: (A) THE LICENSEE FAILED TO PERFORM ADEQUATE INITIAL DESIGN REVIEWS REGARDING ELECTRICAL ISOLATION BETWEEN THE LOCAL SHUTDOWN AND INDICATION (LSI) PANELS.

ENFORCEMENT SUMMARY

CONSEQUENTLY, A LOCAL FIRE COULD HAVE OPENED THE FEEDER BREAKER WITHOUT ISOLATING THE FAULT BETWEEN THE LSI PANELS. THIS COULD HAVE LED TO THE LOSS OF ALL CONTROL ROOM T-HOT AND T-COLD TEMPERATURE INDICATION. (B) THE LICENSEE IMPLEMENTED DESIGN CHANGES TO UNIT 1 (ON DECEMBER 29, 1987) AND TO UNIT 2 (ON DECEMBER 30, 1987) TO CORRECT DESIGN DEFICIENCIES ASSOCIATED WITH ELECTRICAL ISOLATION BETWEEN LSI PANELS (SEE VIOLATION A. ABOVE). DURING REVIEWS OF THESE DESIGN CHANGES, THE LICENSEE FAILED TO VERIFY THE COORDINATION BETWEEN THE LSI PANEL FEEDER BREAKER AND THE NEWLY INSTALLED FUSES. CONSEQUENTLY, A CIRCUIT FAULT COULD HAVE OPENED THE FEEDER BREAKER WITHOUT ISOLATING THE FAULT BETWEEN THE LSI PANELS. THIS COULD HAVE LED TO THE LOSS OF ALL CONTROL ROOM T-HOT AND T-COLD TEMPERATURE INDICATION. (C) THE LICENSEE DISCOVERED (ON SEPTEMBER 17, 1987) DURING A SAFETY SYSTEM FUNCTIONAL INSPECTION (SSFI) REVIEW, THAT A FUSE-BREAKER MISCOORDINATION EXISTED ON EACH SAFETY-RELATED 250 VDC BUS FOR BOTH UNITS. THUS, IN THE EVENT OF A FAULT IN CERTAIN BALANCE OF PLANT (BOP) CABLES, WHICH WOULD INVOLVE DISTRIBUTION PANELS FROM BOTH INDEPENDENT TRAINS, A LOSS OF CONTROL POWER ON BOTH INDEPENDENT TRAINS OF RELATED ESSENTIAL SAFETY SYSTEM (ESS) PANELS COULD HAVE OCCURRED. ESS LOADS THAT COULD HAVE BEEN AFFECTED WERE CERTAIN CONTAINMENT ISOLATION VALVES, REACTOR HEAD VENT VALVES, POST-ACCIDENT SAMPLING VALVES, AND STEAM GENERATOR STOP VALVE DUMP VALVES. 10 CFR 50, APPENDIX B, CRITERION III, AS IMPLEMENTED BY THE D.C. COOK OPERATIONS QUALITY ASSURANCE PROGRAM, REQUIRES THAT DESIGN CONTROL MEASURES BE PROVIDED FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN, INCLUDING DESIGN CHANGES. CONTRARY TO THE ABOVE, THE LICENSEE FAILED TO ENSURE THAT ADEQUATE DESIGN CONTROL MEASURES WERE PROVIDED AS FOLLOWS: (A) THE LICENSEE FAILED TO PERFORM ADEQUATE INITIAL DESIGN REVIEWS REGARDING ELECTRICAL ISOLATION BETWEEN THE LOCAL SHUTDOWN AND INDICATION (LSI) PANELS. CONSEQUENTLY, A LOCAL FIRE COULD HAVE OPENED THE FEEDER BREAKER WITHOUT ISOLATING THE FAULT BETWEEN THE LSI PANELS. THIS COULD HAVE LED TO THE LOSS OF ALL CONTROL ROOM T-HOT AND T-COLD TEMPERATURE INDICATION. (B) THE LICENSEE IMPLEMENTED DESIGN CHANGES TO UNIT 1 (ON DECEMBER 29, 1987) AND TO UNIT 2 (ON DECEMBER 30, 1987) TO CORRECT DESIGN DEFICIENCIES ASSOCIATED WITH ELECTRICAL ISOLATION BETWEEN LSI PANELS (SEE VIOLATION A. ABOVE). DURING REVIEWS OF THESE DESIGN CHANGES, THE LICENSEE FAILED TO VERIFY THE COORDINATION BETWEEN THE LSI PANEL FEEDER BREAKER AND THE NEWLY INSTALLED FUSES. CONSEQUENTLY, A CIRCUIT FAULT COULD HAVE OPENED THE FEEDER BREAKER WITHOUT ISOLATING THE FAULT BETWEEN THE LSI PANELS. THIS COULD HAVE LED TO THE LOSS OF ALL CONTROL ROOM T-HOT AND T-COLD TEMPERATURE INDICATION. (C) THE LICENSEE DISCOVERED (ON SEPTEMBER 17, 1987) DURING A SAFETY SYSTEM FUNCTIONAL INSPECTION (SSFI) REVIEW, THAT A FUSE-BREAKER MISCOORDINATION EXISTED ON EACH SAFETY-RELATED 250 VDC BUS FOR BOTH UNITS. THUS, IN THE EVENT OF A FAULT IN CERTAIN BALANCE OF PLANT (BOP) CABLES, WHICH WOULD INVOLVE DISTRIBUTION PANELS FROM BOTH INDEPENDENT TRAINS, A LOSS OF CONTROL POWER ON BOTH INDEPENDENT TRAINS OF RELATED ESSENTIAL SAFETY SYSTEM (ESS) PANELS COULD HAVE OCCURRED. ESS LOADS THAT COULD HAVE BEEN AFFECTED WERE CERTAIN CONTAINMENT ISOLATION VALVES, REACTOR HEAD VENT VALVES, POST-ACCIDENT SAMPLING VALVES, AND STEAM GENERATOR STOP VALVE DUMP VALVES. (88J0 4)

OTHER ITEMS

## SYSTEMS AND COMPONENT PROBLEMS:

NONE

## FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

## MANAGERIAL ITEMS:

THE ASSISTANT PLANT MANAGER, ENGINEERING IS ACTING FOR THE TECHNICAL SUPERINTENDENT, PHYSICAL SCIENCE RADIATION PROTECTION MANAGER  
 PLANT STATUS:

UNIT 1 OPERATED ROUTINELY THROUGHOUT THE MONTH.

LAST IE SITE INSPECTION DATE: 06/13/88





THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-316 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: HIRSCH (616) 465-5901

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1333 X 0.85 = 1133

6. Design Electrical Rating (Net MWe): 1100

7. Maximum Dependable Capacity (Gross MWe): 1100

8. Maximum Dependable Capacity (Net MWe): 1060

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>92,759.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,715.5</u>	<u>33,587.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>2,715.1</u>	<u>62,210.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2.2</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>7,410,979</u>	<u>191,990,217</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,419,600</u>	<u>61,896,040</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>2,323,265</u>	<u>59,586,746</u>
20. Unit Service Factor	<u>.0</u>	<u>53.1</u>	<u>68.9</u>
21. Unit Avail Factor	<u>.0</u>	<u>53.1</u>	<u>68.9</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>42.9</u>	<u>62.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>41.3</u>	<u>60.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>14.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>10,497.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 02/01/89

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
X COOK 2 X  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
COOK 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* COOK 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
189	04/23/88	S	744.0	C	4		ZZ	ZZZZZZ	THE UNIT WAS REMOVED FROM SERVICE ON 880423 FOR CYCLE 6-7 REFUELING AND THE STEAM GENERATOR REPAIR PROJECT. THE REACTOR CORE IS CURRENTLY UNLOADED. THE EXPECTED DATE FOR RETURN TO SERVICE IS FEBRUARY 1989.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 COOK 2 REMAINED SHUTDOWN IN JULY FOR SCHEDULED REFUELING AND STEAM GENERATOR REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
COUNTY.....BERRIEN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI S OF  
BENTON HARBOR, MI  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 10, 1978  
DATE ELEC ENER 1ST GENER...MARCH 22, 1978  
DATE COMMERCIAL OPERATE...JULY 1, 1978  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....INDIANA MICHIGAN POWER CO.  
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA  
COLUMBUS, OHIO 43216  
CONTRACTOR  
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....J. A. JONES CONSTRUCTION  
TURBINE SUPPLIER.....BROWN BOVERI

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....B. JORGENSEN  
LICENSING PROJ MANAGER.....J. STANG  
DOCKET NUMBER.....50-316  
LICENSE & DATE ISSUANCE...DPR-74, DECEMBER 23, 1977  
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY  
500 MARKET STREET  
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

RESIDENT INSPECTORS OF: ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS; PLANT OPERATIONS; RADIOLOGICAL CONTROLS; MAINTENANCE; SURVEILLANCE; FIRE PROTECTION; SECURITY; OUTAGES; REPORTABLE EVENTS; BULLETINS AND NOTICES; NRC REGION III REQUESTS; TRAINING AND QUALIFICATION EFFECTIVENESS; MANAGEMENT MEETING; AND MEETING AMONG NRC AND COMMUNITY LEADERS. ONE SAFETY ISSUES MANAGEMENT SYSTEM (SIMS) ITEM (BULLETIN 88-01, MULTI-PLANT ACTION MPA NO. B100) WAS REVIEWED DURING THIS INSPECTION. OF THE 14 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 13 AREAS. ONE VIOLATION WAS IDENTIFIED (FAILURE TO FOLLOW PROCEDURE) IN THE REMAINING AREA. MISCELLANEOUS MAJOR WEAKNESSES WERE NOTED WHICH HAD IN COMMON THE FACT THEY INVOLVED CLEANLY "WRAPPING UP" ACTIVITIES (E.G., COMPLETE/ACCURATE PAPERWORK, JOBSITE CLEANUP AND HURRYING AT STEP-OFF PADS). A STRENGTH NOTED DURING THE INSPECTION WAS TIMELY MANAGEMENT INVOLVEMENT IN ITEMS IDENTIFIED AS PROBLEMS OR POTENTIAL PROBLEMS, SUCH AS ALARA REEXAMINATION OF ONGOING JOBS, THOROUGH UPGRADE OF A WEAK MAINTENANCE PROCEDURE, AND STRONG PURSUIT OF MAINTENANCE OBSERVATIONS (PUMP BEARING/OIL) AND TESTING QUESTIONS (THIMBLE TUBES, SEISMIC MONITORS, AND TREVITEST METHOD).

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION III AS COMMITTED TO IN THE QUALITY ASSURANCE PROGRAM DESCRIPTION FOR THE DONALD C. COOK NUCLEAR POWER PLANT REQUIRES THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN. CONTRARY TO THE ABOVE, THE SUBSTITUTION OF WELD MATERIAL UTILIZED FOR THE CHEMICAL AND VOLUME CONTROL SYSTEM CROSS-TIE MODIFICATION DID NOT RECEIVE AN ADEQUATE ENGINEERING REVIEW IN THAT THE SPECIFIED ASME CODE ALLOWABLE STRESS LIMITS WERE NOT CONSIDERED. TECHNICAL





Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-05	07/15/88	F	40.6	H	1	88-019	EL	IPBU	REACTOR MANUALLY SCRAMMED DUE TO INDICATION OF ELECTRICAL FIRE ON 'A' PHASE ISOLATED PHASE BUS DUCT. DEGRADED DUCT COVER GASKETS AND A BROKEN GROUNDING STRAP WERE REPLACED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
COOPER STATION INCURRED ONE FORCED OUTAGE IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)



\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEBRASKA  
COUNTY.....NEMAHA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...23 MI S OF  
NEBRASKA CITY, NEB  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...FEBRUARY 21, 1974  
DATE ELEC ENER 1ST GENER...MAY 10, 1974  
DATE COMMERCIAL OPERATE...JULY 1, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MISSOURI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NEBRASKA PUBLIC POWER DISTRICT  
CORPORATE ADDRESS.....P.O. BOX 499  
COLUMBUS, NEBRASKA 68601  
CONTRACTOR  
ARCHITECT/ENGINEER.....BURNS & ROE  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BURNS & ROE  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....W. BENNETT  
LICENSING PROJ MANAGER.....W. LONG  
DOCKET NUMBER.....50-298  
LICENSE & DATE ISSUANCE...DPR-46, JANUARY 18, 1974  
PUBLIC DOCUMENT ROOM.....AUBURN PUBLIC LIBRARY  
1118 15TH STREET  
AUBURN, NEBRASKA 68305

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED JUNE 27 - JULY 1, 1988 (88-18) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S STARTUP TESTING. THE LICENSEE'S STARTUP TESTING FOLLOWING THE CYCLE 11 REFUELING OUTAGE APPEARED TO GENERALLY BE IN CONFORMANCE WITH NRC REQUIREMENTS AND LICENSEE PROCEDURES. ONE DEVIATION AND NO VIOLATIONS WERE IDENTIFIED. INSPECTION CONDUCTED JUNE 1 - JULY 4, 1988 (88-20) ROUTINE, UNANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, MONTHLY SURVEILLANCE AND MAINTENANCE OBSERVATIONS, ESF WALKDOWN, IE BULLETIN 88-05 FOLLOWUP, RADIOLOGICAL PROTECTION, AND SECURITY. WITHIN THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 3.6.E.1 THE LICENSEE FAILED TO PERFORM JET PUMP OPERABILITY TESTS UNTIL THE REACTOR WAS AT POWER. CONTRARY TO TECHNICAL SPECIFICATION 6.3.2 AND SURVEILLANCE PROCEDURE 6.4.5.17 THE LICENSEE FAILED TO PERFORM MONTHLY INSPECTION FOR FIRE EXTINGUISHERS LOCATED ON VARIOUS ELECTRIC AND OXYGEN-ACETYLENE WELDERS. CONTRARY TO APP.B CRITERION V AND CNS PROCEDURE 0.26 THE LICENSEE FAILED TO PERFORM AN ADEQUATE REVIEW OF SURVEILLANCE PROCEDURES 6.4.5.1, 6.4.5.17, AND GENERAL OPERATING PROCEDURE 2.1.1.2.  
(8800 4)

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    COOPER STATION                    \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

PLANT STARTUP - 100% POWER

LAST IE SITE INSPECTION DATE: JULY 4, 1988

INSPECTION REPORT NO: 50-298/88-20

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-008	04-06-88	06-30-88	FAILURE OF RHM INBOARD INJECTION VALVES TO CLOSE DURING SURVEILLANCE TESTING
88-016	05-17-88	06-30-88	PIPE SUPPORT DESIGN DEFICIENCIES DISCOVERED DURING DESIGN CHANGE ENGINEERING ACTIVITIES
88-017	05-26-88	06-27-88	UNPLANNED AUTOMATIC ACTUATION OF ENGINEERED SAFETY FEATURES DUE TO HUMAN ERRORS DURING SURVEILLANCE TESTING
88-018	06-09-88	07-11-88	INADVERTENT INJECTION OF WATER INTO REACTOR VESSEL DURING SURVEILLANCE TEST

=====

1. Docket: 50-302 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: D. GRAHAM (904) 795-3802

4. Licensed Thermal Power (MWt): 2544

5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 821

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>99,815.0</u>
13. Hours Reactor Critical	<u>714.0</u>	<u>4,840.0</u>	<u>64,166.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,275.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,774.6</u>	<u>62,790.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,852,812</u>	<u>11,748,615</u>	<u>141,495,803</u>
18. Gross Elec Ener (MWH)	<u>625,296</u>	<u>4,027,643</u>	<u>48,401,758</u>
19. Net Elec Ener (MWH)	<u>595,080</u>	<u>3,835,380</u>	<u>45,968,962</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.4</u>	<u>62.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.4</u>	<u>62.9</u>
22. Unit Cap Factor (MDC Net)	<u>97.4</u>	<u>91.4</u>	<u>56.1</u>
23. Unit Cap Factor (DER Net)	<u>97.0</u>	<u>91.0</u>	<u>55.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.9</u>	<u>22.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>93.9</u>	<u>17,728.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
MAINTENANCE-OCTOBER 14, 1988-20 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X CRYSTAL RIVER 3 X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CRYSTAL RIVER 3



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* CRYSTAL RIVER 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-7	07/08/88	S	0.0	B	5		HF	HTEXCH	OPERATED AT A REDUCED LOAD OF APPROXIMATELY 75% TO REPLACE SACRIFICIAL IRON GRATING IN CONDENSER WATERBOXES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
CRYSTAL RIVER 3 INCURRED ONE LOAD REDUCTION IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* CRYSTAL RIVER 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....CITRUS  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NW OF  
CRYSTAL RIVER, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JANUARY 14, 1977  
DATE ELEC ENER 1ST GENER...JANUARY 30, 1977  
DATE COMMERCIAL OPERATE...MARCH 13, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....GULF OF MEXICO  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER CORPORATION  
CORPORATE ADDRESS.....5201 34TH STREET, SOUTH  
ST PETERSBURG, FLORIDA 33733  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....J. A. JONES CONSTRUCTION  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....T. STETKA  
LICENSING PROJ MANAGER....H. SILVER  
DOCKET NUMBER.....50-502  
LICENSE & DATE ISSUANCE...DPR-72, JANUARY 28, 1977  
PUBLIC DOCUMENT ROOM.....CRYSTAL RIVER PUBLIC LIBRARY  
668 N.W. FIRST  
CRYSTAL RIVER, FLORIDA 32629

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 7-9 (88-15): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED THE OBSERVATION AND EVALUATION OF KEY EMERGENCY AND ORGANIZATIONAL FUNCTIONS AND LOCATIONS DURING THIS PARTIAL PARTICIPATION EXERCISE (FULL PARTICIPATION BY RISK COUNTIES AND FEMA EVALUATED). TWO EXERCISE WEAKNESSES WERE IDENTIFIED IN THE AREAS OF PROPERLY CLASSIFYING THE EMERGENCY CONDITIONS AND PROVIDING DOSE ASSESSMENT DATA ON A TIMELY BASIS. NOTWITHSTANDING THESE FINDINGS, THE LICENSEE STAFF DEMONSTRATED THAT THEY WOULD BE ABLE TO SATISFACTORILY RESPOND TO AN EMERGENCY AT THE FACILITY.

INSPECTION MAY 12 - JUNE 8 (88-16): THIS ROUTINE INSPECTION WAS CONDUCTED BY TWO RESIDENT INSPECTORS IN THE AREAS OF PLANT OPERATIONS, RADIOLOGICAL CONTROLS, SECURITY, LICENSEE EVENT REPORTS AND NONCONFORMING OPERATIONS REPORTS, FACILITY MODIFICATIONS, TMI TASK ACTION PLAN REVIEW, OFFSITE REVIEW COMMITTEE ACTIVITIES, AND LICENSEE ACTION ON PREVIOUS INSPECTION ITEMS. NUMEROUS FACILITY TOURS WERE CONDUCTED AND FACILITY OPERATIONS OBSERVED. SOME OF THESE TOURS AND OBSERVATIONS WERE CONDUCTED ON BACKSHIFTS. NRC REGION II PERSONNEL MET WITH THE LICENSEE ON MAY 25, 1988, TO DISCUSS THE LICENSEE'S EFFORTS IN IMPROVING THE SURVEILLANCE PROGRAM. THREE VIOLATIONS WERE IDENTIFIED: FAILURE TO PERFORM A CHANNEL CALIBRATION OF THE CONTAINMENT HYDROGEN ANALYZERS; FAILURE TO ADHERE TO THE REQUIREMENTS OF PROCEDURE CH-101; FAILURE TO PROVIDE ADEQUATE CORRECTIVE ACTION TO PREVENT EXCEEDING THE MAXIMUM RELEASE RATE, OR A LIQUID RELEASE. MANAGEMENT ATTENTION TO SURVEILLANCE WAS EVIDENT.

ENFORCEMENT SUMMARY



1. Docket: 58-346 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: MORTEZA KHARZRAI (419) 249-5000 X7290

4. Licensed Thermal Power (MHT): 2772

5. Nameplate Rating (Gross MWe): 1069 X 0.9 = 962

6. Design Electrical Rating (Net MWe): 906

7. Maximum Dependable Capacity (Gross MWe): 904

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>87,696.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,661.3</u>	<u>45,143.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,050.1</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,580.0</u>	<u>43,380.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,732.7</u>
17. Gross Therm Ener (MWH)	<u>.0</u>	<u>3,306,442</u>	<u>101,268,640</u>
18. Gross Elec Ener (MWH)	<u>.0</u>	<u>1,072,485</u>	<u>33,448,288</u>
19. Net Elec Ener (MWH)	<u>.0</u>	<u>998,787</u>	<u>31,299,434</u>
20. Unit Service Factor	<u>.0</u>	<u>30.9</u>	<u>49.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>30.9</u>	<u>51.4</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>22.7</u>	<u>41.5</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>21.6</u>	<u>39.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>32.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>21,470.0</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 09/29/88

\*\*\*\*\*  
\* DAVIS-BESSE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DAVIS-BESSE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DAVIS-BESSE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
2	05/10/88	S	744.0	C	4			THE UNIT OUTAGE WHICH BEGAN ON MARCH 10, 1988 WAS STILL IN PROGRESS THROUGH THE END OF JULY 1988.

\*\*\*\*\* DAVIS-BESSE 1 REMAINED SHUTDOWN IN JULY FOR SCHEDULED REFUELING  
\* SUMMARY \*  
\*\*\*\*\* OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & M
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)





ENFORCEMENT SUMMARY

(8800 4)

TECHNICAL SPECIFICATIONS, SECTION 6.8.1.B, STATES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED, AND MAINTAINED COVERING ACTIVITIES SUCH AS REFUELING OPERATIONS. TOLEDO EDISON CO. PROCEDURE AD 1828.16, "NON-LICENSED OPERATOR PROFICIENCY TRAINING PROGRAM," REVISION 3, AS IT PERTAINS TO THE TRAINING OF REFUELING EQUIPMENT OPERATORS, STATES IN PART 5.1: "THE PLANT MANAGER IS CHARGED WITH THE OVERALL RESPONSIBILITY FOR ENSURING THAT PERSONNEL ASSIGNED TO THE FACILITY STAFF ARE QUALIFIED IN ACCORDANCE WITH THE NUCLEAR QUALITY ASSURANCE (NQAM)." PROCEDURE PP 1501.01, "FUEL LOADING AND REFUELING LIMITS AND PRECAUTION," REVISION 8, PART 5.4.1 STATES, IN PART, THAT REFUELING PERSONNEL MUST BE THOROUGHLY TRAINED IN THE USE OF HANDLING EQUIPMENT AND TOOLS WHICH THEY WILL USE. PART 15.4.1.1 OF THE NQAM STATES, IN PART, THAT INITIAL AND CONTINUING TRAINING PROGRAMS SHALL BE ESTABLISHED FOR NUCLEAR GROUP AND SUPPORT PERSONNEL TO ENSURE THAT THEY ARE KNOWLEDGEABLE OF APPLICABLE EQUIPMENT AND CAPABLE OF PERFORMING THE ASSIGNED DUTIES OF THEIR INTENDED POSITION. CONTRARY TO THE ABOVE, ON MAY 11, 1988 DURING DEFUELING OPERATIONS A REFUELING EQUIPMENT OPERATOR DEMONSTRATED A LACK OF SUFFICIENT KNOWLEDGE TO OPERATE REFUELING EQUIPMENT, AS EVIDENCED BY AN INABILITY TO OPERATE THE EQUIPMENT WITHOUT SIGNIFICANT ASSISTANCE FROM OTHER PERSONNEL.

(8801 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

SALP MEETING WITH THE LICENSEE AT THE SITE ON MARCH 30, 1988

PLANT STATUS:

SHUT DOWN FOR A 6 MONTH MAINTENANCE/MODIFICATION/REFUELING OUTAGE. RESTART ABOUT MID- SEPTEMBER, 1988.

LAST IE SITE INSPECTION DATE: 06/17/88

INSPECTION REPORT NO: 88016

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-14	060988	071188	ROVING FIRE WATCH EXCEEDING HOURLY PATROL TIME LIMIT
88-15	070288	080188	LOOSE PART DISCOVERED IN THE REACTOR VESSEL

1. Docket: 50-275 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: P. BEDASAM (805) 595-6997

4. Licensed Thermal Power (MWT): 1338

5. Nameplate Rating (Gross MWe): 1137

6. Design Electrical Rating (Net MWe): 1086

7. Maximum Dependable Capacity (Gross MWe): 1124

8. Maximum Dependable Capacity (Net MWe): 1073

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>28,565.3</u>
13. Hours Reactor Critical	<u>536.7</u>	<u>2,068.3</u>	<u>21,807.0</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>436.0</u>	<u>1,959.3</u>	<u>21,277.6</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MMH)	<u>927,368</u>	<u>4,947,972</u>	<u>63,912,435</u>
18. Gross Elec Ener (MMH)	<u>291,400</u>	<u>1,646,400</u>	<u>21,497,232</u>
19. Net Elec Ener (MMH)	<u>258,549</u>	<u>1,513,799</u>	<u>20,325,501</u>
20. Unit Service Factor	<u>58.6</u>	<u>38.3</u>	<u>75.0</u>
21. Unit Avail Factor	<u>58.6</u>	<u>38.3</u>	<u>75.0</u>
22. Unit Cap Factor (MDC Net)	<u>32.4</u>	<u>27.6</u>	<u>66.8</u>
23. Unit Cap Factor (DER Net)	<u>32.0</u>	<u>27.3</u>	<u>66.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.0</u>	<u>5.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>57.9</u>	<u>840.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

XX  
 \* DIABLO CANYON 1 \*  
 XX

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 DIABLO CANYON 1



JULY 1988

\*\*\*\*\*

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DIABLO CANYON 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	06/01/88	S	308.0	C	4			SCHEDULED REFUELING OUTAGE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
DIABLO CANYON 1 COMPLETED SCHEDULED REFUELING OUTAGE DURING JULY AND RETURNED TO POWER OPERATION.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licence Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* DIABLO CANYON 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN LUIS OBISPO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI SW OF  
SAN LUIS OBISPO  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...APRIL 29, 1984  
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1984  
DATE COMMERCIAL OPERATE...MAY 7, 1985  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PACIFIC GAS & ELECTRIC  
CORPORATE ADDRESS.....77 BEALE STREET  
SAN FRANCISCO, CA 94106  
CONTRACTOR  
ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....PACIFIC GAS & ELECTRIC  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....J. BURDOIN  
LICENSING PROJ MANAGER.....H. ROOD  
DOCKET NUMBER.....50-275  
LICENSE & DATE ISSUANCE. .DPR-80, NOVEMBER 2, 1984  
PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY  
CALIFORNIA POLYTECHNIC STATE UNIVERSITY  
SAN LUIS OBISPO, CA. 93407

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JULY 11 - 22, 1988 (REPORT NO. 50-275/88-15) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

: INSPECTION ON MAY 31 - JUNE 17, 1988 (REPORT NO. 50-275/88-16) AREAS INSPECTED: THIS ROUTINE, UNANNOUNCED INSPECTION BY THE PROJECT INSPECTOR INVOLVED THE EVALUATION OF THE LICENSEE'S QUALITY ASSURANCE PROGRAM FOR THE CONTROL OF MEASURING AND TESTING EQUIPMENT; EVALUATION OF THE DESIGN, DESIGN CHANGE, AND MODIFICATION PROGRAM; AND ONSITE FOLLOWUP ON PREVIOUS INSPECTION FINDINGS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. THE MEASURING AND TEST EQUIPMENT PROGRAM WAS ACCEPTABLY IMPLEMENTED UNDER THE GENERAL CONSTRUCTION'S CALIBRATION SHOP; HOWEVER THE I&C CALIBRATION SHOP REMAINS LIMITED IN ITS SCOPE AND RESPONSIBILITIES FOLLOWING WEAKNESSES IDENTIFIED DURING AN INTERNAL QUALITY ASSURANCE AUDIT. THE SURVEILLANCE TESTING AND CALIBRATION CONTROL PROGRAM WAS EXTENSIVE AND INDICATED A THOROUGH AND KNOWLEDGEABLE STAFF IN SUPPORT OF THE PROGRAM. THE DESIGN, DESIGN CHANGE, AND MODIFICATION PROGRAM WAS ACCEPTABLE AND INDICATED THAT PROPER DOCUMENTATION AND REVIEW PROCESSES WERE IN PLACE.

+ INSPECTION ON MAY 29 - JULY 16, 1988 (REPORT NO. 50-275/88-17) AREAS INSPECTED: THE INSPECTION INCLUDED ROUTINE INSPECTION OF PLANT OPERATIONS, MAINTENANCE AND SURVEILLANCE ACTIVITIES, FOLLOW-UP OF ONSITE EVENTS, OPEN ITEMS, AND LICENSEE EVENT REPORTS (LER'S), AS WELL AS SELECTED INDEPENDENT INSPECTION ACTIVITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION

- + INSPECTION ON AUGUST 1, 1987 - JULY 31, 1988 (REPORT NO. 50-275/88-18) SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE INSPECTION; TO BE REPORTED AT A LATER DATE.
- + INSPECTION ON AUGUST 22 - 26, 1988 (REPORT NO. 50-275/88-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 5 - 7, 1988 (REPORT NO. 50-275/88-20) AREAS INSPECTED: ROUTINE INSPECTION OF RADIOCHEMICAL ANALYSIS DATA SUPPLIED BY THE LICENSEE FOR MEASUREMENT INTERCOMPARISON. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED. RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. THE LICENSEE'S ANALYSIS OF AN NRC RADIOCHEMICAL TEST SAMPLE INDICATES AN ACCEPTABLE MEASUREMENT CAPABILITY FOR MOST NUCLIDES IN THE SAMPLE.
- + INSPECTION ON JULY 17 - AUGUST 27, 1988 (REPORT NO. 50-275/88-21) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPL. NO PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS IN A REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: 07/17 - 08/27/88+

INSPECTION REPORT NO: 50-275/88-21+

Report Period JUL 1988

P O R T S F R O M L I C E N S E E

\*\*\*\*\*  
\* DIABLO CANYON 1 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-11-LO	05-12-88	06-09-88	FUEL BLDG (FHB) MONITOR EXCEEDED HI ALARM SETPOINT (7.5MR/HR)
88-16-LO	06-16-88	07-15-88	MISSED SURVEILLANCE DUE TO LACK OF PROCEDURAL GUIDANCE

THIS PAGE INTENTIONALLY LEFT BLANK



1. Locket: 50-323 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: P. BEDESEM (805) 595-4097

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1164

6. Design Electrical Rating (Net MWe): 1119

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1087

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>20,924.0</u>
13. Hours Reactor Critical	<u>391.3</u>	<u>4,691.5</u>	<u>17,607.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>391.3</u>	<u>4,690.9</u>	<u>17,175.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,204,457</u>	<u>15,565,220</u>	<u>54,827,207</u>
18. Gross Elec Ener (MWH)	<u>395,900</u>	<u>5,186,400</u>	<u>18,174,099</u>
19. Net Elec Ener (MWH)	<u>369,605</u>	<u>4,927,550</u>	<u>17,190,942</u>
20. Unit Service Factor	<u>52.6</u>	<u>91.8</u>	<u>82.1</u>
21. Unit Avail Factor	<u>52.6</u>	<u>91.8</u>	<u>82.1</u>
22. Unit Cap Factor (MDC Net)	<u>45.7</u>	<u>88.7</u>	<u>75.6</u>
23. Unit Cap Factor (DER Net)	<u>44.4</u>	<u>86.2</u>	<u>73.4</u>
24. Unit Forced Outage Rate	<u>47.4</u>	<u>8.2</u>	<u>10.1</u>
25. Forced Outage Hrs	<u>352.7</u>	<u>420.1</u>	<u>1,925.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - SEPT. 15, 1988 - 70 DAY DURATION.

27. If Currently Shutdown Estimate Startup Date: 08/08/88

\*\*\*\*\*  
\* DJABLO CANYON 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
DIABLO CANYON 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* DIABLO CANYON 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/01/88	S	0.0	B	5		SG	COND	UNIT 2 REDUCED POWER TO 50% TO BACKFLUSH AND CLEAN CONDENSER WATERBOXES AND TO REPAIR AN INTAKE SCREEN.
2	07/17/88	F	352.7	A	2	2-88-008	AB	GBU	UNIT 2 MANUAL REACTOR TRIP AND MANUAL RCP 2-2 TRIP DUE TO GROUND FAULT INDICATIONS ON 12KV NON-VITAL BUSES. GALLED ALUMINUM THREADS RESULTED IN AN INADEQUATE ELECTRICAL CONNECTION WHICH, WITH THERMAL AND ELECTRICAL CYCLING, DETERIORATED OVER 4 YEARS AND EVENTUALLY PRODUCED ENOUGH HEAT TO CAUSE A GROUND. THE CONNECTION WAS REPAIRED AND RCP 2-2 RETURNED TO SERVICE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 DIABLO CANYON 2 INCURRED ONE LOAD REDUCTION AND ONE FORCED OUTAGE DURING JULY AND ENDED THE MONTH SHUTDOWN.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN LUIS OBISPO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI WSW OF  
SAN LUIS OBISPO  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 19, 1985  
DATE ELEC ENER 1ST GENER...OCTOBER 20, 1985  
DATE COMMERCIAL OPERATE...MARCH 13, 1986  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PACIFIC GAS & ELECTRIC  
CORPORATE ADDRESS.....77 BEALE STREET  
SAN FRANCISCO, CALIFORNIA 94106  
CONTRACTOR  
ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....PACIFIC GAS & ELECTRIC  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....J. BURDGIN  
LICENSING PROJ MANAGER.....H. ROOD  
DOCKET NUMBER.....50-323  
LICENSE & DATE ISSUANCE...DPR-82, AUGUST 26, 1985  
PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY  
CALIFORNIA POLYTECHNIC STATE UNIVERSITY  
SAN LUIS OBISPO, CA. 93407

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON JULY 11 - 22, 1988 (REPORT NO. 50-323/88-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MAY 31 - JUNE 17, 1988 (REPORT NO. 50-323/88-15) AREAS INSPECTED: THIS ROUTINE, UNANNOUNCED INSPECTION BY THE PROJECT INSPECTOR INVOLVED THE EVALUATION OF THE LICENSEE'S QUALITY ASSURANCE PROGRAM FOR THE CONTROL OF MEASURING AND TEST EQUIPMENT; EVALUATION OF THE SURVEILLANCE TESTING AND CALIBRATION CONTROL PROGRAM; EVALUATION OF THE DESIGN, DESIGN CHANGE, AND MODIFICATION PROGRAM; AND ONSITE FOLLOWUP ON PREVIOUS INSPECTION FINDINGS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.  
RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. THE MEASURING AND TEST EQUIPMENT PROGRAM WAS ACCEPTABLY IMPLEMENTED UNDER THE GENERAL CONSTRUCTION'S CALIBRATION SHOP; HOWEVER THE I&C CALIBRATION SHOP REMAINS LIMITED IN ITS SCOPE AND RESPONSIBILITIES FOLLOWING WEAKNESSES IDENTIFIED DURING AN INTERNAL QUALITY ASSURANCE AUDIT. THE SURVEILLANCE TESTING AND CALIBRATION CONTROL PROGRAM WAS EXTENSIVE AND INDICATED A THOROUGH HAND KNOWLEDGEABLE STAFF IN SUPPORT OF THE PROGRAM. THE DESIGN, DESIGN CHANGE, AND MODIFICATION PROGRAM WAS ACCEPTABLE AND INDICATED THAT PROPER DOCUMENTATION AND REVIEW PROCESSES WERE IN PLACE.
- + INSPECTION ON MAY 29 - JULY 16, 1988 (REPORT NO. 50-323-88-16) AREAS INSPECTED: THE INSPECTION INCLUDED ROUTINE INSPECTIONS OF PLANT OPERATIONS, MAINTENANCE AND SURVEILLANCE ACTIVITIES, FOLLOW-UP OF ONSITE EVENTS, OPEN ITEMS, AND LICENSEE EVENT REPORTS (LER'S), AS WELL AS SELECTED INDEPENDENT INSPECTION ACTIVITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON AUGUST 1, 1987 - JULY 31, 1988 (REPORT NO. 50-323/88-17) SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE INSPECTION; TO BE REPORTED AT A LATER DATE.

+ INSPECTION AUGUST 22 - 26, 1988 (REPORT NO. 50-323/88-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 17 - AUGUST 27, 1988 (REPORT NO. 50-323/88-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS IN COMMERCIAL OPERATION, AT APPROXIMATELY 100% POWER.

LAST IE SITE INSPECTION DATE: 07/17 - 08/27/88+

INSPECTION REPORT NO: 50-323/88-19+

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
87-25-L0	12-09-87	06-21-88	POTENTIAL LOSS OF CONT WHEN FCV-661 FAILED DUE TO PERSONNEL ERROR
88-06-L0	06-02-88	07-05-88	MISSED SURVEILLANCE DUE TO PERSONNEL ERROR

1. Docket: 50-237 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: D.C. MAXWELL (815) 942-0920 X 489

4. Licensed Thermal Power (Mwt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 772

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>159,695.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,810.3</u>	<u>121,382.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,768.7</u>	<u>115,862.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,424,111</u>	<u>10,477,663</u>	<u>236,496,486</u>
18. Gross Elec Ener (MWH)	<u>432,775</u>	<u>3,317,347</u>	<u>76,257,317</u>
19. Net Elec Ener (MWH)	<u>408,185</u>	<u>3,155,330</u>	<u>72,091,508</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.3</u>	<u>72.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.3</u>	<u>72.6</u>
22. Unit Cap Factor (NJC Net)	<u>71.1</u>	<u>80.0</u>	<u>58.5</u>
23. Unit Cap Factor (DER Net)	<u>69.1</u>	<u>77.8</u>	<u>56.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.1</u>	<u>11.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>7.1</u>	<u>7,164.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING - OCTOBER, 1988 - 15 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* DRESDEN 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
DRESDEN 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DRESDEN 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
DRESDEN 2 OPERATED ROUTINELY DURING JULY AT A SLIGHTLY  
REDUCED POWER LEVEL DUE TO TEMPERATURE/DROUGHT CONDITIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	3-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....GRUNDY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI E OF  
MORRIS, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JANUARY 7, 1970  
DATE ELEC ENER 1ST GENER...APRIL 13, 1970  
DATE COMMERCIAL OPERATE...JUNE 9, 1970  
CONDENSER COOLING METHOD...COOLING LAKE  
CONDENSER COOLING WATER...KANKAKEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTE:POOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR..... UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....S. DUPONT  
LICENSING PROJ MANAGER.....B. SIEGEL  
DOCKET NUMBER.....50-237  
LICENSE & DATE ISSUANCE....DPR-19, DECEMBER 22, 1969  
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY  
604 LIBERTY STREET  
MORRIS, ILLINOIS 60450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 4-7, MAY 3-5, 16-18, AND JUNE 13-14, 21-22 (88010): ROUTINE UNANNOUNCED INSPECTION OF INSERVICE INSPECTION (ISI) ACTIVITIES INCLUDING REVIEW OF PROGRAM (73051), PROCEDURES (73052), OBSERVATION OF WORK AND WORK ACTIVITIES (73053), OF DATA REVIEW AND EVALUATION (73055); OF THE INSPECTION FOR VERIFICATION OF MARK 1 BWR DRYWELL VACUUM BREAKER MODIFICATIONS (37828) (TI 2515/96); OF IE INFORMATION NOTICES (92704); OF PLANT MODIFICATIONS (37702); AND OF INSPECTION OF THE DRYWELL CONTAINMENT FOR DEGRADATION (GL-87-P5) (92703). ISI ACTIVITIES WERE ACCOMPLISHED WITHIN THE GUIDELINES OF ASME SECTION XI AND GENERIC LETTER (GL) 84-11 REQUIREMENTS. THE LICENSEE HAS RECEIVED GL 88-01 AND IS IN PROCESS OF REVISING THE ISI PROGRAM TO IMPLEMENT THE AUGMENTED REQUIREMENTS WITHIN. PLANT MODIFICATION WELDING AND NONDESTRUCTIVE EXAMINATIONS WERE PERFORMED TO THE APPLICABLE CODE REQUIREMENTS. IMPLEMENTATION OF MODIFICATIONS WERE ADEQUATELY CONTROLLED BY QA, QC REQUIREMENTS. LICENSEE'S ACTIONS TAKEN ON GENERIC LETTERS AND INFORMATION NOTICE WAS ADEQUATE TO ASSURE SAFETY WAS NOT COMPROMISED.

INSPECTION DURING THE PERIOD OF MAY 17-24 (88013): AUGMENTED INSPECTION TEAM (AIT) INSPECTION OF THE MAY 16 AND 17, 1988, UNIT 2 MAIN STEAM ISOLATION VALVES' FAILURE TO CLOSE DURING LOSS OF AIR TESTING. NO VIOLATIONS OR DEVIATIONS WERE INVOLVED. THE ROUTINE TECHNICAL SPECIFICATION REQUIRED SURVEILLANCE DOES NOT IDENTIFY MAIN STEAM ISOLATION VALVE (MSIV) DEGRADATION DUE TO EXCESSIVE STEAM PACKING FRICTION. THE AUTOMATIC VALVE COMPANY (AVCO) 4-WAY SOLENOID VALVES WILL HANGUP IN AN INTERMEDIATE POSITION DURING GRADUAL LOSS OF SYSTEM AIR PRESSURE, RENDERING THE MSIV ACCUMULATORS INOPERABLE. THE ROOT CAUSE OF THE EIGHT UNIT 2 MSIVS' FAILURE TO ACHIEVE FULL CLOSURE DURING THE SPECIAL LOSS OF AIR TEST ON MAY 16 AND 17, 1988, WAS DUE TO EXCESSIVE MSIV STEM PACKING FRICTION. UNIT 3 MSIVS DID NOT EXPERIENCE EXCESSIVE MSIV STEM PACKING FRICTION AND WERE OPERABLE.

INSPECTION FROM MAY 25 THROUGH JUNE 16 (88014; 88015; 88014; 88014): SPECIAL SAFETY INSPECTION OF LICENSEE ACTION ON PREVIOUSLY  
PAGE 2-124





Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
X                   DRESDEN 2                   X  
\*\*\*\*\*

OTHER ITEMS

NONE

PLANT STATUS:

UNIT OPERATING AT POWER. POWER REDUCED DUE TO FEEDWATER HEATER PROBLEMS AND DUE TO TEMPERATURE/DROUGHT RESTRICTIONS

LAST IE SITE INSPECTION DATE: 06/30/88

INSPECTION REPORT NO: 88016

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-13	070888	080588	FUSE IN ANALOG TRIP SYSTEM PANEL 2202-73A OPENED DUE TO FAILED STANDBY GAS TREATMENT MASTER TRIP UNIT
88-16	061788	071588	EMERGENCY CORE COOLING SYSTEM INITIATION INDICATING SWITCHES OUT OF CALIBRATION DUE TO INSTRUMENT DRIFT

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Dockwt: 50-249 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: D.C. MAXWELL (815) 942-2920 X 489

4. Licensed Thermal Power (MWT): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 773

9. If Changes Occur Above Since Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>149,280.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,943.4</u>	<u>106,351.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>742.5</u>	<u>2,915.8</u>	<u>101,763.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,482,813</u>	<u>6,406,582</u>	<u>207,782,104</u>
18. Gross Elec Ener (MWH)	<u>463,256</u>	<u>2,060,522</u>	<u>67,091,764</u>
19. Net Elec Ener (MWH)	<u>438,942</u>	<u>1,953,295</u>	<u>63,531,115</u>
20. Unit Service Factor	<u>99.8</u>	<u>57.0</u>	<u>68.2</u>
21. Unit Avail Factor	<u>99.8</u>	<u>57.0</u>	<u>68.2</u>
22. Unit Cap Factor (MDC Net)	<u>76.3</u>	<u>49.4</u>	<u>55.1</u>
23. Unit Cap Factor (DER Net)	<u>74.3</u>	<u>48.1</u>	<u>53.6</u>
24. Uni' Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>12.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>9,463.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
DUAL UNIT SVC WATER OUTAGE, 11/88, 1 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* DRESDEN 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
DRESDEN 3



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DRESDEN 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
2	07/12/88	S	1.5	B	9			PLANNED OVERSPEED TEST OF THE MAIN TURBINE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 DRESDEN 2 INCURRED ONE SCHEDULED OUTAGE DURING JULY WHILE  
 OPERATING AT SLIGHTLY REDUCED POWER LEVEL DUE TO TEMPERATURE  
 /DROUGHT CONDITIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....GRUNDY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI E OF  
MORRIS, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JANUARY 31, 1971  
DATE ELEC ENER 1ST GENER...JULY 22, 1971  
DATE COMMERCIAL OPERATE...NOVEMBER 16, 1971  
CONDENSER COOLING METHOD...COOLING LAKE  
CONDENSER COOLING WATER...KANKAKEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....S. DUPONT  
LICENSING PROJ MANAGER.....B. SIEGEL  
DOCKET NUMBER.....50-249  
LICENSE & DATE ISSUANCE...DPR-25, MARCH 2, 1971  
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY  
604 LIBERTY STREET  
MORRIS, ILLINOIS 60450

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 4-7, MAY 3-5, 16-18, AND JUNE 13-14, 21-22 (88010): ROUTINE UNANNOUNCED INSPECTION OF INSERVICE INSPECTION (ISI) ACTIVITIES INCLUDING REVIEW OF PROGRAM (73051), PROCEDURES (73052), OBSERVATION OF WORK AND WORK ACTIVITIES (73053), OF DATA REVIEW AND EVALUATION (73055); OF THE INSPECTION FOR VERIFICATION OF MARK 1 BWR DRYWELL VACUUM BREAKER MODIFICATIONS (37828) (TI 2515/96); OF IE INFORMATION NOTICES (92704); OF PLANT MODIFICATIONS (3702); AND OF INSPECTION OF THE DRYWELL CONTAINMENT FOR DEGRADATION (GL-87-05) (92703). ISI ACTIVITIES WERE ACCOMPLISHED WITHIN THE GUIDELINES OF ASME SECTION XI AND GENERIC LETTER (GL) 84-11 REQUIREMENTS. THE LICENSEE HAS RECEIVED GL 88-01 AND IS IN PROCESS OF REVISING THE ISI PROGRAM TO IMPLEMENT THE AUGMENTED REQUIREMENTS WITHIN. PLANT MODIFICATION WELDING AND NONDESTRUCTIVE EXAMINATIONS WERE PERFORMED TO THE APPLICABLE CODE REQUIREMENTS. IMPLEMENTATION OF MODIFICATIONS WERE ADEQUATELY CONTROLLED BY QA, QC REQUIREMENTS. LICENSEE'S ACTIONS TAKEN ON GENERIC LETTERS AND INFORMATION NOTICE WAS ADEQUATE TO ASSURE SAFETY WAS NOT COMPROMISED.

INSPECTION DURING THE PERIOD OF MAY 17-24 (88013): AUGMENTED INSPECTION TEAM (AIT) INSPECTION OF THE MAY 16 AND 17, 1988, UNIT 2 MAIN STEAM ISOLATION VALVES' FAILURE TO CLOSE DURING LOSS OF AIR TESTING. NO VIOLATIONS OR DEVIATIONS WERE INVOLVED. THE ROUTINE TECHNICAL SPECIFICATION REQUIRED SURVEILLANCE DOES NOT IDENTIFY MAIN STEAM ISOLATION VALVE (MSIV) DEGRADATION DUE TO EXCESSIVE STEAM PACKING FRICTION. THE AUTOMATIC VALVE COMPANY (AVCO) 4-WAY SOLENOID VALVES WILL HANGUP IN AN INTERMEDIATE POSITION DURING GRADUAL LOSS OF SYSTEM AIR PRESSURE, RENDERING THE MSIV ACCUMULATORS INOPERABLE. THE ROOT CAUSE OF THE EIGHT UNIT 2 MSIVS' FAILURE TO ACHIEVE FULL CLOSURE DURING THE SPECIAL LOSS OF AIR TEST ON MAY 16 AND 17, 1988, WAS DUE TO EXCESSIVE MSIV STEM PACKING FRICTION. UNIT 3 MSIVS DID NOT EXPERIENCE EXCESSIVE MSIV STEM PACKING FRICTION AND WERE OPERABLE.

INSPECTION FROM MAY 25 THROUGH JUNE 16 (88014; 88015; 88014; 88014): SPECIAL SAFETY INSPECTION OF LICENSEE ACTION ON PREVIOUSLY



=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-12	062888	072888	PRIMARY CONTAINMENT CLEAN DEMINERALIZED WATER ISOLATION VALVE DISCOVERED OPEN DUE TO PROCEDURE INADEQUACY
88-15	061688	071588	MAIN STEAM ISOLATION VALVE PNEUMATIC LINE EXCEEDS FSAR DESIGN CRITERIA DUE TO DESIGN DEFICIENCY
88-16	061488	071288	ANTICIPATED TRANSIENT WITHOUT SCRAM SYSTEM ACTUATION DUE TO IN ADEQUATE OPERATOR TRAINING

=====

THIS PAGE INTENTIONALLY LEFT BLANK



1. Docket: 50-331 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. MILLER (319) 851-7204

4. Licensed Thermal Power (Mwt): 1658

5. Nameplate Rating (Gross MWe): 663 X 0.9 = 597

6. Design Electrical Rating (Net MWe): 538

7. Maximum Dependable Capacity (Gross MWe): 545

8. Maximum Dependable Capacity (Net MWe): 515

9. If Changes Occur Above Since Last Report, Give Reasons:  
ITEM 687 WILL VARY TO REFLECT SEASONAL COND.

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>118,319.0</u>
13. Hours Reactor Critical	<u>691.4</u>	<u>5,037.6</u>	<u>85,351.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>172.8</u>
15. Hrs Generator On-Line	<u>676.0</u>	<u>4,999.9</u>	<u>83,255.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,020,499</u>	<u>7,973,308</u>	<u>108,010,589</u>
18. Gross Elec Ener (MWH)	<u>347,801</u>	<u>2,713,539</u>	<u>36,273,367</u>
19. Net Elec Ener (MWH)	<u>326,226</u>	<u>2,541,718</u>	<u>33,985,046</u>
20. Unit Service Factor	<u>90.9</u>	<u>97.8</u>	<u>70.4</u>
21. Unit Avail Factor	<u>90.9</u>	<u>97.8</u>	<u>70.4</u>
22. Unit Cap Factor (MDC Net)	<u>85.1</u>	<u>94.9</u>	<u>55.8</u>
23. Unit Cap Factor (DER Net)	<u>81.5</u>	<u>92.4</u>	<u>53.4</u>
24. Unit Forced Outage Rate	<u>9.1</u>	<u>1.3</u>	<u>14.4</u>
25. Forced Outage Hours	<u>68.0</u>	<u>68.0</u>	<u>13,985.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - 9/29/88 - TWO MONTH DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* DUANE ARNOLD \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DUANE ARNOLD



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DUANE ARNOLD \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	07/24/88	F	68.0	A	3	88-08	IT	VI	INVESTIGATION OF THE CAUSE OF THE HIGH VIBRATION CONDITION DETERMINED THAT THE MONITOR IN QUESTION HAD FAILED RESULTING IN ERRONEOUS INDICATION. THE VIBRATION MONITOR WAS REPLACED AND THE PLANT RETURNED TO POWER OPERATION ON JULY 27. THE ROOT CAUSE OF THE MONITOR FAILURE IS UNDER INVESTIGATION.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
DUANE ARNOLD INCURRED ONE FORCED OUTAGE IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
X DUANE ARNOLD X  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....IOWA  
  
COUNTY.....LINN  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NW OF  
CEDAR RAPIDS, IA  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...MARCH 25, 1974  
  
DATE ELEC ENER 1ST GENER...MAY 19, 1974  
  
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1975  
  
CONDENSER COOLING METHOD...COOLING TOWER  
  
CONDENSER COOLING WATER...CEDAR RAPIDS RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....IOWA ELECTRIC LIGHT & POWER  
  
CORPORATE ADDRESS.....I E TOWERS, P.O. BOX 351  
CEDAR RAPIDS, IOWA 52406  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
  
CONSTRUCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
  
IE RESIDENT INSPECTOR.....M. PARKER  
  
LICENSING PROJ MANAGER.....J. HALL  
DUCKET NUMBER.....50-331  
  
LICENSE & DATE ISSUANCE...DPR-49, FEBRUARY 22, 1974  
  
PUBLIC DOCUMENT ROOM.....CEDAR RAPIDS PUBLIC LIBRARY  
500 FIRST STREET, S.E.  
CEDAR RAPIDS, IOWA 52401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 16 THROUGH JUNE 13 (88009): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, LICENSEE EVENT REPORTS, INFORMATION NOTICES, OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCE, FOLLOWUP OF EVENTS, REPORT REVIEW, AND MANAGEMENT MEETING. DURING THIS INSPECTION PERIOD THE PLANT HAS OPERATED NEAR 100 PERCENT POWER WITH PERIODIC POWER REDUCTIONS FOR MAINTENANCE AND SURVEILLANCE TESTING. THE PLANT CONDUCTED A SHORT DURATION OUTAGE TO INVESTIGATE AND REPAIR A NITROGEN LEAK IN THE DRYWELL. THE PLANT ALSO PERFORMED A SINGLE LOOP OPERATION. THROUGHOUT THIS INSPECTION PERIOD, SEVERAL AREAS WERE OBSERVED. THERE WERE SEVERAL INSPECTIONS CONDUCTED IN THE AREA OF QA BY DRS (DIVISION OF REACTOR SAFETY). IN GENERAL ALL AREAS INSPECTED WERE ADEQUATE, BUT THE LICENSEE EXHIBITED SOME DIFFICULTIES IN PERFORMING SELECTED SURVEILLANCE AND PROBLEMS NOTED WITH THE PLANT PROCESS COMPUTER. THE LICENSEE IS CONTINUING TO UPGRADE THEIR SURVEILLANCE TEST PROCEDURE PROGRAM THROUGH THEIR ONGOING SURVEILLANCE TEST EVALUATION AND ENHANCEMENT PROGRAM (STEEP). THE PLANT IS ALSO CONTINUING TO RESOLVE PROBLEMS WITH THE PLANT PROCESS COMPUTER. OVERALL, THE PLANT CONTINUES TO OPERATE SATISFACTORILY AND IS SHOWING SOME IMPROVEMENTS IN THEIR STEEP, AND ALSO WITHIN THEIR QA ENHANCEMENT PROGRAM. OF THE NINE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN SEVEN AREAS; ONE VIOLATION WAS IDENTIFIED IN THE REMAINING AREAS (FAILURE TO INCREASE THE OPERATING LIMIT MCPR AS REQUIRED BY SINGLE LOOP OPERATION SURVEILLANCE TEST PROCEDURE (STP) 46F002 AND FAILURE TO HAVE SGBT SYSTEM HAND SWITCHES HS-5825A AND HS-5825B IN THE OPEN POSITION AS REQUIRED BY OPERATING INSTRUCTION (OI) NO. 170). THE VIOLATION CONSISTED OF TWO EXAMPLES OF FAILURE TO ADEQUATELY FOLLOW PROCEDURES AS DELINEATED IN DAEC TECHNICAL SPECIFICATION SECTION 6.8.1.

INSPECTION ON MAY 23-26, 31; JUNE 1-3 (88013): SPECIAL UNANNOUNCED INSPECTION BY ONE REGIONAL INSPECTOR OF THE LICENSEE'S QUALITY ENHANCEMENT PROGRAM AND ITS IMPACT ON PROCUREMENT CONTROL; RECEIPT AND HANDLING OF EQUIPMENT AND MATERIALS, DESIGN SUPPORT,

INSPECTION SUMMARY

SURVEILLANCES, AND THE AUDIT PROGRAM. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE QUALITY ENHANCEMENT PROGRAM WAS DETERMINED TO BE ESSENTIALLY ON TARGET WITH COMMITMENTS, AND ON SCHEDULE.

INSPECTION ON JUNE 20-23 (88015): INCLUDED A REVIEW OF SECURITY MANAGEMENT EFFECTIVENESS; LOCKS, KEYS, AND COMBINATIONS, SECURITY SYSTEM POWER SUPPLY; LIGHTING; ACCESS CONTROL-VEHICLES; DETECTION AIDS-PROTECTED AND VITAL AREAS; SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW AND FOLLOWUP ON PREVIOUS INSPECTION AND REGULATORY EFFECTIVENESS REVIEW (RER) FINDINGS. ALSO REVIEWED WAS THE LICENSEE RESPONSE TO A FITNESS FOR DUTY ALLEGATION. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED. ONE PREVIOUS VIOLATION DEALING WITH AN INADEQUATE PROTECTED AREA BARRIER WAS CLOSED AND ONE OPEN ITEM PERTAINING TO A RESPONSE FORCE CALL-IN PROCEDURE WILL REMAIN OPEN PENDING SUBMITTAL OF A 10 CFR 50.90 PLAN CHANGE. IN ADDITION, ALL REGULATORY EFFECTIVENESS REVIEW (RER) FINDINGS WERE REVIEWED AND ARE CLOSED. FIVE ADDITIONAL ISSUES WERE IDENTIFIED PERTAINING TO FITNESS FOR DUTY REQUIREMENTS, REPORTABILITY OF SECURITY EVENTS, SECURITY FORCE MANNING, LIGHTING AND CONTINGENCY EQUIPMENT. THESE ISSUES REQUIRE SENIOR MANAGEMENT ATTENTION AND SUPPORT FOR RESOLUTION.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: 07/23/88

INSPECTION REPORT NO: 88016

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-04	060988	071188	HIGH PRESSURE COOLANT INJECTION SYSTEM INOPERABILITY FROM INADEQUATE PERIODIC INSPECTION OF GOVERNOR ACTUATOR AND FAILED OIL SYSTEM PRESSURE MICROSWITCH
88-06	070988	080588	REACTOR WATER CLEANUP ISOLATION DUE TO FAILURE OF RILEY PANALARM TEMPERATURE SWITCH

=====

THIS PAGE INTENTIONALLY LEFT BLANK


1. Docket: 50-348 OPERATING STATUS
2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: J. D. HOODARD (205) 899-5156
4. Licensed Thermal Power (MWT): 2652
5. Nameplate Rating (Gross MWe): 860
6. Design Electrical Rating (Net MWe): 829
7. Maximum Dependable Capacity (MWe): 853
8. Maximum Dependable Capacity (MWe): 813
9. If Changes Occur Above St. Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe):
11. Reasons for Restrictions, If Any:         
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>93,503.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,766.7</u>	<u>68,983.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,650.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,718.3</u>	<u>67,543.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,973,088</u>	<u>9,535,975</u>	<u>171,959,292</u>
18. Gross Elec Ener (MWH)	<u>638,334</u>	<u>3,097,758</u>	<u>55,164,094</u>
19. Net Elec Ener (MWH)	<u>606,370</u>	<u>2,924,282</u>	<u>52,093,478</u>
20. Unit Service Factor	<u>100.0</u>	<u>72.8</u>	<u>72.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>72.8</u>	<u>72.2</u>
22. Unit Cap Factor (MDC Net)	<u>100.2</u>	<u>70.4</u>	<u>69.2*</u>
23. Unit Cap Factor (DER Net)	<u>98.3</u>	<u>69.0</u>	<u>67.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.6</u>	<u>9.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>22.8</u>	<u>6,845.9</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Stop Date: <u>N/A</u>			

\*\*\*\*\*  
\* FARLEY 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 1



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

XX  
\* FARLEY 1 \*  
XX

No.   Date   Type   Hours   Reason   Method   LER Number   System Component   Cause & Corrective Action to Prevent Recurrence

NONE

XXXXXXXXXXXX      FARLEY 1 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
\* SUMMARY \*      SIGNIFICANT POWER REDUCTIONS.  
XXXXXXXXXXXX

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Plant or Test	2-Manual Scram	Instructions for
	C-Relabeling	3-Auto Scram	Preparation of
	D-Regulator Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (KUREG-0161)



\*\*\*\*\*  
\* FARLEY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....HOUSTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...18 MI SE OF  
DOTHAN, ALA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 3, 1977  
DATE ELEC ENER 1ST GENER...AUGUST 18, 1977  
DATE COMMERCIAL OPERATE...DECEMBER 1, 1977  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ALABAMA POWER CO.  
CORPORATE ADDRESS.....600 NORTH 18TH STREET  
BIRMINGHAM, ALABAMA 35203  
CONTRACTOR  
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. BRADFORD  
LICENSING PROJ MANAGER.....E. REEVES  
DOCKET NUMBER.....50-348  
LICENSE & DATE ISSUANCE...NPF-2, JUNE 25, 1977  
PUBLIC DOCUMENT ROOM.....HOUSTON/LOVE MEMORIAL LIBRARY  
212 W. BURDESHAW STREET  
DOTHAN, ALABAMA 36302

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 11 - JUNE 10 (88-19): THIS ROUTINE ON-SITE INSPECTION INVOLVED A REVIEW OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, RADIOLOGICAL PROTECTION PROGRAM, PHYSICAL SECURITY PROGRAM, LICENSEE EVENT REPORTS, DESIGN, DESIGN CHANGES AND MODIFICATIONS, 10 CFR 50.59 SAFETY EVALUATIONS, UNIT 1 STARTUP FROM REFUELING, COMPLIANCE WITH ATWS RULE, GENERIC LETTER 83-28, AND ACTION ON PREVIOUS INSPECTION FINDINGS. WITHIN THE AREAS INSPECTED, THE FOLLOWING VIOLATIONS WERE IDENTIFIED: FAILURE TO FOLLOW PROCEDURES FOR STORAGE OF COMPRESSED GAS CYLINDERS; FAILURE TO PROVIDE ADEQUATE OPERABILITY INSPECTIONS OF UNIT 1 POST ACCIDENT CONTAINMENT VENTILATION FILTER UNIT; AND, FAILURE TO PROVIDE ADEQUATE 10 CFR 50.59 EVALUATION FOR EMERGENCY LIGHTING SYSTEM IN UNIT 1 CONTAINMENT.

INSPECTION JUNE 13-17 (88-22): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF: VITAL AREA BARRIERS; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL OF PERSONNEL, PACKAGES, AND VEHICLES; COMMUNICATIONS; AND DETECTION AIDS - VITAL AREAS. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION JUNE 11 - JULY 10 (88-23): THIS ROUTINE ON-SITE INSPECTION INVOLVED A REVIEW OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY SYSTEM INSPECTION, RADIOLOGICAL PROTECTION PROGRAM AND PHYSICAL SECURITY PROGRAM, LICENSEE EVENT REPORTS, AND FOLLOWUP OF EVENTS. WITHIN THE AREAS INSPECTED, THE FOLLOWING VIOLATION WAS IDENTIFIED: FAILURE TO REMOVE CHAPCOAL FILTER UNITS FROM UNIT 2 PENETRATION ROOM VENTILATION EQUIPMENT ROOM.



NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-017	06/15/88	07/13/88	TECHNICAL SPECIFICATION ACTION STATEMENT REQUIREMENT NOT MET FOR AN INOPERABLE FIRE HOSE STATION

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-364 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. HOODARD (205) 899-5156

4. Licensed Thermal Power (Mwt): 2652

5. Nameplate Rating (Gross MWe): 860

6. Design Electrical Rating (Net MWe): 829

7. Maximum Dependable Capacity (Gross MWe): 864

8. Maximum Dependable Capacity (Net MWe): 823

9. If Charges Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>61,416.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,111.0</u>	<u>52,999.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>138.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,111.0</u>	<u>52,359.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.2</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,973,019</u>	<u>13,508,930</u>	<u>134,461,050</u>
18. Gross Elec Ener (MWH)	<u>643,100</u>	<u>4,463,586</u>	<u>43,665,680</u>
19. Net Elec Ener (MWH)	<u>612,476</u>	<u>4,255,130</u>	<u>41,406,868</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>85.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>85.3</u>
22. Unit Cap Factor (MDC Net)	<u>100.0</u>	<u>101.2</u>	<u>81.9</u>
23. Unit Cap Factor (DER Net)	<u>99.3</u>	<u>100.4</u>	<u>81.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>4.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,690.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Start-up Date: N/A

\*\*\*\*\*  
\* FAYLEY 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FAYLEY 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
FARLEY 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*/\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....HOUSTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...28 MI SE OF  
DOTHAN, ALA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 5, 1981  
DATE ELEC ENER 1ST GENER...MAY 25, 1981  
DATE COMMERCIAL OPERATE...JULY 30, 1981  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ALABAMA POWER CO.  
CORPORATE ADDRESS.....600 NORTH 18TH STREET  
BIRMINGHAM, ALABAMA 35203  
CONTRACTOR  
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. BRADFORD  
LICENSING PROJ MANAGER.....E. REEVES  
DOCKET NUMBER.....50-364  
LICENSE & DATE ISSUANCE...NPF-8, MARCH 31, 1981  
PUBLIC DOCUMENT ROOM.....HOUSTON/LOVE MEMORIAL LIBRARY  
212 W. BURDESHAW STREET  
DOTHAN, ALABAMA 36302

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 11 - JUNE 10 (88-19): THIS ROUTINE ON-SITE INSPECTION INVOLVED A REVIEW OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, RADIOLOGICAL PROTECTION PROGRAM, PHYSICAL SECURITY PROGRAM, LICENSEE EVENT REPORTS, DESIGN, DESIGN CHANGES AND MODIFICATIONS, 10 CFR 50.59 SAFETY EVALUATIONS, UNIT 1 STARTUP FROM REFUELING, COMPLIANCE WITH ATWS RULES, GENERIC LETTER 83-28, AND ACTION ON PREVIOUS INSPECTION FINDINGS. WITHIN THE AREAS INSPECTED, THE FOLLOWING VIOLATIONS WERE IDENTIFIED: FAILURE TO FOLLOW PROCEDURES FOR STORAGE OF COMPRESSED GAS CYLINDERS; FAILURE TO PROVIDE ADEQUATE OPERABILITY INSPECTIONS OF UNIT 1 POST ACCIDENT CONTAINMENT VENTILATION FILTER UNIT; AND, FAILURE TO PROVIDE ADEQUATE 10 CFR 50.59 EVALUATION FOR EMERGENCY LIGHTING SYSTEM IN UNIT 1 CONTAINMENT.

INSPECTION JUNE 13-17 (88-22): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF: VITAL AREA BARRIERS; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL OF PERSONNEL, PACKAGES, AND VEHICLES; COMMUNICATIONS; AND DETECTION AIDS VITAL AREAS. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION JUNE 11 - JULY 10 (88-23): THIS ROUTINE ON-SITE INSPECTION INVOLVED A REVIEW OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY SYSTEM INSPECTION, RADIOLOGICAL PROTECTION PROGRAM AND PHYSICAL SECURITY PROGRAM, LICENSEE EVENT REPORTS, AND FOLLOWUP OF EVENTS. WITHIN THE AREAS INSPECTED, THE FOLLOWING VIOLATION WAS IDENTIFIED: FAILURE TO REMOVE CHARCOAL FILTER UNITS FROM UNIT 2 PENETRATION ROOM VENTILATION EQUIPMENT ROOM.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.12.1 AND TS 6.12.2: (1) ON DECEMBER 28, 1987, TWO DECONTAMINATION WORKERS ENTERED ROOM 450/449 IN THE UNIT 1 AUXILIARY BUILDING, A HIGH RADIATION AREA, IN WHICH THE INTENSITY OF RADIATION WAS IN EXCESS OF 100 MILLIREM PER HOUR, WITHOUT HAVING IN THEIR POSSESSION ONE OF THE REQUIRED RADIATION MONITORING DEVICES AND WITHOUT BEING ACCOMPANIED BY A HEALTH PHYSICS QUALIFIED INDIVIDUAL WHO MAINTAINED POSITIVE CONTROL OVER THE WORKERS' ACTIVITIES. (2) AS OF DECEMBER 28, 1987, A RADIOLOGICAL EXCLUSION AREA LOCATED IN ROOM 450/449, WHICH WAS ACCESSIBLE TO PERSONNEL AND WHICH HAD RADIATION LEVELS SUCH THAT A MAJOR PORTION OF THE BODY COULD RECEIVE IN ONE HOUR A DOSE GREATER THAN 1,000 MILLIREM, WAS NOT PROVIDED WITH LOCKED DOORS, BUT WAS PROVIDED WITH THREE YELLOW AND MAGENTA ROPES, RADIOLOGICAL WARNING SIGNS, AND A FLASHING RED LIGHT, WHICH WERE NOT ADEQUATE TO PREVENT UNAUTHORIZED ENTRY. CONTRARY TO TS 6.8.1, REGULATORY GUIDE 1.33, APPENDIX A, SECTION 7.E(1), PLANT PROCEDURE FNP-O-RCP-2, PLANT PROCEDURE FNP-O-M-001, HEALTH PHYSICS MANUAL, SECTION 6.3.6, AND SECTION 4.1.1.1.7, AND RWP 87-0010: (1) ON DECEMBER 28, 1987, A DECONTAMINATION WORKER ENTERED A HIGH RADIATION/EXCLUSION AREA WITH DOSE RATES UP TO APPROXIMATELY 150 REM PER HOUR AT 18 INCHES FROM THE SPENT FUEL POOL DEMINERALIZER WITHOUT HAVING A SPECIAL RWP PRIOR TO ENTRY. (2) ON DECEMBER 28, 1987, TWO INDIVIDUALS ENTERED A HIGH RADIATION AREA (ROOM 450) ON ROUTINE RWP 87-0010 TO PERFORM ROUTINE DECONTAMINATION OF ARTICLES AND EQUIPMENT WITHOUT HIGH RANGE DOSIMETERS AS REQUIRED BY THE RWP. CONTRARY TO 10 CFR 19.12, THREE CONTRACT DECONTAMINATION EMPLOYEES WORKING IN ROOM 450/449 IN THE UNIT 1 AUXILIARY BUILDING (A RESTRICTED AREA) ON DECEMBER 28, 1987, WERE NOT ADEQUATELY INSTRUCTED IN THE PRECAUTIONS OR PROCEDURES TO MINIMIZE EXPOSURE FOR ENTRY INTO EXCLUSION AREAS. (8800 3)

CONTRARY TO 10 CFR 20.201(A) AND (B), THE REQUIREMENT TO PERFORM EVALUATIONS NECESSARY TO DEMONSTRATE COMPLIANCE WITH 10 CFR 20.201(B) AND 20.201(A) WAS NOT MET IN THAT THE LICENSEE FAILED TO MAKE ATTENUATION CORRECTIONS FOR CALIBRATING DETECTORS WITH SOLID GEOMETRIES WHICH RESULTED IN INACCURATE GAMMA SPECTROSCOPY MEASUREMENTS OF GASEOUS RADIOACTIVE MATERIAL RELEASED TO THE ENVIRONMENT. THESE MEASUREMENTS WERE USED TO DETERMINE COMPLIANCE WITH 10 CFR 20.106, TS AND THE OFFSITE DOSE CALCULATIONS MANUAL REQUIREMENTS. (8801 5)

OTHER ITEMS

## SYSTEMS AND COMPONENT PROBLEMS:

LICENSEE CONTINUES TENDON FIELD ANCHORS INSPECTION.

## FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

## MANAGERIAL ITEMS:

## PLANT STATUS:

LAST IE SITE INSPECTION DATE: JULY 10, 1988

INSPECTION REPORT NO: 50-364/88-23



Report Period JUL 1988

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			

.....

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-341 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: P. M. ANTHONY (313) 586-1617

4. Licensed Thermal Power (MWT): 3292

5. Nameplate Rating (Gross MWe): 1215

6. Design Electrical Rating (Net MWe): 1093

7. Maximum Dependable Capacity (Gross MWe): 1093

8. Maximum Dependable Capacity (Net MWe): 1093

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>4,573.0</u>	<u>4,573.0</u>
13. Hours Reactor Critical	<u>543.2</u>	<u>2,621.1</u>	<u>2,621.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>537.5</u>	<u>2,517.8</u>	<u>2,517.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,669,898</u>	<u>6,515,540</u>	<u>6,515,540</u>
18. Gross Elec Ener (MWH)	<u>557,802</u>	<u>2,118,955</u>	<u>2,118,955</u>
19. Net Elec Ener (MWH)	<u>527,638</u>	<u>2,006,532</u>	<u>2,006,532</u>
20. Unit Service Factor	<u>72.2</u>	<u>55.1</u>	<u>55.1</u>
21. Unit Avail Factor	<u>72.2</u>	<u>55.1</u>	<u>55.1</u>
22. Unit Cap Factor (MDC Net)	<u>64.9</u>	<u>40.1</u>	<u>40.1</u>
23. Unit Cap Factor (DER Net)	<u>64.9</u>	<u>40.1</u>	<u>40.1</u>
24. Unit Forced Outage Rate	<u>27.8</u>	<u>9.9</u>	<u>9.9</u>
25. Forced Outage Hours	<u>206.5</u>	<u>278.2</u>	<u>278.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
 X FERM I 2 X  
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FERMI 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FERM I 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-002	07/23/88	F	206.5	A	1	88-026	BJ	V	UNIDENTIFIED LEAKAGE INCREASED UNTIL SHUTDOWN OF THE PLANT IN ACCORDANCE WITH TECHNICAL SPECIFICATION WAS NECESSARY. THREE VALVES WHICH WERE LEAKING WERE REPAIRED AND ITEMS ON THE FORCED OUTAGE SCHEDULE ARE BEING WORKED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
FERMI 2 INCURRED ONE FORCED OUTAGE IN JULY FOR REASONS STATED ABOVE AND REMAINED SHUTDOWN AT END OF MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FERM I 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1985

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
COUNTY.....MONROE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...LAGUNA BEACH, MICH  
TYPE OF REACTOR... BWR  
DATE INITIAL CRITICALITY...JUNE 21, 1985  
DATE ELEC ENER 1ST GENER...SEPTEMBER 21, 1986  
DATE COMMERCIAL OPERATE...JANUARY 23, 1988  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE ERIE  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DETROIT EDISON  
CORPORATE ADDRESS.....2000 SECOND AVENUE  
DETROIT, MICHIGAN 48226  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....NONE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....W. ROGERS  
LICENSING PROJ MANAGER.....T. QUAY  
DOCKET NUMBER.....50-341  
LICENSE & DATE ISSUANCE...NPF-43, JULY 15, 1985  
PUBLIC DOCUMENT ROOM.....MONROE COUNTY LIBRARY SYSTEM  
3700 SOUTH CUSTER ROAD  
MONROE, MI. 48161

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 16-20 AND JUNE 6-10 (88018): SPECIAL, UNANNOUNCED SAFETY INSPECTION OF LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS, MSIV OPEN/CLOSE MANUAL RELAY LOGIC, SURVEILLANCE PROGRAM REVIEW, APPENDIX R-HIGH IMPEDANCE FAULT, DER REVIEW, USE-HISTORY RECORDS, AND ENGINEERING. THE INSPECTION WAS PERFORMED IN ACCORDANCE WITH IE PROCEDURES 92702, 92701, AND 41400. OF THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED (FAILURE TO CONTROL THE REVIEW AND APPROVAL OF MAINTENANCE INSTRUCTIONS AS REQUIRED BY TS 6.8.1 AND FAILURE TO CONTROL USE-HISTORY DOCUMENTS).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE



1. Docket: 50-333 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. COOK (315) 349-6569

4. Licensed Thermal Power (MHT): 2436

5. Nameplate Rating (Gross MWe): 981 X 0.9 = 883

6. Design Electrical Rating (Net MWe): 816

7. Maximum Dependable Capacity (Gross MWe): 805

8. Maximum Dependable Capacity (Net MWe): 778

9. If Changes Occur Above Since Last Report, Give Reasons:  
ITEM 7 & 8 RECALCULATED USING PREVIOUS YEARS DATA.

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>114,072.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,729.3</u>	<u>84,382.0</u>
14. Ex Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,689.9</u>	<u>82,043.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,720,584</u>	<u>11,173,488</u>	<u>178,399,804</u>
18. Gross Elec Ener (MWH)	<u>571,550</u>	<u>3,804,950</u>	<u>60,412,350</u>
19. Net Elec Ener (MWH)	<u>552,115</u>	<u>3,672,240</u>	<u>58,450,710</u>
20. Unit Service Factor	<u>100.0</u>	<u>91.8</u>	<u>71.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>91.8</u>	<u>71.9</u>
22. Unit Cap Factor (MDC Net)	<u>95.4</u>	<u>91.8</u>	<u>65.9*</u>
23. Unit Cap Factor (DER Net)	<u>90.9</u>	<u>88.1</u>	<u>62.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>11.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>10,337.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUEL - 08/26/88 - 75 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* FITZPATRICK \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 FITZPATRICK



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* FITZPATRICK \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	07/01/88	F	0.0	H	5		SG	COND	REDUCED POWER TO CLEAN ALL CONDENSER WATER BOXES THEN RETURNED TO FULL POWER OPERATION.
4	07/16/88	S	0.0	C	5				COMMENCED COAST DOWN TO REFUELING.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 FITZPATRICK INCURRED ONE LOAD REDUCTION IN JULY FOR REASONS STATED ABOVE AND COMMENCED COAST DOWN TO REFUELING ON 7/16/88.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram Instructions for
	C-Refueling	H-Other	3-Auto Scram Preparation of
	D-Regulatory Restriction		4-Continued Data Entry Sheet
	E-Operator Training		5-Reduced Load Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)



\*\*\*\*\*  
\* FITZPATRICK \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUN 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....NEW YORK  
COUNTY.....OSWEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NE OF  
OSWEGO, NY  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...NOVEMBER 17, 1974  
DATE ELEC ENER 1ST GENER...FEBRUARY 1, 1975  
DATE COMMERCIAL OPERATE...JULY 28, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE ONTARIO  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY  
LICENSEE.....NEW YORK POWER AUTHORITY  
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE  
NEW YORK, NEW YORK 10019  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....A. LUPTAK  
LICENSING PROJ MGR.....H. ABELSON  
DOCKET NUMBER.....50-333  
LICENSE & DATE ISSUANCE...D-R-59, OCTOBER 17, 1974  
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO  
PENFIELD LIBRARY - GOVERNMENT DOCUMENTS COL  
OSWEGO, NY 13126  
(315) 341-2323

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):



1. Docket: 50-285                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Du:age + On-line Hrs: 744.0

3. Utility Contact: T. P. MATTHEWS (402) 536-4733

4. Licensed Thermal Power (Mwt):                    1500

5. Nameplate Rating (Gross MWe):                    591 X 0.85 = 502

6. Design Electrical Rating (Net MWe):                    478

7. Maximum Dependable Capacity (Gross MWe):                    502

8. Maximum Dependable Capacity (Net MWe):                    478

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>130,176.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,111.0</u>	<u>102,670.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,309.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,111.0</u>	<u>100,979.9</u>
16. Unit Reserve Shtdwn hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,009,228</u>	<u>6,909,377</u>	<u>131,438,989</u>
18. Gross Elec Ener (MWH)	<u>325,930</u>	<u>2,312,034</u>	<u>43,596,810</u>
19. Net Elec Ener (MWH)	<u>309,051</u>	<u>2,197,648</u>	<u>41,341,716</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>77.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>77.6</u>
22. Unit Cap Factor (MDC Net)	<u>86.9</u>	<u>90.0</u>	<u>68.9*</u>
23. Unit Cap Factor (DER Net)	<u>86.9</u>	<u>90.0</u>	<u>66.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>2.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,857.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - SEPTEMBER 2, 1988 - 76 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* FORT CALHOUN 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT CALHOUN :



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* FORT CALHOUN 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-02	06/18/88	S	0.0	H	S		SD	COND	ON JUNE 18, 1988, POWER WAS REDUCED TO 90% BECAUSE OF A POOR PERFORMING CONDENSER COUPLED WITH HIGH RIVER WATER TEMPERATURE CAUSED HIGH CONDENSER BACK PRESSURE. THE INCREASE IN CONDENSER BACK PRESSURE, ELEVATED THE CONDENSER HOT WELL TEMPERATURE AND CAUSED A REDUCTION IN HYDROGEN COOLING CAPABILITIES. THIS REDUCTION IN COOLING CAPABILITIES IS LIMITING THE ELECTRICAL OUTPUT OF THE GENERATOR. THE UNIT IS REMAINING AT 90%.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 FORT CALHOUN STATION INCURRED ONE POWER REDUCTION IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FORT CALHOUN 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEBRASKA  
COUNTY.....WASHINGTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI N OF  
OMAHA, NEB  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 6, 1973  
DATE ELEC ENER 1ST GENER...AUGUST 25, 1973  
DATE COMMERCIAL OPERATE...JUNE 20, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MISSOURI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....OMAHA PUBLIC POWER DISTRICT  
CORPORATE ADDRESS.....1623 HARNEY STREET  
OMAHA,, NEBRASKA 68102  
CONTRACTOR  
ARCHITECT/ENGINEER.....GIBBS, HILL, DURHAM & RICHARDSON  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....GIBBS, HILL, DURHAM & RICHARDSON  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....P. HARRELL  
LICENSING PROJ MANAGER.....P. MILANO  
DOCKET NUMBER.....50-285  
LICENSE & DATE ISSUANCE...DPR-40, AUGUST 9, 1973  
PUBLIC DOCUMENT ROOM.....W. DALE CLARK LIBRARY  
215 S. 15TH STREET  
OMAHA, NEBRASKA 68102

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1-31, 1988 (88-16) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, PLANT TOURS, SAFETY-RELATED SYSTEM WALKDOWN, MONTHLY MAINTENANCE OBSERVATIONS, MONTHLY SURVEILLANCE OBSERVATIONS, SECURITY OBSERVATIONS, RADIO-LOGICAL PROTECTION OBSERVATIONS, AND IN-OFFICE REVIEW OF PERIODIC AND SPECIAL REPORTS. WITHIN THE EIGHT AREAS INSPECTED, NO VIOLATIONS OR DE-VIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 23-27, 1988 (88-17) ROUTINE, UNANNOUNCED INSPECTION INCLUDING FOLLOW-UP ON PREVIOUSLY IDENTIFIED ITEMS, LICENSEE EVENT REPORT FOLLOW-UP, SECURITY PLAN AND IMPLEMENTING PRO-CEURES, MANAGEMENT EFFECTIVENESS, SECURITY ORGANIZATION, RECORDS AND AND REPORTS, LIGHTING, COMPENSATORY MEASURES, AND PERSONNEL TRAINING AND QUALIFICATION. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 6-10, 1988 (88-18) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S WATER CHEMISTRY AND RADIOCHEMISTRY PROGRAMS, POSTACCIDENT SAMPLING SYSTEM (PASS), AND WATER CHEMISTRY CONFIRMATORY MEASUREMENTS. WITHIN THE AREAS INSPECTED, NO VIOLATION OR DEVIATIONS WERE IDENTIFIED. ONE PREVIOUSLY IDENTIFIED OPEN WAS CLOSED.

INSPECTION CONDUCTED JUNE 21-25, 1988 (88-20) ROUTINE, ANNOUNCED INSPECTION OF THE LICESEE'S PERFORMANCE AND CAPABILIT-IES DURING AN ANNUAL EXERCISE OF THE EMERGENCY PLAN AND PROCEDURES. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. FIFTEEN DEFICIENCIES WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 27-JULY 1, 1988 (88-21) ROUTINE, UNANNOUNCED INSPECTION OF THE CORRECTIVE ACTION PROGRAM. WITHIN THE  
PAGE 2-162

Report Period JUL 1988

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* FORT CALHOUN 1 \*  
\*\*\*\*\*

INSPECTION SUMMARY

AREA INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 29-JULY 18, 1988 (88-22) SPECIAL, UNANNOUNCED INSPECTION OF THE THERMAL MARGIN/LOW PRESSURE REACTOR PROTECTION SYSTEM TRIP SETPOINT AND THE LIMITING CONDITION FOR OPERATION FOR EXCORE MONITORING OF LINEAR HEAT RATE. TWO POTENTIAL VIOLATIONS: (INOPERABILITY OF THE THERMAL MARGIN/LOW PRESSURE TRIP FUNCTION OF THE REACTOR PROTECTION SYSTEM; PARA 5; AND REPORTING OF INACCURATE INFORMATION, PARA 7) WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECH SPEC 5.2.2.E, THE LICENSEE FAILED TO PROVIDE PROPER MANNING ON EACH SHIFT FOR STAFFING OF THE ONSITE FIRE BRIGADE. CONTRARY TO ANSI 18.7-1972 AND PROCEDURE 50-G-7, THREE EXAMPLES OF FAILURE TO FOLLOW PROCEDURE WERE IDENTIFIED. FAILURE TO IMPLEMENT AND FOLLOW PROCEDURES. SAFEGUARDS INFO. FAILURE TO FOLLOW APPROVED PROCEDURES - CROSSTRAIN ISOLATION VALVES IN EMERGENCY DIESEL GENERATOR AIR START SYSTEM WERE OPEN. A REDUNDANT VALVE IN EACH LINE WAS CLOSED. DEFICIENT PROCEDURE - PROCEDURE 50P 45 AND IVL 45-01 FAILED TO ADDRESS ALL OF THESE ISOLATION VALVES IN THE COOLING WATER LINE FROM THE DIESEL DRIVEN FIREWATER PUMP DISCHARGE TO THE DIESEL. FAILURE TO FOLLOW PROCEDURE - FUEL HANDLERS WORKING TO SSR86509136 DISPOSITIONING NCR86-218 HANDLE NEW CONTROL ELEMENTS WITH BARE HANDS IN DIRECT CONFLICT WITH THE STATED GUIDELINES IN THE DISPOSITION TO NCR 86-218. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

90% POWER OPERATION

LAST IE SITE INSPECTION DATE: JULY 18, 1988

INSPECTION REPORT NO: 50-285/88-21

Report Period JUL 1988

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* FORT CALHOUN 1 \*  
\*\*\*\*\*

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE			
.....			

THIS PAGE INTENTIONALLY LEFT BLANK



1. Docket: 59-267 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANK NOVACHEK (303) 785-2224

4. Licensed Thermal Power (Mwt): 842

5. Nameplate Rating (Gross MWe): 403 X 0.85 = 343

6. Design Electrical Rating (Net MWe): 330

7. Maximum Dependable Capacity (Gross MWe): 342

8. Maximum Dependable Capacity (Net MWe): 330

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 271

11. Reasons for Restrictions, If Any:  
REANALYSIS OF SAFE SHUTDOWN COOLING.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>79,656.0</u>
13. Hours Reactor Critical	<u>119.4</u>	<u>3,798.1</u>	<u>37,199.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>113.2</u>	<u>3,487.3</u>	<u>25,068.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>74,262</u>	<u>1,954,374</u>	<u>12,735,787</u>
18. Gross Elec Ener (MWH)	<u>28,121</u>	<u>718,184</u>	<u>4,260,698</u>
19. Net Elec Enr (MWH)	<u>24,804</u>	<u>672,993</u>	<u>3,801,968</u>
20. Unit Service Factor	<u>15.2</u>	<u>68.2</u>	<u>31.5</u>
21. Unit Avail Factor	<u>15.2</u>	<u>68.2</u>	<u>31.5</u>
22. Unit Cap Factor (MDC Net)	<u>10.1</u>	<u>39.9</u>	<u>14.5</u>
23. Unit Cap Factor (DER Net)	<u>10.1</u>	<u>39.9</u>	<u>14.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>22.2</u>	<u>61.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>992.9</u>	<u>39,669.5</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
HELIUM CIRC. REPAIRS, 08/01/88.

27. If Currently Shutdown Estimated Startup Date: 10/11/88

\*\*\*\*\*  
\* FORT ST VRAIN \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT ST VRAIN



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FORT ST VRAIN \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-12	07/05/88	S	630.8	H	1		AB	CMP	REACTOR MANUALLY SHUTDOWN FOR SCHEDULED REPLACEMENT OF HELIUM CIRCULATOR BOLTS. REFER TO LER 87-019.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
FORT ST. VRAIN WAS MANUALLY SHUTDOWN IN JULY FOR SCHEDULED REPLACEMENT OF HELIUM CIRCULATOR BOLTS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FORT ST VRAIN \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....COLORADO  
COUNTY.....WELD  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...35 MI N OF  
DENVER, COL  
TYPE OF REACTOR.....HTGR  
DATE INITIAL CRITICALITY...JANUARY 31, 1974  
DATE ELEC ENER 1ST GENER...DECEMBER 11, 1976  
DATE COMMERCIAL OPERATE....JULY 1, 1979  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....S. PLATTE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE OF COLORADO  
CORPORATE ADDRESS.....P.O. BOX 840  
DENVER, COLORADO 80201  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ATOMIC CORP.  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....R. FARRELL  
LICENSING PROJ MANAGER.....K. HEITNER  
DOCKET NUMBER.....50-267  
LICENSE & DATE ISSUANCE....DPR-34, DECEMBER 21, 1973  
PUBLIC DOCUMENT ROOM.....GREELEY PUBLIC LIBRARY  
CITY COMPLEX BUILDING  
GREELEY, COLORADO 80631

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1-31, 1988 (88-12) ROUTINE, UNANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, LICENSEE EVENT REPORT REVIEW, MONTHLY MAINTENANCE OBSERVATION, MONTHLY SURVEILLANCE OBSERVATION, RADIOLOGICAL PROTECTION, AND MONTHLY SECURITY OBSERVATION. WITHIN THE SIX AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED. ONE DEVIATION WAS IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECH. SPEC. AC 7.4, APPLICABLE PROCEDURES RECOMMENDED IN APP. A OF REG. GUIDE 1.33, 11/72, THE NRC INSPECTORS DETERMINED ON 4/13/88, THAT THE WATER CHEMISTRY INSTRUMENT QUALITY CONTROL CHARTS FOR ANALYSES FOR CHLORIDE BY ION CHROMATOGRAPHY, SILICA BY SPECTROSCOPY, AND IRON AND COPPER BY GRAPHITE FURNACE ATOMIC ABSORPTION HAD NOT BEEN PROPERLY EVALUATED AND SEVERAL EXAMPLES OF OUT-OF-CONTROL SITUATIONS EXISTED FOR EACH OF THE ABOVE ANALYSES DURING THE TIME PERIOD 11/11/87, - 4/13/88, WITH NO DOCUMENTED EVALUATION OR CORRECTIVE ACTION TAKEN AS DIRECTED BY PROCEDURE.  
(8800 5)

OTHER ITEMS

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   ( C O N T I N U E D )

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
\*                    F O R T   S T   V R A I N                    \*  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

80% AT END OF MONTH

LAST IE SITE INSPECTION DATE: MAY 31, 1988

INSPECTION REPORT NO: 50-267/88-12

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE			


=====

1. Docket: 50-244 OPERATING STATUS
2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: ANDREW MC NAMARA (315) 524-4446
4. Licensed Thermal Power (MWT): 1520
5. Nameplate Rating (Gross MWe): 608 X 0.85 = 517
6. Design Electrical Rating (Net MWe): 470
7. Maximum Dependable Capacity (Gross MWe): 490
8. Maximum Dependable Capacity (Net MWe): 470
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe):
11. Reasons for Restrictions, If Any:             
NONE
- |                               | MONTH            | YEAR             | CUMULATIVE         |
|-------------------------------|------------------|------------------|--------------------|
| 12. Report Period Hrs         | <u>744.0</u>     | <u>5,111.0</u>   | <u>163,751.0</u>   |
| 13. Hours Reactor Critical    | <u>728.9</u>     | <u>4,006.2</u>   | <u>128,024.0</u>   |
| 14. Rx Reserve Shtdwn Hrs     | <u>.0</u>        | <u>.0</u>        | <u>1,687.7</u>     |
| 15. Hrs Generator On-Line     | <u>714.3</u>     | <u>3,920.5</u>   | <u>125,568.2</u>   |
| 16. Unit Reserve Shtdwn Hrs   | <u>.0</u>        | <u>.0</u>        | <u>8.5</u>         |
| 17. Gross Therm Ener (MWH)    | <u>1,044,756</u> | <u>5,543,108</u> | <u>176,670,441</u> |
| 18. Gross Elec Ener (MWH)     | <u>345,922</u>   | <u>1,868,470</u> | <u>57,996,056</u>  |
| 19. Net Elec Ener (MWH)       | <u>328,741</u>   | <u>1,771,396</u> | <u>54,985,681</u>  |
| 20. Unit Service Factor       | <u>96.0</u>      | <u>76.7</u>      | <u>76.7</u>        |
| 21. Unit Avail Factor         | <u>96.0</u>      | <u>76.7</u>      | <u>76.7</u>        |
| 22. Unit Cap Factor (MDC Net) | <u>94.0</u>      | <u>73.9</u>      | <u>72.9*</u>       |
| 23. Unit Cap Factor (DER Net) | <u>94.0</u>      | <u>73.9</u>      | <u>72.9*</u>       |
| 24. Unit Forced Outage Rate   | <u>4.0</u>       | <u>7.9</u>       | <u>6.4</u>         |
| 25. Forced Outage Hours       | <u>29.7</u>      | <u>337.5</u>     | <u>4,661.9</u>     |
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE
27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* GINNA \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GINNA



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

XX  
\* GINNA \*  
XX

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-5	07/16/88	F	29.7	A	1	88-006	EA	RELAYX	MANUAL CONTROLLED SHUTDOWN DUE TO A FAULT IN CIRCUIT BREAKER IN OFFSITE POWER TRANSMISSION SYSTEM.

XXXXXXXXXXXX GINNA INCURRED ONE FORCED OUTAGE IN JULY DUE TO A FAULT IN  
\* SUMMARY \*  
CIRCUIT BREAKER.  
XXXXXXXXXXXX

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* GINNA \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YGRK  
COUNTY.....WAYNE  
DIST AND DIRECTION FROM  
NEARFST POPULATION CTR...15 MI NE OF  
ROCHESTER, NY  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...NOVEMBER 8, 1969  
DATE ELEC ENER 1ST GENER...DECEMBER 2, 1969  
DATE COMMERCIAL OPERATE....JULY 1, 1970  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE ONTARIO  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ROCHESTER GAS & ELECTRIC  
CORPORATE ADDRESS.....89 EAST AVENUE  
ROCHESTER, NEW YORK 14604  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....C. MARSCHALL  
LICENSING PROJ MANAGER....C. STAHL  
DOCKET NUMBER.....50-244  
LICENSE & DATE ISSUANCE...DPR-18, DECEMBER 10, 1984  
PUBLIC DOCUMENT ROGM.....ROCHESTER PUBLIC LIBRARY  
BUSINESS AND SOCIAL SCIENCE DIVISION  
115 SOUTH AVENUE  
ROCHESTER, NEW YORK 14510

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.13 "HIGH RADIATION AREA" ON FEBRUARY 15, 1988, AT APPROXIMATELY 1830, A GROUP OF FOUR INDIVIDUALS WAS NOTED WORKING ON THE PRESSURIZER INTERMEDIATE PLATFORM, A POSTED HIGH RADIATION AREA IN THE CONTAINMENT. THE GROUP DID NOT HAVE A RADIATION SURVEY METER OR ALARMING DOSIMETER IN THEIR POSSESSION. ADDITIONALLY, NO HEALTH PHYSICS PERIODIC SURVEILLANCE FREQUENCY WAS SPECIFIED ON THE CONTROLLING WORK PERMIT. CONTRARY TO TS 6.8 "PROCEDURES" NO DESCRIPTION OF RADIATION HAZARDS WHICH MAY BE ENCOUNTERED (I.E., RADIATION OR CONTAMINATION LEVELS) WAS INCLUDED ON SWP 520290, 520475 AND 520947. THESE PERMITS WERE VERIFIED TO HAVE BEEN USED BY WORKERS. ALSO, NO DOCUMENTATION OF HP COVERAGE WAS MADE EITHER BY USE OF ATTACHMENT V OR BY HP SIGN-IN ON THE WORK SWP, FOR SWP NOS 20342, 20387 OR 20337. EACH OF THESE SWPS REQUIRED HP SURVEY EVERY 60 MINUTES. CONTRARY TO PROCEDURE HP-2.2.1 "WHOLE BODY COUNTER SOURCE CHECK" ON JANUARY 19, JANUARY 25, AND FEBRUARY 15, 1988 THE DAILY SOURCE CHECK RESULTS FELL ABOVE THE (3 SIGMA CONTROL LIMIT AND THE WHOLE BODY COUNTER CONTINUED TO BE UTILIZED TO COUNT PERSONNEL.  
(8800 4)





1. Docket: 50-416                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: S. H. HOBBS (601) 969-2458

4. Licensed Thermal Power (MWT):                      3833

5. Nameplate Rating (Gross MWe):                      1373

6. Design Electrical Rating (Net MWe):                      1250

7. Maximum Dependable Capacity (Gross MWe):                      1190

8. Maximum Dependable Capacity (Net MWe):                      1142

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>27,048.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,896.9</u>	<u>20,608.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,766.5</u>	<u>19,889.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,766,968</u>	<u>17,463,247</u>	<u>66,858,919</u>
18. Gross Elec Ener (MWH)	<u>890,810</u>	<u>5,800,320</u>	<u>20,991,730</u>
19. Net Elec Ener (MWH)	<u>855,219</u>	<u>5,574,445</u>	<u>20,053,639</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.3</u>	<u>73.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.3</u>	<u>73.5</u>
22. Unit Cap Factor (MDC Net)	<u>100.7</u>	<u>95.5</u>	<u>64.9</u>
23. Unit Cap Factor (DER Net)	<u>92.0</u>	<u>87.3</u>	<u>59.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.4</u>	<u>6.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>221.2</u>	<u>1,329.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 X                      GRAND GULF 1                      X  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

GRAND GULF 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* GRAND GULF 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
88-5	07/01/88	S	0.0	B	5			ROD SEQUENCE EXCHANGE AND SCRAM TIME TESTING.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
GRAND GULF 1 INCURRED ONE LOAD REDUCTION DURING JULY FOR ROD SEQUENCE EXCHANGE AND SCRAM TIME TESTING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* GRAND GULF 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MISSISSIPPI  
COUNTY.....CLAIBORNE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI S OF  
VICKSBURG, MISS  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 18, 1982  
DATE ELEC ENER 1ST GENER...OCTOBER 20, 1984  
DATE COMMERCIAL OPERATE...JULY 1, 1985  
CONDENSER COOLING METHOD...CCHNDCT  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....MISSISSIPPI POWER & LIGHT COMPANY  
CORPORATE ADDRESS.....P.O. BOX 1640  
JACKSON, MISSISSIPPI 39205  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. BUTCHER  
LICENSING PROJ MANAGER.....L. KINTNER  
DOCKET NUMBER.....50-416  
LICENSE & DATE ISSUANCE...NPF-29, NOVEMBER 1, 1984  
PUBLIC DOCUMENT ROOM.....HINDS JUNIOR COLLEGE  
MC LENDON LIBRARY  
RAYMOND, MISSISSIPPI 39154

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION APRIL 16 - MAY 20 (88-08): THIS ROUTINE INSPECTION WAS CONDUCTED BY THE RESIDENT INSPECTORS AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, INSPECTOR FOLLOWUP AND UNRESOLVED ITEMS, AND INFORMATION MEETING WITH LOCAL OFFICIALS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MAY 23-27 (88-10): THIS SPECIAL ANNOUNCED INSPECTION WAS PERFORMED TO ASSESS THE LICENSEE'S RESPONSE TO GENERIC LETTER 83-28. REQUIRED ACTIONS BASED ON GENERIC IMPLICATIONS OF SALEM ANTICIPATED TRANSIENT WITHOUT SCRAM (ATWS) EVENTS. AREAS INSPECTED INCLUDED POST-TRIP REVIEW, EQUIPMENT CLASSIFICATION AND VENDOR INTERFACE, POST-MAINTENANCE TESTING, REACTOR TRIP SYSTEM (RTS) RELIABILITY, LICENSEE'S ACTION ON IEB'S, IEN'S, AND PREVIOUS INSPECTION FINDINGS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 6-10 (88-11): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF ENGINEERING DESIGN, PLANT MODIFICATIONS, AND CALIBRATION FOR INSTRUMENTATION SYSTEMS TO COMPLY WITH REGULATORY GUIDE 1.97. FOLLOWUP OF OPEN ITEMS FROM PREVIOUS INSPECTIONS INVOLVED ENGINEERING, OPERATIONS AND MAINTENANCE OF ELECTRICAL EQUIPMENT. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED. HOWEVER, AN UNRESOLVED MATTER WAS IDENTIFIED INVOLVING INSTRUMENTATION FOR THE DRYWELL PRESSURE. IN GENERAL, THE LICENSEE'S ORGANIZATION PERFORMED QUITE EFFECTIVELY IN CARRYING OUT ANALYSIS AND IMPLEMENTING MODIFICATIONS TO COMPLY WITH THE COMPREHENSIVE SET OF REQUIREMENTS CONTAINED IN REGULATORY GUIDE 1.97.

INSPECTION MAY 21 - JUNE 24 (88-12): THIS ROUTINE INSPECTION WAS CONDUCTED BY THE RESIDENT INSPECTORS AT THE SITE IN THE AREAS OF  
PAGE 2-176

INSPECTION SUMMARY

LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, ESF SYSTEM WALKDOWN, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, INSPECTOR FOLLOWUP AND UNRESOLVED ITEMS, AND REVIEW OF QUALITY ASSURANCE FOR UNIT 2 EXTENDED CONSTRUCTION DELAY. ALL AREAS EXCEPT FOR UNIT 2 EXTENDED CONSTRUCTION DELAY APPLIES ONLY TO UNIT 1. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING INADVERTENT AUXILIARY LOSE OIL PUMP STARTS ON THE DIVISION 2 DIESEL GENERATOR.

INSPECTION JUNE 25 - JULY 15 (88-14): THIS ROUTINE INSPECTION WAS CONDUCTED BY THE RESIDENT INSPECTORS AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, ESF SYSTEM WALKDOWN, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, INSPECTOR FOLLOWUP AND UNRESOLVED ITEMS, AND DESIGN, DESIGN CHANGES AND MODIFICATIONS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

IN STARTUP FOLLOWING REFUELING AND REPAIR OF NO. 10 MAIN GENERATOR BEARING.

LAST IE SITE INSPECTION DATE: JULY 29, 1988 +

INSPECTION REPORT NO: 50-416/88-16 +

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

1. Docket: 50-213 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. STANFORD (203) 267-2556 X452

4. Licensed Thermal Power (MWT): 1825

5. Nameplate Rating (Gross MWe): 667 X 0.9 = 600

6. Design Electrical Rating (Net MWe): 582

7. Maximum Dependable Capacity (Gross MWe): 596

8. Maximum Dependable Capacity (Net MWe): 569

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>180,431.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,504.0</u>	<u>148,693.2</u>
14. Rx Reserve Shutdown Hrs	<u>0</u>	<u>0</u>	<u>1,221.2</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,367.8</u>	<u>142,567.9</u>
16. Unit Reserve Shutdown Hrs	<u>0</u>	<u>0</u>	<u>398.0</u>
17. Gross Therm Ener (MWH)	<u>1,355,051</u>	<u>4,009,937</u>	<u>246,779,941</u>
18. Gross Elec Ener (MWH)	<u>452,974</u>	<u>1,296,572</u>	<u>81,076,880</u>
19. Net Elec Ener (MWH)	<u>411,694</u>	<u>1,213,742</u>	<u>76,774,356</u>
20. Unit Service Factor	<u>100.0</u>	<u>46.3</u>	<u>79.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>46.3</u>	<u>79.2</u>
22. Unit Cap Factor (MDC Net)	<u>97.3</u>	<u>41.7</u>	<u>77.7*</u>
23. Unit Cap Factor (DER Net)	<u>95.1</u>	<u>40.8</u>	<u>73.1*</u>
24. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>5.9</u>
25. Forced Outage Hours	<u>0</u>	<u>0</u>	<u>2,432.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date:           

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
HADDAM NECK



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
HADDAM NECK  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 HADDAM NECK OPERATED ROUTINELY IN JULY WITH NO SHUTDOWNS OR  
 SIGNIFICANT LOAD REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	* License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....CONNECTICUT  
COUNTY.....MIDDLESEX  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...13 MI E OF  
MERIDEN, CONN  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...JULY 24, 1967  
DATE ELEC ENER 1ST GEN'R...AUGUST 7, 1967  
DATE COMMERCIAL OPERATE...JANUARY 1, 1968  
CONDENSER COOLING METHOD...D/WCE THRU  
CONDENSER COOLING WATER...CONNECTICUT RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONNECTICUT YANKEE ATOMIC POWER  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. SCHEBLOSKY  
LICENSING PROJ MANAGER.....A. WANG  
DOCKET NUMBER.....50-213  
LICENSE & DATE ISSUANCE...DPR-61, DECEMBER 27, 1974  
PUBLIC DOCUMENT ROOM.....RUSSELL LIBRARY  
123 BROAD STREET  
MIDDLETOWN, CONNECTICUT 06457

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    HADDAM NECK                    \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

.....



1. Bucket: 50-600 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: MARK W. HALE (919) 362-2944

4. Licensed Thermal Power (MWT): 2775

5. Nameplate Rating (Gross MWe): 950

6. Design Electrical Rating (Net MWe): 900

7. Maximum Dependable Capacity (Gross MWe): 920

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reason: NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>10,968.0</u>
13. Hours Reactor Critical	<u>700.4</u>	<u>4,877.6</u>	<u>9,527.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>699.6</u>	<u>4,865.0</u>	<u>9,188.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,709,582</u>	<u>12,106,386</u>	<u>24,256,527</u>
18. Gross Elec Ener (MWH)	<u>561,497</u>	<u>4,396,889</u>	<u>8,062,107</u>
19. Net Elec Ener (MWH)	<u>521,056</u>	<u>4,114,828</u>	<u>7,493,657</u>
20. Unit Service Factor	<u>94.0</u>	<u>95.2</u>	<u>83.8</u>
21. Unit Avail Factor	<u>94.0</u>	<u>95.2</u>	<u>83.8</u>
22. Unit Cap Factor (MDC Net)	<u>81.4</u>	<u>93.6</u>	<u>79.4</u>
23. Unit Cap Factor (DER Net)	<u>77.8</u>	<u>89.5</u>	<u>75.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.0</u>	<u>7.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>201.6</u>	<u>704.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): NONE

27. If Currently Shutdown Estimated Startup Date: 09/23/88

\*\*\*\*\*  
 X HARRIS 1 X  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HARRIS 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* HARRIS 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-013	07/09/88	F	0.0	A	5		HH	VALVOP	TURBINE RUNBACK TO 90% DUE TO THE TRIP OF 1A HEATER DRAIN PUMP.
88-014	07/13/88	S	0.0	F	5		ZZ	ZZZZZZ	LOAD REDUCED TO 90% FOR FUEL CONSERVATION. THE LOAD WAS REDUCED TO 80% ON 7/20/88 AND INCREASED TO 83% ON 7/25/88.
88-015	07/20/88	S	0.0	B	5		HA	VALVEX	LOAD REDUCED TO 70% TO PERFORM TURBINE VALVE TESTING. THE REQUIRED TESTS WERE COMPLETED AND UNIT WAS RETURNED TO 80% FOR FUEL CONSERVATION.
88-016	07/23/88	F	0.0	A	5		HC	H:EXCH	LOAD REDUCED TO 30% DUE TO SECONDARY CHEMISTRY PARAMETERS INDICATION OF A CONDENSER TUBE LEAK.
88-017	07/30/88	S	44.4	C	1	88-021	ZZ	ZZZZZZ	UNIT RAMPED DOWN TO OFF LINE FOR REFUELING OUTAGE. DURING THE RAMP DOWN THE RUNNING MAINFEED PUMP (1B) TRIPPED ON LOW FLOW DUE TO A RECIRC VALVE FAILING TO OPEN ON LOAD DECREASE. AS A RESULT, BOTH MOTOR DRIVEN AFM PUMPS STARTED AS REQUIRED.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 HARRIS 1 INCURRED FOUR LOAD REDUCTIONS DURING JULY AND, SUBSEQUENTLY, RAMPED DOWN TO OFF LINE FOR SCHEDULED REFUELING OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
 STATE.....NORTH CAROLINA  
 COUNTY.....WAKE  
 DIST AND DIRECTION FROM  
 NEAREST POPULATION CTR...20 MI SW OF  
 RALEIGH, NC  
 TYPE OF REACTOR.....PWR  
 DATE INITIAL CRITICALITY...JANUARY 3, 1987  
 DATE ELEC ENER 1ST GENER...JANUARY 19, 1987  
 DATE COMMERCIAL OPERATE...MAY 2, 1987  
 CONDENSER COOLING METHOD...NDCT  
 CONDENSER COOLING WATER...MAKEUP RESERVOIR  
 ELECTRIC RELIABILITY  
 COUNCIL.....SOUTHEASTERN ELECTRIC  
 RELIABILITY COUNCIL

UTILITY  
 LICENSEE.....CAROLINA POWER & LIGHT  
 CORPORATE ADDRESS.....356 FAYETTEVILLE STREET,  
 RALEIGH, NORTH CAROLINA 27602  
 CONTRACTOR  
 ARCHITECT/ENGINEER.....EBASCO  
 NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
 CONSTRUCTOR.....DANIEL INTERNATIONAL  
 TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
 IE RESIDENT INSPECTOR.....G. MAXWELL  
 LICENSING PROJ MANAGER.....B. BUCKLEY  
 DOCKET NUMBER.....50-400  
 LICENSE & DATE ISSUANCE...NPF-63, JANUARY 12, 1987  
 PUBLIC DOCUMENT ROOM.....RICHARD B. HARRISON LIBRARY  
 1313 NEW BERN AVE.  
 RALEIGH, N. C., 27610

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

\* INSPECTION MAY 16-19 (88-12): THIS SPECIAL, ANNOUNCED INSPECTION WAS AN EMERGENCY RESPONSE FACILITIES (ERF) APPRAISAL. AREAS EXAMINED DURING THE APPRAISAL INCLUDED A REVIEW OF SELECTED PROCEDURES AND REPRESENTATIVE RECORDS, THE ERFs, AND RELATED EQUIPMENT, AND INTERVIEWS WITH LICENSEE PERSONNEL. SELECTED ACTIVITIES WERE OBSERVED DURING THE 1988 ANNUAL EXERCISE TO ASCERTAIN THE ADEQUACY OF THE ERFs AND RELATED EQUIPMENT. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 21-22 (88-18): THIS SPECIAL, UNANNOUNCED INSPECTION, WAS CONDUCTED IN THE AREA OF NRC BULLETIN 88-05. THE INSPECTION INCLUDED INTERVIEWS WITH RESPONSIBLE LICENSEE PERSONNEL, OBSERVATION OF INVOLVED MATERIALS AND REVIEW OF TEST RECORDS. THE INSPECTION WAS CONDUCTED TO AID IN AN NRC INVESTIGATION RELATED TO THIS BULLETIN. IN THE AREA INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED. THE LICENSEE APPEARED TO HAVE A WELL-PLANNED AND CONTROLLED PROGRAM FOR ADDRESSING THE CONCERNS DESCRIBED IN THE BULLETIN. THE TECHNICAL ASPECTS WERE ADEQUATELY ADDRESSED. MANAGEMENT HAD RECOGNIZED THE IMPORTANCE AND WAS CLEARLY INVOLVED IN ASSURING PROPER RESOLUTION OF THE MATTER.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

## SYSTEMS AND COMPONENT PROBLEMS:

HARRIS HAS NOTIFIED NRC OF WJM MATERIAL (FLANGES) ONSITE. OI HAS TAKEN CUSTODY OF THREE FLANGES KNOWN TO BE FROM A HEAT NOT MEETING SPECIFICATIONS.

## FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

## MANAGERIAL ITEMS:

NONE.

## PLANT STATUS:

+ UNIT SHUTDOWN ON 7/30/88 IN SUPPORT OF SCHEDULED 56 REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: JULY 29, 1988 +

INSPECTION REPORT NO: 50-400/88-23 +

## R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-013	06/03/88	07/05/88	EMERGENCY DIESEL START DUE TO UNDERVOLTAGE ON 1A-SA EMERGENCY BUS
88-015	06/14/88	07/14/88	TECHNICAL SPECIFICATION NON-COMPLIANCE: FAILURE TO OBTAIN VENT STACK SAMPLE WHILE RADIATION MONITOR INOPERABLE
88-016	06/20/88	07/20/88	TECHNICAL SPECIFICATION VIOLATION DUE TO RCS LEAKAGE DETECTION SYSTEMS INOPERABLE

1. Docket: 50-321 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J.M. RICHARDSON (912) 367-7781 X2876

4. Licensed Thermal Power (MWT): 2436

5. Nameplate Rating (Gross MWe): 850

6. Design Electrical Rating (Net MWe): 776

7. Maximum Dependable Capacity (Gross MWe): 789

8. Maximum Dependable Capacity (Net MWe): 756

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):       

11. Reasons for Restrictions, If Any:         
NONE

\*\*\*\*\*  
\* HATCH 1 \*  
\*\*\*\*\*


AVERAGE DAILY POWER LEVEL (MWe) PLOT  
HATCH 1

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>110,305.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,097.9</u>	<u>78,862.8</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-line	<u>744.0</u>	<u>4,082.3</u>	<u>74,779.0</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,758,528</u>	<u>9,469,604</u>	<u>162,224,984</u>
18. Gross Elec Ener (MWH)	<u>563,250</u>	<u>3,036,330</u>	<u>52,415,710</u>
19. Net Elec Ener (MWH)	<u>538,660</u>	<u>2,889,693</u>	<u>49,820,912</u>
20. Unit Service Factor	<u>100.0</u>	<u>78.3</u>	<u>67.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>78.3</u>	<u>67.8</u>
22. Unit Cap Factor (MDC Net)	<u>95.8</u>	<u>74.8</u>	<u>59.7</u>
23. Unit Cap Factor (DER Net)	<u>93.3</u>	<u>72.9</u>	<u>58.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>19.0</u>	<u>13.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>938.1</u>	<u>11,801.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUELING - SEPTEMBER 28, 1988; 75 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* HATCH 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-008	07/06/88	S	0.0	B	5		HC	HTEXCH	REDUCED LOAD FOR CONDENSER TUBE LEAK INSPECTION.
88-009	07/31/88	S	0.0	B	5		HC	HTEXCH	REDUCED LOAD FOR CONDENSER TUBE LEAK INSPECTION. WHILE AT REDUCED POWER PERFORMED A ROD PATTERN ADJUSTMENT AND THE REQUIRED WEEKLY TURBINE TESTING.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 HATCH 1 INCURRED TWO SCHEDULED LOAD REDUCTIONS DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
\* HATCH 1 \*  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXX

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....GEORGIA  
COUNTY.....APPLING  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI N OF  
BAXLEY, GA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 12, 1974  
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1974  
DATE COMMERCIAL OPERATE...DECEMBER 31, 1975  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...ALTAMAHA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GEORGIA POWER  
CORPORATE ADDRESS.....555 PIEDMONT AVENUE  
ATLANTA, GEORGIA 30308  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....GEORGIA POWER CO.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....P. HOLMES RAY  
LICENSING PROJ MANAGER.....L. CROCKER  
DOCKET NUMBER.....50-321  
LICENSE & DATE ISSUANCE...DPR-57, OCTOBER 13, 1974  
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY  
501 CITY HALL DRIVE  
BAXLEY, GEORGIA 31513

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

\* INSPECTION MAY 2-10 (88-12): SPECIAL ANNOUNCED TEAM INSPECTION OF THE EMERGENCY OPERATING PROCEDURES (EOPS) TO INCLUDE A COMPARISON OF THE EOPS WITH THE BWR OWNERS GROUP EMERGENCY PROCEDURE GUIDELINES AND THE PLANT SPECIFIC TECHNICAL GUIDELINES FOR TECHNICAL ADEQUACY, REVIEWS OF THE EOPS THROUGH CONTROL ROOM AND PLANT WALKDOWNS, EVALUATION OF THE EOPS ON THE PLANT SIMULATOR, HUMAN FACTOR ANALYSIS OF THE EOPS, EOP TRAINING, ON-GOING EVALUATION PROGRAM FOR EOPS, QA MEASURES, QUALITY OF THE CONTROL ROOM DRAWINGS AND AN EVALUATION OF THE CONTAINMENT VENTING PROVISIONS.

INSPECTION MAY 21 - JUNE 24 (88-17): THIS ROUTINE INSPECTION WAS CONDUCTED AT THE SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATIONS, SURVEILLANCE TESTING OBSERVATIONS, ESF SYSTEM WALKDOWNS, RADIOLOGICAL PROTECTION, PHYSICAL SECURITY, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, AND LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS. TWO VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED. ONE VIOLATION WAS FOR FAILURE TO ADEQUATELY ESTABLISH AND IMPLEMENT DIESEL GENERATOR BUILDING VENTILATION SYSTEM PROCEDURES. THE SECOND VIOLATION WAS FOR DEFICIENT OPERATING PROCEDURES. THE DEVIATION WAS FOR FAILURE TO PERIODICALLY TEST DIESEL GENERATOR BUILDING VENTILATION SYSTEM THERMOSTATS AND DAMPERS.

INSPECTION JUNE 27 - JULY 1 (88-19): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LIQUID AND GASEOUS RADWASTE MANAGEMENT, LIQUID AND GASEOUS EFFLUENT MONITORING, REACTOR COOLANT CHEMISTRY AND ENVIRONMENTAL MONITORING. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

Report Period JUL 1988

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* HATCH 1 \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JULY 22, 1988

INSPECTION REPORT NO: 50-321/88-22

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-007	05/31/88	06/29/88	LACK OF ADMINISTRATIVE CONTROL CAUSES POTENTIAL EMERGENCY DIESEL GENERATOR INOPERABILITY



1. Docket: 50-366 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. H. RICHARDSON (912) 367-7781 X2878

4. Licensed Thermal Power (Mbt): 2436

5. Nameplate Rating (Gross MWe): 850

6. Design Electrical Rating (Net MWe): 784

7. Maximum Dependable Capacity (Gross MWe): 801

8. Maximum Dependable Capacity (Net MWe): 768

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):       

11. Reasons for Restrictions, If Any:       

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>78,072.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,830.6</u>	<u>55,522.6</u>
14. Rx Reserve Shtdn Hrs	<u>0</u>	<u>0</u>	<u>0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,449.2</u>	<u>53,023.0</u>
16. Unit Reserve Shtdn Hrs	<u>0</u>	<u>0</u>	<u>0</u>
17. Gross Therm Ener (MWH)	<u>1,772,400</u>	<u>5,431,502</u>	<u>114,169,825</u>
18. Gross Elec Ener (MWH)	<u>578,830</u>	<u>1,771,000</u>	<u>37,526,100</u>
19. Net Elec Ener (MWH)	<u>553,939</u>	<u>1,673,162</u>	<u>35,717,674</u>
20. Unit Service Factor	<u>100.0</u>	<u>47.9</u>	<u>67.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>47.9</u>	<u>67.9</u>
22. Unit Cap Factor (MDC Net)	<u>96.9</u>	<u>42.6</u>	<u>59.6</u>
23. Unit Cap Factor (DER Net)	<u>95.0</u>	<u>41.8</u>	<u>58.4</u>
24. Unit Forced Outage Rate	<u>0</u>	<u>29.4</u>	<u>9.6</u>
25. Forced Outage Hours	<u>0</u>	<u>1,021.9</u>	<u>5,605.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* HATCH 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HATCH 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* HATCH 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
88-010	07/02/88	F	0.0	B	S		CD VALVOP	THE MOTOR FOR OUTBOARD MSIV LEAKAGE CONTROL SYSTEM VALVE NO. 2E32-F001P FAILED TO OPERATE PROPERLY DURING A NORMAL SYSTEM SURVEILLANCE AND WAS SUBSEQUENTLY REPAIRED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
HATCH 2 INCURRED ONE FORCED LOAD REDUCTION DURING JULY DUE TO EQUIPMENT FAILURE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & M
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HATCH 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....GEORGIA  
COUNTY.....APPLING  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI N OF  
BAXLEY, GA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JULY 4, 1978  
DATE ELEC ENER 1ST GENER...SEPTEMBER 22, 1978  
DATE COMMERCIAL OPERATE...SEPTEMBER 5, 1979  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...ALTAMAHA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GEORGIA POWER  
CORPORATE ADDRESS.....333 PIEDMONT AVENUE  
ATLANTA, GEORGIA 30308  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....GEORGIA POWER CO.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....P. HOLMES RAY  
LICENSING PROJ MANAGER....L. CROCKER  
DOCKET NUMBER.....50-366  
LICENSE & DATE ISSUANCE...NPF-5, JUNE 13, 1978  
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY  
501 CITY HALL DRIVE  
BAXLEY, GEORGIA 31513

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

\* INSPECTION MAY 2-10 (88-12): SPECIAL ANNOUNCED TEAM INSPECTION OF THE EMERGENCY OPERATING PROCEDURES (EOPS) TO INCLUDE A COMPARISON OF THE EOPS WITH THE BWR OWNERS GROUP EMERGENCY PROCEDURE GUIDELINES AND THE PLANT SPECIFIC TECHNICAL GUIDELINES FOR TECHNICAL ADEQUACY, REVIEWS OF THE EOPS THROUGH CONTROL ROOM AND PLANT WALKDOWNS, EVALUATION OF THE EOPS ON THE PLANT SIMULATOR, HUMAN FACTOR ANALYSIS OF THE EOPS, EOP TRAINING, ON-GOING EVALUATION PROGRAM FOR EOPS, QA MEASURES, QUALITY OF THE CONTROL ROOM DRAWINGS AND AN EVALUATION OF THE CONTAINMENT VENTING PROVISIONS.

INSPECTION MAY 21 - JUNE 24 (88-17): THIS ROUTINE INSPECTION WAS CONDUCTED AT THE SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATIONS, SURVEILLANCE TESTING OBSERVATIONS, ESF SYSTEM WALKDOWNS, RADIOLOGICAL PROTECTION, PHYSICAL SECURITY, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, AND LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS. TWO VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED. ONE VIOLATION WAS FOR FAILURE TO ADEQUATELY ESTABLISH AND IMPLEMENT DIESEL GENERATOR BUILDING VENTILATION SYSTEM PROCEDURES. THE SECOND VIOLATION WAS FOR DEFICIENT OPERATING PROCEDURES. THE DEVIATION WAS FOR FAILURE TO PERIODICALLY TEST DIESEL GENERATOR BUILDING VENTILATION SYSTEM THERMOSTATS AND DAMPERS.

INSPECTION JUNE 27 - JULY 1 (88-19): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LIQUID AND GASEOUS RADWASTE MANAGEMENT, LIQUID AND GASEOUS EFFLUENT MONITORING, REACTOR COOLANT CHEMISTRY AND ENVIRONMENTAL MONITORING. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.



1. Docket: 50-356                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: BRYAN W. GORMAN (609) 529-5400

4. Licensed Thermal Power (MWh):                      5295

5. Nameplate Rating (Gross MWe):                      1118

6. Design Electrical Rating (Net MWe):                      1067

7. Maximum Dependable Capacity (Gross MWe):                      1118

8. Maximum Dependable Capacity (Net MWe):                      1067

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>16,129.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,680.1</u>	<u>11,538.2</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,524.0</u>	<u>11,269.1</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MMH)	<u>2,465,594</u>	<u>11,444,256</u>	<u>35,252,823</u>
18. Gross Elec Ener (MMH)	<u>791,845</u>	<u>3,772,394</u>	<u>11,684,891</u>
19. Net Elec Ener (MMH)	<u>759,077</u>	<u>3,607,192</u>	<u>11,172,230</u>
20. Unit Service Factor	<u>100.0</u>	<u>68.9</u>	<u>79.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>68.9</u>	<u>79.6</u>
22. Unit Cap Factor (MDC Net)	<u>95.6</u>	<u>66.1</u>	<u>74.0</u>
23. Unit Cap Factor (DER Net)	<u>95.6</u>	<u>66.1</u>	<u>74.0</u>
24. Unit Forced Outage R :	<u>.0</u>	<u>2.6</u>	<u>7.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>92.3</u>	<u>852.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

MID-CYCLE - 1/14/89, 21 DAY DURATION.

27. If Currently Shut-down Estimated Startup Date: N/A

\*\*\*\*\*  
 \* HOPE CREEK 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLCT  
 HOPE CREEK 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* HOPE CREEK 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
HOPE CREEK OPERATED ROUTINELY DURING JULY WITH NO OUTAGES OR  
SIGNIFICANT LOAD REDUCTIONS.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HOPE CREEK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
COUNTY.....SALEM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...18 MI SE OF  
WILMINGTON, DEL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JUNE 28, 1986  
DATE ELEC ENER 1ST GENER...AUGUST 1, 1986  
DATE COMMERCIAL OPERATE...DECEMBER 20, 1986  
CONDENSER COOLING METHOD...NDCT  
CONDENSER COOLING WATER...DELAWARE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS  
CORPORATE ADDRESS.....80 PARK PLACE  
NEWARK, NEW JERSEY 07101  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....  
LICENSING PROJ MANAGER.....G. RIVENBARK  
DOCKET NUMBER.....50-354  
LICENSE & DATE ISSUANCE...NPF-57, JULY 25, 1986  
PUBLIC DOCUMENT ROOM.....PENNSVILLE PUBLIC LIBRARY  
190 SOUTH BROADWAY  
PENNSVILLE, N. J. 08070

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION





1. Docket: 50-247 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: K. KRIEGER (914) 526-5155

4. Licensed Thermal Power (Mwt): 2758

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 873

7. Maximum Dependable Capacity (Gross MWe): 885

8. Maximum Dependable Capacity (Net MWe): 849

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>123,480.0</u>
13. Hours Reactor Critical	<u>336.4</u>	<u>3,973.0</u>	<u>84,592.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,867.6</u>
15. Hrs Generator On-Line	<u>318.9</u>	<u>3,785.7</u>	<u>82,182.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>854,192</u>	<u>10,099,100</u>	<u>214,941,970</u>
18. Gross Elec Ener (MWH)	<u>267,196</u>	<u>3,292,382</u>	<u>66,905,938</u>
19. Net Elec Ener (MWH)	<u>252,206</u>	<u>3,153,570</u>	<u>63,289,358</u>
20. Unit Service Factor	<u>42.9</u>	<u>74.1</u>	<u>66.6</u>
21. Unit Avail Factor	<u>42.9</u>	<u>74.1</u>	<u>66.6</u>
22. Unit Cap Factor (MDC Net)	<u>39.9</u>	<u>72.1</u>	<u>60.3*</u>
23. Unit Cap Factor (DER Net)	<u>38.8</u>	<u>70.7</u>	<u>58.7</u>
24. Unit Forced Outage Rate	<u>57.1</u>	<u>11.4</u>	<u>8.9</u>
25. Forced Outage Hours	<u>425.1</u>	<u>488.0</u>	<u>7,746.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* INDIAN POINT 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
INDIAN POINT 2



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* INDIAN POINT 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	07/07/88	F	425.1	A	2		CH	HTEXCH	22 STEAM GENERATOR TUBE LEAK.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
INDIAN POINT 2 INCURRED ONE FORCED OUTAGE IN JULY DUE TO 22  
STEAM GENERATOR TUBE LEAK.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* INDIAN POINT 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
COUNTY.....WESTCHESTER  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI N OF  
NEW YORK CITY, NY  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 22, 1973  
DATE ELEC ENER 1ST GENER...JUNE 26, 1973  
DATE COMMERCIAL OPERATE...AUGUST 1, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...HUDSON RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONSOLIDATED EDISON  
CORPORATE ADDRESS.....4 IRVING PLACE  
NEW YORK, NEW YORK 10003  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....L. ROSSBACH  
LICENSING PROJ MANAGER.....M. BLOSSON  
DOCKET NUMBER.....50-217  
LICENSE & DATE ISSUANCE...DPR-26, SEPTEMBER 28, 1973  
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY  
100 MARTINE AVENUE  
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*            I N D I A N   P O I N T   2            \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NO INPUT PROVIDED.			

=====

1. Docket: 59-286                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: L. KELLY (914) 739-8200

4. Licensed Thermal Power (MWT):                    3025

5. Nameplate Rating (Gross MWe):                    1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe):                    965

7. Maximum Dependable Capacity (Gross MWe):                    1000

8. Maximum Dependable Capacity (Net MWe):                    965

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>104,496.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,571.6</u>	<u>63,916.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,513.6</u>	<u>61,979.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,249,006</u>	<u>13,333,803</u>	<u>165,345,946</u>
18. Gross Elec Ener (MWH)	<u>721,760</u>	<u>4,371,360</u>	<u>52,749,416</u>
19. Net Elec Ener (MWH)	<u>694,684</u>	<u>4,216,950</u>	<u>50,607,508</u>
20. Unit Service Factor	<u>100.0</u>	<u>88.3</u>	<u>59.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>88.3</u>	<u>59.3</u>
22. Unit Cap Factor (MDC Net)	<u>96.8</u>	<u>85.5</u>	<u>50.2</u>
23. Unit Cap Factor (DER Net)	<u>96.8</u>	<u>85.5</u>	<u>50.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.3</u>	<u>17.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>156.0</u>	<u>13,245.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                    INDIAN POINT 3                    \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 3



JULY 1988

Report Period: JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* INDIAN POINT 3 \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
INDIAN POINT 3 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* INDIAN POINT 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period: JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
COUNTY.....WESTCHESTER  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR....25 MI N OF  
NEW YORK CITY, NY  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...APRIL 6, 1976  
DATE ELEC ENER 1ST GENER...APRIL 27, 1976  
DATE COMMERCIAL OPERATE....AUGUST 30, 1976  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...HUDSON RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NEW YORK POWER AUTHORITY  
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE  
NEW YORK, NEW YORK 10019  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....P. KOLTAY  
LICENSING PROJ MANAGER.....J. NEPPERS  
DOCKET NUMBER.....50-286  
LICENSE & DATE ISSUANCE...DPR-64, APRIL 5, 1976  
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY  
100 MARTINE AVENUE  
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

```

=====
NUMBER    DATE OF    DATE OF    SUBJECT
          EVENT    REPORT
-----
NO INPUT PROVIDED.
=====

```



1. Docket: 50-305 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. RUITER (414) 388-2560 X225

4. Licensed Thermal Power (Mwt): 1650

5. Nameplate Rating (Gross MWe): 622 X 0.9 = 560

6. Design Electrical Rating (Net MWe): 535

7. Maximum Dependable Capacity (Gross MWe): 529

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>123,840.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,153.6</u>	<u>105,615.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,330.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,090.0</u>	<u>103,971.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>10.0</u>
17. Gross Therm Ener (MWH)	<u>1,196,631</u>	<u>6,462,051</u>	<u>163,881,925</u>
18. Gross Elec Ener (MWH)	<u>401,400</u>	<u>2,166,500</u>	<u>54,152,600</u>
19. Net Elec Ener (MWH)	<u>382,106</u>	<u>2,064,942</u>	<u>51,569,452</u>
20. Unit Service Factor	<u>100.0</u>	<u>80.0</u>	<u>84.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>80.0</u>	<u>84.0</u>
22. Unit Cap Factor (MDC Net)	<u>102.1</u>	<u>80.3</u>	<u>80.8*</u>
23. Unit Cap Factor (DER Net)	<u>96.0</u>	<u>75.5</u>	<u>77.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.2</u>	<u>2.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>50.1</u>	<u>2,888.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
 X KEWAUNEE X  
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 KEWAUNEE



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* Kewaunee \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/30/88	S	0.0	B	5		HC	HTEXCH	UNIT LOAD WAS REDUCED TO 225 MWE GROSS TO PERMIT CLEANING OF THE MAIN CONDENSER TUBES TO REMOVE BIOLOGICAL FOULING. THE UNIT WAS RETURNED TO FULL POWER ON 7/31/88.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 KEWAUNEE INCURRED ONE LOAD REDUCTION IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

\*\*\*\*\*  
\* KWAUNEE \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....KEWAUNEE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...27 MI E OF  
GREEN BAY, WI.  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 7, 1974  
DATE ELEC ENER 1ST GENER...APRIL 8, 1974  
DATE COMMERCIAL OPERATE...JUNE 16, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY  
LICENSEE.....WISCONSIN PUBLIC SERVICE  
CORPORATE ADDRESS.....P.O. BOX 19002  
GREEN BAY, WISCONSIN 54307  
CONTRACTOR  
ARCHITECT/ENGINEER.....PIONEER SERVICES & ENGINEERING  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....PIONEER SERVICES & ENGINEERING  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. NELSON  
LICENSING PROJ MANAGER.....J. GIITTER  
DOCKET NUMBER.....50-305  
LICENSE & DATE ISSUANCE...DPR-43, DECEMBER 21, 1973  
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF WISCONSIN  
LIBRARY LEARNING CENTER  
2420 NICOLET DRIVE  
GREEN BAY, WISCONSIN 54301

INSPECTION SUMMARY

INSPECTION STATUS

INSPECTION FROM MAY 15 THROUGH JUNE 30 (88014): ROUTINE UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; GENERIC LETTER FOLLOWUP; ONSITE FOLLOWUP OF EVENT; VERIFICATION OF QUALITY ASSURANCE FOR DIESEL GENERATOR FUEL OIL; AND PERSONNEL ACCESS. ONE VIOLATION OF REGULATORY REQUIREMENTS WAS IDENTIFIED IN THE AREA OF PERSONNEL ACCESS TO CONTROLLED AREAS. TWO OPEN ITEMS FROM A PREVIOUS INSPECTION WERE CLOSED (REPORT NO. 305/87013(DRS)). IN GENERAL, THE INSPECTION RESULTS INDICATE A CONTINUING GOOD PERFORMANCE. THE INSPECTORS NOTED THAT THE LICENSEE HAS INITIATED A COMPREHENSIVE INVESTIGATION AND EVALUATION TO DETERMINE THE ROOT CAUSE OF THREE ASCO SOLENOID VALVE FAILURES.

INSPECTION ON JUNE 20-24 (88015): ROUTINE, ANNOUNCED INSPECTION OF THE CHEMISTRY PROGRAM, INCLUDING (1) PROCEDURES, ORGANIZATION, AND TRAINING (IP 83722, 83723); (2) REACTOR SYSTEMS WATER QUALITY CONTROL PROGRAMS (IP 79701); (3) QUALITY ASSURANCE/QUALITY CONTROL PROGRAM IN THE LABORATORY (IP 79701); AND (4) NONRADIOLOGICAL CONFIRMATORY MEASUREMENTS (IP 79701). THE LICENSEE HAS AN EXTENSIVE WATER QUALITY CONTROL PROGRAM, INCLUDING THE USE OF BORON ADDITION TO THE SECONDARY SYSTEM. HOWEVER, THE ACTION LEVELS IN THE PROGRAM DO NOT PROVIDE SPECIFIC RESPONSES THAT CONFORM TO THOSE OF THE EPRI STEAM GENERATOR OWNERS GUIDELINES. THE NONRADIOLOGICAL CONFIRMATORY MEASUREMENTS RESULTS DEMONSTRATED SOME WEAKNESSES IN THE CHEMICAL MEASUREMENTS QA/QC PROGRAM. LICENSEE REPRESENTATIVES AGREED TO CORRECT THESE PROBLEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.



1. Docket: 50-373 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. J. KIRCHNER (815) 357-6761 X 705

4. Licensed Thermal Power (Mwt): 3523

5. Nameplate Rating (Gross MWe): 1078

6. Design Electrical Rating (Net MWe): 1078

7. Maximum Dependable Capacity (Gross MWe): 1078

8. Maximum Dependable Capacity (Net MWe): 1036

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>40,573.0</u>
13. Hours Reactor Critical	<u>528.3</u>	<u>2,258.1</u>	<u>22,301.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,540.9</u>
15. Hrs Generator On-Line	<u>416.5</u>	<u>2,146.3</u>	<u>21,574.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1.0</u>
17. Gross Therm Ener (MWH)	<u>777,504</u>	<u>6,029,592</u>	<u>63,999,908</u>
18. Gross Elec Ener (MWH)	<u>237,635</u>	<u>2,015,266</u>	<u>18,982,525</u>
19. Net Elec Ener (MWH)	<u>221,668</u>	<u>1,923,401</u>	<u>18,033,189</u>
20. Unit Service Factor	<u>56.0</u>	<u>42.0</u>	<u>53.7</u>
21. Unit Avail Factor	<u>56.0</u>	<u>42.0</u>	<u>53.7</u>
22. Unit Cap Factor (MDC Net)	<u>28.8</u>	<u>36.3</u>	<u>43.3</u>
23. Unit Cap Factor (DER Net)	<u>27.6</u>	<u>34.9</u>	<u>41.6</u>
24. Unit Forced Outage Rate	<u>26.0</u>	<u>6.4</u>	<u>13.7</u>
25. Forced Outage Hours	<u>146.3</u>	<u>146.3</u>	<u>3,410.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
N

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* LASALLE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* LASALLE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
4	07/01/88	S	172.4	C	4			CONTINUATION OF SECOND REFUEL OUTAGE.
5	07/11/88	S	8.8	B	1			TU <sup>B</sup> BINE OFF-LINE FOR OVERSPEED TESTING.
6	07/23/88	F	146.3	B	2			REPAIR STEAM LEAKS IN HEATER BAY AND OTHER MAINTENANCE. REPLACE G S/RV.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 LA SALLE 1 ENTERED JULY SHUTDOWN FOR SCHEDULED REFUELING.  
 SUBSEQUENTLY INCURRED TWO OUTAGES WHILE RETURNING TO POWER.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* LA SALLE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....LA SALLE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI SE OF  
OTTAWA, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JUNE 21, 1982  
DATE ELEC ENER 1ST GENER...SEPTEMBER 4, 1982  
DATE COMMERCIAL OPERATE...JANUARY 1, 1984  
CONDENSER COOLING METHOD...POND  
CONDENSER COOLING WATER...RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....M. JORDAN  
LICENSING PROJ MANAGER.....P. SHEMANSKI  
DOCKET NUMBER.....50-373  
LICENSE & DATE ISSUANCE...NPF-11, AUGUST 13, 1982  
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE  
RURAL ROUTE NO. 1  
OGLESBY, ILLINOIS 61348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 4-6 AND MAY 3 (88012; 88011): ROUTINE, ANNOUNCED SAFETY INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; AND DRYWELL TEMPERATURE MONITORING PROGRAM REVIEW (92700, 92701, 92702, 41400). OF THE TWO AREAS INSPECTED, NO VIOLATION OR DEVIATION WAS IDENTIFIED IN ONE AREA; ONE VIOLATION WITH TWO EXAMPLES: (1) FAILURE TO PROMPTLY CORRECT A POTENTIAL SIGNIFICANT DEFICIENCY FOR MORE THAN FIVE MONTHS; AND (2) FAILURE TO OBTAIN AND TRANSMIT TEMPERATURE DATA TO BWRED FOR EVALUATION ON A DAILY BASIS WHEN TRIGGER SET POINTS WERE EXCEEDED; AND ONE VIOLATION FOR FAILURE TO SUBMIT A SPECIAL REPORT WITHIN THE TIME FRAME REQUIRED BY TECHNICAL SPECIFICATION 3.7.7.A WERE IDENTIFIED IN THE REMAINING AREA.

INSPECTION ON MAY 10 THROUGH JUNE 20 (88015; 88014): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; TRAINING; LICENSEE EVENT REPORTS; OUTAGES; SECURITY; ESF SYSTEM WALKDOWNS; EMERGENCY PREPAREDNESS; REGIONAL REQUESTS; SPENT FUEL POOL ACTIVITIES; TEMPORARY INSTRUCTIONS; CONFIRMATORY ACTION LETTER FOLLOWUP; AND ONSITE FOLLOWUP OF EVENTS AT OPERATING POWER REACTORS. OF THE FIFTEEN AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED. THE LICENSEE IS ROUGHLY 87 PERCENT COMPLETE WITH THEIR SECOND REFUELING/MAINTENANCE OUTAGE ON UNIT 1. ALL MAJOR WORK ACTIVITIES ARE BEING COMPLETED. THE REACTOR VESSEL REASSEMBLY IS ALMOST COMPLETE, DRYWELL CLEANUP AND CLOSE OUT IS IN PROGRESS, AND FINAL PAPER WORK REVIEW IS UNDERWAY. THE REACTOR VESSEL HYDRO IS COMPLETE WITH SATISFACTORY RESULTS. DURING THE INSPECTION PERIOD, THE LICENSEE HELD THEIR 1988 GENERAL SITE EMERGENCY PREPAREDNESS DRILL. THE EXERCISE WENT WELL. ONE UNRESOLVED ITEM WAS IDENTIFIED DURING THE INSPECTION PERIOD DEALING WITH THE LICENSEE'S REPORTING OF THE MARCH 9, 1988, POWER OSCILLATION EVENT. THE TRANSMITTAL LETTER OF THIS INSPECTION REPORT CONTAINS A REQUEST FOR THE LICENSEE'S CORRECTIVE ACTIONS TO ENSURE THAT FUTURE COMMUNICATIONS ARE PROMPT, ACCURATE AND COMPLETE.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    LASALLE 1                    \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT 1 RESTATED FROM ITS REFUELING OUTAGE ON JULY 4, 1988 AND IS NOW OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: 06/16/88

INSPECTION REPORT NO: 88017

R E P O R T S   F R O M   L I C E N S E E

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-14	040388	072288	MECHANICAL SNUBBER FUNCTIONAL TEST FAILURES DURING UNIT 1 SECOND REFUEL SURVEILLANCE

.....



1. Docket: 50-374                      O P E R A T I N G   S T A T U S
2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0
3. Utility Contact: G. J. KIRCHNER (815) 357-6751 X 704
4. Licensed Thermal Power (MHT):                      3523
5. Nameplate Rating (Gross MWe):                      1078
6. Design Electrical Rating (Net MWe):                      1078
7. Maximum Dependable Capacity (Gross MWe):                      1078
8. Maximum Dependable Capacity (Net MWe):                      1036
9. If Changes Occur Above 'nce Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe): 810
11. Reasons for Restrictions, If Any: \_\_\_\_\_

FUEL DEPLETION

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>33,167.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,909.5</u>	<u>21,694.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,716.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,892.9</u>	<u>21,364.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,977,576</u>	<u>14,273,616</u>	<u>62,068,671</u>
18. Gross Elec Ener (MWH)	<u>610,648</u>	<u>4,714,651</u>	<u>20,522,862</u>
19. Net Elec Ener (MWH)	<u>582,563</u>	<u>4,532,179</u>	<u>19,614,702</u>
20. Unit Service Factor	<u>100.0</u>	<u>95.7</u>	<u>64.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>95.7</u>	<u>64.4</u>
22. Unit Cap Factor (MDC Net)	<u>75.6</u>	<u>85.6</u>	<u>57.1</u>
23. Unit Cap Factor (DER Net)	<u>72.6</u>	<u>82.3</u>	<u>54.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.3</u>	<u>16.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>218.1</u>	<u>4,317.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUEL - OCTOBER 15, 1988 - 15 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* LASALLE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* LASALLE 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NCNE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
LA SALLE 2 OPERATED ROUTINELY IN JULY WITH NO SIGNIFICANT LOAD REDUCTIONS OR POWER OUTAGES.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

\*\*\*\*\*  
X LASALLE 2 X  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....LA SALLE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI SE OF  
OTTAWA, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MARCH 10, 1984  
DATE ELEC ENER 1ST GENER...APRIL 20, 1984  
DATE COMMERCIAL OPERATE...OCTOBER 19, 1984  
CONDENSER COOLING METHOD...POND  
CONDENSER COOLING WATER...RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....M. JORDAN  
LICENSING PROJ MANAGER....P. SHEMANSKI  
DOCKET NUMBER.....50-374  
LICENSE & DATE ISSUANCE...NPF-18, MARCH 23, 1984  
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE  
RURAL ROUTE NO. 1  
OGLESBY, ILLINOIS 61348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON APRIL 4-6 AND MAY 3 (88012; 88011): ROUTINE, ANNOUNCED SAFETY INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; AND DRYWELL TEMPERATURE MONITORING PROGRAM REVIEW (92700, 92701, 92702, 41460). OF THE TWO AREAS INSPECTED, NO VIOLATION OR DEVIATION WAS IDENTIFIED IN ONE AREA; ONE VIOLATION WITH TWO EXAMPLES: (1) FAILURE TO PROMPTLY CORRECT A POTENTIAL SIGNIFICANT DEFICIENCY FOR MORE THAN FIVE MONTHS; AND (2) FAILURE TO OBTAIN AND TRANSMIT TEMPERATURE DATA TO BWRD FOR EVALUATION ON A DAILY BASIS WHEN TRIGGER SET POINTS WERE EXCEEDED; AND ONE VIOLATION FOR FAILURE TO SUBMIT A SPECIAL REPORT WITHIN THE TIME FRAME REQUIRED BY TECHNICAL SPECIFICATION 3.7.7.A WERE IDENTIFIED IN THE REMAINING AREA.

INSPECTION ON MAY 10 THROUGH JUNE 20 (88015; 88014): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; SURVEILLANCE; MAINTENANCE; TRAINING; LICENSEE EVENT REPORTS; OUTAGES; SECURITY; ESF SYSTEM WALKDOWNS; EMERGENCY PREPAREDNESS; REGIONAL REQUESTS; SPENT FUEL POOL ACTIVITIES; TEMPORARY INSTRUCTIONS; CONFIRMATORY ACTION LETTER FOLLOWUP; AND ONSITE FOLLOWUP OF EVENTS AT OPERATING POWER REACTORS. OF THE FIFTEEN AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED. THE LICENSEE IS ROUGHLY 87 PERCENT COMPLETE WITH THEIR SECOND REFUELING/MAINTENANCE OUTAGE ON UNIT 1. ALL MAJOR WORK ACTIVITIES ARE BEING COMPLETED. THE REACTOR VESSEL REASSEMBLY IS ALMOST COMPLETE, DRYWELL CLEANUP AND CLOSE OUT IS IN PROGRESS, AND FINAL PAPER WORK REVIEW IS UNDERWAY. THE REACTOR VESSEL HYDRO IS COMPLETE WITH SATISFACTORY RESULTS. DURING THE INSPECTION PERIOD, THE LICENSEE HELD THEIR 1988 GENERAL SITE EMERGENCY PREPAREDNESS DRILL. THE EXERCISE WENT WELL. ONE UNRESOLVED ITEM WAS IDENTIFIED DURING THE INSPECTION PERIOD DEALING WITH THE LICENSEE'S REPORTING OF THE MARCH 9, 1988, POWER OSCILLATION EVENT. THE TRANSMITTAL LETTER OF THIS INSPECTION REPORT CONTAINS A REQUEST FOR THE LICENSEE'S CORRECTIVE ACTIONS TO ENSURE THAT FUTURE COMMUNICATIONS ARE PROMPT, ACCURATE AND COMPLETE.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

XXXXXXXXXXXXXXXXXXXXX:XXXXXXXXXXXXX  
\*                   LASALLE 2                   \*  
XXXXXXXXXXXXXXXXXXXXX

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT OPERATING AT POWER COASTING DOWN TO FALL REFUELING (SHORT SHUTDOWN PLANNED FOR 8/12 TO REPAIR LEAKING GAMMA PLUG ON MAIN STEAM LINE)

LAST IE SITE INSPECTION DATE: 06/16/88

INSPECTION REPORT NO: 88016

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-08	061788	071188	TWO EMERGENCY CORE COOLING SYSTEMS INOPERABLE CAUSED BY LOOSE CONNECTIONS ON FEED BREAKER

1. Docket: 50-352 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: R. W. GROPP (215) 841-5058  
 4. Licensed Thermal Power (MWT): 3293  
 5. Nameplate Rating (Gross MWe): 1138  
 6. Design Electrical Rating (Net MWe): 1055  
 7. Maximum Dependable Capacity (Gross MWe): 1092  
 8. Maximum Dependable Capacity (Net MWe): 1055  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): 915  
 11. Reasons for Restrictions, If Any:

ADMIN. POWER RESTRICTION - FUEL LEAK.

	MONTH	YEAR	CUMULATIVE
12. Report Per. od Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>21,887.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,803.3</u>	<u>17,647.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-line	<u>744.0</u>	<u>4,797.0</u>	<u>17,359.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,095,891</u>	<u>14,404,951</u>	<u>53,301,332</u>
18. Gross Elec Ener (MWH)	<u>668,260</u>	<u>4,644,660</u>	<u>17,344,070</u>
19. Net Elec Ener (MWH)	<u>638,938</u>	<u>4,464,019</u>	<u>16,631,856</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.9</u>	<u>79.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.9</u>	<u>79.3</u>
22. Unit Cap Factor (MDC Net)	<u>81.4</u>	<u>82.8</u>	<u>72.0</u>
23. Unit Cap Factor (DER Net)	<u>81.4</u>	<u>82.8</u>	<u>72.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>6.1</u>	<u>4.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>314.0</u>	<u>805.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* LIMERICK 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LIMERICK 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* LIMERICK 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
LIMERICK 1 OPERATED AT AN ADMINISTRATIVELY RESTRICTED POWER LEVEL IN JULY WITH NO OUTAGES OR SIGNIFICANT LOAD REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....MONTGOMERY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...21 MI NW OF  
PHILADELPHIA, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...DECEMBER 22, 1984  
DATE ELEC ENER 1ST GENER...APRIL 13, 1985  
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1986  
CONDENSER COOLING METHOD...CC HNDCT  
CONDENSER COOLING WATER...SCHUYLKILL RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PHILADELPHIA ELECTRIC  
CORPORATE ADDRESS.....2301 MARKET STREET  
PHILADELPHIA, PENNSYLVANIA 19105

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....G. KELLY  
LICENSING PROJ MANAGER....D. CLARK  
DOCKET NUMBER.....50-352  
LICENSE & DATE ISSUANCE...NPF-39, AUGUST 8, 1985  
PUBLIC DOCUMENT ROOM.....POTTSTOWN PUBLIC LIBRARY  
500 HIGH STREET  
POTTSTOWN, PENNSYLVANIA 19464

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SIVE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			



1. Docket: 59-309 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. M. TAYLOR (207) 882-6321

4. Licensed Thermal Power (MWT): 2630

5. Nameplate Rating (Gross MWe): 864

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 850

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>137,867.6</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,094.9</u>	<u>110,947.5</u>
14. Rx Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,081.8</u>	<u>107,740.7</u>
16. Unit Reserve Shtdn Hrs:	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWh)	<u>1,949,589</u>	<u>13,279,028</u>	<u>247,639,362</u>
18. Gross Elec Ener (MWh)	<u>601,300</u>	<u>4,152,260</u>	<u>81,040,990</u>
19. Net Elec Ener (MWh)	<u>581,439</u>	<u>4,015,946</u>	<u>77,490,895</u>
20. Unit Service Factor	<u>100.0</u>	<u>99.4</u>	<u>78.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>99.4</u>	<u>78.1</u>
22. Unit Cap Factor (MDC Net)	<u>96.5</u>	<u>97.0</u>	<u>70.9*</u>
23. Unit Cap Factor (DER Net)	<u>94.7</u>	<u>95.2</u>	<u>69.2*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.6</u>	<u>7.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>29.2</u>	<u>7,739.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - 10/15/88 - 8 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MAINE YANKEE \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MAINE YANKEE



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MAINE YANKEE \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
MAINE YANKEE OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* MAINE YANKEE \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MAINE  
COUNTY.....LINCOLN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI N OF  
BATH, ME  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...OCTOBER 23, 1972  
DATE ELEC ENER 1ST GENER...NOVEMBER 8, 1972  
DATE COMMERCIAL OPERAT. ...DECEMBER 28, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...BACK RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....MAINE YANKEE ATOMIC POWER  
CORPORATE ADDRESS.....83 EDISON DRIVE  
AUGUSTA, MAINE 04366  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....C. HOLDEN  
LICENSING PROJ MANAGER.....P. SEARS  
DOCKET NUMBER.....50-309  
LICENSE & DATE ISSUANCE...DPR-36, JUNE 29, 1973  
PUBLIC DOCUMENT ROOM.....WISCASSET PUBLIC LIBRARY  
HIGH STREET  
WISCASSET, MAINE 04578

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   ( C O N T I N U E D )

\*\*\*\*\*  
\*                    MAINE YANKEE                    \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-369                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (Mwt):                      3411

5. Nameplate Rating (Gross MWe):                      1305

6. Design Electrical Rating (Net MWe):                      1180

7. Maximum Dependable Capacity (Gross MWe):                      1225

8. Maximum Dependable Capacity (Net MWe):                      1129

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>58,432.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,030.4</u>	<u>41,894.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,018.2</u>	<u>41,361.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,485,619</u>	<u>16,685,939</u>	<u>121,754,356</u>
18. Gross Elec Ener (MWH)	<u>831,719</u>	<u>5,730,977</u>	<u>42,126,554</u>
19. Net Elec Ener (MWH)	<u>798,508</u>	<u>5,519,350</u>	<u>40,184,848</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.2</u>	<u>70.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.2</u>	<u>70.8</u>
22. Unit Cap Factor (MDC Net)	<u>95.1</u>	<u>95.7</u>	<u>60.9</u>
23. Unit Cap Factor (DER Net)	<u>91.0</u>	<u>91.5</u>	<u>58.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.8</u>	<u>12.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>92.8</u>	<u>6,115.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - OCTOBER 14, 1988 - 10 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 X                      MCGUIRE 1                      X  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* MCGUIRE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
26-P	07/02/88	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCHER REQUEST.
27-P	07/05/88	F	0.0	B	5		HB	XXXXXX	FEEDWATER VENTURI FOULING COEFFICIENT VERIFICATION.
28-P	07/06/88	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCHER REQUEST.
29-P	07/30/88	S	0.0	B	5		RC	XXXXXX	MODERATOR TEMPERATURE COEFFICIENT EOC TEST.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 MCGUIRE 1 INCL'ED FOUR LOAD REDUCTIONS DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)



INSPECTION SUMMARY

LICENSEE'S ALARA PROGRAM IS NEEDED TO REDUCE THE FACILITIES PERSON-REM TOTALS TO THOSE COMPARABLE WITH THE NATIONAL AVERAGES.

INSPECTION JUNE 20-24 (88-17): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF LIQUID AND GASEOUS EFFLUENTS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 20-24 (88-18): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREA; SECURITY SYSTEM POWER SUPPLY; LIGHTING; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - VEHICLES, AND PERSONNEL TRAINING AND QUALIFICATION - GENERAL REQUIREMENTS. IN THE AREAS INSPECTED NO INSPECTOR IDENTIFIED VIOLATIONS OR DEVIATIONS WERE NOTED. HOWEVER, ONE LICENSEE IDENTIFIED VIOLATION, PREVIOUSLY REPORTED AS A PHYSICAL SECURITY EVENT, AS DISCUSSED IN SECTION 4 OF THIS REPORT WAS CONFIRMED.

INSPECTION JUNE 27 - JULY 1 (88-19): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF UNIT 2 NONDESTRUCTIVE EXAMINATION (NDE) ACTIVITIES ASSOCIATED WITH THE RESISTANCE TEMPERATURE DETECTOR (RTD) SYSTEM MODIFICATIONS, INDEPENDENT REVIEW OF RADIOGRAPHS ASSOCIATED WITH THE UPPER HEAD SAFETY INJECTION SYSTEM (UHSIS) PIPING DELETION, AND INSERVICE INSPECTION (ISI) AND PRESERVICE INSPECTION (PSI) BEING ACCOMPLISHED DURING THIS OUTAGE. ALSO, INQUIRIES AND DISCUSSIONS WITH REGARD TO BULLETINS 88-02 AND 88-05. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

ENFORCEMENT SUMMARY

FAILURE TO MAINTAIN COMPENSATORY MEASURES IN FORCE.

FAILURE TO COMPLY WITH BADGING/ACCESS CONTROL REQUIREMENTS.

CONTRARY TO: TS 6.8.1; APPENDIX A OF RG 1.33, REV. 2, FEBRUARY 1978; TS 4.0.5; ASME BOILER AND PRESSURE VESSEL CODE, 1980 EDITION, SECTION XI; 10 CFR 50, APPENDIX B, CRITERION V; STATION DIRECTIVES 2.B.2, OPERABILITY DETERMINATION, AND 3.1.19, SAFETY TAGS: (1) PROCEDURE PT/1/A/4252/01, AUXILIARY FEEDWATER PUMP NUMBER 1 PERFORMANCE TEST, WAS INADEQUATE IN THAT HORIZONTAL VIBRATION RANGES SPECIFIED DID NOT CORRESPOND TO THOSE REQUIRED BY ASME SECTION XI AND PUMP BASELINE DATA. (2) STATION DIRECTIVE 2.8.2 WAS NOT PROPERLY IMPLEMENTED IN THAT NO TECHNICAL DISCUSSION OF OPERABILITY WAS DOCUMENTED IN THE OPERABILITY DETERMINATION ASSOCIATED WITH PROBLEM INVESTIGATION REPORT (PIR) O-M88-0089. THIS PIR CONCERNED THE OPERABILITY OF THE TURBINE DRIVEN AUXILIARY FEEDWATER PUMPS WITH QUESTIONABLE CONTACT AREA BETWEEN THE EMERGENCY HEAD LEVER AND THE TAPPET NUT. (3) STATION DIRECTIVE 3.1.19 WAS NOT PROPERLY IMPLEMENTED IN THAT THE RESTORATION AND TAG REMOVAL PERFORMED ON MAY 12, 1988, FOR WORK REQUESTS 500184 AND 08380 WAS NOT DONE IN THE SEQUENCE DESIGNATED ON THE REMOVAL AND RESTORATION RECORD SHEET. THIS LED TO AN ESF ACTUATION INVOLVING SWAP OVER OF CA B PUMP SUCTION SUPPLY TO NUCLEAR SERVICE WATER. (4) PROCEDURE PT/1/A/4350-04B, D/G 1B LOAD SEQUENCE TEST, WAS NOT PROPERLY IMPLEMENTED ON MAY 16, 1988 DURING A TEST ON UNIT 1 IN THAT THE REQUIREMENTS OF STEP 12.9 WERE NOT PERFORMED. THIS LED TO AN INADVERTENT ACTUATION OF ESF EQUIPMENT.

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XI, THE TEST PROGRAM ESTABLISHED TO DEMONSTRATE THAT THE TURBINE DRIVEN AUXILIARY FEEDWATER PUMPS WILL PERFORM SATISFACTORY IN SERVICE WAS INADEQUATE. THE PROCEDURE USED TO TEST THE PUMPS DOES NOT PERFORM THE TEST IN THE AS FOUND CONDITION IN THAT THE STEAM LINES TO THE PUMP TURBINE WERE DRAINED OF CONDENSATE PRIOR TO TESTING. (8801 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.



OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JULY 31, 1988 +

INSPECTION REPORT NO: 50-369/88-21 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-011	06/01/88	07/01/88	UNIT 1 ENTERED TECH SPEC 3.0.3 WHEN TWO VITAL BATTERY CHARGERS WERE DEENERGIZED WHEN DIESEL GENERATOR 2A TRIPPED DUE TO OIL LEAK FROM DIESEL GOVERNOR VALVE
88-012	02/05/88	07/14/88	INVESTIGATION OF POSSIBLE VALVE ACTUATOR PROBLEMS
88-013	06/20/88	07/20/88	REACTOR TRIP DUE TO FAILURE OF PRIMARY POWER SUPPLY TO THE CONTROL RODS
88-014	06/24/88	07/25/88	ESF ACTUATION AND BLACKOUT OCCURRED AS A RESULT OF PERSONNEL TAKING WRONG ACTION, COINCIDENT WITH VALID FAILURE OF DIESEL GENERATOR 2A

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-370 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS EXT (704) 373-7567

4. Licensed Thermal Power (MWT): 3411

5. Nameplate Rating (Gross MWe): 1450 X .9 = 1305

6. Design Electrical Rating (Net MWe): 1180

7. Maximum Dependable Capacity (Gross MWe): 1225

8. Maximum Dependable Capacity (Net MWe): 1129

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>38,735.0</u>
13. Hours Reactor Critical	<u>132.3</u>	<u>3,647.3</u>	<u>28,093.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>95.6</u>	<u>3,605.3</u>	<u>27,432.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>182,814</u>	<u>11,870,637</u>	<u>90,116,241</u>
18. Gross Elec Ener (MWH)	<u>56,434</u>	<u>4,138,384</u>	<u>31,213,612</u>
19. Net Elec Ener (MWH)	<u>41,909</u>	<u>3,968,686</u>	<u>29,904,682</u>
20. Unit Service Factor	<u>12.8</u>	<u>70.5</u>	<u>70.8</u>
21. Unit Avail Factor	<u>12.8</u>	<u>70.5</u>	<u>70.8</u>
22. Unit Cap Factor (MDC Net)	<u>5.0</u>	<u>68.8</u>	<u>68.4</u>
23. Unit Cap Factor (DER Net)	<u>4.8</u>	<u>65.8</u>	<u>65.4</u>
24. Unit Forced Outage Rate	<u>4.6</u>	<u>.8</u>	<u>11.1</u>
25. Forced Outage Hours	<u>4.6</u>	<u>27.4</u>	<u>3,421.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* MCGUIRE 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* MCGUIRE 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	05/27/88	S	643.4	C	4		RC	FUELOX	END OF CYCLE 4 REFUELING OUTAGE.
13-P	07/27/88	S	0.0	H	5		HA	TURBI	TURBINE SOAK PERIOD
4	07/28/88	S	0.4	B	1		HA	TURBIN	TURBINE OVERSPEED TRIP TEST.
14-P	07/28/88	F	0.0	H	5		HB	TRANSF	FEEDWATER TRANSIENT.
15-P	07/28/88	S	0.0	B	5		IE	XXXXXX	FLUX MAPPING.
16-P	07/29/88	S	0.0	B	5		IE	INSTRU	NUCLEAR INSTRUMENTATION CALIBRATION.
17-P	07/30/88	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH.
18-P	07/31/88	S	0.0	A	5		HJ	PUMPXX	REPAIR SEAL LEAK ON HEATER DRAIN PUMP.
5	07/31/88	F	4.6	A	2		HH	VALVEX	MANUAL TRIP - FAN FELL ON THE SOLENOID VALVE OF THE MAIN FEEDWATER REG VALVE (CF-32).

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 MCGUIRE 2 ENTERED JULY IN A SCHEDULED OUTAGE FOR REFUELING.  
 SUBSEQUENTLY, DURING RETURN TO POWER IT INCURRED TWO OUTAGES  
 AND SEVERAL LOAD REDUCTIONS.

Type	Reason	Method	System & Component
1-Force	4-Equip Failure	F-Admin	1-Manual
5-Sched	8-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	7-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
COUNTY.....MECKLENBURG  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 M. N OF  
CHARLOTTE, NC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 8, 1983  
DATE ELEC ENER 1ST GENER...MAY 23, 1983  
DATE COMMERCIAL OPERATE...MARCH 1, 1984  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE NORMAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....POWER BLDG., BOX 2178  
CHARLOTTE, NORTH CAROLINA 28201  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE POWER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. ORDERS  
LICENSING PROJ MANAGER.....D. HOOD  
DOCKET NUMBER.....50-370  
LICENSE & DATE ISSUANCE...NPF-17, MAY 27, 1983  
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS  
ATKINS LIBRARY  
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE  
UNCC STATION,  
CHARLOTTE, NC 28223

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 21 - JUNE 24 (88-14): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES, REFUELING OUTAGE ACTIVITIES, AND FOLLOWUP ON PREVIOUS INSPECTION FINDINGS. IN THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED. ONE OF THESE VIOLATIONS WAS CLASSIFIED AS A LICENSEE IDENTIFIED VIOLATION (LIV). THE INSPECTION FINDINGS INDICATE A CONTINUED WEAKNESS IN THE PROCEDURAL COMPLIANCE AREA. A STRENGTH WAS NOTED IN THE ESTABLISHMENT AND USE OF AN ONSITE DESIGN ENGINEERING STAFF. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING THE FAILURE OF THE MCGUIRE SAFETY REVIEW GROUP (MSRG) TO PERFORM THE ACTIVITIES INTENDED BY TECHNICAL SPECIFICATIONS 6.2.3.3 AND 6.2.3.4. WITHIN THE AREAS INSPECTED, THE FOLLOWING VIOLATIONS WERE IDENTIFIED: INADEQUATE PROCEDURE/FAILURE TO FOLLOW PROCEDURE WITH RESPECT TO SAFETY INJECTION CHECK VALVE TESTING. THIS VIOLATION IS CLASSIFIED AS AN LIV; AND FAILURE TO FOLLOW PROCEDURE AND FAILURE TO USE A PROCEDURE TO PERFORM SAFETY RELATED WORK WHEN ADJUSTING DIESEL GENERATOR POWER OUTPUT WITHOUT A WORK REQUEST OR A PROCEDURE.

INSPECTION JUNE 13-17 (88-15): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF INSERVICE INSPECTION (ISI) UNIT 2, INCLUDING REVIEW OF INSPECTION PLAN FOR THIS OUTAGE, NONDESTRUCTIVE EXAMINATION (NDE) PROCEDURES REVIEW UNITS 1 AND 2, OBSERVATION AND REVIEW OF INPROCESS NDE EXAMINATIONS, AND REVIEW OF ISI EXAMINATION DATA. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION JUNE 20-24 (88-16): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF OCCUPATIONAL EXPOSURE DURING EXTENDED OUTAGES. IN THE AREAS INSPECTED, THERE WERE NO VIOLATIONS OR DEVIATIONS IDENTIFIED. CONTINUED IMPROVEMENT IN THE



Report Period JUL 1988

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* MCGUIRE 2 \*  
\*\*\*\*\*

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-003	06/03/88	07/15/88	TECH SPEC LIMIT FOR CRANE LOAD OVER THE SPENT FUEL STORAGE POOL WAS EXCEEDED DUE TO MANAGEMENT DEFICIENCY - INADEQUATE POLICY
88-004	05/12/88	07/13/88	TWO INADVERTENT ACTUATIONS OF UNIT 2 ENGINEERED SAFETY FEATURES COMPONENTS OCCURRED DUE TO PERSONNEL ERROR - PROCEDURE NONCOMPLIANCE

=====

THIS PAGE INTENTIONALLY LEFT BLANK



1. Docket: 50-245                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: G. NEWBURGH (203) 447-1791 X4400

4. Licensed Thermal Power (MHT):                    2011

5. Nameplate Rating (Gross MWe):                    735 X 0.9 = 662

6. Design Electrical Rating (Net MWe):                    660

7. Maximum Dependable Capacity (Gross MWe):                    684

8. Maximum Dependable Capacity (Net MWe):                    654

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>15,919.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,081.8</u>	<u>12,408.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,283.3</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,072.6</u>	<u>118,265.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>277.4</u>
17. Gross Therm Ener (MWH)	<u>1,485,660</u>	<u>10,041,118</u>	<u>220,247,213</u>
18. Gross Elec Ener (MWH)	<u>503,300</u>	<u>3,429,900</u>	<u>74,206,496</u>
19. Net Elec Ener (MWH)	<u>481,369</u>	<u>3,282,781</u>	<u>70,800,242</u>
20. Unit Service Factor	<u>100.0</u>	<u>99.2</u>	<u>76.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>99.2</u>	<u>76.5</u>
22. Unit Cap Factor (MDC Net)	<u>98.9</u>	<u>98.2</u>	<u>69.9</u>
23. Unit Cap Factor (DER Net)	<u>98.0</u>	<u>97.3</u>	<u>69.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.8</u>	<u>10.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>38.4</u>	<u>6,344.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                    MILLSTONE 1                    \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
  
MILLSTONE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MILLSTONE 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
MILLSTONE 1 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
X MILLSTONE 1 X  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....CONNECTICUT  
COUNTY.....NEW LONDON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI SW OF  
NEW LONDON, CONN  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...OCTOBER 26, 1970  
DATE ELEC ENER 1ST GENER...NOVEMBER 29, 1970  
DATE COMMERCIAL OPERATE...MARCH 1, 1971  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LONG ISLAND SOUND  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHEAST NUCLEAR ENERGY  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....W. RAYMOND  
LICENSING PROJ MANAGER....M. BOYLE  
DOCKET NUMBER.....50-245  
LICENSE & DATE ISSUANCE...DPR-21, OCTOBER 26, 1970  
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY  
49 ROPE FERRY ROAD  
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

-----

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

-----

1. Docket: 50-356 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. NERON (203) 447-1791 X4417

4. Licensed Thermal Power (MWT): 2700

5. Nameplate Rating (Gross MWe): 1011 X 0.9 = 910

6. Design Electrical Rating (Net MWe): 870

7. Maximum Dependable Capacity (Gross MWe): 894

8. Maximum Dependable Capacity (Net MWe): 863

9. If Changes Occur Above Since Last Report, Give Reasons:  
CH IN 687 RESULT OF SECONDARY SIDE EFFICIENCY WK.

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>110,447.0</u>
13. Core Reactor Critical	<u>744.0</u>	<u>3,306.0</u>	<u>79,570.0</u>
14. Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>2,166.9</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,174.5</u>	<u>76,426.2</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>468.2</u>
17. Gross Therm Ener (MWH)	<u>2,008,427</u>	<u>8,306,372</u>	<u>195,622,363</u>
18. Gross Elec Ener (MWH)	<u>666,447</u>	<u>2,742,908</u>	<u>63,605,481</u>
19. Net Elec Ener (MWH)	<u>643,491</u>	<u>2,629,107</u>	<u>61,005,304</u>
20. Unit Service Factor	<u>100.0</u>	<u>62.1</u>	<u>69.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>62.1</u>	<u>69.6</u>
22. Unit Cap Factor (MDC Net)	<u>100.2</u>	<u>59.9</u>	<u>65.2*</u>
23. Unit Cap Factor (DER Net)	<u>99.4</u>	<u>59.1</u>	<u>64.1*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>5.7</u>	<u>14.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>193.0</u>	<u>11,978.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MILLSTONE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
MILLSTONE 2



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MILLSTONE 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
MILLSTONE 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	G-Oper Error	3 Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....CONNECTICUT  
COUNTY.....NEW LONDON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI SW OF  
NEW LONDON, CONN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 17, 1975  
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1975  
DATE COMMERCIAL OPERATE...DECEMBER 26, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LONG ISLAND SOUND  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHEAST NUCLEAR ENERGY  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....W. RAYMOND  
LICENSING PROJ MANAGER....D. JAFFE  
DOCKET NUMBER.....50-336  
LICENSE & DATE ISSUANCE...DPR-65, SEPTEMBER 30, 1975  
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY  
49 ROPE FERRY ROAD  
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.





1. Docket: 50-423 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: A. ELMS (203) 444-5388

4. Licensed Thermal Power (MWT): 3411

5. Nameplate Rating (Gross MWe): 1253

6. Design Electrical Rating (Net MWe): 1154

7. Maximum Dependable Capacity (Gross MWe): 1197

8. Maximum Dependable Capacity (Net MWe): 1142

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>19,943.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,972.0</u>	<u>15,735.5</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>20.2</u>	<u>246.2</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,780.9</u>	<u>15,371.4</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,535,537</u>	<u>12,569,587</u>	<u>54,839,018</u>
18. Gross Elec Ener (MWH)	<u>875,613</u>	<u>4,376,017</u>	<u>17,585,287</u>
19. Net Elec Ener (MWH)	<u>840,090</u>	<u>4,167,290</u>	<u>16,771,367</u>
20. Unit Service Factor	<u>100.0</u>	<u>74.0</u>	<u>77.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>74.0</u>	<u>77.1</u>
22. Unit Cap Factor (MDC Net)	<u>98.9</u>	<u>71.4</u>	<u>73.6</u>
23. Unit Cap Factor (DER Net)	<u>97.8</u>	<u>70.7</u>	<u>72.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>9.0</u>	<u>8.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>375.7</u>	<u>1,450.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MILLSTONE 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 3



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MILLSTONE 3 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
MILLSTONE 3 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* MILLSTONE 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION:  
STATE.....CONNECTICUT  
COUNTY.....NEW LONDON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3.2 MI WSW OF  
NEW LONDON CT.  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...JANUARY 23, 1986  
DATE ELEC ENER 1ST GENER...FEBRUARY 12, 1986  
DATE COMMERCIAL OPERATE...APRIL 23, 1986  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...ATLANTIC BAY  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHEAST NUCLEAR ENERGY  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE REGIONAL INSPECTOR.....S. BARBER  
LICENSING PROJ MANAGER.....D. JAFFE  
DOCKET NUMBER .....50-423  
LICENSE & DATE ISSUANCE...NPF-49, JANUARY 31, 1986  
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY  
49 ROPE FERRY ROAD  
WATERFORD, CONNECTICUT 06385

INSPECTION STATUS

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

\*\*\*\*\*  
MILLSTONE 3  
\*\*\*\*\*

INSPECTION STATUS - (CONTINUED)

Report Period Jul 1988

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

REPORTS FROM LICENSEE

.....  
NUMBER DATE OF DATE OF SUBJECT  
EVENT REPORT

-----  
INFO. NOT SUPPLIED BY REGION  
.....

1. Bucket: 50-265 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: A. L. Myrabo (612) 295-5151

4. Licensed Thermal Power (Mbt): 1670

5. Nameplate Ratio (Gross MWe): 632 X 0.9 = 569

6. Design Electrical Rating (Net MWe): 545

7. Maximum Dependable Capacity (Gross MWe): 564

8. Maximum Dependable Capacity (Net MWe): 536

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>149,784.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,111.0</u>	<u>117,348.0</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>940.7</u>
15. Hrs Generate On-Line	<u>744.0</u>	<u>5,111.0</u>	<u>115,124.6</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MMBt)	<u>1,167,794</u>	<u>8,411,124</u>	<u>184,089,198</u>
18. Gross Elec Ener (MMWh)	<u>380,091</u>	<u>2,822,417</u>	<u>59,702,473</u>
19. Net Elec Ener (MMWh)	<u>362,372</u>	<u>2,709,740</u>	<u>57,080,858</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>76.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>72.9</u>
22. Unit Cap Factor (MDC Net)	<u>90.9</u>	<u>98.9</u>	<u>71.1</u>
23. Unit Cap Factor (DER Net)	<u>89.4</u>	<u>97.3</u>	<u>69.9</u>
24. Unit forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>4.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,498.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MONTICELLO \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MONTICELLO



JULY 1988

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 MONTICELLO OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
 SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* MONTICELLO \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....MINNESOTA  
COUNTY.....WRIGHT  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...36 MI NW OF  
MINNEAPOLIS, MINN  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...DECEMBER 10, 1975  
DATE ELEC ENER 1ST GENER...MARCH 5, 1971  
DATE COMMERCIAL OPERATE...JUNE 30, 1971  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY  
LICENSEE.....NORTHERN STATES POWER  
CORPORATE ADDRESS.....414 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....P. HARTMAN  
LICENSING PROJ MANAGER.....J. STEFANO  
DOCKET NUMBER.....50-263  
LICENSE & DATE ISSUANCE...DPR-22, JANUARY 9, 1981  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY  
MINNEAPOLIS PUBLIC LIBRARY  
300 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 24 THROUGH APRIL 8 (88004): A ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY VERIFICATION; MAINTENANCE; SURVEILLANCE; EMERGENCY DIESEL GENERATOR LOADING; INFORMATION NOTICE; LICENSEE EVENT REPORTS; BULLETINS; AND TEMPORARY INSTRUCTIONS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED. ONE UNRESOLVED ITEM WAS IDENTIFIED RELATING TO INADEQUATE REVIEW OF A MODIFICATION PACKAGE FOR INSTALLATION OF THE EMERGENCY FILTRATION TRAIN SYSTEM.

INSPECTION ON APRIL 9 THROUGH MAY 27 (88006): A ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY VERIFICATION; MAINTENANCE; SURVEILLANCE; REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM TURBINE TRIPS; CONDENSER TUBING INVESTIGATION; SMALL VALVE ISSUE; FIRE DOORS; INFORMATIONAL NOTICES; AND GENERIC LETTERS. DURING THIS INSPECTION PERIOD, THE UNIT CONTINUED 100 PERCENT POWER OPERATIONS AND IN GENERAL THE PLANT CONTINUES TO OPERATE WELL. CONCERN STILL EXISTS, HOWEVER WITH THE OPERATION OF THE RCIC TURBINE. AN UPDATED STATUS REPORT OF THE "SMALL VALVE" ISSUE IS DISCUSSED. OF THE TEN AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED IN THE AREA OF CONTROL AND MAINTENANCE OF FIRE DOORS AND NO NEW UNRESOLVED ITEMS WERE IDENTIFIED.

INSPECTION ON JUNE 13-17 (88010): ROUTINE, UNANNOUNCED INSPECTION OF RADIATION PROTECTION AND RADWASTE ACTIVITIES DURING REACTOR OPERATION, INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS (IP 83722); AUDITS (IP 83722); TRAINING AND QUALIFICATION OF PERSONNEL (IP 83723); EXPOSURE CONTROLS (IP 83724, 83725); ALARA (IP 83728); CONTROL OF RADIOACTIVE MATERIAL AND CONTAMINATION (IP 83726); FACILITIES AND EQUIPMENT (IP 83727); SOLID RADWASTE (IP 83722); LIQUID RADWASTE (IP 84725); GASEOUS RADWASTE (IP 84724) AND

INSPECTION SUMMARY

TRANSPORTATION (IP 86721). IN ADDITION, THE INSPECTOR REVIEWED ACTIONS TAKEN ON NRC INFORMATION NOTICES AND PERFORMED INDEPENDENT CONTAMINATION SURVEYS. THE LICENSEE'S RADIATION PROTECTION PROGRAM CONTINUES TO BE EFFECTIVE IN PROTECTING THE HEALTH AND SAFETY OF WORKERS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT CONFERENCE ON JUNE 15 (88011): INCLUDED A REVIEW AND DISCUSSION OF THE ENFORCEMENT OPTIONS AND CIRCUMSTANCES SURROUNDING AND CORRECTIVE ACTIONS IN RESPONSE TO POTENTIAL VIOLATIONS OF THE LICENSEE'S SECURITY PLAN RELATING TO A DEGRADED VITAL AREA BARRIER AND REPORTING REQUIREMENTS ASSOCIATED WITH THE BARRIER DEGRADATION.

ENFORCEMENT SUMMARY

FAILURE TO CONTROL ACCESS TO A DEGRADED VITAL AREA BARRIER.  
(8800 3)

FAILURE TO MAINTAIN AN ADEQUATE RESPONSE FORCE. FAILURE TO SUBMIT A REQUIRED REPORT IN A TIMELY MANNER.

FAILURE TO MAINTAIN AN ADEQUATE VITAL AREA BARRIER.

FAILURE TO IMPLEMENT COMPENSATORY MEASURES ON TWO OCCASIONS. A PORTION OF THE ALARM SYSTEM FAILED TO DETECT PROPERLY.

CONTRARY TO TS 3.6.3.1 AND TS 4.6.5.1.1.B, ON SEPTEMBER 15, 1986, UNIT 1 ENTERED MODE 4 WITH NINE CONTAINMENT ISOLATION VALVES, SPECIFIED IN TABLE 3.6-1, THAT WERE NOT STROKE TIME TESTED FOLLOWING MAINTENANCE. THE MAINTENANCE INVOLVED A MODIFICATION TO THE VENT PATHS OF THE SOLENOID VALVES ASSOCIATED WITH THE CONTAINMENT ISOLATION VALVES. THIS MODIFICATION INCREASED THE STROKE TIMES OF SEVERAL OF THE VALVES. THE VALVES WERE NOT STROKE TIME TESTED UNTIL JUNE OF 1987. CONTRARY TO TS 6.4.1, S.D.2.2.2 WAS NOT ADEQUATE TO ASSURE THE CORRECT COMPONENT WAS IDENTIFIED PRIOR TO PERFORMING WORK AS INDICATED BY TWO EXAMPLES - ONE ASSOCIATED WITH A SPILL OF CONTAMINATED WATER ON UNIT 1 WHEN WORK WAS PERFORMED ON AN INCORRECT VALVE, AND ONE ASSOCIATED WITH A UNIT 2 MAIN STEAM VALVE THAT WAS INCORRECTLY REMOVED FROM A SUPPLY LINE TO THE AUXILIARY FEEDWATER PUMP TURBINE. CONTRARY TO TS 6.4.1, S.D.2.2.2 WAS NOT ADEQUATE TO ASSURE THE CORRECT COMPONENT WAS IDENTIFIED PRIOR TO PERFORMING WORK AS INDICATED BY TWO EXAMPLES - ONE ASSOCIATED WITH A SPILL OF CONTAMINATED WATER ON UNIT 1 WHEN WORK WAS PERFORMED ON AN INCORRECT VALVE, AND ONE ASSOCIATED WITH A UNIT 2 MAIN STEAM VALVE THAT WAS INCORRECTLY REMOVED FROM A SUPPLY LINE TO THE AUXILIARY FEEDWATER PUMP TURBINE. CONTRARY TO TS 6.4.1, S.D.2.2.2 WAS NOT ADEQUATE TO ASSURE THE CORRECT COMPONENT WAS IDENTIFIED PRIOR TO PERFORMING WORK AS INDICATED BY TWO EXAMPLES - ONE ASSOCIATED WITH A SPILL OF CONTAMINATED WATER ON UNIT 1 WHEN WORK WAS PERFORMED ON AN INCORRECT VALVE, AND ONE ASSOCIATED WITH A UNIT 2 MAIN STEAM VALVE THAT WAS INCORRECTLY REMOVED FROM A SUPPLY LINE TO THE AUXILIARY FEEDWATER PUMP TURBINE.  
(8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE





THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-220      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: THOMAS W. ROMAN (315) 349-2422

4. Licensed Thermal Power (Mwt):      1850

5. Nameplate Rating (Gross MWe):      755 X 0.85 = 642

6. Design Electrical Rating (Net MWe):      620

7. Maximum Dependable Capacity (Gross MWe):      630

8. Maximum Dependable Capacity (Net MWe):      610

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_


11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>164,551.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>115,205.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,294.2</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>112,102.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>20.2</u>
17. Gross Therm Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>68,473,049</u>
18. Gross Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>62,973,071</u>
19. Net Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>60,523,379</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>68.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>68.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>60.4</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>59.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>100.0</u>	<u>14.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>516.0</u>	<u>15,047.9</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
 \*                    NINE MILE POINT 1                    \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NINE MILE POINT 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* NINE MILE POINT 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
02	01/22/88	S	744.0	C	4				THE DECISION WAS MADE TO STARY THE REFUEL OUTAGE SINCE THE PLANT WAS ALREADY SHUTDOWN DUE TO PROBLEMS WITHIN THE FW SYSTEM.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
NINE MILE POINT 1 REMAINED SHUTDOWN IN JULY FOR REFUELING MAINTENANCE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* NINE MILE POINT 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
COUNTY.....OSWEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NE OF  
OSWEGO, NY  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1969  
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1969  
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE ONTARIO  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NIAGARA MOHAWK POWER CORP.  
CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST  
SYRACUSE, NEW YORK 13202  
CONTRACTOR  
ARCHITECT/ENGINEER.....NIAGARA MOHAWK POWER CORP.  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....S. HUDSON  
LICENSING PROJ MANAGER.....R. BENEDICT  
DOCKET NUMBER.....50-220  
LICENSE & DATE ISSUANCE...DPR-63, DECEMBER 26, 1974  
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO  
PENFIELD LIBRARY - DOCUMENTS  
OSWEGO, NY 13126  
(315) 341-2323

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   ( C O N T I N U E D )

\*\*\*\*\*  
\*            NINE MILE POINT 1            \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

-----  
NUMBER      DATE OF      DATE OF      SUBJECT  
            EVENT            REPORT  
-----

NO INPUT PROVIDED.  
-----

1. Docket: 50-410      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-Line Hrs: 744.0

3. Utility Contact: E. TOMLINSON (313) 349-2761

4. Licensed Thermal Power (MWe):      3323

5. Nameplate Rating (Gross MWe):      1214

6. Design Electrical Rating (Net MWe):      1080

7. Maximum Dependable Capacity (Gross MWe):      1090

8. Maximum Dependable Capacity (Net MWe):      1080

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>3,416.0</u>	<u>3,416.0</u>
13. Hours Reactor Critical	<u>705.7</u>	<u>2,287.1</u>	<u>2,287.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>638.1</u>	<u>2,143.9</u>	<u>2,143.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,039,081</u>	<u>6,595,279</u>	<u>6,595,279</u>
18. Gross Elec Ener (MWH)	<u>667,400</u>	<u>2,107,640</u>	<u>2,107,640</u>
19. Net Elec Ener (MWH)	<u>624,726</u>	<u>1,951,900</u>	<u>1,951,900</u>
20. Unit Service Factor	<u>92.5</u>	<u>62.8</u>	<u>62.8</u>
21. Unit Avail Factor	<u>92.5</u>	<u>62.8</u>	<u>62.8</u>
22. Unit Cap Factor (MDC Net)	<u>77.7</u>	<u>52.9</u>	<u>52.9</u>
23. Unit Cap Factor (DER Net)	<u>77.7</u>	<u>52.9</u>	<u>52.9</u>
24. Unit Forced Outage Rate	<u>7.5</u>	<u>19.7</u>	<u>19.7</u>
25. Forced Outage Hours	<u>55.9</u>	<u>525.6</u>	<u>525.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


MAINT/SURV - 9/17/88 - 48 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \*                    NINE MILE POINT 2                    \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NINE MILE POINT 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* NINE MILE POINT 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-9	07/08/88	F	0.0	A	5				REDUCED POWER TO PERFORM REPAIRS ON AND TEST LV10C. POWER REDUCTION WAS IN EFFECT WHEN MANUAL SCRAM OCCURRED ON 7/11/88.
88-10	07/11/88	F	55.9	A	2	88-28			TURBINE CONTROL VALVE NO.3 DEVELOPED A LEAK OF CONTROL OIL FROM A LOOSENED PIPE FITTING THAT COULD NOT BE REPAIRED DURING OPERATION. AN ORDERLY PLANT SHUTDOWN WAS IN PROGRESS WHEN THE OIL RESERVOIR REACHED THE LGW LEVEL MARK. THE REACTOR WAS MANUALLY SCRAMMED FROM APPROXIMATELY 45% POWER TO ENSURE ADEQUATE PRESSURE CONTROL. CORRECTIVE MAINTENANCE WAS PERFORMED ON THE PIPE FITTING.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 NINE MILE POINT 2 INCURRED ONE FORCED LOAD REDUCTION AND ONE FORCED OUTAGE IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	6-Other	(LER) File (NUREG-0161)



XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
\* NINE MILE POINT 2 \*  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

F A C I L I T Y   D A T A

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
COUNTY.....OSWEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NE OF  
OSWEGO, NY  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MAY 23, 1967  
DATE ELEC ENER 1ST GENER...AUGUST 6, 1967  
DATE COMMERCIAL OPERATE...MARCH 11, 1988  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...LAKE ONTARIO  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NIAGARA MOHAWK POWER CORP.  
CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST  
SYRACUSE, NEW YORK 13202  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....W. COOK  
LICENSING PROJ MANAGER.....M. HAUGHEY  
DOCKET NUMBER.....50-410  
LICENSE & DATE ISSUANCE...NPF-69, JULY 2, 1987  
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO  
PENFIELD LIBRARY - DOCUMENTS  
OSWEGO, NY 13126  
(315) 341-2323

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*           NINE MILE POINT 2           \*  
\*\*\*\*\*

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

R E P O R T S   F R O M   L I C E N S E E

-----  
NUMBER      DATE OF      DATE OF      SUBJECT  
            EVENT       REPORT

-----  
INFO. NOT SUPPLIED BY REGION  
-----

1. Docket: 50-338                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: B. GARNER (703) 994-5151 X2527

4. Licensed Thermal Power (MWT):                      2893

5. Nameplate Rating (Gross MWe):                      947

6. Design Electrical Rating (Net MWe):                      907

7. Maximum Dependable Capacity (Gross MWe):                      963

8. Maximum Dependable Capacity (Net MWe):                      915

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:                                     
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>39,016.0</u>
13. Hours Referred Critical	<u>744.0</u>	<u>6,385.8</u>	<u>61,817.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>148.6</u>	<u>5,796.6</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,225.5</u>	<u>59,994.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,127,839</u>	<u>11,928,155</u>	<u>158,104,909</u>
18. Gross Elec Ener (MWH)	<u>698,225</u>	<u>3,949,023</u>	<u>51,852,911</u>
19. Net Elec Ener (MWH)	<u>667,806</u>	<u>3,775,905</u>	<u>49,045,399</u>
20. Unit Service Factor	<u>100.0</u>	<u>82.7</u>	<u>67.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>82.7</u>	<u>67.4</u>
22. Unit Cap Factor (MDC Net)	<u>97.2</u>	<u>80.1</u>	<u>60.2</u>
23. Unit Cap Factor (DER Net)	<u>98.1</u>	<u>80.8</u>	<u>60.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>15.4</u>	<u>15.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>771.7</u>	<u>10,593.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      NORTH ANNA 1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

XX  
X NORTH ANNA 1 X  
XX

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

XXXXXXXXXXXX NORTH ANNA 1 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
\* SUMMARY \* SIGNIFICANT POWER REDUCTIONS.  
XXXXXXXXXXXX

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	G-Oper Error	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA  
  
COUNTY.....LOUISA  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI NW OF  
RICHMOND, VA  
  
TYPE OF REACTOR..... PWR  
  
DATE INITIAL CRITICALITY...APRIL 5, 1978  
  
DATE ELEC ENER 1ST GENER...APRIL 17, 1978  
  
DATE COMMERCIAL OPERATE...JUNE 6, 1978  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER...LAKE ANNA  
  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA POWER  
  
CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....STONE & WEBSTER  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
  
IE RESIDENT INSPECTOR.....M. BRANCH  
  
LICENSING PROJ MANAGER.....L. ENGLE  
DOCKET NUMBER.....50-338  
  
LICENSE & DATE ISSUANCE...NPF-4, APRIL 1, 1978  
  
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.  
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MARCH 28 - APRIL 1 AND 11-15 (88-06): THIS WAS A SPECIAL ANNOUNCED OPERATIONAL PERFORMANCE ASSESSMENT (OPA). THE OPA EVALUATED THE LICENSEE'S CURRENT LEVEL OF PERFORMANCE IN THE AREA OF PLANT OPERATIONS. THE INSPECTION INCLUDED AN EVALUATION OF THE EFFECTIVENESS OF VARIOUS PLANT GROUPS INCLUDING OPERATIONS, MAINTENANCE, QUALITY ASSURANCE, ENGINEERING AND TRAINING, IN SUPPORTING SAFE PLANT OPERATIONS. PLANT MANAGEMENT AWARENESS OF, INVOLVEMENT IN, AND SUPPORT OF SAFE PLANT OPERATION WAS ALSO EVALUATED. THE INSPECTION WAS DIVIDED INTO THREE MAJOR AREAS INCLUDING OPERATIONS, MAINTENANCE SUPPORT OF OPERATIONS, AND MANAGEMENT CONTROLS. EMPHASIS WAS PLACED ON NUMEROUS INTERVIEWS OF PERSONNEL AT ALL LEVELS, OBSERVATION OF PLANT ACTIVITIES AND MEETINGS, EXTENDED CONTROL ROOM OBSERVATIONS, PLANT AND SYSTEM WALKDOWNS. THE INSPECTORS ALSO REVIEWED PLANT DEVIATION REPORTS AND LICENSEE EVENT REPORTS (LERS) FOR THE CURRENT SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE (SALP) EVALUATION PERIOD, AND EVALUATED THE EFFECTIVENESS OF THE LICENSEE'S ROOT CAUSE IDENTIFICATION; SHORT TERM AND PROGRAMMATIC CORRECTIVE ACTIONS; AND, REPETITIVE FAILURE TRENDING AND RELATED CORRECTIVE ACTIONS.

INSPECTION APRIL 20-22 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF SNUBBER SURVEILLANCE PROGRAM AND FOLLOWUP ON LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. TWO UNRESOLVED ITEMS WERE IDENTIFIED: ONE CONCERNING THE EVALUATION OF VISUAL SNUBBER INSPECTION RESULTS; SECONDLY, CORRECTIVE ACTIONS ON SNUBBERS WITH FLUID LEAKS.

INSPECTION JUNE 6-10 (88-17): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF REVIEW AND EVALUATION OF INSERVICE INSPECTION (ISI) DATA FROM UNIT 2, 1987 REFUELING OUTAGE. ALSO MAINTENANCE RECORDS REVIEW OF REACTOR COOLANT PUMP (RCP), 1-A O-RING LEAK REPAIR; ELECTRO HYDRAULIC CONTROL (EHC), SYSTEM MALFUNCTION REPAIR; LICENSEE EVENT REPORTS (LERS). INSPECTOR IDENTIFIED OPEN ITEMS WERE REVIEWED AND CLOSED AS APPROPRIATE. THE MAIN ACTIVITIES INSPECTED INCLUDED A REVIEW OF ISI

INSPECTION SUMMARY

NONDESTRUCTIVE EXAMINATION RECORDS, COMPLETED PROCEDURES OF MAINTENANCE WORK ON RC PUMP 1-A, O-RING AND ON EHC SYSTEM VALVES. IN BOTH AREAS, THE LICENSEE'S WORK PROCEDURES WERE ADEQUATE, PROBLEMS WHICH LEAD TO THE FAILURE WERE ADEQUATELY INVESTIGATED AND TECHNICAL ISSUES ADDRESSED. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

RESIN IN SECONDARY PLANT.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

COLD SHUTDOWN FOR RESIN CLEANUP.

LAST IE SITE INSPECTION DATE: JULY 15, 1988

INSPECTION REPORT NO: 50-338/88-21

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

1. Docket: 50-339 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: B. GARNER (703) 894-5151 X2527  
 4. Licensed Thermal Power (Mwt): 2893  
 5. Nameplate Rating (Gross MWe): 947  
 6. Design Electrical Rating (Net MWe): 907  
 7. Maximum Dependable Capacity (Gross MWe): 963  
 8. Maximum Dependable Capacity (Net MWe): 915  
 9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>66,887.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,061.9</u>	<u>53,522.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>49.1</u>	<u>4,093.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,035.2</u>	<u>52,463.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,151,975</u>	<u>14,527,069</u>	<u>138,849,823</u>
18. Gross Elec Ener (MWH)	<u>769,470</u>	<u>4,830,996</u>	<u>46,058,177</u>
19. Net Elec Ener (MWH)	<u>673,448</u>	<u>4,590,267</u>	<u>43,648,625</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.5</u>	<u>78.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.5</u>	<u>78.4</u>
22. Unit Cap Factor (MDC Net)	<u>98.9</u>	<u>98.2</u>	<u>71.3</u>
23. Unit Cap Factor (DER Net)	<u>99.8</u>	<u>99.0</u>	<u>71.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>8.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>4,768.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* NORTH ANNA 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* NORTH ANNA 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
NORTH ANNA 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		



FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA  
COUNTY.....LOUISA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI NW OF  
RICHMOND, VA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 12, 1980  
DATE ELEC ENER. 1ST GENER...AUGUST 25, 1980  
DATE COMMERCIAL OPERATE...DECEMBER 14, 1980  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE ANNA  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA POWER  
CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....M. BRANCH  
LICENSING PROJ MANAGER.....L. ENGLE  
DOCKET NUMBER.....50-339  
LICENSE & DATE ISSUANCE...NPF-7, AUGUST 21, 1980  
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.  
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

\* INSPECTION MARCH 28 - APRIL 1 AND 11-15 (88-06): THIS WAS A SPECIAL ANNOUNCED OPERATIONAL PERFORMANCE ASSESSMENT (OPA). THE OPA EVALUATED THE LICENSEE'S CURRENT LEVEL OF PERFORMANCE IN THE AREA OF PLANT OPERATIONS. THE INSPECTION INCLUDED AN EVALUATION OF THE EFFECTIVENESS OF VARIOUS PLANT GROUPS INCLUDING OPERATIONS, MAINTENANCE, QUALITY ASSURANCE, ENGINEERING AND TRAINING, IN SUPPORTING SAFE PLANT OPERATIONS. PLANT MANAGEMENT AWARENESS OF, INVOLVEMENT IN, AND SUPPORT OF SAFE PLANT OPERATION WAS ALSO EVALUATED. THE INSPECTION WAS DIVIDED INTO THREE MAJOR AREAS INCLUDING OPERATIONS, MAINTENANCE SUPPORT OF OPERATIONS, AND MANAGEMENT CONTROLS. EMPHASIS WAS PLACED ON NUMEROUS INTERVIEWS OF PERSONNEL AT ALL LEVELS, OBSERVATION OF PLANT ACTIVITIES AND MEETINGS, EXTENDED CONTROL ROOM OBSERVATIONS, PLANT AND SYSTEM WALKDOWNS. THE INSPECTORS ALSO REVIEWED PLANT DEVIATION REPORTS AND LICENSEE EVENT REPORTS (LERS) FOR THE CURRENT SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE (SALP) EVALUATION PERIOD, AND EVALUATED THE EFFECTIVENESS OF THE LICENSEE'S ROOT CAUSE IDENTIFICATION; SHORT TERM AND PROGRAMMATIC CORRECTIVE ACTIONS; AND, REPETITIVE FAILURE TRENDING AND RELATED CORRECTIVE ACTIONS.

INSPECTION APRIL 20-22 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF SNUBBER SURVEILLANCE PROGRAM AND FOLLOWUP ON LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. TWO UNRESOLVED ITEMS WERE IDENTIFIED: ONE CONCERNING THE EVALUATION OF VISUAL SNUBBER INSPECTION RESULTS; SECONDLY, CORRECTIVE ACTIONS ON SNUBBERS WITH FLUID LEAKS.

INSPECTION JUNE 6-10 (88-17): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF REVIEW AND EVALUATION OF INSERVICE INSPECTION (ISI) DATA FROM UNIT 2, 1987 REFUELING OUTAGE. ALSO MAINTENANCE RECORDS REVIEW OF REACTOR COOLANT PUMP (RCP), 1-A O-RING LEAK REPAIR; ELECTRO HYDRAULIC CONTROL (EHC), SYSTEM MALFUNCTION REPAIR; LICENSEE EVENT REPORTS (LERS). INSPECTOR IDENTIFIED OPEN ITEMS WERE REVIEWED AND CLOSED AS APPROPRIATE. THE MAIN ACTIVITIES INSPECTED INCLUDED A REVIEW OF ISI

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    NORTH ANNA 2                    \*  
\*\*\*\*\*

INSPECTION SUMMARY

NONDESTRUCTIVE EXAMINATION RECORDS, COMPLETED PROCEDURES OF MAINTENANCE WORK ON RC PUMP 1-A, O-RING AND ON EHC SYSTEM VALVES. IN BOTH AREAS, THE LICENSEE'S WORK PROCEDURES WERE ADEQUATE, PROBLEMS WHICH LEAD TO THE FAILURE WERE ADEQUATELY INVESTIGATED AND TECHNICAL ISSUES ADDRESSED. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

RESIN IN SECONDARY PLANT.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

COLD SHUTDOWN FOR RESIN CLEANUP.

LAST IE SITE INSPECTION DATE: JULY 15, 1988

INSPECTION REPORT NO: 50-339/88-21

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

1. Docket: 59-269 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MHT): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 846

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE


10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>151,888.0</u>
13. Hours Reactor Critical	<u>729.0</u>	<u>5,096.0</u>	<u>98,405.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>725.0</u>	<u>5,092.0</u>	<u>94,789.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,770,696</u>	<u>12,799,704</u>	<u>229,284,769</u>
18. Gross Elec Ener (MWH)	<u>600,827</u>	<u>4,403,077</u>	<u>79,510,734</u>
19. Net Elec Ener (MWH)	<u>571,919</u>	<u>4,206,946</u>	<u>75,418,051</u>
20. Unit Service Factor	<u>97.4</u>	<u>99.6</u>	<u>71.9</u>
21. Unit Avail Factor	<u>97.4</u>	<u>99.6</u>	<u>71.9</u>
22. Unit Cap Factor (MDC Net)	<u>90.9</u>	<u>97.3</u>	<u>66.4*</u>
23. Unit Cap Factor (DER Net)	<u>86.7</u>	<u>92.8</u>	<u>64.5*</u>
24. Unit Forced Outage Rate	<u>2.6</u>	<u>.4</u>	<u>13.3</u>
25. Forced Outage Hours	<u>19.0</u>	<u>19.0</u>	<u>13,533.7</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>REFUELING - JANUARY 11, 1989, 7 WEEK DURATION.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* OCONEE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
OCONEE 1



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* OCONEE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9-P	07/01/88	F	0.0	A	5		CB	PUMPXX	REACTOR COOLANT PUMP '1B2' OIL ADDITION.
10-P	07/01/88	F	0.0	A	5		IF	INSTRU	INTEGRATED CONTROL SYSTEM PUT IN MANUAL TO RESET HI FLUX LIMITER.
11-P	07/01/88	F	0.0	B	5		RB	CRDRVE	CONTROL ROD DRIVE POWER SUPPLY CHECK.
12-P	07/01/88	S	0.0	F	5		ZZ	XXXXXX	DISPATCHER REQUEST.
13-P	07/02/88	F	0.0	H	5		HJ	PUMPXX	'1D2' HEATER DRAIN PUMP PUT IN SERVICE.
1	07/05/88	F	19.0	G	3		ZZ	INSTRU	REACTOR TRIP DUE TO AN INDICATED LOSS OF FEEDWATER.
14-P	07/06/88	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCHER REQUEST.
15-P	07/06/88	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCH REQUEST.
16-P	07/06/88	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCH REQUEST.
17-P	07/07/88	F	0.0	A	5		HJ	PUMPXX	LIMITED BY CONDENSATE BOOSTER PUMP SUCTION PRESSURE.
18-P	07/07/88	F	0.0	H	5		RC	FUELXX	QUADRANT POWER TILT GREATER THAN STEADY STATE LIMIT.
19-P	07/07/88	F	0.0	B	5		IF	XXXXXX	RESET HIGH FLUX LIMITER.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 OCONEE 1 INCURRED ONE FORCED OUTAGE AND SEVERAL LOAD REDUCTIONS DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* OCONEE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....OCONEE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...36 MI W OF  
GREENVILLE, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...APRIL 19, 1973  
DATE ELEC ENER 1ST GENER...MAY 6, 1973  
DATE COMMERCIAL OPERATE....JULY 15, 1973  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE KEOWEE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE & BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. BRYANT  
LICENSING PROJ MANAGER.....H. PASTIS  
DOCKET NUMBER.....50-269  
LICENSE & DATE ISSUANCE...DPR-38, FEBRUARY 6, 1973  
PUBLIC DOCUMENT ROOM..... OCONEE COUNTY LIBRARY  
501 W. SOUTH BROAD ST.  
VALHALLA, SOUTH CAROLINA 29691

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MAY 17 - JULY 15 (88-15): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED RESIDENT INSPECTION ON-SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, SAFEGUARDS AND RADIATION PROTECTION, INSPECTION REPORT FOLLOWUP. OF THE SIX AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED. OPEN ITEMS, AND SAFETY SYSTEM FUNCTIONAL TESTS.

INSPECTION MAY 23-27 (88-16): THIS ROUTINE, ANNOUNCED INSPECTION WAS FOR BULLETIN FOLLOWUP. WEAKNESSES WERE IDENTIFIED IN THE LICENSEE BULLETIN AND PRESSURE TEST MOTOR OPERATED VALVES IN ACCORDANCE WITH BULLETIN GUIDELINES. OPERATED VALVE TESTING PER A PREVIOUS LICENSEE COMMITMENT. STRENGTHS WERE IDENTIFIED THAT INVOLVE THE FOLLOWING LICENSEE COMMITMENTS: (1) EXPAND THE SCOPE OF INSPECTION TO INCLUDE DIAGNOSTIC TESTING ON BULLETIN VALVES EACH REFUELING AND FOLLOWING MAINTENANCE; (2) PERFORM FULL FLOW HIGH PRESSURE TEST LOOP IN ORDER TO PERFORM ADDITIONAL TESTING OF AREAS OF COMPLEX SURVEILLANCE TESTING AND INVOLVED FAILURE TO DIFFERENTIAL MOTOR TO PERFORM POST-MAINTENANCE MOTOR TESTS. SEE IE BULLETIN 85-03 PROGRAM ON VALVE-RELATED VALVES; (2) PERFORM POST-MAINTENANCE MOTOR TESTS; AND (3) CONSTRUCT A

INSPECTION JUNE 20-24 (88-18): THIS ROUTINE, ANNOUNCED INSPECTION WAS FOR THE PURPOSE OF OBTAINING NRC COVERAGE IN THE ABSENCE OF BOTH RESIDENT INSPECTORS; REVIEW OF LICENSEE ACTION OF INSPECTOR IDENTIFIED ITEMS INCLUDING LICENSEE EVENT REPORTS (LERS); INSERVICE TESTING OF PUMPS AND VALVES; REVIEW AND EVALUATE NONDESTRUCTIVE EXAMINATION RESULTS FROM TESTS SCHEDULED FOR THE UPCOMING UNIT 3 OUTAGE. OF THE TWO AREAS INSPECTED, THE INSERVICE INSPECTION OF PUMPS AND VALVES PROGRAM PRODUCED ONE AREA OF CONCERN IN THAT THE ROOT CAUSE OF A RECURRING VALVE FAILURE HAD NOT BEEN DETERMINED AND CORRECTED EVEN THOUGH ITS FAILURE RESULTED IN REPEATED INSERVICE TEST FAILURES OF "1A" MOTOR DRIVEN EMERGENCY FEEDWATER PUMP. FOLLOWING DISCUSSION ON THIS SUBJECT, THE LICENSEE AGREED TO INITIATE SPECIAL TESTING DESIGNED TO IDENTIFY AND CORRECT THE PROBLEM. NO VIOLATIONS OR DEVIATIONS WERE

INSPECTION SUMMARY

IDENTIFIED.

INSPECTION JUNE 27 - JULY 1 (88-19): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF QUALITY ASSURANCE/QUALITY CONTROL (QA/QC) CONTROLS AND WORK ACTIVITIES FOR FIRE PROTECTION, SEISMIC MONITORING AND FOLLOWUP ON LICENSEE IDENTIFIED ITEM (LER) 269/88-05. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST SITE INSPECTION DATE: JULY 29, 1988 +

INSPECTION REPORT NO: 50-269/88-21 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-007	05/18/88	07/06/88	TECHNICAL SPECIFICATION VIOLATION DUE TO MISSED FIREWATCHES RESULTING FROM PERSONNEL ERRORS AND MANAGEMENT DEFICIENCY

1. Docket: 50-270 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (Mwt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 846

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_


11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>121,800.0</u>
13. Hours Reactor Critical	<u>518.7</u>	<u>3,319.0</u>	<u>92,015.7</u>
14. Rx Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-line	<u>515.5</u>	<u>3,216.7</u>	<u>90,510.1</u>
16. Unit Reserve Shtdn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Thermal Power (MWH)	<u>1,302,912</u>	<u>7,769,976</u>	<u>215,410,077</u>
18. Gross Electrical (MWH)	<u>440,957</u>	<u>2,624,461</u>	<u>73,307,142</u>
19. Net Elec Ener (MWH)	<u>318,756</u>	<u>2,492,073</u>	<u>69,689,591</u>
20. Unit Service Factor	<u>69.3</u>	<u>62.9</u>	<u>74.3</u>
21. Unit Avail Factor	<u>69.3</u>	<u>62.9</u>	<u>74.3</u>
22. Unit Cap Factor (MDC Net)	<u>66.6</u>	<u>57.6</u>	<u>66.4*</u>
23. Unit Cap Factor (DER Net)	<u>63.5</u>	<u>55.0</u>	<u>64.5*</u>
24. Unit Forced Outage Rate	<u>30.7</u>	<u>8.3</u>	<u>11.8</u>
25. Forced Outage Hours	<u>228.5</u>	<u>290.6</u>	<u>11,253.6</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* OCONEE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
OCONEE 2



JULY 1988

\* Item calculated with a Weighted Average

PAGE 2-276

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* OCONEE 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	07/06/88	F	228.5	A	1		CH	HTEXCH	*2A2* STEAM GENERATOR TUBE LEAK.
19-P	07/16/88	F	0.0	A	5		HR	PUMPXX	HIGH INBOARD SEAL TEMPERATURE ON *2B* FEEDWATER PUMP.
20-P	07/16/88	F	0.0	A	5		HB	HTEXCH	ISOLATE *2A2* FEEDWATER HEATER DUE TO TUBE LEAK.
21-P	07/18/88	F	0.0	H	5		HB	XXXXXX	FEEDWATER SWINGS.
22-P	07/22/88	F	0.0	H	5		HB	HTEXCH	PLACE *2A2* FEEDWATER HEATER IN SERVICE.
23-P	07/29/88	F	0.0	B	5		HB	HTEXCH	FEEDWATER HEATER ADJUSTMENTS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 OCONEE 2 INCURRED ONE FORCED OUTAGE DUE TO STEAM GENERATOR TUBE LEAK AND 5 FORCED LOAD REDUCTIONS DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)



\*\*\*\*\*  
\* OCONEE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....OCONEE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...30 MI W OF  
GREENVILLE, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 11, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 5, 1973  
DATE COMMERCIAL OPERATE....SEPTEMBER 9, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE KEOWEE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE & BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. BRYANT  
LICENSING PROJ MANAGER.....H. PASTIS  
DOCKET NUMBER.....50-270  
LICENSE & DATE ISSUANCE...DPR-47, OCTOBER 6, 1973  
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY  
501 W. SOUTH BRD ST.  
WALHALLA, SOUTH CAROLINA 29691

INSPECTION STATUS

INSPECTION SUMMARY

\* INSPECTION MAY 17 - JULY 15 (88-15): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED RESIDENT INSPECTION ON-SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, SAFEGUARDS AND RADIATION PROTECTION, INSPECTION OF OPEN ITEMS, AND SAFETY SYSTEM FUNCTIONAL INSPECTION REPORT FOLLOWUP. OF THE SIX AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION MAY 23-27 (88-16): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF COMPLEX SURVEILLANCE TESTING AND BULLETIN FOLLOWUP. WEAKNESSES WERE IDENTIFIED IN THE LICENSEE BULLETIN 85-03 PROGRAM THAT INVOLVED FAILURE TO DIFFERENTIAL PRESSURE TEST MOTOR OPERATED VALVES IN ACCORDANCE WITH BULLETIN GUIDELINES, AND A FAILURE TO PERFORM POST-MAINTENANCE MOTOR OPERATED VALVE TESTING PER A PREVIOUS LICENSEE COMMITMENT. STRENGTHS WERE IDENTIFIED IN THE LICENSEE IE BULLETIN 85-03 PROGRAM THAT INVOLVE THE FOLLOWING LICENSEE COMMITMENTS: (1) EXPAND THE SCOPE OF BULLETIN 85-03 TO ALL SAFETY-RELATED VALVES; (2) PERFORM DIAGNOSTIC TESTING ON BULLETIN VALVES EACH REFUELING AND FOLLOWING MAINTENANCE THAT COULD EFFECT STEM THRUST; AND (3) CONSTRUCT A FULL FLOW HIGH PRESSURE TEST LOOP IN ORDER TO PERFORM ADDITIONAL TESTING ON MOTOR OPERATED VALVES.

INSPECTION JUNE 20 - JULY 15 (88-17): THIS ROUTINE, ANNOUNCED INSPECTION WAS FOR THE PURPOSE OF PROVIDING NRC COVERAGE IN THE ABSENCE OF BOTH RESIDENT INSPECTION AND THE ACTION OF INSPECTOR IDENTIFIED ITEMS INCLUDING LICENSEE EVENT REPORTS (LERS); INSERVICE TESTING OF PUMPS AND VALVES; REVIEW AND EVALUATE NONDESTRUCTIVE EXAMINATION RESULTS FROM TESTS SCHEDULED FOR THE UPCOMING UNIT 3 OUTAGE. OF THE TWO AREAS INSPECTED, THE INSERVICE INSPECTION OF PUMPS AND VALVES PROGRAM PRODUCED ONE AREA OF CONCERN IN THAT THE ROOT CAUSE OF A RECURRING VALVE FAILURE HAD NOT BEEN DETERMINED AND CORRECTED EVEN THOUGH ITS FAILURE RESULTED IN REPEATED INSERVICE TEST FAILURES OF "1A" MOTOR DRIVEN EMERGENCY FEEDWATER PUMP. FOLLOWING DISCUSSION ON THIS SUBJECT, THE LICENSEE AGREED TO INITIATE SPECIAL TESTING DESIGNED TO IDENTIFY AND CORRECT THE PROBLEM. NO VIOLATIONS OR DEFICIENCIES WERE



1. Docket: 56-287 OPERATING STATUS
2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: J. A. REAVIS (704) 373-7567
4. Licensed Thermal Power (MWT): 2568
5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934
6. Design Electrical Rating (Net MWe): 887
7. Maximum Dependable Capacity (Gross MWe): 899
8. Maximum Dependable Capacity (Net MWe): 846
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>119,447.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,594.7</u>	<u>87,943.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,587.4</u>	<u>86,573.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,909,976</u>	<u>11,571,416</u>	<u>212,470,877</u>
18. Gross Elec Ener (MWH)	<u>645,085</u>	<u>3,976,137</u>	<u>73,186,682</u>
19. Net Elec Ener (MWH)	<u>617,418</u>	<u>3,804,651</u>	<u>69,733,281</u>
20. Unit Service Factor	<u>100.0</u>	<u>89.8</u>	<u>72.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>89.8</u>	<u>72.5</u>
22. Unit Cap Factor (MDC Net)	<u>98.1</u>	<u>88.0</u>	<u>67.8*</u>
23. Unit Cap Factor (DER Net)	<u>93.6</u>	<u>83.9</u>	<u>65.8*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>10.2</u>	<u>13.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>523.6</u>	<u>13,148.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - AUGUST 10, 1988 - 7 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* OCONEE 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 3



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* OCONEE 3 \*  
\*\*\*\*\*

No   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
OCONEE 3 OPERATED ROUTINELY DURING JULY WITH NO OUTAGES OR  
SIGNIFICANT LOAD REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* OCONEE 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....OCONEE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...30 MI W OF  
GREENVILLE, SC  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1974  
DATE ELEC ENER 1ST GENER...SEPTEMBER 18, 1974  
DATE COMMERCIAL OPERATE...DECEMBER 16, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE KEOWE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE & BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC  
REGULATORY INFORMATION  
IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. BRYANT  
LICENSING PROJ MANAGER.....H. PASTIS  
DOCKET NUMBER.....50-287  
LICENSE & DATE ISSUANCE...DPR-55, JULY 19, 1974  
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY  
501 W. SOUTH BROAD ST.  
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

\* INSPECTION MAY 17 - JULY 15 (88-15): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED RESIDENT INSPECTION ON-SITE IN THE AREAS OF OPERATIONS, SURVEILLANCE, MAINTENANCE, SAFEGUARDS AND RADIATION PROTECTION, INSPECTION OF OPEN ITEMS, AND SAFETY SYSTEM FUNCTIONAL INSPECTION REPORT FOLLOWUP. OF THE SIX AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION MAY 23-27 (88-16): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF COMPLEX SURVEILLANCE TESTING AND BULLETIN FOLLOWUP. WEAKNESSES WERE IDENTIFIED IN THE LICENSEE BULLETIN 85-03 PROGRAM THAT INVOLVED FAILURE TO DIFFERENTIAL PRESSURE TEST MOTOR OPERATED VALVES IN ACCORDANCE WITH BULLETIN GUIDELINES, AND A FAILURE TO PERFORM POST-MAINTENANCE MOTOR OPERATED VALVE TESTING PER A PREVIOUS LICENSEE COMMITMENT. STRENGTHS WERE IDENTIFIED IN THE LICENSEE IE BULLETIN 85-03 PROGRAM THAT INVOLVE THE FOLLOWING LICENSEE COMMITMENTS: (1) EXPAND THE SCOPE OF BULLETIN 85-03 TO ALL SAFETY-RELATED VALVES; (2) PERFORM DIAGNOSTIC TESTING ON BULLETIN VALVES EACH REFUELING AND FOLLOWING MAINTENANCE THAT COULD EFFECT STEM THRUST; AND (3) CONSTRUCT A FULL FLOW HIGH PRESSURE TEST LOOP IN ORDER TO PERFORM ADDITIONAL TESTING OF MOTOR OPERATED VALVES.

INSPECTION JUNE 20-24 (88-18): THIS ROUTINE, ANNOUNCED INSPECTION WAS FOR THE PURPOSE OF PROVIDING NRC COVERAGE IN THE ABSENCE OF BOTH RESIDENT INSPECTORS; REVIEW OF LICENSEE ACTION OF INSPECTOR IDENTIFIED ITEMS INCLUDING LICENSEE EVENT REPORTS (LERS); INSERVICE TESTING OF PUMPS AND VALVES; REVIEW AND EVALUATE NONDESTRUCTIVE EXAMINATION RESULTS FROM TESTS SCHEDULED FOR THE UPCOMING UNIT 3 OUTAGE. OF THE TWO AREAS INSPECTED, THE INSERVICE INSPECTION OF PUMPS AND VALVES PROGRAM PRODUCED ONE AREA OF CONCERN IN THAT THE ROOT CAUSE OF A RECURRING VALVE FAILURE HAD NOT BEEN DETERMINED AND CORRECTED EVEN THOUGH ITS FAILURE RESULTED IN REPEATED INSERVICE TEST FAILURES OF "1A" MOTOR DRIVEN EMERGENCY FEEDWATER PUMP. FOLLOWING DISCUSSION ON THIS SUBJECT, THE LICENSEE AGREED TO INITIATE SPECIAL TESTING DESIGNED TO IDENTIFY AND CORRECT THE PROBLEM. NO VIOLATIONS OR DEVIATIONS WERE

INSPECTION SUMMARY

IDENTIFIED.

INSPECTION JUNE 27 - JULY 1 (88-19): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF QUALITY ASSURANCE/QUALITY CONTROL (QA/QC) CONTROLS AND WORK ACTIVITIES FOR FIRE PROTECTION, SEISMIC MONITORING AND FOLLOWUP ON LICENSEE IDENTIFIED ITEM (LER) 269/88-05. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: JULY 29, 1988 +

INSPECTION REPORT NO: 50-287/88-21 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

1. Docket: 50-219                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: JOHN H. SEDAR JR. (609) 971-4698

4. Licensed Thermal Power (MWT):                    1930

5. Nameplate Rating (Gross MWe):                    687.5 X 0.8 = 550

6. Design Electrical Rating (Net MWe):                    650

7. Maximum Dependable Capacity (Gross MWe):                    642

8. Maximum Dependable Capacity (Net MWe):                    620

9. If Changes Occur Above Since Last Report, Give Reasons:  
MDC GRID: CHANGED TO REFLECT SUMMER GENERATION.

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>163,703.0</u>
13. Hours Reactor Critical	<u>211.9</u>	<u>4,578.9</u>	<u>105,730.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,208.0</u>
15. Hrs Generator On-Line	<u>211.7</u>	<u>4,578.7</u>	<u>102,370.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,761.4</u>
17. Gross Therm Ener (MWH)	<u>383,500</u>	<u>8,683,500</u>	<u>171,447,908</u>
18. Gross Elec Ener (MWH)	<u>126,590</u>	<u>2,958,220</u>	<u>57,876,574</u>
19. Net Elec Ener (MWH)	<u>118,908</u>	<u>2,848,830</u>	<u>55,571,718</u>
20. Unit Service Factor	<u>28.5</u>	<u>89.6</u>	<u>62.8</u>
21. Unit Avail Factor	<u>28.5</u>	<u>89.6</u>	<u>63.8</u>
22. Unit Cap Factor (MDC Net)	<u>25.8</u>	<u>89.9</u>	<u>55.0*</u>
23. Unit Cap Factor (DER Net)	<u>24.6</u>	<u>85.8</u>	<u>52.4</u>
24. Unit Forced Outage Rate	<u>71.5</u>	<u>10.4</u>	<u>14.2</u>
25. Forced Outage Hours	<u>532.3</u>	<u>532.3</u>	<u>14,978.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - OCTOBER 15, 1988 - 84 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: 08/10/88

\*\*\*\*\*  
 \* OYSTER CREEK 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 OYSTER CREEK 1



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* OYSTER CREEK 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
68	07/09/88	F	532.3	A	2			PLANT SHUTDOWN WAS REQUIRED AFTER MSIV "NS03A" FAILED TO OPERATE PROPERLY DURING ROUTINE TESTING. THE RX WAS MANUALLY SCRAMMED AFTER THE GENERATOR WAS TAKEN OFF THE LINE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

OYSTER CREEK INCURRED ONE FORCED OUTAGE IN JULY DUE TO EQUIPMENT FAILURE AND REMAINED SHUTDOWN AT THE END OF THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)



\*\*\*\*\*  
\* OYSTER CREEK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
COUNTY.....OCEAN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI S OF  
TOMS RIVER, NJ  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...Feb, 5, 1969  
DATE ELEC ENER 1ST GENER...SEPTEMBER 23, 1969  
DATE COMMERCIAL OPERATE....DECEMBER 1, 1969  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...BARNEGAT BAY  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GPU NUCLEAR CORPORATION  
CORPORATE ADDRESS.....100 INTERPACE PARKWAY  
PARSIPPANY, NEW JERSEY 07054  
CONTRACTOR  
ARCHITECT/ENGINEER.....BURNS & ROE  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BURNS & ROE  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....J. WECHSELBERGR  
LICENSING PROJ MANAGER.....A. DROMERICK  
DOCKET NUMBER.....50-219  
LICENSE & DATE ISSUANCE....DPR-16, AUGUST 1, 1969  
PUBLIC DOCUMENT ROOM.....OCEAN COUNTY LIBRARY  
101 WASHINGTON STREET  
TOMS RIVER, NEW JERSEY 08753

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    OYSTER CREEK 1                    \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

-----

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

-----

1. Docket: 50-255 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: O. C. PACKARD (616) 764-8913

4. Licensee Thermal Power (MWT): 2530

5. Nameplate Rating (Gross MWe): 955 X 0.85 = 812

6. Design Electrical Rating (Net MWe): 805

7. Maximum Dependable Capacity (Gross MWe): 770

8. Maximum Dependable Capacity (Net MWe): 730

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>195,670.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,401.2</u>	<u>78,418.7</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,361.4</u>	<u>74,628.1</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,794,168</u>	<u>10,434,336</u>	<u>157,622,253</u>
18. Gross Elec Ener (MWH)	<u>566,320</u>	<u>3,343,585</u>	<u>49,254,105</u>
19. Net Elec Ener (MWH)	<u>536,426</u>	<u>3,168,436</u>	<u>46,385,470</u>
20. Unit Service Factor	<u>100.0</u>	<u>85.3</u>	<u>51.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>85.3</u>	<u>51.2</u>
22. Unit Cap Factor (MDC Net)	<u>98.8</u>	<u>84.9</u>	<u>42.6</u>
23. Unit Cap Factor (DER Net)	<u>89.6</u>	<u>77.0</u>	<u>39.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>14.7</u>	<u>24.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>749.6</u>	<u>26,009.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - SEPTEMBER 5, 1988 - 95 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

XX  
 X PALISADES X  
 XXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 PALISADES



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PALISADES \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

PALISADES OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT LOAD REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
COUNTY.....VANBUREN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
SOUTH HAVEN, MI  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 24, 1971  
DATE ELEC ENER 1ST GENER...DECEMBER 31, 1971  
DATE COMMERCIAL OPERATE...DECEMBER 31, 1971  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONSUMERS POWER  
CORPORATE ADDRESS.....217 WEST MICHIGAN AVENUE  
JACKSON, MICHIGAN 49201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IF RESIDENT INSPECTOR.....E. SWANSON  
LICENSING PROJ MANAGER.....T. WAMBACH  
DOCKET NUMBER.....50-255  
LICENSE & DATE ISSUANCE....DPR-20, OCTOBER 16, 1972  
PUBLIC DOCUMENT ROOM.....VAN ZOEREN LIBRARY  
HOPE COLLEGE  
HOLLAND, MICHIGAN 49423

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

10 CFR 21.21 REQUIRES NOTIFICATION OF THE NRC (REGION OR HQ) WITHIN TWO DAYS OF RECEIPT OF INFORMATION REASONABLY INDICATING THAT A DEFECT OR FAILURE TO COMPLY EXISTS, AND THAT THE INITIAL NOTIFICATION BE FOLLOWED UP IN WRITING WITHIN FIVE DAYS. CONTRARY TO THE ABOVE, THE LICENSEE DETERMINED ON MAY 13, 1988 THAT A REPORTABLE FAILURE CONCERNING ITE K 225 480V K-LINE CIRCUIT BREAKERS HAD OCCURRED AND ASIDE FROM NOTIFYING THE RESIDENT INSPECTOR, NO TELEPHONE NOTIFICATIONS TO THE NRC OCCURRED, AND THE FIVE DAY LETTER WAS NOT SUBMITTED UNTIL MAY 20, 1988.  
(8801 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

REFUELING OUTAGE PLANNED FOR 9/6/88

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATED AT 95% (FUEL CONSERVATION) ENTIRE MONTH.

LAST IE SITE INSPECTION DATE: 07/06/88

INSPECTION REPORT NO: 88016

R E P O R T S   F R O M   L I C E N S E E

```

=====

```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-11	062488	072588	SINGLE FAILURE CRITERIA NOT MET FOR ALL INSTRUMENT AC BUS ALIGNMENTS
88-26	062388	072388	REACTOR SCRAM DUE TO UNEXPECTED MAIN TURBINE TRIP CAUSED BY MECHANICAL FAILURE OF TURBINE TRIP LATCH ASSEMBLY
88-27	062988	072988	HIGH PRESSURE CORE SPRAY PLACED IN SECURED STATUS DUE TO A FAILED LEAK DETECTION TRANSMITTER

```

=====

```

1. Docket: 50-528 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. L. HULL (602) 393-2679

4. Licensed Thermal Power (Mwt): 3800

5. Nameplate Rating (Gross MWe): 1403

6. Design Electrical Rating (Net MWe): 1270

7. Maximum Dependable Capacity (Gross MWe): 1303

8. Maximum Dependable Capacity (Net MWe): 1221

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,112.0</u>	<u>21,984.0</u>
13. Hours Reactor Critical	<u>132.1</u>	<u>2,710.9</u>	<u>12,688.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-line	<u>132.1</u>	<u>2,629.3</u>	<u>12,346.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>503,771</u>	<u>9,541,006</u>	<u>44,573,843</u>
18. Gross Elec Ener (MWH)	<u>174,000</u>	<u>3,330,700</u>	<u>15,474,000</u>
19. Net Elec Ener (MWH)	<u>158,169</u>	<u>3,119,869</u>	<u>14,447,983</u>
20. Unit Service Factor	<u>17.8</u>	<u>51.4</u>	<u>56.2</u>
21. Unit Avail Factor	<u>17.8</u>	<u>51.4</u>	<u>56.2</u>
22. Unit Cap Factor (MDC Net)	<u>17.4</u>	<u>50.0</u>	<u>53.8</u>
23. Unit Cap Factor (DER Net)	<u>16.7</u>	<u>48.1</u>	<u>51.7</u>
24. Unit Forced Outage Rate	<u>82.2</u>	<u>45.5</u>	<u>34.4</u>
25. Forced Outage Hours	<u>611.9</u>	<u>2,198.2</u>	<u>6,469.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 08/15/88

\*\*\*\*\*  
 \* PALO VERDE 1 \*  
 \*\*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

FALO VERDE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PALO VERDE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/06/88	F	611.9	A	3	1-88-010	EA	NSBU	A FAULT ON THE 13.8KV BUS RESULTED IN AN EXPLOSION/FIRE OF THE AUXILIARY TRANSFORMER. THE RESULTANT LOSS OF POWER TO THE RCPS LED TO A REACTOR TRIP ON LOW DNBR. CORRECTIVE ACTIONS INCLUDED INSPECTIONS AND CLEANING OF SIMILAR 13.8KV BUSES IN UNIT 1 AND A SAMPLE OF UNIT 3'S BUSES. IN ADDITION, A REVIEW OF THE PREVENTIVE MAINTENANCE ASSOCIATED WITH THE BUSES IS BEING CONDUCTED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
PALO VERDE 1 INCURRED ONE FORCED OUTAGE IN JULY DUE TO EQUIPMENT FAILURE AND REMAINED SHUTDOWN AT END OF MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)



\*\*\*\*\*  
\* PALO VERDE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....ARIZONA  
COUNTY.....MARICOPA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...56 MI W OF  
PHOENIX, AZ  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 25, 1985  
DATE ELEC ENER 1ST GENER...JUNE 10, 1985  
DATE COMMERCIAL OPERATE...JANUARY 28, 1986  
CONDENSER COOLING METHOD...TREATED SEWAGE  
CONDENSER COOLING WATER...SEWAGE TREATMENT  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY  
LICENSEE.....ARIZONA PUBLIC SERVICE  
CORPORATE ADDRESS.....P.O. BOX 21666  
PHOENIX, ARIZONA 85036  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....T. POLICH  
LICENSING PROJ MANAGER.....E. LICITRA  
DOCKET NUMBER.....50-528  
LICENSE & DATE ISSUANCE...NPF-41, JUNE 1, 1985  
PUBLIC DOCUMENT ROOM.....MS STEFANIE MORITZ  
DOCUMENTS LIBRARIAN  
PHOENIX PUBLIC LIBRARY  
12 EAST MCDOWELL ROAD  
PHOENIX, ARIZONA 85004

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON MAY 22 - JULY 4, 1988 (REPORT NO. 50-528/88-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JUNE 13 - 17, 1988 (REPORT NO. 50-528/88-19) AREAS INSPECTED: AN ANNOUNCED INSPECTION BY ONE REGIONALLY BASED INSPECTOR OF VARIOUS VITAL AREAS AND EQUIPMENT IN THE PLANT AND FOLLOW-UP OF ENFORCEMENT ITEMS, OPEN ITEMS, AND BULLETINS/NOTICES/LETTERS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.  
RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. THE LICENSEE'S CORRECTIVE MEASURES FOR ENFORCEMENT ITEMS AND ACTIONS ON FOLLOWUP ITEMS WERE APPROPRIATE, WELL DOCUMENTED AND ADEQUATE.
- + INSPECTION ON MAY 25 - JUNE 24, 1988 (REPORT NO. 50-528/88-20) AREAS INSPECTED: THIS SPECIAL INSPECTION BY REGIONALLY BASED INSPECTORS REVIEWED THE CIRCUMSTANCES SURROUNDING A REACTOR STARTUP OF PALO VERDE UNIT 1 ON MAY 14, 1988, IN WHICH THE REACTOR WENT CRITICAL WITH THE CONTROL ELEMENT ASSEMBLIES (CEAS, COMMONLY KNOWN AS CONTROL RODS) INSERTED BELOW THE TECHNICAL SPECIFICATION LIMIT. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.  
RESULTS: SIX VIOLATIONS WERE IDENTIFIED: FAILURE TO IDENTIFY A SIGNIFICANT CALCULATIONAL ERROR AS A NONCONFORMANCE ENTRY INTO MODE 2 WITH CEAS BELOW THE TRANSIENT INSERTION LIMITS, IMPROPER CONTROL OF REACTIVITY DURING CONDUCT OF STARTUP PROCEDURE, FAILURE TO IMMEDIATELY BORATE THE REACTOR WITH APPARENTLY INADEQUATE SHUTDOWN MARGIN, FAILURE TO RECORD REACTOR CRITICALITY, AND FAILURE

INSPECTION SUMMARY

TO REPORT THIS EVENT AS REQUIRED BY 10 CFR 50.72. IN ADDITION, THE LICENSEE'S POST TRIP REVIEW REPORT WAS NOT ADEQUATE IN SCOPE AND DEPTH TO ALLOW THE LICENSEE TO FULLY UNDERSTAND THE EVENT AND TO INITIATE ADEQUATE CORRECTIVE ACTIONS PRIOR TO RESTART OF PALO VERDE UNIT 1.

+ MANAGEMENT MEETING ON MAY 2, 1988 (REPORT NO. 50-528/88-21) A MANAGEMENT MEETING WAS HELD ON THE ABOVE DATE TO DISCUSS ISSUES OF CURRENT INTEREST RELATING TO THE PALO VERDE UNIT 1 NUCLEAR GENERATING STATION.

+ INSPECTION ON JUNE 27 - JULY 1, 1988 (REPORT NO. 50-528/88-22) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION INCLUDING ONSITE FOLLOWUP OF WRITTEN REPORTS OF NONROUTINE EVENTS; ONSITE FOLLOWUP OF EVENTS AT OPERATING REACTORS; RADIATION PROTECTION, PLANT CHEMISTRY, RADWASTE AND TRANSPORTATION; TRAINING AND QUALIFICATION; CONTROL OF RADIOACTIVE MATERIAL, CONTAMINATION AND SURVEYS; SOLID WASTES; LIQUIDS AND LIQUID WASTES; GASEOUS WASTE SYSTEM AND A TOUR OF UNIT 1. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 5 - AUGUST 6, 1988 (REPORT NO. 50-528/88-23) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 5 - 8, 1988 (REPORT NO. 50-528/88-24) AREAS INSPECTED: THIS SPECIAL INSPECTION REVIEWED THE INOPERABILITY OF BOTH TRAINS OF ESSENTIAL CHILLED WATER AT UNIT 1 DURING THE PERIOD OF MAY 20-29, 1988. DURING THIS INSPECTION, TWO INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: ONE VIOLATION OF TECHNICAL SPECIFICATIONS WAS IDENTIFIED IN THAT TWO TRAINS OF ESSENTIAL CHILLED WATER WERE INOPERABLE FOR A PERIOD OF APPROXIMATELY NINE DAYS.

+ INSPECTION ON JULY 18 - 22, 1988 (REPORT NO. 50-528/88-25) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

## SYSTEMS AND COMPONENT PROBLEMS:

THE UNIT AUXILIARY TRANSFORMER FAILED ON JULY 6, 1988 RESULTING IN A FIRE AND LOSS OF OFFSITE POWER TO THE NON-VITAL ELECTRICAL BUSES.

## FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

## MANAGERIAL ITEMS:

MR. DON KARNER RELIEVES MR. ED VAN BRUNT AS EXECUTIVE VP ON AUGUST 1, 1988.

## PLANT STATUS:

OTHER ITEMS

IN MODE 4 COOLING DOWN TO MODE 5 TO REPAIR DAMAGE CAUSED BY THE AUXILIARY TRANSFORMER FIRE.

LAST IE SITE INSPECTION DATE: 07/05 - 08/06/88+

INSPECTION REPORT NO: 50-528/88-23+

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-14-L0	02-10-88	06-06-88	MAIN STM SAFETY VALVE SETPT OUT OF TOLERANCE
88-16-L0	05-14-88	06-13-88	RX TRIP FOLLOWING EARLY CRIT
88-17-L0	05-29-88	06-28-88	BOTH ESSENTIAL CHILLERS INOPERABLE

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-529 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. L. HULL (602) 393-2679

4. Licensed Thermal Power (MWh): 3800

5. Nameplate Rating (Gross MWe): 1403

6. Design Electrical Rating (Net MWe): 1270

7. Maximum Dependable Capacity (Gross MWe): 1393

8. Maximum Dependable Capacity (Net MWe): 1221

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,112.0</u>	<u>16,368.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,256.6</u>	<u>11,531.7</u>
14. Rx Reserve Shtdm Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,142.0</u>	<u>11,268.2</u>
16. Unit Reserve Shtdm Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,794,833</u>	<u>7,813,952</u>	<u>41,021,119</u>
18. Gross Elec Ener (MWH)	<u>978,100</u>	<u>2,729,800</u>	<u>14,391,070</u>
19. Net Elec Ener (MWH)	<u>919,688</u>	<u>2,542,033</u>	<u>13,478,915</u>
20. Unit Service Factor	<u>100.0</u>	<u>41.9</u>	<u>68.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>41.9</u>	<u>68.8</u>
22. Unit Cap Factor (MDC Net)	<u>101.2</u>	<u>40.7</u>	<u>67.4</u>
23. Unit Cap Factor (DER Net)	<u>97.3</u>	<u>39.2</u>	<u>64.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>637.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PALO VERDE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALO VERDE 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PALO VERDE 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
PALO VERDE 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Contined	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)



INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

- + INSPECTION ON JULY 5 - AUGUST 6, 1988 (REPORT NO. 50-529/88-23) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 18 - 22, 1988 (REPORT NO. 50-528/88-24) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS PRESENTLY AT FULL POWER.

LAST IE SITE INSPECTION DATE: 07/05 - 08/06/88+

INSPECTION REPORT NO: 50-529-88-23+

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-07-L0	05-11-88	06-08-88	FUEL BLDG EXHAUST VENTILATION DUE TO RADIATION MONITOR MALFUNCTION
88-11-L0	05-22-88	06-22-88	OVEREXPOSURE TO RADIATION



1. Docket: 50-550 OPERATING STATUS
2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: J.M. COLVILLE 602-393-2679
4. Licensed Thermal Power (Mwt): 3800
5. Nameplate Rating (Gross MWe): 1403
6. Design Electrical Rating (Net MWe): 1270
7. Maximum Dependable Capacity (Gross MWe): 1303
8. Maximum Dependable Capacity (Net MWe): 1221
9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>4,944.0</u>	<u>4,944.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,944.0</u>	<u>4,944.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>736.6</u>	<u>4,936.6</u>	<u>4,936.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.2</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,780,396</u>	<u>18,385,572</u>	<u>18,385,572</u>
18. Gross Elec Ener (MWH)	<u>967,500</u>	<u>6,471,500</u>	<u>6,471,500</u>
19. Net Elec Ener (MWH)	<u>912,625</u>	<u>6,112,539</u>	<u>6,112,539</u>
20. Unit Service Factor	<u>99.0</u>	<u>99.9</u>	<u>99.9</u>
21. Unit Avail Factor	<u>99.0</u>	<u>99.9</u>	<u>99.9</u>
22. Unit Cap Factor (MDC Net)	<u>100.5</u>	<u>101.3</u>	<u>101.3</u>
23. Unit Cap Factor (DER Net)	<u>96.6</u>	<u>97.4</u>	<u>97.4</u>
24. Unit Forced Outage Rate	<u>1.0</u>	<u>.1</u>	<u>.1</u>
25. Forced Outage Hours	<u>7.4</u>	<u>7.4</u>	<u>7.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 08/16/88

\*\*\*\*\*  
 \* PALO VERDE 3 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALO VERDE 3



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PALO VERDE 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
6	07/31/88	F	7.4	H	2			TURBINE TRIP OCCURRED WHEN A LIGHTNING STRIKE TRIPPED THE B-PHASE MAIN TRANSFORMER.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
PALO VERDE 3 INCURRED ONE FORCED OUTAGE DURING JULY WHEN A LIGHTNING STRIKE TRIPPED THE B-PHASE MAIN TRANSFORMER.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram Instructions for
	C-Refueling	H-Other	3-Auto Scram Preparation of
	D-Regulatory Restriction		4-Continued Data Entry Sheet
	E-Operator Training		5-Reduced Load Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION  
STATE.....ARIZONA  
COUNTY.....MARICOPA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...36 MI W OF  
PHOENIX, AZ  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 25, 1987  
DATE ELEC ENEP 1ST GENER...NOVEMBER 28, 1987  
DATE COMMERCIAL OPERATE....JANUARY 8, 1988  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER....SEWAGE TREATMENT  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ARIZONA PUBLIC SERVICE  
CORPORATE ADDRESS.....P.O. BOX 21666  
PHOENIX, ARIZONA 85036  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....T. POLICH  
LICENSING PROJ MANAGER.....M. DAVIS  
DOCKET NUMBER.....50-530  
LICENSE & DATE ISSUANCE...NPF-74, NOVEMBER 25, 1987  
PUBLIC DOCUMENT ROOM.....MS STEFANIE MORITZ  
DOCUMENTS LIBRARIAN  
PHOENIX PUBLIC LIBRARY  
12 EAST MCDOWELL ROAD  
PHOENIX, ARIZONA 85004

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON MAY 22 - JULY 4, 1988 (REPORT NO. 50-530/88-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JUNE 13 - 17, 1988 (REPORT NO. 50-530/88-19) AREAS INSPECTED: AN ANNOUNCED INSPECTION BY ONE REGIONALLY BASED INSPECTOR OF VARIOUS VITAL AREAS AND EQUIPMENT IN THE PLANT AND FOLLOW-UP OF ENFORCEMENT ITEMS, OPEN ITEMS, AND BULLETINS/NOTICES/LETTERS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. THE LICENSEE'S CORRECTIVE MEASURES FOR ENFORCEMENT ITEMS AND ACTIONS ON FOLLOWUP ITEMS WERE APPROPRIATE, WELL DOCUMENTED AND ADEQUATE.
- + MANAGEMENT MEETING ON MAY 2, 1988 (REPORT NO. 50-530/88-20) A MANAGEMENT MEETING WAS HELD ON THE ABOVE DATE TO DISCUSS ISSUES OF CURRENT INTEREST RELATING TO THE PALO VERDE UNIT 3 NUCLEAR GENERATING STATION.
- + INSPECTION ON JUNE 27 - JULY 1, 1988 (REPORT NO. 50-530/88-21) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION INCLUDING ONSITE FOLLOWUP OF WRITTEN REPORTS OF NONROUTINE EVENTS; ONSITE FOLLOWUP OF EVENTS AT OPERATING REACTORS; RADIATION PROTECTION, PLANT CHEMISTRY, RADWASTE AND TRANSPORTATION; TRAINING AND QUALIFICATION; CONTROL OF RADIOACTIVE MATERIAL, CONTAMINATION AND SURVEYS; SOLID WASTES; LIQUIDS AND LIQUID WASTES; GASEOUS WASTE SYSTEM AND A TOUR OF UNIT 3. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 5 - AUGUST 6, 1988 (REPORT NO. 50-530/88-22) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 18 -22, 1988 (REPORT NO. 50-530/88-23) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

REFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

TK2 UNIT IS AT FULL POWER

LAST IE SITE INSPECTION DATE: 07/05 - 08/06/88+

INSPECTION REPORT NO: 50-530/88-22+

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE

1. Docket: 50-277 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. L. MIDDLETON (215) 841-6374

4. Licensed Thermal Power (MWh): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1051

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NRC ORDER OF 3/31/87

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>123,383.2</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>74,196.2</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>71,866.8</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWh)	<u>.0</u>	<u>.0</u>	<u>212,810,745</u>
18. Gross Elec Ener (MWh)	<u>.0</u>	<u>.0</u>	<u>70,019,230</u>
19. Net Elec Ener (MWh)	<u>-3,656</u>	<u>-26,891</u>	<u>67,014,225</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>58.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>58.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>51.7</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>51.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>14.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>12,324.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimate Startup Date: N/A

\*\*\*\*\*  
 \* PEACH BOTTOM 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PEACH BOTTOM 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	05/31/87	S	744.0	C	4		RC	FUELXY	NRC REQUIRED SHUTDOWN.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
PEACH BOTTOM 2 REMAINED SHUTDOWN DURING JULY UNDER NRC ORDER.  
RESTART ACTIVITIES CONTINUED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PEACH BOTTOM 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....YORK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI S OF  
LANCASTER, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1973  
DATE ELEC ENER 1ST GENER...FEBRUARY 18, 1974  
DATE COMMERCIAL OPERATE...JULY 5, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PHILADELPHIA ELECTRIC  
CORPORATE ADDRESS.....2301 MARKET STREET  
PHILADELPHIA, PENNSYLVANIA 19105

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. JOHNSON  
LICENSING PROJ MANAGER.....R. MARTIN  
DOCKET NUMBER.....50-277  
LICENSE & DATE ISSUANCE...DPR-44, DECEMBER 14, 1973  
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====



1. Docket: 53-278 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: L. L. MIDDLETON (215) 841-6374

4. Licensed Thermal Power (Mht): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1035

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NRC ORDER OF 3/31/87.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>119,279.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>76,366.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>74,059.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>215,278,901</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>70,611,432</u>
19. Net Elec Ener (MWH)	<u>-3,656</u>	<u>-26,891</u>	<u>67,675,264</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>62.1</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>62.1</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>54.8</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>53.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>13.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>11,372.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 3



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	03/31/87	S	744.0	C	4		RC	FUELXX	PIPE REPLACEMENT OUTAGE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 PEACH BOTTOM 3 REMAINED SHUTDOWN DURING JULY UNDER NRC ORDER.  
 REFUELING AND PIPE REPLACEMENT IN PROGRESS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....YORK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI S OF  
LANCASTER, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 7, 1974  
DATE ELEC ENER 1ST GENER...SEPTEMBER 1, 1974  
DATE COMMERCIAL OPERATE...DECEMBER 23, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY  
LICENSEE.....PHILADELPHIA ELECTRIC  
CORPORATE ADDRESS.....2301 MARKET STREET  
PHILADELPHIA, PENNSYLVANIA 19105

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. JOHNSON  
LICENSING PROJ MANAGER.....R. MARTIN  
DOCKET NUMBER.....50-278  
LICENSE & DATE ISSUANCE...DPR-56, JULY 2, 1974  
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-440 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: S. A. DUNN (216) 259-3737

4. Licensed Thermal Power (Mwt): 3579

5. Nameplate Rating (Gross MWe): 1250

6. Design Electrical Rating (Net MWe): 1205

7. Maximum Dependable Capacity (Gross MWe): 1230

8. Maximum Dependable Capacity (Net MWe): 1205

9. If Changes Occur Above Since Last Report, Give Reasons:

ITEMS 7/8-VALUES REFLECT SEAS. DERATE COND.

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>6,155.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,799.7</u>	<u>4,611.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,608.2</u>	<u>4,381.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,575,590</u>	<u>11,933,315</u>	<u>14,494,834</u>
18. Gross Elec Ener (MWH)	<u>856,213</u>	<u>4,070,892</u>	<u>4,949,354</u>
19. Net Elec Ener (MWH)	<u>815,015</u>	<u>3,842,947</u>	<u>4,671,431</u>
20. Unit Service Factor	<u>100.0</u>	<u>70.6</u>	<u>71.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>70.6</u>	<u>71.2</u>
22. Unit Cap Factor (MDC Net)	<u>90.9</u>	<u>62.5</u>	<u>63.0</u>
23. Unit Cap Factor (DER Net)	<u>90.9</u>	<u>62.4</u>	<u>63.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>19.6</u>	<u>20.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>876.9</u>	<u>1,147.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


MAINTENANCE - OCTOBER 1988- 10 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
X PERRY 1 X  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PERRY 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PERRY 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
PERRY 1 OPERATED ROUTINELY DURING JULY WITH NO OUTAGES OR  
SIGNIFICANT LOAD REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	G-Oper Error	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

\*\*\*\*\*  
\* PERRY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....OHIO  
COUNTY.....LAKE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NE OF  
PAINESVILLE, OHIO  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JUNE 6, 1986  
DATE ELEC ENER 1ST GENER...DECEMBER 19, 1986  
DATE COMMERCIAL OPERATE...NOVEMBER 18, 1987  
CONDENSER COOLING METHOD...CC HNDCT  
CONDENSER COOLING WATER...LAKE ERIE  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CLEVELAND ELECTRIC ILLUMINATING  
CORPORATE ADDRESS.....P.O. BOX 5000  
CLEVELAND, OHIO 44101  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....KAISER ENGINEERS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....K. CONNAUGHTON  
LICENSING PROJ MANAGER.....T. COLBURN  
DOCKET NUMBER.....50-440  
LICENSE & DATE ISSUANCE...NPF-58, NOVEMBER 13, 1986  
PUBLIC DOCUMENT ROOM.....PERRY PUBLIC LIBRARY  
3753 MAIN ST.  
PERRY, OH. 44081

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 13-17 (88011): ROUTINE UNANNOUNCED INSPECTION BY A REGIONAL INSPECTOR OF INFORMATION NOTICES. OF THE TEN INFORMATION NOTICES EXAMINED, ALL TEN WERE FOUND TO HAVE BEEN THOROUGHLY REVIEWED. THE LICENSEE'S RELIABILITY AND DESIGN ASSURANCE SECTION (R AND DAS) HAS OVERALL RESPONSIBILITY FOR THE INS. THIS GROUP SELECTS THE SITE GROUPS FROM WHICH TO OBTAIN INFORMATION, REVIEW, OR ANALYSIS. THIS GROUP WAS FOUND TO CONTAIN HIGHLY CAPABLE PERSONS SKILLED IN EITHER PLANT SYSTEMS OR PLANT ADMINISTRATION. TWO MEMBERS OF THE R AND DAS GROUP ASSEMBLE THE COMPLETED PACKAGES FOR REVIEW. AN R AND DAS REVIEW GROUP IS ASSEMBLED FROM PEOPLE WITH VARIOUS PLANT EXPERTISE. THE PACKAGES ARE REVIEWED FOR COMPLETENESS AND TO ADDRESS CONCERNS THAT MAY NOT HAVE BEEN COVERED IN THE REVIEWED PACKAGE. WHEN THE GROUP IS SATISFIED, THE REVIEW PACKAGE IS SIGNED COMPLETE BY EACH GROUP MEMBER. THE ACTIONS TO BE CARRIED OUT ARE FOLLOWED BY VARIOUS LICENSEE TRACKING AND COMMITMENT SYSTEMS. THE INSPECTOR PERFORMED REVIEWS OF THE WORK PERFORMED BY THIS GROUP AND ATTENDED A R AND DAS REVIEW GROUP MEETING. THE INSPECTOR WAS SATISFIED WITH THE THOROUGHNESS OF THE IN PACKAGE REVIEW PROCESS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS





1. Docket: 50-293 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: P. HAMILTON (617) 746-7900

4. Licensed Thermal Power (Mwt): 1998

5. Nameplate Rating (Gross MWe): 780 X 0.87 = 678

6. Design Electrical Rating (Net MWe): 655

7. Maximum Dependable Capacity (Gross MWe): 690

8. Maximum Dependable Capacity (Net MWe): 670

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>137,135.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>79,778.7</u>
14. 2x Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>77,216.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>135,480,048</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>45,444,604</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>43,675,429</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>56.3</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>56.3</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>47.5</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>48.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>12.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>10,922.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 08/01/88

\*\*\*\*\*  
 X PILGRIM 1 X  
 \*\*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

PILGRIM 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PILGRIM 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
01	07/25/86	S	744.0	C	4				SHUTDOWN FOR RFO 7.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
PILGRIM 1 REMAINED SHUTDOWN FOR SCHEDULED REFUELING OUTAGE IN JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PILGRIM 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MASSACHUSETTS  
COUNTY.....PLYMOUTH  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...4 MI SE OF  
PLYMOUTH, MASS  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JUNE 16, 1972  
DATE ELEC ENER 1ST GENER...JULY 19, 1972  
DATE COMMERCIAL OPERATE...DECEMBER 1, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...CAPE COD BAY  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....BOSTON EDISON  
CORPORATE ADDRESS.....800 BOYLSTON STREET  
BOSTON, MASSACHUSETTS 02199  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....C. WARREN  
LICENSING PROJ MANAGER.....D. MCDONALD  
DCKET NUMBER.....50-293  
LICENSE & DATE ISSUANCE...DPR-35, SEPTEMBER 15, 1972  
PUBLIC DOCUMENT ROOM.....PLYMOUTH PUBLIC LIBRARY  
11 NORTH STREET  
PLYMOUTH, MASSACHUSETTS 02360

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.A AND ANSI N18.7-1972 ON NOVEMBER 24, 1987 SAFETY RELATED RELAY COIL 16AK55 WAS REPLACED WITHOUT PROPER PREPLANNING AND WITHOUT SUFFICIENTLY DETAILED PROCEDURES. AS A RESULT SEVERAL UNANTICIPATED ESE ACTIVITIES OCCURRED. CONTRARY TO TS 6.11 AND STATION RADIATION PROTECTION PROCEDURE 6.1-022 A RADIOACTIVE WASTE WORKER WAS FOUND INSIDE A POSTED HIGH RADIATION AREA WITHOUT THE REQUIRED RWP, REQUIRED ANTICONTAMINATION CLOTHING AND REQUIRED HEALTH PHYSICS COVERAGE.

(8705 4)

CONTRARY TO TS 6.6 AND 10 CFR 50.72 TWO ESF ACTUATIONS OCCURRING ON NOVEMBER 23 AND 24, 1987 WERE NOT REPORTED TO THE NRC WITHIN FOUR HOURS AS REQUIRED.

(8705 5)

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   ( C O N T I N U E D )

\*\*\*\*\*  
\*                   PILGRIM 1                   \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====

1. Docket: 50-266                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: C. H. KRAUSE (414) 221-2001

4. Licensed Thermal Power (MWT):                      1518

5. Nameplate Rating (Gross MWe):                      582 X 0.9 = 524

6. Design Electrical Rating (Net MWe):                      497

7. Maximum Dependable Capacity (Gross MWe):                      509

8. Maximum Dependable Capacity (Net MWe):                      485

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>155,471.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,174.7</u>	<u>126,942.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>652.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,114.8</u>	<u>124,159.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.6</u>	<u>837.9</u>
17. Gross Therm Ener (MWH)	<u>1,126,686</u>	<u>6,158,324</u>	<u>171,785,378</u>
18. Gross Elec Ener (MWH)	<u>383,220</u>	<u>2,104,070</u>	<u>57,927,420</u>
19. Net Elec Ener (MWH)	<u>366,745</u>	<u>2,011,515</u>	<u>55,179,943</u>
20. Unit Service Factor	<u>100.0</u>	<u>80.5</u>	<u>79.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>80.5</u>	<u>80.4</u>
22. Unit Cap Factor (MDC Net)	<u>101.6</u>	<u>81.1</u>	<u>72.7*</u>
23. Unit Cap Factor (DER Net)	<u>99.2</u>	<u>79.2</u>	<u>71.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>2.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,464.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      POINT BEACH 1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
POINT BEACH 1



JULY 1988

\* Item calculated with a Weighted Average

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 POINT BEACH 1 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
 SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* POINT BEACH 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....MANITOWOC  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...15 MI N OF  
MANITOWOC, WISC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 2, 1970  
DATE ELEC ENER 1ST GENER...NOVEMBER 6, 1970  
DATE COMMERCIAL OPERATE...DECEMBER 21, 1970  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY  
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY  
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET  
MILWAUKEE, WISCONSIN 53201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. HAGUE  
LICENSING PROJ MANAGER....W. SWENSON  
DOCKET NUMBER.....50-266  
LICENSE & DATE ISSUANCE...DPR-24, OCTOBER 5, 1970  
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY  
1516 16TH ST.  
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION FROM MAY 1 THROUGH JUNE 30 (88012; 88011): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; PHYSICAL SECURITY; RADIOLOGICAL PROTECTION; TEMPORARY INSTRUCTION FOLLOWUP; IE BULLETIN FOLLOWUP; AND VERIFICATION OF CONTAINMENT INTEGRITY. ALL ACTIVITIES OBSERVED WERE CONDUCTED IN A SATISFACTORY MANNER AND NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ALL OTHER INSPECTION RESULTS INDICATED ACCEPTABLE LICENSEE PERFORMANCE.

INSPECTION ON JUNE 6 AND 23 (88015; 88013): SPECIAL SAFETY INSPECTION OF LICENSEE ACTION ON IE BULLETIN 79-14 (92703). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ALTHOUGH PREVIOUS INSPECTIONS IDENTIFIED POTENTIAL WEAKNESSES IN THE ORIGINAL 79-14 PROGRAM, SUBSEQUENT REVIEWS HAVE NOT IDENTIFIED ANY ADDITIONAL DISCREPANCIES. FURTHER WORK WILL BE REQUIRED TO DETERMINE THE EXTENT OF ANY PREVIOUS PROGRAMMATIC PROBLEMS. THE LICENSEE'S REACTION TO THE POTENTIAL WEAKNESSES WAS AGGRESSIVE AND INDICATED A STRONG DESIRE TO IMMEDIATELY ADDRESS AND RESOLVE THIS ISSUE.

INSPECTION ON JUNE 13-17 (88014): ROUTINE, ANNOUNCED SAFETY INSPECTION OF CONTROL ROD TESTING (72700), CORE POWER DISTRIBUTION LIMITS (61702), CALIBRATION OF NUCLEAR INSTRUMENTATION SYSTEMS (61705), CORE THERMAL POWER EVALUATION (61706), MODERATOR TEMPERATURE COEFFICIENT DETERMINATION (61708), ESTIMATED CRITICAL CONDITION (61707), AND CONTROL ROD WORTH MEASUREMENTS (61710). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.





Report Period JUL 1988

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* POINT BEACH 1 \*  
\*\*\*\*\*

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-301 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 221-2001

4. Licensed Thermal Power (MWT): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 509

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>140,256.0</u>
13. Hours Reactor Critical	<u>44.0</u>	<u>5,091.6</u>	<u>123,486.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>1.1</u>	<u>216.1</u>
15. Hrs Generator On-line	<u>744.0</u>	<u>5,048.2</u>	<u>121,518.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>5.0</u>	<u>297.4</u>
17. Gross Therm Ener (MWH)	<u>1,126,029</u>	<u>7,599,973</u>	<u>172,170,568</u>
18. Gross Elec Ener (MWH)	<u>384,060</u>	<u>2,598,870</u>	<u>58,379,090</u>
19. Net Elec Ener (MWH)	<u>366,945</u>	<u>2,484,155</u>	<u>55,628,569</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.8</u>	<u>86.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.9</u>	<u>86.9</u>
22. Unit Cap Factor (MDC Net)	<u>101.7</u>	<u>100.2</u>	<u>81.0*</u>
23. Unit Cap Factor (DER Net)	<u>99.2</u>	<u>97.8</u>	<u>79.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.5</u>	<u>1.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>23.6</u>	<u>874.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUEL/MAINT - OCTOBER 7, 1988 - 6 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
POINT BEACH 2



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
POINT BEACH 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& license Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....MANITOWOC  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...15 MI N OF  
MANITOWOC, WISC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 30, 1972  
DATE ELEC ENER 1ST GENER...AUGUST 2, 1972  
DATE COMMERCIAL OPERATE...OCTOBER 1, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY  
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET  
MILWAUKEE, WISCONSIN 53201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. HAGUE  
LICENSING PROJ MANAGER.....W. SWENSON  
DOCKET NUMBER.....50-301  
LICENSE & DATE ISSUANCE...DPR-27, MARCH 8, 1973  
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY  
1516 16TH ST.  
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION FROM MAY 1 THROUGH JUNE 30 (88012; 88011): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; PHYSICAL SECURITY; RADIOLOGICAL PROTECTION; TEMPORARY INSTRUCTION FOLLOWUP; IE BULLETIN FOLLOWUP; AND VERIFICATION OF CONTAINMENT INTEGRITY. ALL ACTIVITIES OBSERVED WERE CONDUCTED IN A SATISFACTORY MANNER AND NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ALL OTHER INSPECTION RESULTS INDICATED ACCEPTABLE LICENSEE PERFORMANCE.

INSPECTION ON JUNE 6 AND 23 (88015; 88013): SPECIAL SAFETY INSPECTION OF LICENSEE ACTION ON IE BULLETIN 79-14 (92703). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ALTHOUGH PREVIOUS INSPECTIONS IDENTIFIED POTENTIAL WEAKNESSES IN THE ORIGINAL 79-14 PROGRAM, SUBSEQUENT REVIEWS HAVE NOT IDENTIFIED ANY ADDITIONAL DISCREPANCIES. FURTHER WORK WILL BE REQUIRED TO DETERMINE THE EXTENT OF ANY PREVIOUS PROGRAMMATIC PROBLEMS. THE LICENSEE'S REACTION TO THE POTENTIAL WEAKNESSES WAS AGGRESSIVE AND INDICATED A STRONG DESIRE TO IMMEDIATELY ADDRESS AND RESOLVE THIS ISSUE.

INSPECTION ON JUNE 13-17 (88014): ROUTINE, ANNOUNCED SAFETY INSPECTION OF CONTROL ROD TESTING (72700), CORE POWER DISTRIBUTION LIMITS (61702), CALIBRATION OF NUCLEAR INSTRUMENTATION SYSTEMS (61705), CORE THERMAL POWER EVALUATION (61706), MODERATOR TEMPERATURE COEFFICIENT DETERMINATION (61708), ESTIMATED CRITICAL CONDITION (61707), AND CONTROL ROD WORTH MEASUREMENTS (61710). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.



Report Period JUL 1988

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING AT POWER.

LAST IE SITE INSPECTION DATE: 07/15/88

INSPECTION REPORT NO: 88015

REPORTS FROM LICENSEE

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

.....

THIS PAGE INTENTIONALLY LEFT BLANK



1. Docket: 50-282 O P E R A T I N G S T A T U S

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (Mwt): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 534

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report. Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>128,207.0</u>
13. Hours Reactor Critical	<u>706.5</u>	<u>4,991.9</u>	<u>107,535.1</u>
14. Rx P serve Shtdm Hrs	<u>.0</u>	<u>.0</u>	<u>5,571.1</u>
15. Hrs Generator On-Line	<u>704.7</u>	<u>4,986.5</u>	<u>106,094.5</u>
16. Unit Reserve Shtdm Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,050,810</u>	<u>8,006,521</u>	<u>167,060,445</u>
18. Gross Elec Ener (MWH)	<u>337,910</u>	<u>2,635,720</u>	<u>54,709,730</u>
19. Net Elec Ener (MWH)	<u>314,350</u>	<u>2,482,792</u>	<u>51,320,457</u>
20. Unit Service Factor	<u>94.7</u>	<u>97.6</u>	<u>82.8</u>
21. Unit Avail Factor	<u>94.7</u>	<u>97.6</u>	<u>82.8</u>
22. Unit Cap Factor (MDC Net)	<u>84.0</u>	<u>96.6</u>	<u>79.6</u>
23. Unit Cap Factor (DER Net)	<u>79.7</u>	<u>91.7</u>	<u>75.5</u>
24. Unit Forced Outage Rate	<u>5.3</u>	<u>.8</u>	<u>6.4</u>
25. Forced Outage Hours	<u>39.3</u>	<u>39.3</u>	<u>3,754.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

REFUEL/MAINT - AUGUST 24, 1988

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* PRAIRIE ISLAND 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
 PRAIRIE ISLAND 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* PRAIRIE ISLAND 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
880703	07/03/88	S	0.0	B	5			TURBINE VALVES TESTING.
880710	07/10/88	S	0.0	F	5			BEGINNING OF COASTDCWN OPERATION.
880725	07/25/88	S	0.0	B	5			ADD OIL TO REACTOR COOLANT PUMP NO.11.
880726	07/26/88	F	39.3	A	1	RE-1-88-4		GENERIC PROBLEM WITH FLUX TILT CONTROLLERS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 PRAIRIE ISLAND 1 INCURRED THREE POWER REDUCTIONS AND ONE FORCED  
 DOWNTIME IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MINNESOTA  
COUNTY.....GOODHUE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...28 MI SE OF  
MINNEAPOLIS, MINN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 1, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1973  
DATE COMMERCIAL OPERATE...DECEMBER 16, 1973  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHERN STATES POWER  
CORPORATE ADDRESS.....414 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401  
CONTRACTOR  
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. HARD  
LICENSING PROJ MANAGER.....D. DIANNI  
DOCKET NUMBER.....50-282  
LICENSE & DATE ISSUANCE...DPR-42, APRIL 5, 1974  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY  
MINNEAPOLIS PUBLIC LIBRARY  
300 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 15 THROUGH JUNE 25 (88008; 88008): ROUTINE UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS, PLANT OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCES, ESF SYSTEMS, LER FOLLOWUP, SPENT FUEL POOL ACTIVITIES, DESIGN CHANGES AND MODIFICATIONS, LICENSEE INVESTIGATION OF RYERSON STEEL, AND THE NRC CHAIRMAN'S VISIT. DURING THIS INSPECTION PERIOD, BOTH UNITS OPERATED CONTINUOUSLY AT 100 PERCENT POWER AND IN GENERAL THE PLANT CONTINUES TO OPERATE WELL. AS NOTED IN THIS AND PREVIOUS INSPECTION REPORTS, THERE CONTINUES TO BE A NEED FOR SPECIAL EMPHASIS REGARDING PAYING ATTENTION TO DETAILS. IN ADDITION, ANOTHER UNPLANNED BREAKER ACTUATION OCCURRED AS A RESULT OF ACTIVITIES IN THE SUBSTATION AND REMAINS AN AREA OF CONCERN. NO VIOLATIONS OF NRC REQUIREMENTS WERE IDENTIFIED DURING THE COURSE OF THIS INSPECTION.

INSPECTION ON MAY 26 AND JUNE 17 (88009; 88009): SPECIAL SAFETY INSPECTION OF LICENSEE ACTION ON PREVIOUSLY IDENTIFIED CONCERNS RELATED TO PIPING OPERABILITY ANALYSES (82701). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 6-21 (88010; 88010): SPECIAL ANNOUNCED SAFETY INSPECTION TO VERIFY THAT THE PRAIRIE ISLAND EMERGENCY OPERATING PROCEDURES (EOPs) ARE TECHNICALLY CORRECT; THAT THEIR SPECIFIED ACTIONS CAN BE MEANINGFULLY ACCOMPLISHED USING EXISTING EQUIPMENT, CONTROLS, AND INSTRUMENTATION; AND THAT THE AVAILABLE PROCEDURES HAVE THE USABILITY NECESSARY TO PROVIDE THE OPERATOR WITH AN EFFECTIVE OPERATING TOOL. THE INSPECTION WAS CONDUCTED IN ACCORDANCE WITH TEMPORARY INSTRUCTION (TI) 2515/92. (SIMS NO. HF 4.1) ONE VIOLATION WAS IDENTIFIED AGAINST 10 CFR 50, APPENDIX B, CRITERION XVIII: FAILURE TO PERFORM PLANNED AND PERIODIC AUDITS OF THE PRAIRIE ISLAND EMERGENCY OPERATING PROCEDURES BETWEEN APRIL 1984 AND APRIL 14, 1988.

INSPECTION SUMMARY

INSPECTION ON JUNE 21-24 (88006; 88006): ROUTINE, ANNOUNCED INSPECTION (IP 82301) OF THE PRAIRIE ISLAND NUCLEAR GENERATING PLANT EMERGENCY PREPAREDNESS EXERCISE, INVOLVING OBSERVATIONS BY THREE NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION WAS CONDUCTED BY TWO NRC INSPECTORS AND ONE CONSULTANT. AN UPDATED SUMMARY OF THE STATUS OF ALL EMERGENCY PREPAREDNESS RELATED TMI (SIMS) ITEMS IS INCLUDED. NO VIOLATIONS, DEFICIENCIES OR DEVIATIONS WERE IDENTIFIED AS A RESULT OF THIS INSPECTION. THE LICENSEE DEMONSTRATED AN ADEQUATE RESPONSE CAPABILITY TO A SIMULATED ACCIDENT SCENARIO INVOLVING AN OFFSITE RADIOACTIVE RELEASE. TWO OPEN ITEMS WERE IDENTIFIED AS A RESULT OF THIS INSPECTION.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 3.7.A.1 REQUIRES THAT THE REACTOR SHALL NOT BE MAINTAINED CRITICAL OR ABOVE 200 DEGREES F. UNLESS AT LEAST TWO SEPARATE PATHS FROM THE GRID TO THE PLANT 4KV SAFETY BUSES ARE FULLY OPERATIONAL. TECHNICAL SPECIFICATION 3.7.B REQUIRES THAT THE REACTOR SHALL BE PLACED IN THE COLD SHUTDOWN CONDITION IF THE REQUIREMENTS OF SPECIFICATION 3.7.A CAN NOT BE SATISFIED. CONTRARY TO THE ABOVE, ON APRIL 26, 1988, ONE OF THE TWO PATHS FROM THE GRID TO SAFEGUARDS 4KV BUS NO. 16 WAS NOT FULLY OPERATIONAL FOR 20 MINUTES AND ACTION WAS NOT INITIATED TO PLACE THE REACTOR IN COLD SHUTDOWN.

FAILURE TO PROVIDE ADEQUATE PROTECTED AREA INTRUSION CAPABILITY IN THAT 8 OF 19 ALARM ZONES FAILED TO DETECT PENETRATIONS.  
FAILURE TO PROVIDE ADEQUATE PROTECTED AREA INTRUSION CAPABILITY IN THAT 8 OF 19 ALARM ZONES FAILED TO DETECT PENETRATIONS.  
(8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT OPERATED CONTINUOUSLY FOR ENTIRE MONTH EXCEPT FOR A 37 HOUR SHUTDOWN (7/27-7/28) TO CORRECT FOXBERO CONTROLLER PROBLEM.

LAST IE SITE INSPECTION DATE: 06/21/88

INSPECTION REPORT NO: 88010

Report Period JUL 1988

R E P O R T S F R O M L I C E N S E E

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-04	072688	080488	UNIT SHUTDOWN REQUIRED DUE TO DEGRADED DELTA-T REAL OR TRIP CHANNELS

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-306 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (MWT): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 531

8. Maximum Dependable Capacity (Net MWe): 500

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>119,325.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,212.7</u>	<u>104,447.7</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>1,761.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,193.2</u>	<u>103,388.0</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MMH)	<u>1,218,063</u>	<u>6,751,510</u>	<u>162,897,587</u>
18. Gross Elec Ener (MWH)	<u>392,910</u>	<u>2,195,390</u>	<u>53,027,720</u>
19. Net Elec Ener (MWh)	<u>369,410</u>	<u>2,068,129</u>	<u>49,847,552</u>
20. Unit Service Factor	<u>100.0</u>	<u>82.0</u>	<u>86.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>82.0</u>	<u>86.6</u>
22. Unit Cap Factor (MDC Net)	<u>99.3</u>	<u>80.9</u>	<u>83.5</u>
23. Unit Cap Factor (DER Net)	<u>93.7</u>	<u>76.3</u>	<u>78.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>3.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>1.1</u>	<u>3,360.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PRAIRIE ISLAND 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* PRAIRIE ISLAND 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
880710	07/10/88	S	0.0	B	5				TURBINE VALVES TESTING.
880726	07/26/88	F	0.0	A	5	RE-1-88-4			STARTED REDUCTION PER T.S. 3.5 DUE TO AXIAL FLUX TILT CONTROLLERS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 PRAIRIE ISLAND 2 INCURRED 2 POWER REDUCTIONS IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)



FACILITY DESCRIPTION

LOCATION  
 STATE.....MINNESOTA  
 COUNTY.....GOODHUE  
 DIST AND DIRECTION FROM  
 NEAREST POPULATION CTR....28 MI SE OF  
 MINNEAPOLIS, MINN  
 TYPE OF REACTOR.....PWR  
 DATE INITIAL CRITICALITY...DECEMBER 17, 1974  
 DATE ELEC ENER 1ST GENER...DECEMBER 21, 1974  
 DATE COMMERCIAL OPERATE....DECEMBER 21, 1974  
 CONDENSER COOLING METHOD...COOLING TOWERS  
 CONDENSER COOLING WATER...MISSISSIPPI RIVER  
 ELECTRIC RELIABILITY  
 COUNCIL.....MID-CONTINENT AREA  
 RELIABILITY COORDINATION  
 AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
 LICENSEE.....NORTHERN STATES POWER  
 CORPORATE ADDRESS.....414 NICOLLET MALL  
 MINNEAPOLIS, MINNESOTA 55401  
 CONTRACTOR  
 ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.  
 NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
 CONSTRUCTOR.....NORTHERN STATES POWER COMPANY  
 TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
 IE RESIDENT INSPECTOR.....J. HARD  
 LICENSING PROJ MANAGER....D. DIANNI  
 DOCKET NUMBER.....50-306  
 LICENSE & DATE ISSUANCE...DPR-60, OCTOBER 29, 1974  
 PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY  
 MINNEAPOLIS PUBLIC LIBRARY  
 300 NICOLLET MALL  
 MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N    S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 15 THROUGH JUNE 25 (88008; 88008): ROUTINE UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS, PLANT OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCES, ESF SYSTEMS, LER FOLLOWUP, SPENT FUEL POOL ACTIVITIES, DESIGN CHANGES AND MODIFICATIONS, LICENSEE INVESTIGATION OF RYERSON STEEL, AND THE NRC CHAIRMAN'S VISIT. DURING THIS INSPECTION PERIOD, BOTH UNITS OPERATED CONTINUOUSLY AT 100 PERCENT POWER AND IN GENERAL THE PLANT CONTINUES TO OPERATE WELL. AS NOTED IN THIS AND PREVIOUS INSPECTION REPORTS, THERE CONTINUES TO BE A NEED FOR SPECIAL EMPHASIS REGARDING PAYING ATTENTION TO DETAILS. IN ADDITION, ANOTHER UNPLANNED BREAKER ACTUATION OCCURRED AS A RESULT OF ACTIVITIES IN THE SUBSTATION AND REMAINS AN AREA OF CONCERN. NO VIOLATIONS OF NRC REQUIREMENTS WERE IDENTIFIED DURING THE COURSE OF THIS INSPECTION.

INSPECTION ON MAY 26 AND JUNE 17 (88009; 88009): SPECIAL SAFETY INSPECTION OF LICENSEE ACTION ON PREVIOUSLY IDENTIFIED CONCERNS RELATED TO PIPING OPERABILITY ANALYSES (92701). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 6-21 (88010; 88010): SPECIAL ANNOUNCED SAFETY INSPECTION TO VERIFY THAT THE PRAIRIE ISLAND EMERGENCY OPERATING PROCEDURES (EOPS) ARE TECHNICALLY CORRECT; THAT THEIR SPECIFIED ACTIONS CAN BE MEANINGFULLY ACCOMPLISHED USING EXISTING EQUIPMENT, CONTROLS, AND INSTRUMENTATION; AND THAT THE AVAILABLE PROCEDURES HAVE THE USABILITY NECESSARY TO PROVIDE THE OPERATOR WITH AN EFFECTIVE OPERATING TOOL. THE INSPECTION WAS CONDUCTED IN ACCORDANCE WITH TEMPORARY INSTRUCTION (TI) 515/92. (SIMS NO. HF 4.1) ONE VIOLATION WAS IDENTIFIED AGAINST 10 CFR 50, APPENDIX B, CRITERION XVIII: FAILURE TO PERFORM PLANNED AND PERIODIC AUDITS OF THE PRAIRIE ISLAND EMERGENCY OPERATING PROCEDURES BETWEEN APRIL 1984 AND APRIL 14, 1988.

INSPECTION SUMMARY

INSPECTION ON JUNE 21-24 (88006; 88006): ROUTINE, ANNOUNCED INSPECTION (IP 82301) OF THE PRAIRIE ISLAND NUCLEAR GENERATING PLANT EMERGENCY PREPAREDNESS EXERCISE, INVOLVING OBSERVATIONS BY THREE NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION WAS CONDUCTED BY TWO NRC INSPECTORS AND ONE CONSULTANT. AN UPDATED SUMMARY OF THE STATUS OF ALL EMERGENCY PREPAREDNESS RELATED TMI (SIMS) ITEMS IS INCLUDED. NO VIOLATIONS, DEFICIENCIES OR DEVIATIONS WERE IDENTIFIED AS A RESULT OF THIS INSPECTION. THE LICENSEE DEMONSTRATED AN ADEQUATE RESPONSE CAPABILITY TO A SIMULATED ACCIDENT SCENARIO INVOLVING AN OFFSITE RADIOACTIVE RELEASE. TWO OPEN ITEMS WERE IDENTIFIED AS A RESULT OF THIS INSPECTION.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATED CONTINUALLY THROUGHOUT MONTH.

LAST IE SITE INSPECTION DATE: 06/17/88

INSPECTION REPORT NO: 88009

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE			


=====

1. Docket: 50-254                      O P E R A T I N G   S T A T U S
2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0
3. Utility Contact: K.A. SCHMIDT (309) 654-2241 X2147
4. Licensed Thermal Power (MWT):                      2511
5. Nameplate Rating (Gross MWe):                      920 X 0.9 = 828
6. Design Electrical Rating (Net MWe):                      789
7. Maximum Dependable Capacity (Gross MWe):                      815
8. Maximum Dependable Capacity (Net MWe):                      769
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE
- |                               | MONTH            | YEAR              | CUMULATIVE         |
|-------------------------------|------------------|-------------------|--------------------|
| 12. Report Period Hrs         | <u>744.0</u>     | <u>5,111.0</u>    | <u>142,199.0</u>   |
| 13. Hours Reactor Critical    | <u>744.0</u>     | <u>4,862.2</u>    | <u>113,926.6</u>   |
| 14. Rx Reserve Shtdwn Hrs     | <u>.0</u>        | <u>.0</u>         | <u>3,421.9</u>     |
| 15. Hrs Generator On-Line     | <u>744.0</u>     | <u>4,608.2</u>    | <u>110,065.7</u>   |
| 16. Unit Reserve Shtdwn Hrs   | <u>.0</u>        | <u>.0</u>         | <u>909.2</u>       |
| 17. Gross Therm Ener (MWH)    | <u>1,435,960</u> | <u>10,464,382</u> | <u>233,805,139</u> |
| 18. Gross Elec Ener (MWH)     | <u>450,157</u>   | <u>3,389,521</u>  | <u>75,815,139</u>  |
| 19. Net Elec Ener (MWH)       | <u>427,044</u>   | <u>3,231,321</u>  | <u>71,135,391</u>  |
| 20. Unit Service Factor       | <u>100.0</u>     | <u>90.2</u>       | <u>77.4</u>        |
| 21. Unit Avail Factor         | <u>100.0</u>     | <u>90.2</u>       | <u>78.0</u>        |
| 22. Unit Cap Factor (MDC Net) | <u>74.6</u>      | <u>82.2</u>       | <u>65.1</u>        |
| 23. Unit Cap Factor (DER Net) | <u>72.7</u>      | <u>80.1</u>       | <u>63.4</u>        |
| 24. Unit Forced Outage Rate   | <u>.0</u>        | <u>5.8</u>        | <u>5.2</u>         |
| 25. Forced Outage Hours       | <u>.0</u>        | <u>281.5</u>      | <u>5,717.9</u>     |
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE
27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X                      Q U A D   C I T I E S   1                      X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

Q U A D   C I T I E S   1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* QUAD CITIES 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-13	07/07/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.
88-14	07/08/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.
88-15	07/09/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.
88-16	07/16/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.
88-17	07/17/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 QUAD CITIES 1 INCURRED 5 FORCED LOAD REDUCTIONS DURING JULY DUE TO HIGH RIVER TEMPERATURES.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
X QUAD CITIES 1 X  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
  
COUNTY.....ROCK ISLAND  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI NE OF  
MOLINE, ILL  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...OCTOBER 18, 1971  
  
DATE ELEC ENER 1ST GENER...APRIL 12, 1972  
  
DATE COMMERCIAL OPERATE...FEBRUARY 18, 1973  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
  
IE RESIDENT INSPECTOR.....A. MADISON  
  
LICENSING PROJ MANAGER.....T. ROSS  
DOCKET NUMBER.....50-254  
  
LICENSE & DATE ISSUANCE...DPR-29, DECEMBER 14, 1972  
  
PUBLIC DOCUMENT ROOM.....DIXON PUBLIC LIBRARY  
221 HENNEPIN AVENUE  
DIXON, ILLINOIS 61021

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MARCH 10, APRIL 11-12, 18, 21, 26-29, MAY 10, 17-18, JUNE 1 AND 20 (88012; 88006): ROUTINE, UNANNOUNCED INSPECTION OF INSERVICE INSPECTION (ISI) ACTIVITIES INCLUDING REVIEW OF PROGRAMS (73051), PROCEDURES (73052), OBSERVATION OF WORK ACTIVITIES (73753), AND DATA REVIEW (73755); OF ACTIONS ON INFORMATION NOTICE NO. 88-03 (90717); OF AN INDEPENDENT MEASUREMENTS INSPECTION (73051, 73052, 73753, 73755, AND 37701); OF ACTIONS ON IE BULLETIN 80-07; OF TEMPORARY INSTRUCTION 2515/96 ACTIVITIES (37828); OF ACTIONS ON A LICENSEE EVENT REPORT (92700) AND OF A MODIFICATION/REPLACEMENT (37701). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 7-15 (88016; 88016): ROUTINE ANNOUNCED INSPECTION BY A REGION-BASED INSPECTOR OF THE CONTAINMENT INTEGRATED LEAK RATE TEST (CILRT) PROCEDURE, CILRT PERFORMANCE WITNESSING, CILRT RESULTS, LOCAL LEAK RATE TEST RESULTS, ACTION ON PREVIOUS INSPECTION FINDINGS, AND LICENSEE EVENT REPORT FOLLOWUP. NRC INSPECTION MODULES UTILIZED DURING THIS INSPECTION INCLUDED 70307, 70313, 70323, 61720 AND 92701. ONE VIOLATION WAS IDENTIFIED (FAILURE TO ADEQUATELY FOLLOW PROCEDURES).

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.2.B. REQUIRES THAT RADIATION CONTROL PROCEDURES BE MAINTAINED, MADE AVAILABLE TO ALL STATION PERSONNEL, AND ADHERED TO. QUAD CITIES RADIATION PROTECTION PROCEDURE QRP 100 0-1 REQUIRES EACH INDIVIDUAL TO READ, UNDERSTAND AND SIGN THE RWP AND COMPLY WITH ITS REQUIREMENTS IN ALL RESPECTS. CONTRARY TO THE ABOVE, ON OCTOBER 25, 1987 AND MAY 17, 1988, TWO LICENSEE

ENFORCEMENT SUMMARY

WORKERS FAILED TO COMPLY WITH RWP PROTECTIVE CLOTHING REQUIREMENTS WHILE WORKING ON UNDERWATER CAMERA EQUIPMENT REMOVED FROM THE FUEL POOL AND REACTOR CAVITY, RESPECTIVELY, IN THAT RWP REQUIRED FULL-FACE MASKS WERE NOT WORN. 1 WORKER HANDLING THE EQUIPMENT WAS EXTERNALLY CONTAMINATED & ANOTHER WAS BOTH EXTERNALLY & INTERNALLY CONTAINED. QUAD CITIES RAD PROTECTION PROC. QRP 1000-1 REQ'S THAT THE RAD/CHEM DEPT BE INFORMED AND/OR CONSULTED BEFORE THE FACT SO THAT A RADIOLOGICAL EVALUATION CAN BE MADE WHEN UNCOVERING CONTAMINATED MATERIALS OR DISASSEMBLING POTENTIALLY CONTAMINATED EQUIPMENT WHERE DOSE RATES OR AIRBORNE RADIOACTIVITY MAY BE EXPECTED TO INCREASE SIGNIFICANTLY. CONTRARY TO THE ABOVE, ON 10-25-87, THE RAD/CHEM DEPARTMENT WAS NOT INFORMED OR CONSULTED PRIOR TO UNCOVERING (UNBAGGING) CONTAMINATED CAMERA EQUIPMENT AND SUBSEQUENTLY DISASSEMBLING PORTIONS OF IT. TECHNICAL SPECIFICATION 6.2.B. REQUIRES THAT RADIATION CONTROL PROCEDURES BE MAINTAINED, MADE AVAILABLE TO ALL STATION PERSONNEL, AND ADHERED TO. QUAD CITIES RADIATION PROTECTION PROCEDURE QRP 100 0-1 REQUIRES EACH INDIVIDUAL TO READ, UNDERSTAND AND SIGN THE RWP AND COMPLY WITH ITS REQUIREMENTS IN ALL RESPECTS. CONTRARY TO THE ABOVE, ON OCTOBER 25, 1987 AND MAY 17, 1988, TWO LICENSEE WORKERS FAILED TO COMPLY WITH RWP PROTECTIVE CLOTHING REQUIREMENTS WHILE WORKING ON UNDERWATER CAMERA EQUIPMENT REMOVED FROM THE FUEL POOL AND REACTOR CAVITY, RESPECTIVELY, IN THAT RWP REQUIRED FULL-FACE MASKS WERE NOT WORN. 1 WORKER HANDLING THE EQUIPMENT WAS EXTERNALLY CONTAMINATED & ANOTHER WAS BOTH EXTERNALLY & INTERNALLY CONTAINED. QUAD CITIES RAD PROTECTION PROC. QRP 1000-1 REQ'S THAT THE RAD/CHEM DEPT BE INFORMED AND/OR CONSULTED BEFORE THE FACT SO THAT A RADIOLOGICAL EVALUATION CAN BE MADE WHEN UNCOVERING CONTAMINATED MATERIALS OR DISASSEMBLING POTENTIALLY CONTAMINATED EQUIPMENT WHERE DOSE RATES OR AIRBORNE RADIOACTIVITY MAY BE EXPECTED TO INCREASE SIGNIFICANTLY. CONTRARY TO THE ABOVE, ON 10-25-87, THE RAD/CHEM DEPARTMENT WAS NOT INFORMED OR CONSULTED PRIOR TO UNCOVERING (UNBAGGING) CONTAMINATED CAMERA EQUIPMENT AND SUBSEQUENTLY DISASSEMBLING PORTIONS OF IT. DURING AN NRC INSPECTION CONDUCTED ON MARCH 30 THROUGH MAY 2, 1988, A VIOLATION OF NRC REQUIREMENTS WAS IDENTIFIED. IN ACCORDANCE WITH THE "GENERAL STATEMENT OF POLICY AND PROCEDURE FOR NRC ENFORCEMENT ACTIONS," 10 CFR PART 2, APPENDIX C, THE VIOLATION IS LISTED BELOW: 10 CFR 50.72 (B)(2)(II) STATES, IN PART: "(B) NON-EMERGENCY EVENTS - ... (2) FOUR-HOUR REPORTS. ... THE LICENSEE SHALL NOTIFY THE NRC AS SOON AS PRACTICAL AND IN ALL CASES, WITHIN FOUR HOURS OF THE OCCURRENCE OF ANY OF THE FOLLOWING: (II) ANY EVENT OR CONDITION THAT RESULTS IN MANUAL OR AUTOMATIC ACTUATION OF ANY ENGINEERED SAFETY FEATURE (ESF)..." CONTRARY TO THE STATED REQUIREMENTS, ON APRIL 11, 1988, AT 2:38 PM, THE CONTROL ROOM ESSENTIAL HEATING, VENTILATION AND AIR CONDITIONING (HVAC) SYSTEM, AN ENGINEERED SAFETY FEATURE, WAS ACTUATED AND WAS NOT REPORTED TO THE NRC WITHIN FOUR HOURS. (8801 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT OPERATING AT REDUCED POWER DUE TO TEMPERATURE DROUGHT CONDITIONS

LAST IE SITE INSPECTION DATE: 07/21/88

INSPECTION REPORT NO: 88018

Report Period JUL 1988

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* QUAD CITIES 1 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-11	062588	071588	REACTOR CORE ISOLATION COOLING SYSTEM DECLARED INOPERBLE DUE TO POOR FLOW CONTROLLER PLUG CONNECTION

THIS PAGE INTENTIONALLY LEFT BLANK



1. Docket: 50-265                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: K.A. SCHMIDT (309) 654-2241 X 2147

4. Licensed Thermal Power (Mwt):                      2511

5. Nameplate Rating (Gross MWe):                      920 X 0.9 = 828

6. Design Electrical Rating (Net MWe):                      789

7. Maximum Dependable Capacity (Gross MWe):                      813

8. Maximum Dependable Capacity (Net MWe):                      769

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:                                     
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>141,309.0</u>
13. Hours Reactor Critical	<u>567.3</u>	<u>3,008.3</u>	<u>107,665.7</u>
14. Rx Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>2,985.8</u>
15. Hrs Generator On-Line	<u>555.8</u>	<u>2,941.7</u>	<u>104,477.1</u>
16. Unit Reserve Shutdown Hrs	<u>.0</u>	<u>.0</u>	<u>702.9</u>
17. Gross Therm Ener (MWH)	<u>968,550</u>	<u>6,224,580</u>	<u>223,595,147</u>
18. Gross Elec Ener (MWH)	<u>301,041</u>	<u>2,001,600</u>	<u>71,559,374</u>
19. Net Elec Ener (MWH)	<u>284,596</u>	<u>1,907,322</u>	<u>67,458,753</u>
20. Unit Service Factor	<u>74.7</u>	<u>57.6</u>	<u>73.9</u>
21. Unit Avail Factor	<u>74.7</u>	<u>57.6</u>	<u>74.4</u>
22. Unit Cap Factor (MDC Net)	<u>49.7</u>	<u>48.5</u>	<u>62.1</u>
23. Unit Cap Factor (DER Net)	<u>48.5</u>	<u>47.3</u>	<u>60.5</u>
24. Unit Forced Outage Rate	<u>25.3</u>	<u>10.3</u>	<u>8.3</u>
25. Forced Outage Hours	<u>188.2</u>	<u>338.7</u>	<u>5,621.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X                      QUAD CITIES 2                      X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

QUAD CITIES 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* QUAD CITIES 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-7	07/08/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.
88-8	07/09/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.
88-9	07/16/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.
88-10	07/17/88	F	0.0	H	5		ZZ	ZZZZZZ	POWER REDUCTION TAKEN DUE TO HIGH RIVER TEMPERATURES.
88-11	07/24/88	F	188.2	A	2		HA	GENERA	REACTOR MANUALLY SCRAMMED DUE TO MAIN GENERATOR GROUND FAULT.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 QUAD CITIES 2 INCURRED 4 LOAD REDUCTIONS DUE TO HIGH RIVER TEMPERATURES AND ONE FORCED OUTAGE DUE TO MAIN GENERATOR GROUND FAULT DURING JULY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

\*\*\*\*\*  
\* QUAD CITIES 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....ROCK ISLAND  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI NE OF  
MOLINE, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...APRIL 26, 1972  
DATE ELEC ENER 1ST GENER...MAY 23, 1972  
DATE COMMERCIAL OPERATE...MARCH 10, 1973  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....F.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....A. MADISON  
LICENSING PROJ MANAGER.....T. ROSS  
DOCKET NUMBER.....50-265  
LICENSE & DATE ISSUANCE...DPR-30, DECEMBER 14, 1972  
PUBLIC DOCUMENT ROOM.....DIXON PUBLIC LIBRARY  
221 HENNEPIN AVENUE  
DIXON, ILLINOIS 61021

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MARCH 10, APRIL 11-12, 18, 21, 26-29, MAY 10, 17-18, JUNE 1 AND 20 (88012; 88006): ROUTINE, UNANNOUNCED INSPECTION OF INSERVICE INSPECTION (ISI) ACTIVITIES INCLUDING REVIEW OF PROGRAMS (73051), PROCEDURES (73052), OBSERVATION OF WORK ACTIVITIES (73753), AND DATA REVIEW (73755); OF ACTIONS ON INFORMATION NOTICE NO. 88-03 (90717); OF AN INDEPENDENT MEASUREMENTS INSPECTION (73051, 73052, 73753, 73755, AND 37701); OF ACTIONS ON IE BULLETIN 80-07; OF TEMPORARY INSTRUCTION 2515/96 ACTIVITIES (37828); OF ACTIONS ON A LICENSEE EVENT REPORT (92700) AND OF A MODIFICATION/REPLACEMENT (37701). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 7-15 (88016; 88016): ROUTINE ANNOUNCED INSPECTION BY A REGION-BASED INSPECTOR OF THE CONTAINMENT INTEGRATED LEAK RATE TEST (CILRT) PROCEDURE, CILRT PERFORMANCE WITNESSING, CILRT RESULTS, LOCAL LEAK RATE TEST RESULTS, ACTION ON PREVIOUS INSPECTION FINDINGS, AND LICENSEE EVENT REPORT FOLLOWUP. NRC INSPECTION MODULES UTILIZED DURING THIS INSPECTION INCLUDED 70307, 70313, 70323, 61720 AND 92701. ONE VIOLATION WAS IDENTIFIED (FAILURE TO ADEQUATELY FOLLOW PROCEDURES).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

SHUTDOWN TO REPAIR MAIN GENERATOR GROUND

LAST IE SITE INSPECTION DATE: 07/21/88

INSPECTION REPORT NO: 88018

REPORTS FROM LICENSEE

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-20	061988	071288	UNIT TWO EMERGENCY CORE COOLING SYSTEM INITIATION SIGNAL RECEIVED DURING IMPROPER VALVING SEQUENCE ON REACTOR WATER LEVEL INSTRUMENTATION
88-21	062688	072288	HIGH PRESSURE COOLANT INJECTION SYSTEM AUTOMATIC ISOLATION DURING PREWARMING DUE TO DESIGN DEFICIENCY
88-23	062288	072188	FAILURE OF MOTOR CONTROL CENTER 28/29-5 MAIN FEED SWAPOVER DUE TO UNLANDED LEAD CAUSED BY INSTALLATION ERROR
88-24	062188	072088	1/2 DIESEL GENERATOR AUTOMATICALLY STARTED DUE TO A FALSE SIGNAL DURING TROUBLESHOOTING ACTIVITIES DUE TO APPARENT MANUFACTURING OR INSTALLATION ERROR

.....

1. Bucket: 50-312                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: R. MILLER (916) 452-5211 X4477

4. Licensed Thermal Power (MHT):                      2772

5. Nameplate Rating (Gross MWe):                      1070 X 0.9 = 963

6. Design Electrical Rating (Net MWe):                      918

7. Maximum Dependable Capacity (Gross MWe):                      917

8. Maximum Dependable Capacity (Net MWe):                      873

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>116,496.0</u>
13. Hours React: Critical	<u>744.0</u>	<u>2,717.3</u>	<u>55,282.3</u>
14. Rx Reserve Shdwn Hrs	<u>.0</u>	<u>.0</u>	<u>10,647.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,465.9</u>	<u>52,829.7</u>
16. Unit Reserve Shdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,210.2</u>
17. Gross Therm Ener (MWH)	<u>1,285,029</u>	<u>3,092,474</u>	<u>127,321,009</u>
18. Gross Elec Ener (MWH)	<u>421,612</u>	<u>981,919</u>	<u>42,510,068</u>
19. Net Elec Ener (MWH)	<u>388,877</u>	<u>825,875</u>	<u>39,815,070</u>
20. Unit Service Factor	<u>100.0</u>	<u>48.2</u>	<u>45.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>48.2</u>	<u>46.4</u>
22. Unit Cap Factor (MDC Net)	<u>59.9</u>	<u>18.5</u>	<u>39.1</u>
23. Unit Cap Factor (DER Net)	<u>56.9</u>	<u>17.6</u>	<u>37.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>46.5</u>	<u>43.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>2,143.0</u>	<u>41,048.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
P02 OUTAGE - AUGUST 6, 1988.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      RANCHO SECO 1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

RANCHO SECO 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* RANCHO SECO 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
RANCHO SECO OPERATED ROUTINELY DURING JULY WITH NO OUTAGES OR  
SIGNIFICANT LOAD REDUCTIONS WHILE IN THE POWER ASCENSION TEST  
PROGRAM.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
  
COUNTY.....SACRAMENTO  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI SE OF  
SACRAMENTO, CA  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1974  
  
DATE ELEC ENER 1ST GENER...OCTOBER 13, 1974  
  
DATE COMMERCIAL OPERATE...APRIL 17, 1975  
  
CONDENSER COOLING METHOD...COOLING TOWERS  
  
CONDENSER COOLING WATER...FOLSOM CANAL  
  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SACRAMENTO MUN. UTIL. DISTRICT  
  
CORPORATE ADDRESS.....6201 S STREET P.O. BOX 15830  
SACRAMENTO, CALIFORNIA 95813  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
  
CONSTRUCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
  
IE RESIDENT INSPECTOR.....A. DANDELO  
  
LICENSING PROJ MANAGER.....G. KALMAN  
DOCKET NUMBER.....50-312  
  
LICENSE & DATE ISSUANCE...DPR-54, AUGUST 16, 1974  
  
PUBLIC DOCUMENT ROOM.....BUSINESS AND MUNICIPAL DEPARTMENT  
SACRAMENTO LIBRARY  
828 I STREET  
SACRAMENTO, CALIFORNIA 95814

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON JANUARY 4 - MARCH 10, 1988 (REPORT NO. 50-312/88-02) HEADQUARTERS REPORT; TO BE REPORTED AT A LATER DATE.
- + INSPECTION ON JUNE 1 - JULY 8, 1988 (REPORT NO. 50-312/88-16) AREAS INSPECTED: THIS ROUTINE INSPECTION BY RESIDENT INSPECTORS INVOLVED THE AREAS OF OPERATIONAL SAFETY VERIFICATION, HEALTH PHYSICS AND SECURITY OBSERVATIONS, ENGINEERED SAFETY FEATURES SYSTEM WALKDOWN, MAINTENANCE, SURVEILLANCE AND TESTING REVIEW OF CORE POWER DISTRIBUTION LIMITS AND REACTOR SHUTDOWN MARGIN DETERMINATIONS, REVIEW OF NUCLEAR INSTRUMENTATION CALIBRATIONS, AND FOLLOW-UP ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. A SIGNIFICANT STRENGTH OBSERVED WAS THE OPERATOR'S RESPONSE TO THE MAIN FEEDWATER BLOCK VALVE CLOSURE. A WEAKNESS WAS OBSERVED IN THAT THE MANNER IN WHICH TROUBLESHOOTING MAINTENANCE WAS TO BE PERFORMED WAS NOT DOCUMENTED IN THE PREPLANNED SECTION OF THE WORK REQUEST.
- + INSPECTION ON JUNE 27 - JULY 6, 1988 (REPORT NO. 50-312/88-18) AREAS INSPECTED: SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTENANCE; PHYSICAL BARRIERS-VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ACCESS; ALARM STATIONS; COMMUNICATIONS; PERSONNEL TRAINING AND QUALIFICATIONS PLAN; SECURITY EVENT FOLLOW-UP; FOLLOW-UP ITEMS FROM PREVIOUS SECURITY INSPECTIONS; FOLLOW-UP ON VIOLATIONS AND DEVIATIONS; FOLLOW-UP ON INFORMATION NOTICES 86-106 AND 88-26; AND INDEPENDENT INSPECTION EFFORT. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JUNE 13 - 17, 1988 (REPORT NO. 50-312/88-19) AREAS INSPECTED: THIS WAS A SPECIAL ENHANCED OPERATIONAL INSPECTION, PHASE II, DURING POWER ASCENSION TESTING, AT THE 40 PERCENT POWER PLATEAU, FOLLOWING AN EXTENDED PERIOD OF PLANT SHUTDOWN. THE INSPECTION WAS CONDUCTED BY REGIONAL AND RESIDENT INSPECTORS FROM REGION V AND REGION III, A REACTOR SYSTEMS ENGINEER FROM NRC HEADQUARTERS, AND A CONSULTANT FROM THE BATTELLE-PACIFIC NORTHWEST LABORATORIES, AND INCLUDED THE AREAS OF PLANT OPERATION AND OPERATIONAL SUPPORT ACTIVITIES. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED. STRENGTHS WERE OBSERVED IN THE KNOWLEDGE AND PERFORMANCE OF PLANT OPERATORS; A GENERALLY STRONG DISCIPLINE IN ADHERENCE TO WRITTEN PROCEDURES BY ESSENTIALLY ALL PLANT PERSONNEL; AND THE COORDINATION BETWEEN OPERATIONS, MAINTENANCE, QC, AND TEST PERSONNEL DURING THE CONDUCT OF TROUBLESHOOTING AND "FINE TUNING" OF PLANT CONTROL SYSTEMS. A WEAKNESS WAS OBSERVED IN COMPUTERIZED SCHEDULING OF THE CALIBRATION OF PLANT INSTRUMENTATION.

+ INSPECTION ON JULY 11 - 15, 1988 (REPORT NO. 50-312/88-21) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF LICENSEE ACTION ON FASTENER TESTING, PRIMARY COOLANT SYSTEM PRESSURE ISOLATION VALVES, NATURAL CIRCULATION COOLDOWN, REACTOR TRIP BREAKERS VENDOR RECOMMENDED MODIFICATIONS, AND QUALITY ASSURANCE OF EMERGENCY DIESEL GENERATOR FUEL OIL. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ ENFORCEMENT CONFERENCE ON JULY 7, 1988 (REPORT NO. 50-312/88-22) CONFERENCE SUMMARY: AN ENFORCEMENT CONFERENCE WAS HELD ON JULY 7, 1988 AT THE LICENSEE'S FACILITY TO DISCUSS THE IMPLEMENTATION OF THE LICENSEE'S CORRECTIVE ACTIONS TO IMPROVE ITS RADIATION PROTECTION PROGRAM FOLLOWING AN INCIDENT ON FEBRUARY 4, 1988, THAT RESULTED IN AN INDIVIDUAL RECEIVING RADIATION EXPOSURE IN EXCESS OF THE REGULATORY LIMITS FROM A 25.8 UCI COBALT PARTICLE AS DESCRIBED IN NRC INSPECTION REPORT NO. 50-312/88-07. THE NRC FINDINGS AS A RESULT OF THIS INSPECTION (50-312/88-07) AND SUBSEQUENT FOLLOW-UP INSPECTIONS IN MARCH AND JUNE, 1988, REPORT NOS. 50-312/88-08, 17 AND 20, WERE PRESENTED TO THE LICENSEE. THE NRC NOTED THAT THIS INCIDENT APPEARED TO BE AN ISOLATED EXAMPLE OF A VERTICAL FAILURE TO IMPLEMENT BASIC RADIATION PROTECTION PROCEDURES TO CONTROL WORKER EXPOSURES.

+ INSPECTION ON JULY 9 - AUGUST 12, 1988 (REPORT NO. 50-312/88-23) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 19 - 22, 1988 (REPORT NO. 50-312/88-24) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 18 - 22, 1988 (REPORT NO. 50-312/88-25) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PLANT IS PERFORMING VARIOUS TESTING IN CONJUNCTION WITH STEPPED INCREASES TO COMMERCIAL OPERATION.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE



OTHER ITEMS

MANAGERIAL ITEMS:

PLANT HAD BEEN SHUT DOWN SINCE DECEMBER 26, 1985. NUCLEAR REGULATORY COMMISSION APPROVAL FOR RESTART WAS OBTAINED ON MARCH 22, 1988. STAR/UP COMMENCED MARCH 30, 1988.

NRC SALP BOARD MEETING WAS HELD ON AUGUST 12, 1986.

PLANT STATUS:

+ THE PLANT IS CURRENTLY PERFORMING A GRADUAL APPROACH TO FULL POWER TEST PROGRAM. A PLANNED REACTOR TRIP FROM APPROXIMATELY 80 PERCENT POWER WAS PERFORMED ON AUGUST 6, 1988. PLANT IS CURRENTLY IN HOT SHUTDOWN WHILE PERFORMING VARIOUS OUTAGE ITEMS. CURRENT SCHEDULES INDICATE A RETURN TO POWER OPERATION UP TO 80% POWER ON AUGUST 12, 1988.

LAST IE SITE INSPECTION DATE: 07/09 - 08/12/88+

INSPECTION REPORT NO: 50-512/88-23+

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE			
-----			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-458 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: R. H. MARTIN (504) 635-6094 X4836

4. Licensed Thermal Power (MWT): 2894

5. Nameplate Rating (Gross MWe): 2894

6. Design Electrical Rating (Net MWe): 936

7. Maximum Dependable Capacity (Gross MWe): 936

8. Maximum Dependable Capacity (Net MWe): 936

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
1. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>23,327.0</u>
15. Hours Reactor Critical	<u>744.0</u>	<u>4,943.7</u>	<u>16,657.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,886.3</u>	<u>15,418.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2 35,906</u>	<u>13,712,198</u>	<u>39,182,082</u>
18. Gross Elec Ener (MWH)	<u>731,773</u>	<u>4,728,672</u>	<u>13,349,546</u>
19. Net Elec Ener (MWH)	<u>684,749</u>	<u>4,432,682</u>	<u>12,457,887</u>
20. Unit Service Factor	<u>100.0</u>	<u>95.6</u>	<u>66.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>95.6</u>	<u>66.1</u>
22. Unit Cap Factor (MDC Net)	<u>98.3</u>	<u>92.7</u>	<u>57.1</u>
23. Unit Cap Factor (DER Net)	<u>98.3</u>	<u>92.7</u>	<u>57.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.8</u>	<u>11.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>193.5</u>	<u>1,991.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* RIVER BEND 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

RIVER BEND 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* RIVER BEND 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
RIVER BEND OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Plant or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
M RIVER POND 1 M  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....LOUISIANA  
COUNTY.....WEST FELICIANA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...24 MI NNW OF  
BATON ROUGE, LA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...OCTOBER 31, 1985  
DATE ELEC ENER 1ST GENER...DECEMBER 3, 1985  
DATE COMMERCIAL OPERATE...JUNE 16, 1986  
CONDENSER COOLING METHOD...MDCT  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GULF STATES UTILITIES  
CORPORATE ADDRESS.....P.O. BOX 2951  
BEAUMONT, LOUISIANA 77704  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE...IV  
IE RESIDENT INSPECTOR.....D. CHAMBERLAIN  
LICENSING PROJ MANAGER.....W. PAULSON  
DOCKET NUMBER.....50-458  
LICENSE & DATE ISSUANCE...NPF-47, NOVEMBER 20, 1985  
PUBLIC DOCUMENT ROOM.....GOVERNMENT DOCUMENTS DEPARTMENT  
TROY H. MIDDLETON LIBRARY  
LOUISIANA STATE UNIVERSITY  
BATON ROUGE, LOUISIANA 70803

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1 - JUNE 30, 1988 (88-13) ROUTINE, UNANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, NRC BULLETIN 88-01, NRC BULLETIN 88-07, NRC INFORMATION NOTICES, SURVEILLANCE TEST OBSERVATION, MAINTENANCE OBSERVATION, SAFETY SYSTEM WALK-DOWN, OPERATIONAL SAFETY VERIFICATION AND LICENSEE PLANS FOR COPING WITH STRIKES. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED JUNE 13-17, 1988 (88-15) ROUTINE, UNANNOUNCED INSPECTION OF FIRE PROTECTION/PREVENTION PROGRAM AND IMPLEMENTATION. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period JUL 1988

INSPECTION STATUS - (CONTINUED)

\*\*\*\*\*  
\* RIVER BEND 1 \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURE):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

100% POWER LEVEL

LAST IE SITE INSPECTION DATE: JUNE 30, 1988

INSPECTION REPORT NO: 50-458/88-13

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-013	06-23-88	07-22-88	FAILURE TO INITIATE ANNULUS MIXING SYSTEM AND STANDBY GAS TREATMENT SYSTEM DUE TO MISINTERPRETATION OF TECHNICAL SPECIFICATION REQUIRED ACTION

1. Docket: 50-261 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: V.E. FRAZIER (803) 383-4524 X 1220

4. Licensed Thermal Power (MWT): 2300

5. Nameplate Rating (Gross MWe): 854 X 0.9 = 769

6. Design Electrical Rating (Net MWe): 700

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 665

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE


10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>152,621.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,948.7</u>	<u>109,477.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,159.6</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,891.7</u>	<u>106,916.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>23.2</u>
17. Gross Therm Ener (MWH)	<u>1,698,101</u>	<u>6,725,059</u>	<u>214,877,620</u>
18. Gross Elec Ener (MWH)	<u>541,151</u>	<u>2,148,026</u>	<u>69,531,363</u>
19. Net Elec Ener (MWH)	<u>515,097</u>	<u>2,019,119</u>	<u>65,697,048</u>
20. Unit Service Factor	<u>100.0</u>	<u>76.1</u>	<u>70.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>76.1</u>	<u>70.1</u>
22. Unit Cap Factor (MDC Net)	<u>104.1</u>	<u>59.4</u>	<u>64.7</u>
23. Unit Cap Factor (DER Net)	<u>98.9</u>	<u>56.4</u>	<u>61.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>23.7</u>	<u>13.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,209.3</u>	<u>11,412.0</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>REFUEL/MAINT - NOV. 12, 1988, 49 DAY DURATION.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

ROBINSON 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ROBINSON 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (N <sup>o</sup> REG-0161)



\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....DARLINGTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI NW OF  
HARTSVILLE, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...SEPTEMBER 20, 1970  
DATE ELEC ENER 1ST GENER...SEPTEMBER 26, 1970  
DATE COMMERCIAL OPERATE...MARCH 7, 1971  
CONDENSER COOLING METHOD...RECIRCULATION  
CONDENSER COOLING WATER...ROBINSON IMPOUNDMENT  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CAROLINA POWER & LIGHT  
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET  
RALEIGH, NORTH CAROLINA 27601  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....P. KRUG  
LICENSING PROJ MANAGER.....R. LO  
DOCKET NUMBER.....50-261  
LICENSE & DATE ISSUANCE...DPR-23, SEPTEMBER 23, 1970  
PUBLIC DOCUMENT ROOM.....HARTSVILLE MEMORIAL LIBRARY  
220 N. FIFTH ST.  
HARTSVILLE, SOUTH CAROLINA 29550

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 6-10 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF VERIFICATION OF COMPLIANCE WITH ORDER MODIFICATION OF LICENSEE: PRIMARY COOLANT SYSTEM PRESSURE ISOLATION (EVENT V) VALVES (TI-2515/84) INSERVICE TESTING (IST) OF PUMPS AND VALVES (73756) AND SERVICE WATER PIPING DEGRADATION (92706B). IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THERE APPEARS TO BE A WEAKNESS IN THE AREAS OF MANAGEMENT INVOLVEMENT IN ASSURING QUALITY AND RESOLUTION OF TECHNICAL ISSUES FROM A SAFETY STANDPOINT, IN THAT THE LICENSEE FAILED TO FORMALLY DOCUMENT THE ENGINEERING EVALUATION OF THE JUSTIFICATION FOR CONTINUED OPERATION AFTER THE IDENTIFICATION OF POSSIBLE COMPROMISE OF CONTAINMENT AND AN EXTREME RELUCTANCE TO COMMIT TO PLANNED AND SCHEDULED PIPE REPLACEMENT TO PERMANENTLY CORRECT THE PROBLEM. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING THE ADEQUACY OF FORWARD FLOW TESTING OF CHECK VALVES.

INSPECTION JUNE 13-17 (88-14): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF HYDROSTATIC TESTING - REVIEW OF PROGRAM AND REVIEW OF COMPLETED TEST PROCEDURES AND EVALUATIONS. IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED.

INSPECTION JUNE 13-17 (88-15): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS AND COMBINATIONS; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROL - PERSONNEL, PACKAGES AND VEHICLES; ASSESSMENT AIDS; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATIONS; AND PERSONNEL TRAINING AND QUALIFICATION - GENERAL REQUIREMENTS. IN THE AREAS INSPECTED, VIOLATIONS WERE NOT IDENTIFIED.



Report Period JUL 1988

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-272 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: BRYAN W. GORMAN (609) 339-3400

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1300 X 0.9 = 1170

6. Design Electrical Rating (Net MWe): 1115

7. Maximum Dependable Capacity (Gross MWe): 1149

8. Maximum Dependable Capacity (Net MWe): 1106

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>97,200.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,432.3</u>	<u>61,127.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,088.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,349.2</u>	<u>59,140.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,541,662</u>	<u>11,292,842</u>	<u>183,764,055</u>
18. Gross Elec Ener (MWH)	<u>839,880</u>	<u>3,778,840</u>	<u>60,971,128</u>
19. Net Elec Ener (MWH)	<u>805,491</u>	<u>3,601,183</u>	<u>57,997,892</u>
20. Unit Service Factor	<u>100.0</u>	<u>65.5</u>	<u>60.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>65.5</u>	<u>60.8</u>
22. Unit Cap Factor (MDC Net)	<u>97.9</u>	<u>63.7</u>	<u>53.9</u>
23. Unit Cap Factor (DER Net)	<u>97.1</u>	<u>63.2</u>	<u>53.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.1</u>	<u>24.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>38.2</u>	<u>19,498.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* SALEM 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SALEM 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SALEM 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SALEM 1 OPERATED ROUTINELY DURING JULY WITH NO OUTAGES OR  
SIGNIFICANT POWER REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SALEM 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
COUNTY.....SALEM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI S OF  
WILMINGTON, DEL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 11, 1976  
DATE ELEC ENER 1ST GENER...DECEMBER 25, 1976  
DATE COMMERCIAL OPERATE...JUNE 30, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...DELAWARE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS  
CORPORATE ADDRESS.....80 PARK PLACE  
NEWARK, NEW JERSEY 07101  
CONTRACTOR  
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. LINVILLE  
LICENSING PROJ MANAGER.....D. FISCHER  
DOCKET NUMBER.....50-272  
LICENSE & DATE ISSUANCE...DPR-70, DECEMBER 1, 1976  
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY  
112 WEST BROADWAY  
SALEM, NEW JERSEY 08079

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1985

I N S P E C T I O N   S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*                   SALEM 1                   \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IF SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====



1. Docket: 50-311 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: BRYAN W. GORMAN (609) 339-3400

4. Licensed Thermal Power: (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1162

6. Design Electrical Rating (Net MWe): 1115

7. Maximum Dependable Capacity (Gross MWe): 1149

8. Maximum Dependable Capacity (Net MWe): 1106

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>59,616.0</u>
13. Hours Reactor Critical	<u>718.0</u>	<u>4,962.7</u>	<u>37,340.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,533.6</u>
15. Hrs Generator On-Line	<u>714.2</u>	<u>4,913.2</u>	<u>36,210.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,388,288</u>	<u>16,452,295</u>	<u>113,218,024</u>
18. Gross Elec Ener (MWH)	<u>775,310</u>	<u>5,454,620</u>	<u>37,084,090</u>
19. Net Elec Ener (MWH)	<u>741,649</u>	<u>5,229,114</u>	<u>35,248,582</u>
20. Unit Service Factor	<u>96.0</u>	<u>96.1</u>	<u>60.7</u>
21. Unit Avail Factor	<u>96.0</u>	<u>96.1</u>	<u>60.7</u>
22. Unit Cap Factor (MDC Net)	<u>90.1</u>	<u>92.5</u>	<u>53.5</u>
23. Unit Cap Factor (DER Net)	<u>89.4</u>	<u>91.8</u>	<u>53.0</u>
24. Unit Forced Outage Rate	<u>4.0</u>	<u>3.9</u>	<u>30.3</u>
25. Forced Outage Hours	<u>29.8</u>	<u>197.8</u>	<u>15,715.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - 9/2/88 - 52 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: 08/01/88

\*\*\*\*\*  
\* SALEM 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

SALEM 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SALEM 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
0150	07/21/88	F	0.0	A	5		XX	FUELXX	NUCLEAR FUEL LIMITS NEEDED FLUX.
0174	07/31/88	F	29.8	A	3		EB	TRANSF	"C" VITAL INSTRUMENT BUS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

SALEM 2 INCURRED ONE FORCED LOAD REDUCTION AND ONE FORCED OUTAGE DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
COUNTY.....SALEM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI S OF  
WILMINGTON, DEL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 8, 1980  
DATE ELEC ENER 1ST GENER...JUNE 3, 1981  
DATE COMMERCIAL OPEKATE...OCTOBER 13, 1981  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...DELAWARE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS  
CORPORATE ADDRESS.....80 PARK PLACE  
NEWARK, NEW JERSEY 07101  
CONTRACTOR  
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. L'NVILLE  
LICENSING PROJ MANAGER....D. FISCHER  
DOCKET NUMBER.....50-311  
LICENSE & DATE ISSUANCE...DPR-75, MAY 20, 1981  
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY  
112 WEST BROADWAY  
SALEM, NEW JERSEY 08079

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.



1. Docket: 50-206 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: E. R. SIACOB (714) 368-6223

4. Licensed Thermal Power (MWT): 1347

5. Nameplate Rating (Gross MWe): 500 X 0.9 = 450

6. Design Electrical Rating (Net MWe): 436

7. Maximum Dependable Capacity (Gross MWe): 456

8. Maximum Dependable Capacity (Net MWe): 436

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 390

11. Reasons for Restrictions, If Any:  
SELF-IMPOSED TO CONTROL S.G. TUBE CORROSION

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>185,215.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,068.7</u>	<u>107,540.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,063.1</u>	<u>103,493.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>1,304,993</u>	<u>130,434,853</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>430,200</u>	<u>44,107,926</u>
19. Net Elec Ener (MWH)	<u>-2,952</u>	<u>395,731</u>	<u>41,638,996</u>
20. Unit Service Factor	<u>.0</u>	<u>20.8</u>	<u>55.9</u>
21. Unit Avail Factor	<u>.0</u>	<u>20.8</u>	<u>55.9</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>17.8</u>	<u>51.5</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>17.8</u>	<u>51.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>19.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>13,140.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 08/05/88

\*\*\*\*\*  
X SAN ONOFRE 1 X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONOFRE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SAN ONOFRE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
118	03/28/88	S	744.0	H	4	88-001	BA	ISV	MID-CYCLE MAINTENANCE OUTAGE EXTENDED TO UPGRADE CERTAIN COMPONENTS IN ORDER TO MEET 10CFR 50.49 REQUIREMENTS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SAN ONOFRE 1 REMAINED SHUTDOWN DURING JULY DUE TO EXTENSION OF MID-CYCLE MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SAN ONOFRE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN DIEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
SAN CLEMENTE, CA  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...JUNE 14, 1967  
DATE ELEC ENER 1ST GENER...JULY 16, 1967  
DATE COMMERCIAL OPERATE...JANUARY 1, 1968  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SOUTHERN CALIFORNIA EDISON  
CORPORATE ADDRESS\*.....2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....R. HUEY  
LICENSING PROJ MANAGER....C. TRAMMELL  
DOCKET NUMBER.....50-206  
LICENSE & DATE ISSUANCE...DPR-13, MARCH 27, 1967  
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA  
GENERAL LIBRARY  
IRVINE, CA. 92713

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON MAY 22 - JUNE 18, 1988 (REPORT NO. 50-206/88-16) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 25 - 29, 1988 (REPORT NO. 50-206/88-17) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 3 - AUGUST 13, 1988 (REPORT NO. 50-206/88-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ NONE

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE LICENSEE EXPECTS TO RETURN THE UNIT TO SERVICE IN EARLY AUGUST.

LAST IE SITE INSPECTION DATE: 07/13 - 08/13/88+

INSPECTION REPORT NO: 50-206/88-19+

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-08-LO	05-24-88	06-23-88	INADVERTENT OMISSION OF SAFETY INJECTION VENT VALVES FROM LLRT PROGRAM
88-09-LO	05-26-88	06-27-88	POTENTIAL DIESEL-GENERATOR LOADS IN EXCESS OF TECH SPEC REQUIREMENTS



1. Docket: 50-361                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: E. R. SIACOR (714) 368-6223

4. Licensed Thermal Power (MWT):                    3390

5. Nameplate Rating (Gross MWe):                    1127

6. Design Electrical Rating (Net MWe):                    1070

7. Maximum Dependable Capacity (Gross MWe):                    1127

8. Maximum Dependable Capacity (Net MWe):                    1070

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>43,680.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,661.6</u>	<u>30,454.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,624.0</u>	<u>29,809.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,466,288</u>	<u>15,394,954</u>	<u>96,361,377</u>
18. Gross Elec Ener (MWH)	<u>836,245</u>	<u>5,286,890</u>	<u>32,549,464</u>
19. Net Elec Ener (MWH)	<u>798,268</u>	<u>5,034,293</u>	<u>30,823,173</u>
20. Unit Service Factor	<u>100.0</u>	<u>90.5</u>	<u>68.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>90.5</u>	<u>68.2</u>
22. Unit Cap Factor (MDC Net)	<u>100.3</u>	<u>92.1</u>	<u>65.9</u>
23. Unit Cap Factor (DER Net)	<u>100.3</u>	<u>92.1</u>	<u>65.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>3.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,183.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Start-up Date: N/A

\*\*\*\*\*  
 \*                    SAN ONOFRE 2                    \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONOFRE 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SAN ONOFRE 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
43	07/02/88	S	0.0	B	5			POWER REDUCTIGN OF 20% OR GREATER TO PERFORM HEAT TREATING OF THE INTAKE STRUCTURE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SAN ONOFRE 2 INCURRED ONE POWER REDUCTION IN JULY FOR REASON STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation o'
	G-Oper Error	4-Continued	Data Entry Shee.
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* SAN ONOFRE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN DIEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
SAN CLEMENTE, CA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JULY 26, 1982  
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1982  
DATE COMMERCIAL OPERATE...AUGUST 8, 1983  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SOUTHERN CALIFORNIA EDISON  
CORPORATE ADDRESS.....P.O. BOX 800  
ROSEMEAD, CALIFORNIA 91770  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....R. HUEY  
LICENSING PROJ MANAGER.....D. HICKMAN  
DOCKET NUMBER.....50-361  
LICENSE & DATE ISSUANCE...NPF-10, SEPTEMBER 7, 1982  
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA  
GENERAL LIBRARY  
IRVINE, CA. 92713

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON MAY 2 - JUNE 10, 1988 (REPORT NO. 50-361/88-10) AREAS INSPECTED: THIS SPECIAL, ANNOUNCED TEAM SAFETY SYSTEM FUNCTIONAL INSPECTION (SSFI) INVOLVED THE AREAS OF ENGINEERING, MAINTENANCE, SURVEILLANCE TESTING, OPERATIONS, HEALTH PHYSICS, QUALITY ASSURANCE AND ADMINISTRATION. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: OF THE AREAS INSPECTED, FOUR VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED. THE TEAM CONCLUDED THAT THE LICENSEE DOES NOT FULLY UNDERSTAND THE DESIGN OF THE SYSTEMS REVIEWED; THAT THE LICENSEE DOES NOT HAVE READY ACCESS TO ACCURATE DESIGN INFORMATION; AND THAT TECHNICAL WORK IS NOT ALWAYS PERFORMED IN A COMPLETE, TECHNICALLY CORRECT MANNER. DEFICIENCIES WERE ALSO IDENTIFIED WITH TESTING, MAINTENANCE, AND OPERATION ASPECTS OF THE SYSTEMS REVIEWED.

+ INSPECTION ON JUNE 5 - 12, 1988 (REPORT NO. 50-361/88-13) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MAY 22 - JULY 2, 1988 (REPORT NO. 50-361/88-15) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JULY 25 - 29, 1988 (REPORT NO. 50-361/88-16) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 27 - JULY 1, 1988 (REPORT NO. 50-361/88-18) AREAS INSPECTED: A SPECIAL, ANNOUNCED INSPECTION OF REPRESENTATIVE SUBSYSTEMS OF THE POST-ACCIDENT MONITORING SYSTEM AT THE SAN ONOFRE NUCLEAR GENERATING STATION (SONGS), UNIT 2. THIS INSPECTION ASSESSED THE CONFORMANCE OF THE SONGS WITH REGULATORY GUIDE 1.97, REVISION 2. THIS INSPECTION ADDRESSES SAFETY ISSUE MANAGEMENT SYSTEM ITEM NUMBER 67.3.3. DURING THIS INSPECTION, TWO INSPECTION PROCEDURES WERE UTILIZED.



1. Docket: 50-362 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: E. R. SIACOR (714) 368-6223

4. Licensed Thermal Power (MWT): 3390

5. Nameplate Rating (Gross MWe): 1127

6. Design Electrical Rating (Net MWe): 1080

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1080

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>37,991.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,632.3</u>	<u>26,354.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>2,580.8</u>	<u>25,454.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>.0</u>	<u>8,593,478</u>	<u>78,049,239</u>
18. Gross Elec Ener (MWH)	<u>.0</u>	<u>2,952,875</u>	<u>26,430,769</u>
19. Net Elec Ener (MWH)	<u>-6,209</u>	<u>2,782,358</u>	<u>24,870,004</u>
20. Unit Service Factor	<u>.0</u>	<u>50.5</u>	<u>67.0</u>
21. Unit Avail Factor	<u>.0</u>	<u>50.5</u>	<u>67.0</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>50.4</u>	<u>60.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>50.4</u>	<u>60.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>10.4</u>	<u>9.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>299.8</u>	<u>2,708.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 08/14/88

XX  
X SAN ONOFRE 3 X  
XX

AVERAGE DAILY POWER LEVEL (PWe) PLOT

SAN ONOFRE 3



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SAN ONOFRE 3 \*  
\*\*\*\*\*

<u>No.</u>	<u>Date</u>	<u>Type</u>	<u>Hours</u>	<u>Reason</u>	<u>Method</u>	<u>LER Number</u>	<u>System Component</u>	<u>Cause &amp; Corrective Action to Prevent Recurrence</u>
41	04/30/88	S	744.0	C	4			CYCLE 4 REFUELING OUTAGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SAN ONOFRE 3 REMAINED SHUTDOWN IN JULY FOR SCHEDULED REFUELING OUTAGE.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN DIEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
SAN CLEMENTE, CA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 29, 1983  
DATE ELEC ENER 1ST GENER...SEPTEMBER 25, 1983  
DATE COMMERCIAL OPERATE...APRIL 1, 1984  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SOUTHERN CALIFORNIA EDISON  
CORPORATE ADDRESS.....P.O. BOX 800  
ROSEMEAD, CALIFORNIA 91770  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....R. HUEY  
LICENSEE'S PROJ MANAGER.....D. HICKMAN  
PROJECT NUMBER.....50-362  
LICENSE & DATE ISSUANCE...NPF-15, NOVEMBER 15, 1982  
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA  
GENERAL LIBRARY  
IRVINE, CA. 92713

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON MAY 2 - JUNE 10, 1988 (REPORT NO. 50-362/88-10) AREAS INSPECTED: THIS SPECIAL, ANNOUNCED TEAM SAFETY SYSTEM FUNCTIONAL INSPECTION (SSFI) INVOLVED THE AREAS OF ENGINEERING, MAINTENANCE, SURVEILLANCE TESTING, OPERATIONS, HEALTH PHYSICS, QUALITY ASSURANCE AND ADMINISTRATION. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.
- RESULTS: OF THE AREAS INSPECTED, FOUR VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED. THE TEAM CONCLUDED THAT THE LICENSEE DOES NOT FULLY UNDERSTAND THE DESIGN OF THE SYSTEMS REVIEWED; THAT THE LICENSEE DOES NOT HAVE READY ACCESS TO ACCURATE DESIGN INFORMATION; AND THAT TECHNICAL WORK IS NOT ALWAYS PERFORMED IN A COMPLETE, TECHNICALLY CORRECT MANNER. DEFICIENCIES WERE ALSO IDENTIFIED WITH TESTING, MAINTENANCE, AND OPERATION ASPECTS OF THE SYSTEMS REVIEWED.
- + INSPECTION ON JUNE 5 - 12, 1988 (REPORT NO. 50-362/83-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MAY 22 - JULY 2, 1988 (REPORT NO. 50-362/88-16) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 25 - 29, 1988 (REPORT NO. 50-362/88-17) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JUNE 27 - JULY 1, 1988 (REPORT NO. 50-362-88-19) AREAS INSPECTED: A SPECIAL, ANNOUNCED INSPECTION OF REPRESENTATIVE SUBSYSTEMS OF THE POST-ACCIDENT MONITORING SYSTEM AT THE SAN ONOFRE NUCLEAR GENERATING STATION (SONGS), UNIT 3. THIS INSPECTION ASSESSED THE CONFORMANCE OF THE SONGS WITH REGULATORY GUIDE 1.97, REVISION 2. THIS INSPECTION ADDRESSES SAFETY ISSUE MANAGEMENT SYSTEM ITEM NUMBER 67.3.3. DURING THIS INSPECTION, TWO INSPECTION PROCEDURES WERE UTILIZED.

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 3 - AUGUST 13, 1988 (REPORT NO. 50-362/88-20) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT WAS SHUT DOWN ON APRIL 29, 1988, FOR THE CYCLE FOUR REFUELING. THE LICENSEE EXPECTS TO RETURN THE UNIT TO SERVICE IN EARLY AUGUST.

LAST IE SITE INSPECTION DATE: 07/03 - 08/13/88+

INSPECTION REPORT NO: 50-362/88-20+

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-04-10	05-11-88	06-15-88	SPURIOUS CPIS ON FAILURE CIRCUIT ACTUATION DUE TO CIRCUIT ERRORS




1. Docket: 50-327                    O P E R A T I N G   S T A T U S
2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0
3. Utility Contact: DAVID DUPREE (615) 870-6722
4. Licensed Thermal Power (MWT):                    3411
5. Nameplate Rating (Gross MWe):                    1220
6. Design Electrical Rating (Net MWe):                    1148
7. Maximum Dependable Capacity (Gross MWe):                    1183
8. Maximum Dependable Capacity (Net MWe):                    1148
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE
- |                               | MONTH         | YEAR           | CUMULATIVE        |
|-------------------------------|---------------|----------------|-------------------|
| 12. Report Period Hrs         | <u>744.0</u>  | <u>5,111.0</u> | <u>62,112.0</u>   |
| 13. Hours Reactor Critical    | <u>.0</u>     | <u>.0</u>      | <u>24,444.7</u>   |
| 14. Rx Reserve Shtdwn Hrs     | <u>.0</u>     | <u>.0</u>      | <u>.0</u>         |
| 15. Hrs Generator On-Line     | <u>.0</u>     | <u>.0</u>      | <u>23,871.0</u>   |
| 16. Unit Reserve Shtdwn Hrs   | <u>.0</u>     | <u>.0</u>      | <u>.0</u>         |
| 17. Gross Therm Ener (MWH)    | <u>.0</u>     | <u>.0</u>      | <u>77,060,921</u> |
| 18. Gross Elec Ener (MWH)     | <u>.0</u>     | <u>.0</u>      | <u>25,978,386</u> |
| 19. Net Elec Ener (MWh)       | <u>-3,766</u> | <u>-34,053</u> | <u>24,820,270</u> |
| 20. Unit Service Factor       | <u>.0</u>     | <u>.0</u>      | <u>38.4</u>       |
| 21. Unit Avail Factor         | <u>.0</u>     | <u>.0</u>      | <u>38.4</u>       |
| 22. Unit Cap Factor (MDC Net) | <u>.0</u>     | <u>.0</u>      | <u>34.8</u>       |
| 23. Unit Cap Factor (BER Net) | <u>.0</u>     | <u>.0</u>      | <u>34.8</u>       |
| 24. Unit Forced Outage Rate   | <u>100.0</u>  | <u>100.0</u>   | <u>54.9</u>       |
| 25. Forced Outage Hours       | <u>744.0</u>  | <u>5,111.0</u> | <u>29,002.1</u>   |
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE
27. If Currently Shutdown Estimated Startup Date: 09/01/88

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXLXXX  
 X                    SEQUOYAH 1                    X  
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SEQUOYAH 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

XX  
\* SEQUOYAH 1 \*  
XX

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	12/20/85	F	744.0	F	4			DESIGN CONTROL, CONFIGURATION UPDATING, AND EMPLOYEE CONCERNS.

XXXXXXXXXXXX SEQUOYAH 1 REMAINED SHUTDOWN IN JULY BECAUSE OF DESIGN CONTROL,  
\* SUMMARY \* CONFIGURATION UPDATING, AND EMPLOYEE CONCERNS.  
XXXXXXXXXXXX

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SEQUOYAH 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....TENNESSEE  
COUNTY.....HAMILTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9.5 MI NE OF  
CHATTANOOGA, TN  
TYPE OF REACTOR.....PHR  
DATE INITIAL CRITICALITY...JULY 5, 1980  
DATE ELEC ENER 1ST GENER...JULY 22, 1980  
DATE COMMERCIAL OPERATE...JULY 1, 1981  
CONDENSER COOLING METHOD. .ONCE THRU  
CONDENSER COOLING WATER...CHICKAMAUGA LAKE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS.....6 NORTH 38A LOOKOUT PLACE  
CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR  
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. FORD  
LICENSING PROJ MANAGER.....E. MCKENNA  
DOCKET NUMBER.....50-327  
LICENSE & DATE ISSUANCE...DPR-77, SEPTEMBER 17, 1980  
PUBLIC DOCUMENT ROOM.....CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY  
1001 BROAD STREET  
CHATTANOOGA, TENNESSEE 37402

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

\* INSPECTION MAY 1-30 (08-27): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF: OPERATIONAL SAFETY VERIFICATION; REVIEW OF PREVIOUS INSPECTION FINDINGS; FOLLOWUP OF EVENTS; REVIEW OF LICENSEE IDENTIFIED ITEMS; REVIEW OF NRC BULLETINS; AND REVIEW OF INSPECTOR FOLLOWUP ITEMS. ONE VIOLATION WAS IDENTIFIED - VIOLATION 327, 328/88-27-01, INADEQUATE CORRECTIVE ACTION FOR IMPROPER POSITIVE REACTIVITY CHANGES. NO UNRESOLVED ITEMS OR INSPECTOR FOLLOWUP ITEMS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V AND DRAWINGS 47W470-4, AND 47B473 SHEETS 2, 5, AND 6, PRIOR TO MARCH 6, 1988, 16 POLAR CRANE WALL PENETRATIONS WERE NOT SEALED IN ACCORDANCE WITH THESE DESIGN DRAWINGS. CONTRARY TO TS 6.8.1, PRIOR TO MARCH 6, 1988, THE LICENSEE FAILED TO HAVE AN ADEQUATE PROCEDURE FOR PERIODIC INSPECTIONS OF THE SHIELD BUILDING PENETRATION FIRE BARRIER FOAM SEALS. FABRIC BOOT SLEEVES WERE INSTALLED DURING ORIGINAL PLANT CONSTRUCTION ON 53 OF THESE PENETRATIONS, FOR HYDRAULIC CONSIDERATIONS, MAKING THE FOAM FIRE BARRIERS INACCESSIBLE. SURVEILLANCE INSTRUCTION (SI) 233.1, "VISUAL INSPECTIONS OF PENETRATION FIRE BARRIERS-MECHANICAL SYSTEM 302 (PENETRATIONS)" AND ITS PREDECESSORS DID NOT REQUIRE REMOVAL OF THESE SLEEVES TO PERMIT FIRE BARRIER INSPECTION OR REQUIRE INSPECTION OF THE BARRIER FROM THE OPPOSITE SIDE OF THE WALL. AS A RESULT, THE LICENSEE HAD NOT MET THE REQUIREMENTS OF TS 4.7.12 FOR VISUAL INSPECTION OF FIRE BARRIER SEALS SINCE PLANT LICENSING. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V AND DRAWINGS 47W470-4, AND 47B473 SHEETS 2, 5, AND 6, PRIOR TO MARCH 6, 1988, 16 POLAR CRANE WALL PENETRATIONS WERE NOT SEALED IN ACCORDANCE WITH THESE DESIGN DRAWINGS. CONTRARY TO TS 6.8.1, PRIOR TO MARCH 6, 1988, THE LICENSEE





Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SEQUOYAH 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
10	07/16/88	S	0.0	B	5			MAINTENANCE PERFORMED ON THE SPEEDCHANGER OF BOTH MAIN FEEDWATER PUMPS.
11	07/30/88	S	0.0	B	5			MAINTENANCE ON 2A-A MAIN FEEDWATER PUMP SPEEDCHANGER.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SEQUOYAH 2 INCURRED TWO SCHEDULED LOAD REDUCTIONS IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)







1. Docket: 50-498                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: C.A. AYALA (512) 972-8628

4. Licensed Thermal Power (MWT):                    3800

5. Nameplate Rating (Gross MWe):                    \_\_\_\_\_

6. Design Electrical Rating (Net MWe):                    1250

7. Maximum Dependable Capacity (Gross MWe):                    1250

8. Maximum Dependable Capacity (Net MWe):                    1250

9. If Changes Occur Above Since Last Report, Give Reasons: \_\_\_\_\_

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>2,966.1</u>	<u>2,966.1</u>
13. Hours Reactor Critical	<u>650.5</u>	<u>1,843.3</u>	<u>1,843.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>595.0</u>	<u>1,634.1</u>	<u>1,634.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,543,286</u>	<u>2,695,221</u>	<u>2,695,221</u>
18. Gross Elec Ener (MWH)	<u>490,470</u>	<u>798,543</u>	<u>798,543</u>
19. Net Elec Ener (MWH)	<u>444,404</u>	<u>628,919</u>	<u>628,919</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>58.1</u>	<u>665.3</u>	<u>665.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


BOTTOM MOUNTED INST. INSPECT. 09/88 - 14 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: 08/01/88

\*\*\*\*\*  
 \* SOUTH TEXAS 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SOUTH TEXAS 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SOUTH TEXAS 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-13	07/05/88	F	4.8	B	9		TA	TRB	STEAM LEAK REPAIR. (RX CRITICAL)
88-14	07/16/88	S	0.0	B	5		TA	V-65	REDUCED POWER TO DETERMINE THE REQUIRED GOVERNOR VALVE POSITION TO RE-PERFORM THE LARGE LOAD REDUCTION TEST WITH TURBINE CONTROL IN THE "IMPULSE PRESSURE OUT" MODE. (RX CRITICAL)
88-15	07/17/88	S	4.9	B	9				PERFORMED LARGE LOAD REDUCTION TEST AT 75% (RX CRITICAL).
88-16	07/19/88	F	53.3	G	3	88-045	JC	CAB	REACTOR TRIP DUE TO I&C TECHNICIAN INADVERTANTLY TRIPPING THE WRONG CHANNEL OF DELTA-T INSTRUMENT. WILL BE ADDRESSED IN LER 88-045.
88-17	07/28/88	S	86.0	B	1				PERFORMED REACTOR TRIP TEST AT 100% POWER PLATEAU.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SOUTH TEXAS INCURRED FOUR POWER OUTAGES AND ONE REDUCTION DURING JULY FOR REASONS STATED ABOVE WHILE IN POWER ASCENSION TESTING PHASE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION  
STATE.....TEXAS  
  
COUNTY.....MATAGORDA  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI SSW OF  
BAY CITY, TEX  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...MARCH 8, 1988  
  
DATE ELEC ENER 1ST GENER...MARCH 30, 1988  
  
DATE COMMERCIAL OPERATE...\*\*\*\*\*  
  
CONDENSER COOLING METHOD...CC  
  
CONDENSER COOLING WATER...COLORADO RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....ELECTRIC RELIABILITY  
COUNCIL OF TEXAS

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....HOUSTON LIGHTING & POWER COMPANY  
  
CORPORATE ADDRESS.....P.O. BOX 1706  
HOUSTON, TEXAS 77001  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....EBASCO  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
  
IE RESIDENT INSPECTOR.....C. JOHNSON  
  
LICENSING PROJ MANAGER.....G. DICK  
DOCKET NUMBER.....50-498  
  
LICENSE & DATE ISSUANCE....NPF-76, MARCH 22, 1988  
  
PUBLIC DOCUMENT ROOM.....GLEN ROSE-SOMERVELL LIBRARY  
BERNARD AND HIGHWAY 144  
P.O. BOX 417  
GLEN ROSE, TX. 76043

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1-31 (88-34) ROUTINE, UNANNOUNCED INSPECTION INCLUDED LOSS OF OFFSITE POWER, BOTTOM MOUNTED INSTRUMENTATION, OBSERVATION SAFETY VERIFICATION, ENGINEERED SAFETY FEATURE SYSTEM WALKDOWN, SURVEILLANCE OBSERVATIONS, SECURITY OBSERVATIONS, RADIOLOGICAL PROTECTION OBSERVATION, AND SECURITY FENCE CONSTRUCTION. WITHIN THE AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MAY 23-27, 1988 (88-37) ROUTINE, UNANNOUNCED INSPECTION OF PHYSICAL SECURITY PROGRAMS, INCLUDING LOCK AND KEY CONTROL, PHYSICAL PROTECTION OF SAFEGUARDS INFORMATION, ASSESSMENT AIDS, TEST AND MAINTENANCE, ACCESS CONTROL - PERSONNEL, DETECTION AIDS - PROTECTED AREA, AND FOLLOW UP ON PREVIOUSLY IDENTIFIED INSPECTION FINDINGS. WITHIN THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED (INADEQUATE LOCK AND KEY CONTROL, PARA 3; AND INADEQUATE PROTECTION OF SAFEGUARDS INFORMATION, PARA 4).

INSPECTION CONDUCTED JULY 5-8, 1988 (88-44) ROUTINE, UNANNOUNCED INSPECTION OF STP'S UNITS 1 AND 2 REVIEW OF SELECTED OPEN ITEMS AND EVALUATION OF TEST RESULTS FOR CONTROL ROD TESTING. WITHIN TWO AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   ( C O N T I N U E D )

\*\*\*\*\*  
X                    SOUTH TEXAS 1                    X  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

PLANT STATUS:

LAST IE SITE INSPECTION DATE: JULY 8, 1988

INSPECTION REPORT NO: 50-498/88-44

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

=====

1. Docket: 50-335                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 694-4452

4. Licensed Thermal Power (MWT):                      2700

5. Nameplate Rating (Gross MWe):                      1000 X 0.89 = 890

6. Design Electrical Rating (Net MWe):                      830

7. Maximum Dependable Capacity (Gross MWe):                      872

8. Maximum Dependable Capacity (Net MWe):                      839

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted                      Any (Net MWe):                     

11. Reasons for Restrictions, If A  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>101,783.0</u>
13. Hours Reactor Critical	<u>240.4</u>	<u>4,568.3</u>	<u>77,120.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>205.3</u>
15. Hrs Generator On-Line	<u>232.6</u>	<u>4,554.4</u>	<u>75,524.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>39.3</u>
17. Gross Therm Ener (MWH)	<u>612,621</u>	<u>12,220,446</u>	<u>193,566,083</u>
18. Gross Elec Ener (MWH)	<u>198,750</u>	<u>4,084,970</u>	<u>63,608,555</u>
19. Net Elec Ener (MWH)	<u>185,268</u>	<u>3,875,792</u>	<u>60,067,381</u>
20. Unit Service Factor	<u>31.3</u>	<u>89.1</u>	<u>74.2</u>
21. Unit Avail Factor	<u>31.3</u>	<u>89.1</u>	<u>74.2</u>
22. Unit Cap Factor (MDC Net)	<u>29.7</u>	<u>90.4</u>	<u>70.3</u>
23. Unit Cap Factor (DER Net)	<u>30.0</u>	<u>91.4</u>	<u>71.1</u>
24. Unit Forced Outage Rate	<u>3.2</u>	<u>1.1</u>	<u>3.8</u>
25. Forced Outage Hours	<u>7.6</u>	<u>52.8</u>	<u>2,993.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 08/26/88

\*\*\*\*\*  
\*                      ST LUCIE 1                      \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

ST LUCIE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* ST LUCIE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
02	06/30/88	F	3.9	A	4	335/88-04	HM	RELAY	UNIT NO.1 WAS OPERATING AT 100% POWER WHEN THE REACTOR TRIPPED ON HIGH-PRESSURIZER PRESSURE. THE TRIP WAS CAUSED BY A SPURIOUS ACTUATION OF THE CURRENT BALANCE RELAY ASSOCIATED WITH THE 1B CONDENSATE PUMP. THE RELAY WAS REPLACED. RETURN TO POWER OPERATION THEN COMMENCED.
03	07/01/88	F	3.7	A	2		H	VALVEX	UNIT NO.1 REACHED APPROXIMATELY 15% POWER WHEN IT WAS MANUALLY SHUTDOWN TO REPAIR A LEAKING SAFETY RELIEF VALVE IN THE FEEDWATER FILTER SYSTEM. FOLLOWING REPAIRS THE UNIT WAS RETURNED TO FULL POWER OPERATION.
04	07/11/88	S	503.8	C	1		RC	FUELXX	UNIT SHUTDOWN FOR SCHEDULED REFUELING AND MAINTENANCE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 ST. LUCIE 1 ENTERED JULY IN AN OUTAGE. SUBSEQUENTLY, INCURRED ONE FORCED OUTAGE AND SHUTDOWN FOR SCHEDULED REFUELING AND MAINTENANCE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ST LUCIE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....ST LUCIE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI SE OF  
FT. PIERCE, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...APRIL 22, 1976  
DATE ELEC ENER 1ST GENER...MAY 7, 1976  
DATE COMMERCIAL OPERATE...DECEMBER 21, 1976  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...ATLANTIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 529100  
MIAMI, FLORIDA 33152  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. CRLENJAK  
LICENSING PROJ MANAGER....E. TOURIGNY  
DOCKET NUMBER.....50-335  
LICENSE & DATE ISSUANCE...DPR-67, MARCH 1, 1976  
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY  
3209 VIRGINIA AVENUE  
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ NONE.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   ST LUCIE 1                   \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JULY 31, 1988 +

INSPECTION REPORT NO: 50-335/88-17 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			
=====			



1. Docket: 50-389 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 694-4432

4. Licensed Thermal Power (Mwt): 2700

5. Nameplate Rating (Gross MWe): 850

6. Design Electrical Rating (Net MWe): 830

7. Maximum Dependable Capacity (Gross MWe): 882

8. Maximum Dependable Capacity (Net MWe): 839

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>43,680.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,111.0</u>	<u>37,868.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,111.0</u>	<u>37,148.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,005,648</u>	<u>13,729,002</u>	<u>96,725,644</u>
18. Gross Elec Ener (MWH)	<u>661,320</u>	<u>4,591,860</u>	<u>32,290,520</u>
19. Net Elec Ener (MWH)	<u>627,285</u>	<u>4,358,751</u>	<u>30,526,539</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>85.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>85.0</u>
22. Unit Cap Factor (MDC Net)	<u>100.5</u>	<u>101.6</u>	<u>83.3</u>
23. Unit Cap Factor (DER Net)	<u>101.6</u>	<u>102.7</u>	<u>84.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>6.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,511.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X ST LUCIE 2 X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ST LUCIE 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

XX  
X ST LUCIE 2 X  
XX

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

XXXXXXXXXXXX ST. LUCIE 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
\* SUMMARY \*  
XXXXXXXXXXXX SIGNIFICANT LOAD REDUCTIONS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& license Examination	9-Other	(LER) File (NURLJ-0161)

\*\*\*\*\*  
\* ST LUCIE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....ST LUCIE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI SE OF  
FT. PIERCE, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 2, 1983  
DATE ELEC ENER 1ST GENER...JUNE 13, 1983  
DATE COMMERCIAL OPERATE...AUGUST 8, 1983  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...ATLANTIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER ST., P.O. BOX 529100  
MIAMI, FLORIDA 33152  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. CRLENJAK  
LICENSING PROJ MANAGER.....E. TOURIGNY  
DOCKET NUMBER.....50-389  
LICENSE & DATE ISSUANCE...NPF-16, JUNE 10, 1983  
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY  
3209 VIRGINIA AVENUE  
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ NONE.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   ST LUCIE 2                   \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JULY 31, 1988 +

INSPECTION REPORT NO: 50-389/88-17 +

R E P O R T S   F R O M   L I C E N S E E

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			

.....

1. Docket: 50-395 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: J. W. HALTIWANGER (803) 345-5209  
 4. Licensed Thermal Power (MWh): 2775  
 5. Nameplate Rating (Gross MWe): 900  
 6. Design Electrical Rating (Net MWe): 900  
 7. Maximum Dependable Capacity (Gross MWe): 900  
 8. Maximum Dependable Capacity (Net MWe): 885  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
 NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>40,175.0</u>
13. Hours Reactor Critical	<u>704.0</u>	<u>4,808.6</u>	<u>31,477.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.2</u>	<u>4,770.9</u>	<u>30,899.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,894,116</u>	<u>12,880,991</u>	<u>81,664,671</u>
18. Gross Elec Ener (MWH)	<u>618,650</u>	<u>4,270,640</u>	<u>27,100,053</u>
19. Net Elec Ener (MWH)	<u>591,388</u>	<u>4,084,325</u>	<u>25,823,908</u>
20. Unit Service Factor	<u>93.6</u>	<u>93.3</u>	<u>76.9</u>
21. Unit Avail Factor	<u>93.6</u>	<u>93.3</u>	<u>76.9</u>
22. Unit Cap Factor (MDC Net)	<u>89.8</u>	<u>90.3</u>	<u>72.6</u>
23. Unit Cap Factor (DER Net)	<u>88.3</u>	<u>88.8</u>	<u>71.4</u>
24. Unit Forced Outage Rate	<u>6.4</u>	<u>6.7</u>	<u>6.5</u>
25. Forced Outage Hours	<u>47.8</u>	<u>340.1</u>	<u>2,163.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - SEPTEMBER 16, 1988 - 85 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
 X SUMMER 1 X  
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUMMER 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
 X SUMMER 1 X  
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
6	07/05/88	F	0.0	A	5			REPAIR REACTOR COOLANT DRAIN TANK PUMP.
7	07/26/88	F	47.8	H	3			TRIP RESULTED FROM AN EQUIPMENT MALFUNCTION IN CONJUNCTION WITH PERSONNEL ERRORS. ADDITIONAL ADMINISTRATIVE CONTROLS WERE IMPLEMENTED AND PLANT STARTUP INITIATED.

XXXXXXXXXX SUMMER 1 INCURRED ONE FORCED LOAD REDUCTION AND ONE FORCED  
 X SUMMARY X OUTAGE DURING JULY AS DISCUSSED ABOVE.  
 XXXXXXXXXXXX

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....FAIRFIELD  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...26 MI NW OF  
COLUMBIA, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 22, 1982  
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982  
DATE COMMERCIAL OPERATE...JANUARY 1, 1984  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MONTICELLO RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SOUTH CAROLINA ELECTRIC & GAS CO.  
CORPORATE ADDRESS.....P.O. BOX 764  
COLUMBIA, SOUTH CAROLINA 29202  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. PREVATTE  
LICENSING PROJ MANAGER.....J. HAYES  
DOCKET NUMBER.....50-395  
LICENSE & DATE ISSUANCE...NPF-12, NOVEMBER 12, 1982  
PUBLIC DOCUMENT ROOM.....FAIRFIELD COUNTY LIBRARY  
GARDEN & WASHINGTON STREETS  
WINNSBORO, SOUTH CAROLINA 29180

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JUNE 13-17 (88-15): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF THE SERVICE WATER SYSTEM. A REVIEW WAS PERFORMED OF THE CURRENT SYSTEM, ITS DESIGN BASIS AND THOSE PLANT ACTIONS TAKEN TO RESPOND TO CURRENT GENERIC NRC SERVICE WATER CONCERNS. A SYSTEM WALKDOWN WAS CONDUCTED, AND SURVEILLANCE TEST RESULTS WERE REVIEWED. THIS INSPECTION SHOWED THE SERVICE WATER SYSTEM TO BE MAINTAINED IN ACCORDANCE WITH THE EXISTING REQUIREMENTS OF THE TECHNICAL SPECIFICATIONS AND THE GUIDELINES OF ASME. THE PLANT PERSONNEL ARE NOT IN A MODE OF LOOKING FOR PROBLEMS RELATED TO SERVICE WATER. PROBLEMS ARE DEALT WITH AS THEY OCCUR, INSTEAD OF BEING ANTICIPATED. THIS APPROACH IS CONSISTENT WITH THE OBSERVATIONS MADE ON SERVICE WATER INSPECTIONS OF THE PROGRAMS AT OTHER LICENSEE'S FACILITIES. ALTHOUGH IE BULLETIN 81-03 "FLOW BLOCKAGE OF COOLING WATER TO SAFETY RELATED COMPONENTS BY CORBICULA SP.", WAS ISSUED IN APRIL OF 1981, ONLY RELATIVELY RECENTLY HAS THE PLANT BEEN ACTIVELY SEEKING A SOLUTION TO ITS CLAM PROBLEM. DEGRADATION OF SERVICE WATER PERFORMANCE HAS BEEN NOTED IN THE PAST. POTENTIAL FUTURE PROBLEMS INCLUDE SILTING AND MICROBIOLOGICALLY INDUCED CORROSION. A SYSTEM WALKDOWN SHOWED THE SYSTEM TO HAVE A WELL KEPT APPEARANCE. PERFORMANCE TESTING ON THE ACTIVE COMPONENTS SHOWS THEM TO BE WITHIN THE ASME GUIDELINES. THE SYSTEM ENGINEER CONCEPT WAS RECENTLY INSTITUTED AT THE PLANT. THE FOCUS ON THE SYSTEM AS A WHOLE RESULTED IN SERVICE WATER FLOW BALANCING BEING PERFORMED RECENTLY AT THE REQUEST OF THE SYSTEM ENGINEER. THIS WAS BEYOND THE MINIMUM REQUIRED TESTING. OVERALL, THE PLANT WOULD RATE AVERAGE WITH OTHER PLANTS INSPECTED WITH RESPECT TO ITS SERVICE WATER SYSTEM PROGRAMS. THE SYSTEM IS BETTER INSTRUMENTED WITH RESPECT TO FLOW AND TEMPERATURE THAN MOST. THE PROGRAMS FOR ASSURING SYSTEM PERFORMANCE ARE MORE REACTIVE THAN PROACTIVE, HOWEVER. ONE VIOLATION, ONE DEVIATION, AND ONE UNRESOLVED ITEM WERE IDENTIFIED. THE VIOLATION WAS FAILURE TO PROVIDE AN ADEQUATE PROCEDURE FOR SERVICE WATER OPERATIONS DURING AN EXTENDED EQUIPMENT OUTAGE. THIS IS DISCUSSED IN SECTION 4 OF THE REPORT. THE DEVIATION INVOLVED REACTOR BUILDING COOLING UNITS AIR FLOWS AT LESS THAN THE FSAR DESIGN FLOWS. THIS IS DISCUSSED IN SECTION 3 OF THE REPORT. THE UNRESOLVED ITEM IS A QUESTION OF ADEQUACY OF THE 'C' SERVICE WATER PUMP. THIS IS DISCUSSED IN SECTION 3 OF THE





1. Docket: 50-280                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: L. A. WARREN (804) 357-3184

4. Licensed Thermal Power (MWT):                    2441

5. Nameplate Rating (Gross MWe):                    992 X 0.9 = 898

6. Design Electrical Rating (Net MWe):                    788

7. Maximum Dependable Capacity (Gross MWe):                    820

8. Maximum Dependable Capacity (Net MWe):                    781

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>136,823.0</u>
13. Hours Reactor Critical	<u>415.7</u>	<u>2,728.3</u>	<u>87,467.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,774.5</u>
15. Hrs Generator On-Line	<u>331.0</u>	<u>2,628.6</u>	<u>85,599.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,736.2</u>
17. Gross Therm Ener (MWH)	<u>721,410</u>	<u>6,044,220</u>	<u>198,271,486</u>
18. Gross Elec Ener (MWH)	<u>234,110</u>	<u>2,028,795</u>	<u>64,403,968</u>
19. Net Elec Ener (MWH)	<u>221,010</u>	<u>1,926,514</u>	<u>61,078,676</u>
20. Unit Service Factor	<u>44.5</u>	<u>51.4</u>	<u>62.6</u>
21. Unit Avail Factor	<u>44.5</u>	<u>51.4</u>	<u>65.3</u>
22. Unit Cap Factor (RDC Net)	<u>38.0</u>	<u>48.3</u>	<u>57.2</u>
23. Unit Cap Factor (DER Net)	<u>37.7</u>	<u>47.8</u>	<u>56.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.9</u>	<u>17.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>79.2</u>	<u>14,499.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X                    SURRY 1                    X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 1



JULY 1988



\*\*\*\*\*  
\* SURRY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA  
COUNTY.....SURRY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI NW OF  
NEWPORT NEWS, VA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JULY 1, 1972  
DATE ELEC ENER 1ST GENER...JULY 4, 1972  
DATE COMMERCIAL OPERATE...DECEMBER 22, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...JAMES RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA POWER  
CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. BURKE  
LICENSING PROJ MANAGER.....C. PATEL  
DOCKET NUMBER.....50-280  
LICENSE & DATE ISSUANCE....DPR-32, MAY 25, 1972  
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY  
COLLEGE OF WILLIAM AND MARY  
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

\* INSPECTION MAY 16-20 (88-19): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF LOCAL LEAK RATE TESTING AND CONTAINMENT INTEGRITY. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING DETERMINING THE "AS-FOUND" CONTAINMENT LEAK RATE RELATIVE TO REPAIR OF SECONDARY SYSTEM LEAKAGE.

INSPECTION JUNE 20-24 (88-22): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF EMERGENCY PREPAREDNESS, AND INCLUDED A REVIEW OF THE FOLLOWING PROGRAMMATIC AREAS: (1) EMERGENCY PLAN AND IMPLEMENTING PROCEDURES; (2) EMERGENCY FACILITIES, EQUIPMENT, INSTRUMENTATION, AND SUPPLIES; (3) ORGANIZATION AND MANAGEMENT CONTROL; (4) TRAINING AND (5) INDEPENDENT REVIEWS/AUDITS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE FINDINGS OF THIS INSPECTION APPEARED TO INDICATE THAT THE LICENSEE WAS PREPARED TO RESPOND TO A RADIOLOGICAL EMERGENCY INVOLVING THE SURRY FACILITY.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS



1. Docket: 50-281 OPERATING STATUS
2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: L. A. WARREN (804) 357-3184
4. Licensed Thermal Power (Mwt): 2491
5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848
6. Design Electrical Rating (Net MWe): 788
7. Maximum Dependable Capacity (Gross MW): 820
8. Maximum Dependable Capacity (Net MWe): 781
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>133,705.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,066.3</u>	<u>88,735.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>25.8</u>
15. Hrs Generator On-line	<u>744.0</u>	<u>4,032.7</u>	<u>87,331.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Ther. Ener (MWH)	<u>1,771,100</u>	<u>9,700,719</u>	<u>295,871,068</u>
18. Gross Elec Ener (MWH)	<u>568,210</u>	<u>3,255,545</u>	<u>66,573,369</u>
19. Net Elec Ener (MWH)	<u>530-530</u>	<u>3,059,089</u>	<u>63,128,870</u>
20. Unit Service Factor	<u>100.0</u>	<u>78.9</u>	<u>65.3</u>
21. Unit Avail factor	<u>100.0</u>	<u>78.9</u>	<u>65.3</u>
22. Unit C <sub>1</sub> Factor (MDC Net)	<u>92.9</u>	<u>76.4</u>	<u>60.5</u>
23. Unit Cap Factor (DER Net)	<u>92.0</u>	<u>75.7</u>	<u>59.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>21.1</u>	<u>14.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,078.3</u>	<u>11,937.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING, 09/09/88, 68 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
 \* SURRY 2 \*  
 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SURRY 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
88-06	07/11/88	S	0.0	A	5			UNIT REDUCED TO 75% POWER, 560 MWS TO CLEAN WATERBOXES.
88-09	07/22/88	S	0.0	A	5			UNIT REDUCED TO 65% POWER, 490 MWS FOR PT-29.1 AND TO CLEAN WATERBOXES.
88-10	07/23/88	S	0.0	A	5			UNIT REDUCED TO 63% POWER, 500 MWS TO WORK 'A' MFP AND TO CLEAN WATERBOXES.
88-11	07/30/88	S	0.0	A	5			UNIT REDUCED TO 77% POWER, 570 MWS TO ALLOW REMOVAL OF '3B' FEEDWATER HEATER.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SURRY 2 INCURRED FOUR SCHEDULED POWER REDUCTIONS IN JULY FOR REASONS STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
X SURRY 2 X  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA  
COUNTY.....SURRY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI NW OF  
NEWPORT NEWS, VA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 7, 1973  
DATE ELEC ENER 1ST GENER...MARCH 10, 1973  
DATE COMMERCIAL OPERATE...MAY 1, 1973  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...JAMES RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA POWER  
CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. BURKE  
LICENSING PROJ MANAGER....C. PATEL  
DOCKET NUMBER.....50-281  
LICENSE & DATE ISSUANCE...DPR-37, JANUARY 29, 1973  
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY  
COLLEGE OF WILLIAM AND MARY  
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 16-20 (88-19): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF LOCAL LEAK RATE TESTING AND CONTAINMENT INTEGRITY. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ONE UNRESOLVED ITEM WAS IDENTIFIED INVOLVING DETERMINING THE "AS-FOUND" CONTAINMENT LEAK RATE RELATIVE TO REPAIR OF SECONDARY SYSTEM LEAKAGE.

INSPECTION JUNE 20-24 (88-22): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF EMERGENCY PREPAREDNESS, AND INCLUDED A REVIEW OF THE FOLLOWING PROGRAMMATIC AREAS: (1) EMERGENCY PLAN AND IMPLEMENTING PROCEDURES; (2) EMERGENCY FACILITIES, EQUIPMENT, INSTRUMENTATION, AND SUPPLIES, (3) ORGANIZATION AND MANAGEMENT CONTROL, (4) TRAINING AND (5) INDEPENDENT REVIEWS/AUDITS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE FINDINGS OF THIS INSPECTION APPEARED TO INDICATE THAT THE LICENSEE WAS PREPARED TO RESPOND TO A RADIOLOGICAL EMERGENCY INVOLVING THE SURRY FACILITY.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS





1. Docket: 50-387 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. HIRT (717) 542-3917

4. Licensed Thermal Power (MHT): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1068

8. Maximum Dependable Capacity (Net MWe): 1032

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>45,144.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,616.7</u>	<u>33,270.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>219.3</u>	<u>992.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,534.2</u>	<u>32,483.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,424,243</u>	<u>14,561,776</u>	<u>100,608,201</u>
18. Gross Elec Ener (MWH)	<u>783,120</u>	<u>4,777,718</u>	<u>32,788,317</u>
19. Net Elec Ener (MWH)	<u>755,835</u>	<u>4,607,433</u>	<u>31,454,831</u>
20. Unit Service Factor	<u>100.0</u>	<u>88.7</u>	<u>72.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>88.7</u>	<u>72.0</u>
22. Unit Cap Factor (MDC Net)	<u>98.4</u>	<u>87.4</u>	<u>67.5</u>
23. Unit Cap Factor (DER Net)	<u>95.4</u>	<u>84.6</u>	<u>65.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>8.2</u>	<u>17.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>407.2</u>	<u>3,823.8</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration)


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* SUSQUEHANNA 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUSQUEHANNA 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SUSQUEHANNA 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	07/31/88	S	0.0	B	5		ZZ	ZZZZZZ	ON JULY 30, 1988, AT APPROXIMATELY 0000 HOURS, OPERATIONS PERSONNEL BEGAN REDUCING REACTOR POWER IN ORDER TO COMPLETE A CONTROL ROD SEQUENCE EXCHANGE. MINIMUM REACTOR POWER REACHED WAS 52%. FOLLOWING THE SEQUENCE EXCHANGE OPERATORS INCREASED REACTOR POWER. FULL POWER OPERATION WAS RE-ESTABLISHED AT APPROXIMATELY 1700 HOURS ON JULY 31, 1988.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SUSQUEHANNA 1 INCURRED ONE SCHEDULED LOAD REDUCTION DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SUSQUEHANNA 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....LUZERNE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NE OF  
BERWICK, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 10, 1982  
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982  
DATE COMMERCIAL OPERATE...JUNE 8, 1983  
CONDENSER COOLING METHOD...CC,HNDCT  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY  
LICENSEE.....PENNSYLVANIA POWER & LIGHT  
CORPORATE ADDRESS.....2 NORTH NINTH STREET  
ALLENTOWN, PENNSYLVANIA 18101  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....F. YOUNG  
LICENSING PROJ MANAGER.....M. THADANI  
DOCKET NUMBER.....50-387  
LICENSE & DATE ISSUANCE...NPF-14, NOVEMBER 12, 1982  
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY  
71 SOUTH FRANKLIN STREET  
WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   ( C O N T I N U E D )

\*\*\*\*\*  
\*                   SUSQUEHANNA 1                   \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====

1. Docket: 50-388                    O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. HIRT (717) 542-3917

4. Licensed Thermal Power (Mwt):                    3293

5. Nameplate Rating (Gross MWe):                    1152

6. Design Electrical Rating (Net MWe):                    1065

7. Maximum Dependable Capacity (Gross MWe):                    1068

8. Maximum Dependable Capacity (Net MWe):                    1032

9. If Changes Occur Above ...ice Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>30,383.0</u>
13. Hours Reactor Critical	<u>679.2</u>	<u>2,483.9</u>	<u>24,035.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>693.9</u>
15. Hrs Generator On-Line	<u>645.9</u>	<u>2,319.4</u>	<u>23,480.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,016,044</u>	<u>7,051,219</u>	<u>73,676,937</u>
18. Gross Elec Ener (MWH)	<u>649,526</u>	<u>2,292,546</u>	<u>24,099,308</u>
19. Net Elec Ener (MWH)	<u>625,035</u>	<u>2,183,438</u>	<u>23,184,402</u>
20. Unit Service Factor	<u>86.8</u>	<u>45.4</u>	<u>77.3</u>
21. Unit Avail Factor	<u>86.8</u>	<u>45.4</u>	<u>77.3</u>
22. Unit Cap Factor (MDC Net)	<u>81.4</u>	<u>41.4</u>	<u>73.9</u>
23. Unit Cap Factor (DER Net)	<u>78.9</u>	<u>40.1</u>	<u>71.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.3</u>	<u>8.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>6.1</u>	<u>2,155.1</u>

26. Shutdowns Sched Ov'r Next 6 Months (Type, Datr, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \*                    SUSQUEHANNA 2                    \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUSQUEHANNA 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SUSQUEHANNA 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	07/01/88	S	98.1	A	1		SB	H	ON JUNE 30, 1988, AT APPROXIMATELY 2130 HOURS, A SHIFT TECHNICAL ADVISOR (STA) DISCOVERED THAT THE U-BOLT HANGER TO THE NO.2 CONTROL VALVE OF THE MAIN STEAM SYSTEM WAS BROKEN. THE STA WAS MAKING A ROUTINE CHECK OF THE TV MONITOR MONITORING THE HANGER AND OBSERVED THAT THE HANGER WAS BROKEN. OPERATIONS PERSONNEL MANUALLY SHUTDOWN THE REACTOR BY INSERTING CONTROL RODS. THE SHUTDOWN WAS COMPLETED AT 0510 HOURS ON JULY 2, 1988. MAINTENANCE PERSONNEL REPAIRED THE HANGER. FOLLOWING THE REPAIR, OPERATORS BROUGHT THE UNIT CRITICAL AT 2156 HOURS ON JULY 4, 1988. THEY SYNCHRONIZED THE UNIT TO THE GRID AT 2140 HOURS ON JULY 5, 1988.
5	07/23/88	S	0.0	B	5		AD	ZZZZZ	OPERATORS REDUCED RX POWER IN ORDER TO OBTAIN BASELINE APRM AND LPRM NEUTRON FLUX NOISE VALUES IN ACCORDANCE WITH SURVEILLANCE REQUIREMENT 4.4.1.1.1.4.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SUSQUEHANNA 2 INCURRED ONE OUTAGE AND ONE LOAD REDUCTION DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Dper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SUSQUEHANNA 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....LUZERNE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NE OF  
BERWICK, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MAY 8, 1984  
DATE ELEC ENER 1ST GENER...JULY 3, 1984  
DATE COMMERCIAL OPERATE...FEBRUARY 12, 1985  
CONDENSER COOLING METHOD...CC,HNDCT  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PENNSYLVANIA POWER & LIGHT  
CORPORATE ADDRESS.....2 NORTH NINTH STREET  
ALLENTOWN, PENNSYLVANIA 18101  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....F. YOUNG  
LICENSING PROJ MANAGER....M. THADANI  
DOCKET NUMBER.....50-388  
LICENSE & DATE ISSUANCE...NPF-22, JUNE 27, 1984  
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY  
71 SOUTH FRANKLIN STREET  
WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====



1. Docket: 50-289 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. SMYTH (717) 948-8551

4. Licensed Thermal Power (MWT): 2535

5. Nameplate Rating (Gross MWe): 968 X 0.9 = 871

6. Design Electrical Rating (Net MWe): 819

7. Maximum Dependable Capacity (Gross MWe): 824

8. Maximum Dependable Capacity (Net MWe): 776

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>121,968.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>3,991.4</u>	<u>50,511.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>61.6</u>	<u>1,947.8</u>
15. Hrs Generator On-line	<u>.0</u>	<u>3,988.9</u>	<u>49,588.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>10,064,153</u>	<u>120,551,853</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>3,454,503</u>	<u>40,322,724</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>3,261,050</u>	<u>37,765,313</u>
20. Unit Service Factor	<u>.0</u>	<u>78.0</u>	<u>40.7</u>
21. Unit Avail Factor	<u>.0</u>	<u>78.0</u>	<u>40.7</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>82.2</u>	<u>39.7*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>77.9</u>	<u>37.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.6</u>	<u>54.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>63.6</u>	<u>59,376.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 08/14/88

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
THREE MILE ISLAND 1



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
88-02	06/17/88	S	744.0	C	4			UNIT SHUTDOWN FOR REFUELING OUTAGE. OUTAGE COMMENCED 6/17/88. TOTAL NUMBER OF OUTAGE HOURS AS OF THIS REPORT PERIOD IS 1058.5.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
THREE MILE ISLAND 1 REMAINED SHUTDOWN IN JULY FOR SCHEDULED REFUELING OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....DAUPHIN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI SE OF  
HARRISBURG, PA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 5, 1974  
DATE ELEC ENER 1ST GENER...JUNE 19, 1974  
DATE COMMERCIAL OPERATE...SEPTEMBER 2, 1974  
CONDENSER COOLING METHOD... COOLING TOWERS  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GPU NUCLEAR CORP.  
CORPORATE ADDRESS.....P.O. BOX 480  
MIDDLETOWN, PENNSYLVANIA 17057

CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....R. CONTE  
LICENSING PROJ MANAGER.....R. HERNAN  
DOCKET NUMBER.....50-289  
LICENSE & DATE ISSUANCE...DPR-50, APRIL 19, 1974  
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*           THREE MILE ISLAND 1           \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-344                      O P E R A T I N G   S T A T U S

2. Reporting Period: 07/01/88    Outage + On-line Hrs: 744.0

3. Utility Contact: F. J. UHMER (503) 556-3713 X495

4. Licensed Thermal Power (MWh):                      3411

5. Nameplate Rating (Gross MWe):                      1280 X 0.95 = 1216

6. Design Electrical Rating (Net MWe):                      1130

7. Maximum Dependable Capacity (Gross MWe):                      1153

8. Maximum Dependable Capacity (Net MWe):                      1095

9. If Changes Occur Above Since Last Report, Give Reasons:

MDC RATINGS DUE TO IMPROVED PLANT PERFORMANCE FROM UPGRADE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>104,447.0</u>
13. Hours Reactor Critical	<u>521.5</u>	<u>2,866.1</u>	<u>65,211.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,875.4</u>
15. Hrs Generator On-Line	<u>479.8</u>	<u>2,822.0</u>	<u>63,493.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,237.0</u>
17. Gross Therm Ener (MWH)	<u>1,534,782</u>	<u>9,490,210</u>	<u>202,835,574</u>
18. Gross Elec Ener (MWH)	<u>509,875</u>	<u>3,202,338</u>	<u>66,090,409</u>
19. Net Elec Ener (MWH)	<u>479,921</u>	<u>3,052,667</u>	<u>62,541,944</u>
20. Unit Service Factor	<u>64.5</u>	<u>55.2</u>	<u>60.8</u>
21. Unit Avail Factor	<u>64.5</u>	<u>55.2</u>	<u>63.9</u>
22. Unit Cap Factor (MDC Net)	<u>58.9</u>	<u>54.4</u>	<u>54.7</u>
23. Unit Cap Factor (DER Net)	<u>57.1</u>	<u>52.7</u>	<u>53.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.4</u>	<u>13.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>129.1</u>	<u>9,932.6</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \*                      TROJAN                      \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TROJAN



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* TROJAN \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
88-02	04/13/88	S	264.2	C	4			REFUELING OUTAGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
TROJAN COMPLETED SCHEDULED REFUELING IN JULY AND RETURNED TO POWER.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* TROJAN \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....OREGON  
  
COUNTY.....COLUMBIA  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...32 MI N OF  
PORTLAND, ORE  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...DECEMBER 15, 1975  
  
DATE ELEC ENER 1ST GENER...DECEMBER 23, 1975  
  
DATE COMMERCIAL OPERATE...MAY 20, 1976  
  
CONDENSER COOLING METHOD...COOLING TOWERS  
  
CONDENSER COOLING WATER...COOLING TOWER  
  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PORTLAND GENERAL ELECTRIC  
  
CORPORATE ADDRESS.....121 S.W. SALMON STREET  
PORTLAND, OREGON 97204  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
  
IE RESIDENT INSPECTOR.....R. BARR  
  
LICENSING PROJ MANAGER.....T. CHAN  
DUCKET NUMBER.....50-344  
  
LICENSE & DATE ISSUANCE...NPF-1, NOVEMBER 21, 1975  
  
PUBLIC DOCUMENT ROOM.....LIBRARY ASSOCIATION OF PORTLAND  
SOCIAL SCIENCES & SCIENCE DEPARTMENT  
801 SW 10TH AVENUE  
PORTLAND, OREGON 97207

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON APRIL 21 - MAY 20, 1988 (REPORT NO. 50-344/88-16) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE SECURITY PROGRAM. THIS INSPECTION INCLUDED ACTIVITIES RELATED TO PHYSICAL PROTECTION AND CONSISTED OF SELECTIVE EXAMINATIONS OF PROCEDURES AND RECORDS, INTERVIEWS WITH FACILITY AND CONTRACTOR PERSONNEL, AND OBSERVATIONS BY THE INSPECTORS.

RESULTS: OF THE AREAS INSPECTED, THREE VIOLATIONS RELATED TO SECURITY ISSUES WERE IDENTIFIED.

+ INSPECTION ON MAY 8 - JUNE 18, 1988 (REPORT NO. 50-344/88-24) AREAS INSPECTED: ROUTINE INSPECTION OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE (CONTAINMENT LOCAL LEAK RATE TESTING), EVENT FOLLOW-UP, AND OPEN ITEM FOLLOW-UP. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: ONE VIOLATION WAS IDENTIFIED FOR A FAILURE TO FOLLOW PROCEDURAL REQUIREMENTS FOR WORK HOUR LIMITATIONS. NO GENERAL CONCLUSIONS REGARDING THE STRENGTHS OR WEAKNESSES OF THE PROGRAM AREAS INSPECTED WERE IDENTIFIED DURING THIS INSPECTION PERIOD.

+ INSPECTION ON JUNE 6 - 17, 1988 (REPORT NO. 50-344/88-26) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF COMMERCIAL GRADE PROCUREMENT AND INSERVICE INSPECTION ACTIVITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: TWO VIOLATIONS WERE IDENTIFIED - USE OF AN UNAPPROVED PROCEDURE AND FAILURE TO PROVIDE PROCEDURES PRESCRIBING THE







THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-250 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 694-4432

4. Licensed Thermal Power (MHT): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>137,240.6</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,922.4</u>	<u>93,617.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>844.3</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,837.0</u>	<u>90,632.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>121.8</u>
17. Gross Therm Ener (MWH)	<u>1,625,539</u>	<u>8,146,710</u>	<u>187,950,975</u>
18. Gross Elec Ener (MWH)	<u>518,910</u>	<u>2,635,370</u>	<u>60,233,371</u>
19. Net Elec Ener (MWH)	<u>494,465</u>	<u>2,492,452</u>	<u>56,971,238</u>
20. Unit Service Factor	<u>100.0</u>	<u>75.1</u>	<u>66.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>75.1</u>	<u>66.1</u>
22. Unit Cap Factor (MDC Net)	<u>99.8</u>	<u>73.2</u>	<u>63.7*</u>
23. Unit Cap Factor (DER Net)	<u>95.9</u>	<u>70.4</u>	<u>59.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>24.7</u>	<u>10.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,258.1</u>	<u>10,505.4</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* TURKEY POINT 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
TURKEY POINT 3



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* TURKEY POINT 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
07	07/29/88	S	0.0	B	5		HA	VALVOP	UNIT NO.3 HAS REDUCED TO APPROXIMATELY 40% POWER TO PERFORM TURBINE VALVE TESTING.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
TURKEY POINT 3 INCURRED ONE LOAD REDUCTION DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* TURKEY POINT 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....DADE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI S OF  
MIAMI, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 20, 1972  
DATE ELEC ENER 1ST GENER...NOVEMBER 2, 1972  
DATE COMMERCIAL OPERATE....DECEMBER 14, 1972  
CONDENSER COOLING METHOD...CLOSED CANAL  
CONDENSER COOLING WATER...CLOSED CYCLE CANAL  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100  
MIAMI, FLORIDA 33174  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM S/S SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. BUTCHER  
LICENSING PROJ MANAGER.....G. EDISON  
DOCKET NUMBER.....50-250  
LICENSE & DATE ISSUANCE...DPR-31, JULY 19, 1972  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY  
FLORIDA INTERNATIONAL UNIVERSITY  
MIAMI, FLORIDA 33199

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION APRIL 25 - JUNE 3 (88-11): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FACILITY MODIFICATIONS, PLANT PHYSICAL SECURITY AND PLANTS EVENTS. ONE VIOLATION OF TS 6.8.1 WAS IDENTIFIED. FAILURE TO FOLLOW PROCEDURE, IN THAT DIESEL FUEL OIL TANK SUCTION VALVE 003 WAS FOUND LOCKED CLOSED WHEN REQUIRED TO BE LOCKED OPEN. ONE UNRESOLVED ITEM WAS IDENTIFIED, EVALUATE LICENSEE'S METHOD OF TESTING CHECK VALVES TO MEET THE REQUIREMENTS OF ASME BOILER AND PRESSURE VESSEL CODE, SECTION XI. ONE INSPECTOR FOLLOWUP ITEM WAS IDENTIFIED, RESOLUTION OF THE DIFFERENCES IN DOCUMENTATION ASSOCIATED WITH THE INTAKE COOLING WATER GAUGE ASSEMBLY'S MATERIALS.

INSPECTION JUNE 6-10 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF EMERGENCY PREPAREDNESS, AND INCLUDED REVIEW OF THE FOLLOWING PROGRAMMATIC ELEMENTS: (1) EMERGENCY PLAN AND IMPLEMENTING PROCEDURES; (2) EMERGENCY FACILITIES, EQUIPMENT, INSTRUMENTATION, AND SUPPLIES; (3) ORGANIZATION AND MANAGEMENT CONTROL; (4) TRAINING; AND (5) INDEPENDENT REVIEWS/AUDITS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE FINDINGS OF THIS INSPECTION APPEARED TO INDICATE THAT THE LICENSEE WAS PREPARED TO RESPOND EFFECTIVELY TO A RADIOLOGICAL EMERGENCY AT THE TURKEY POINT PLANT.

INSPECTION JUNE 3-25 (88-14): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCES, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FACILITY MODIFICATIONS AND PLANT EVENTS. ONE VIOLATION OF 10 CFR 50, APPENDIX B, WAS IDENTIFIED. FAILURE TO CONTROL MATERIALS USED IN SAFETY RELATED SYSTEMS, IN THAT SOME GAUGE FITTINGS USED IN THE INTAKE COOLING WATER (ICW) SYSTEM WERE CARBON STEEL IN LIEU OF STAINLESS STEEL, (250, 251/88-14-01). TWO INSPECTOR FOLLOWUP ITEMS (IFIS) WERE IDENTIFIED: EVALUATE THE

INSPECTION SUMMARY

ROOT CAUSE OF USING A 20 AMPERE BREAKER INSTEAD OF THE REQUIRED 30 AMPERE BREAKER IN THE ALTERNATE POWER SUPPLY TO THE ROD POSITION INDICATOR (RPI) SYSTEM (IFI 250, 251/88-14-02); AND EVALUATE THE BASIS FOR SELECTING MAXIMUM STROKE TIMES FOR THE POWER OPERATED RELIEF VALVES (PORVS), (IFI 250,251/88-14-03).

INSPECTION JUNE 27 - JULY 1 (88-16): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF SECURITY PLAN AND PROCEDURES; RECORDS AND REPORTS; LOCKS, KEYS, AND COMBINATIONS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS, DETECTION AIDS - VITAL AREAS; TRAINING AND QUALIFICATION; SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION. IN THE AREAS INSPECTED ONE VIOLATION WAS IDENTIFIED: FAILURE TO SUBMIT A PLAN CHANGE IN A TIMELY FASHION.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

SELECT SAFETY SYSTEM OPERABILITY REVIEW IN PROGRESS.

FACILITY ITEMS (PLANS AND PROCEDURES):

PROCEDURE UPGRADE PROGRAM (PUP) IN PROGRESS.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JULY 25, 1988 +

INSPECTION REPORT NO: 50-250/88-18 +

Report Period JUL 1988

REPORTS FROM LICENSEE

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
X TURKEY POINT 3 X  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

=====

NUMBER	DATE OF EVENT	DATE OF R <sup>C</sup> PORT	SUBJECT
88-011	05/29/88	06/30/88	MISPOSITIONED DIESEL OIL TRANSFER VALVE DUE TO PERSONNEL ERROR RESULTS IN POTENTIAL LOSS OF LONG TERM FUEL SUPPLY TO EMERGENCY DIESEL GENERATOR
88-012	06/14/88	07/18/88	VERIFICATION OF FIRE DETECTION OPERABILITY NOT PERFORMED AS REQUIRED BY T.S. 3.14 DUE TO WEAKNESSES IN ADMINISTRATIVE CONTROLS OF PENETRATION SEAL SURVEILLANCE TEST

=====

THIS PAGE INTENTIONALLY LEFT BLANK



1. Docket: 59-251 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: N. H. GRANT (305) 694-4432

4. Licensed Thermal Power (MWT): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE


10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>130,968.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,989.9</u>	<u>89,176.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>166.6</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,935.5</u>	<u>86,148.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>31.2</u>
17. Gross Therm Ener (MWH)	<u>1,613,332</u>	<u>8,448,854</u>	<u>181,913,477</u>
18. Gross Elec Ener (MWH)	<u>516,005</u>	<u>2,758,110</u>	<u>58,057,934</u>
19. Net Elec Ener (MWH)	<u>471,765</u>	<u>2,616,173</u>	<u>54,938,004</u>
20. Unit Service Factor	<u>100.0</u>	<u>77.0</u>	<u>65.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>77.0</u>	<u>65.8</u>
22. Unit Cap Factor (MDC Net)	<u>99.2</u>	<u>76.9</u>	<u>64.3*</u>
23. Unit Cap Factor (DER Net)	<u>95.4</u>	<u>73.9</u>	<u>60.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>23.0</u>	<u>11.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,174.5</u>	<u>10,711.4</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>REFUELING - 9/17/88 - 105 DAY DURATION.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* TURKEY POINT 4 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
TURKEY POINT 4



JULY 1988

\* Item calculated with a Weighted Average

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 59-251 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 694-4432

4. Licensed Thermal Power (MWh): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE


10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>130,968.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,989.9</u>	<u>89,176.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>166.6</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,935.3</u>	<u>86,148.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>31.2</u>
17. Gross Therm Ener (MWH)	<u>1,613,332</u>	<u>8,448,854</u>	<u>181,913,477</u>
18. Gross Elec Ener (MWH)	<u>516,005</u>	<u>2,758,110</u>	<u>58,057,934</u>
19. Net Elec Ener (MWH)	<u>491,703</u>	<u>2,616,173</u>	<u>54,938,004</u>
20. Unit Service Factor	<u>100.0</u>	<u>77.0</u>	<u>65.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>77.0</u>	<u>65.8</u>
22. Unit Cap Factor (MDC Net)	<u>99.2</u>	<u>76.9</u>	<u>64.3*</u>
23. Unit Cap Factor (DER Net)	<u>95.4</u>	<u>73.9</u>	<u>60.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>23.0</u>	<u>11.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,174.5</u>	<u>10,755.4</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>REFUELING - 9/17/88 - 105 DAY DURATION.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* TURKEY POINT 4 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT  
TURKEY POINT 4



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* TURKEY POINT 4 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
09	07/30/88	S	0.0	B	5		HA	VALVOP	UNIT NO.4 WAS REDUCED TO APPROXIMATELY 50% POWER TO PERFORM TURBINE VALVE TESTING. WHILE THE UNIT WAS AT REDUCED POWER, A LEAK IN THE 4A CONDENSER WATERBOX WAS REPAIRED.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 TURKEY POINT 4 INCURRED ONE LOAD REDUCTION DURING JULY TO PERFORM TURBINE VALVE TESTING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulator Restriction	4-Continued	Data Entry Sheet
	E-Operator Training & License Examination	5-Reduced Load	Licensee Event Report
		9-Other	(LER) File (NUREG-0161)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
X TURKEY POINT 4 X  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXX

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....DADE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI S OF  
MIAMI, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 11, 1973  
DATE ELEC ENER 1ST GENER...JUNE 21, 1973  
DATE COMMERCIAL OPERATE...SEPTEMBER 7, 1973  
CONDENSER COOLING METHOD...CLOSED CANAL  
CONDENSER COOLING WATER...CLOSED CYCLE CANAL  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100  
MIAMI, FLORIDA 33174  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. BUTCHER  
LICENSING PROJ MANAGER....G. EDISON  
DOCKET NUMBER.....50-251  
LICENSE & DATE ISSUANCE...DPR-41, APRIL 10, 1973  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY  
FLORIDA INTERNATIONAL UNIVERSITY  
MIAMI, FLORIDA 33199

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION APRIL 25 - JUNE 3 (88-11): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FACILITY MODIFICATIONS, PLANT PHYSICAL SECURITY AND PLANTS EVENTS. ONE VIOLATION OF TS 6.8.1 WAS IDENTIFIED. FAILURE TO FOLLOW PROCEDURE, IN THAT DIESEL FUEL OIL TANK SUCTION VALVE 003 WAS FOUND LOCKED CLOSED WHEN REQUIRED TO BE LOCKED OPEN. ONE UNRESOLVED ITEM WAS IDENTIFIED, EVALUATE LICENSEE'S METHOD OF TESTING CHECK VALVES TO MEET THE REQUIREMENTS OF ASME BOILER AND PRESSURE VESSEL CODE, SECTION XI. ONE INSPECTOR FOLLOWUP ITEM WAS IDENTIFIED, RESOLUTION OF THE DIFFERENCES IN DOCUMENTATION ASSOCIATED WITH THE INTAKE COOLING WATER GAUGE ASSEMBLY'S MATERIALS.

INSPECTION JUNE 6-10 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF EMERGENCY PREPAREDNESS, AND INCLUDED REVIEW OF THE FOLLOWING PROGRAMMATIC ELEMENTS: (1) EMERGENCY PLAN AND IMPLEMENTING PROCEDURES; (2) EMERGENCY FACILITIES, EQUIPMENT, INSTRUMENTATION, AND SUPPLIES; (3) ORGANIZATION AND MANAGEMENT CONTROL; (4) TRAINING; AND (5) INDEPENDENT REVIEWS/AUDITS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. THE FINDINGS OF THIS INSPECTION APPEARED TO INDICATE THAT THE LICENSEE WAS PREPARED TO RESPOND EFFECTIVELY TO A RADIOLOGICAL EMERGENCY AT THE TURKEY POINT PLANT.

INSPECTION JUNE 3-25 (88-14): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTIONS, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCES, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FACILITY MODIFICATIONS AND PLANT EVENTS. ONE VIOLATION OF 10 CFR 50, APPENDIX B, WAS IDENTIFIED. FAILURE TO CONTROL MATERIALS USED IN SAFETY RELATED SYSTEMS, IN THAT SOME GAUGE FITTINGS USED IN THE INTAKE COOLING WATER (ICW) SYSTEM WERE CARBON STEEL IN LIEU OF STAINLESS STEEL, (250, 251/88-14-01). TWO INSPECTOR FOLLOWUP ITEMS (IFIS) WERE IDENTIFIED: EVALUATE THE

INSPECTION SUMMARY

ROOT CAUSE OF USING A 20 AMPERE BREAKER INSTEAD OF THE REQUIRED 30 AMPERE BREAKER IN THE ALTERNATE POWER SUPPLY TO THE ROD POSITION INDICATOR (RPI) SYSTEM (IFI 250, 251/88-14-02); AND EVALUATE THE BASIS FOR SELECTING MAXIMUM STROKE TIMES FOR THE POWER OPERATED RELIEF VALVES (PORVS), (IFI 250,251/88-14-03).

INSPECTION JUNE 27 - JULY 1 (08-16): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF SECURITY PLAN AND PROCEDURES; RECORDS AND REPORTS; LOCKS, KEYS, AND COMBINATIONS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS, DETECTION AIDS - VITAL AREAS; TRAINING AND QUALIFICATION; SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION. IN THE AREAS INSPECTED ONE VIOLATION WAS IDENTIFIED: FAILURE TO SUBMIT A PLAN CHANGE IN A TIMELY FASHION.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

SELECT SAFETY SYSTEM OPERABILITY REVIEW IN PROGRESS.

FACILITY ITEMS (PLANS AND PROCEDURES):

PROCEDURE UPGRADE PROGRAM (PUP) IN PROGRESS.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JULY 25, 1988 +

INSPECTION REPORT NO: 50-250/88-18 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

1. Docket: 50-271 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: G. A. HALLIN (802) 257-7711 X2272

4. Licensed Thermal Power (Mwt): 1593

5. Nameplate Rating (Gross MWe): 626 X 0.9 = 563

6. Design Electrical Rating (Net MWe): 514

7. Maximum Dependable Capacity (Gross MWe): 535

8. Maximum Dependable Capacity (Net MWe): 504

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>139,033.8</u>
13. Hours Reactor Critical	<u>607.3</u>	<u>4,808.5</u>	<u>109,653.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>567.0</u>	<u>4,764.3</u>	<u>107,054.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>804,084</u>	<u>7,407,500</u>	<u>157,148,198</u>
18. Gross Elec Ener (MWH)	<u>257,669</u>	<u>2,476,105</u>	<u>52,316,049</u>
19. Net Elec Ener (MWH)	<u>240,794</u>	<u>2,361,251</u>	<u>49,656,338</u>
20. Unit Service Factor	<u>76.2</u>	<u>93.2</u>	<u>77.0</u>
21. Unit Avail Factor	<u>76.2</u>	<u>93.2</u>	<u>77.0</u>
22. Unit Cap Factor (MDC Net)	<u>64.2</u>	<u>91.7</u>	<u>70.9</u>
23. Unit Cap Factor (DER Net)	<u>63.0</u>	<u>89.9</u>	<u>59.5</u>
24. Unit Forced Outage Rate	<u>19.2</u>	<u>3.3</u>	<u>6.2</u>
25. Forced Outage Hours	<u>134.3</u>	<u>162.0</u>	<u>5,755.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* VERMONT YANKEE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

VERMONT YANKEE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* VERMONT YANKEE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-07	06/24/88	S	41.5	B	4		ZZ	ZZZZZZ	SCHEDULED SHUTDOWN TO PERFORM PREVENTATIVE AND CORRECTIVE MAINTENANCE.
88-08	07/02/88	S	1.2	B	1				TURBINE OVERSPEED TESTING.
88-09	07/03/88	F	134.3	B	1		HH	HTEXCH	STEAM LEAK ON THE 3B LOW PRESSURE HEATER EXTRACTION LINE CAUSED BY INTERNAL EROSION. THE EXTRACTION LINE WAS REINFORCED WITH A WELDED SLEEVE.
88-10	07/12/88	S	0.0	H	5		RB	CONROD	ROD PATTERN ADJUSTMENT.
88-11	07/15/88	F	0.0	B	5		CH	XXXXXX	LEAK ON THE 2A FEEDWATER HEATER SIGHT GLASS GASKET AREA. THE SIGHT GLASS WAS REMOVED AND THE LINE WAS CAPPED.
88-12	07/31/88	S	0.0	B	5		RB	ZZZZZZ	POWER REDUCTION FOR TURBINE BYPASS VALVE TESTING.
88-13	07/31/88	S	0.0	H	5		RB	CONROD	POWER REDUCTION FOR A CONTROL ROD PATTERN ADJUSTMENT.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 VERMONT YANKEE ENTERED MONTH SHUTDOWN AND WHILE RETURNING TO POWER INCURRED TWO OUTAGES AND FOUR LOAD REDUCTIONS FOR REASONS STATED ABOVE.

Type	Reason	Method	System * Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LCR) File (NUREG-0161)



FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....VERMONT  
COUNTY.....WINDHAM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
BRATTLEBORO, VT  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MARCH 24, 1972  
DATE ELEC ENER 1ST GENek...SEPTEMBER 20, 1972  
DATE COMMERCIAL OP<sup>S</sup>RATE...NOVEMBER 30, 1972  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...CONNECTICUT RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VERMONT YANKEE NUCLEAR POWER  
CORPORATE ADDRESS.....RD #5, BOX 169, FERRY ROAD  
BRATTLEBORO, VERMONT 05301  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....W. RAYMOND  
LICENSING PROJ M<sup>A</sup>NAGER.....V. ROONEY  
DOCKET NUMBER.....50-271  
LICENSE & DATE ISSUANCE...DPR-28, FEBRUARY 28, 1973  
PUBLIC DOCUMENT ROOM.....BROOKS MEMORIAL LIBRARY  
224 MAIN STREET  
BRATTLEBORO, VERMONT 05301

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1978

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   VERMONT YANKEE 1                   \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-424 OPERATING STATUS
2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: S. C. DILWORTH (404) 724-8114 X3870
4. Licensed Thermal Power (MWh): 3411
5. Nameplate Rating (Gross MWe): 1157
6. Design Electrical Rating (Net MWe): 1101
7. Maximum Dependable Capacity (Gross MWe): 1133
8. Maximum Dependable Capacity (Net MWe): 1079
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>10,248.0</u>
13. Hours Reactor Critical	<u>700.7</u>	<u>5,389.6</u>	<u>8,457.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>654.7</u>	<u>4,277.3</u>	<u>8,197.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWh)	<u>2,220,349</u>	<u>14,312,912</u>	<u>26,973,850</u>
18. Gross Elec Ener (MWh)	<u>724,510</u>	<u>4,753,730</u>	<u>8,937,620</u>
19. Net Elec Ener (MWh)	<u>684,870</u>	<u>4,489,460</u>	<u>8,410,980</u>
20. Unit Service Factor	<u>88.0</u>	<u>83.7</u>	<u>80.0</u>
21. Unit Avail Factor	<u>88.0</u>	<u>83.7</u>	<u>80.0</u>
22. Unit Cap Factor (MDC Net)	<u>85.3</u>	<u>81.4</u>	<u>76.1</u>
23. Unit Cap Factor (DER Net)	<u>83.6</u>	<u>79.8</u>	<u>74.5</u>
24. Unit Forced Outage Rate	<u>12.0</u>	<u>15.5</u>	<u>17.4</u>
25. Forced Outage Hours	<u>89.3</u>	<u>786.6</u>	<u>1,730.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - OCTOBER 7, 1988 - 44 DAY DURATION.
27. If Currently Shutdown Estimated Startup Date: 08/02/88

XX  
 X VOGTLE 1 X  
 XXX

AVERAGE DAILY POWER LEVEL (MWe) PLOT

VOGTLE 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* VOGTLE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-9	07/14/88	F	57.2	A	3		TL	XPT	FAILURE OF A POTENTIAL TRANSFORMER (2A) CAUSED A PRIMARY SIDE FUSE TO FAIL. THE RESULTANT TRANSIENT CAUSED THE GENEREX VOLTAGE REGULATOR TO INCREASE GENERATOR VOLTAGE TO THE VOLTS/HERTZ RELAY TRIP SETPOINT, WHICH SUBSEQUENTLY INITIATED A GENERATOR/TURBINE/REACTOR TRIP.
88-10	07/30/88	F	28.3	A	3		FK	INS	FAILURE OF A CONNECTION POINT ON DISCONNECT SWITCH NO.161716 FOR PHASE "A". THE CONNECTION WAS BELIEVED TO BE LOOSE, CAUSING ARCING AND A HOT SPOT, WHICH RESULTED IN THE FAILURE OF THE INSULATOR CREATING A DIRECT PATH TO GROUND. THE CABLE MELTED AT THE DISCONNECT SWITCH AND SEPARATED.
88-11	07/31/88	F	3.8	H	3		AA	ECBD	REACTOR TRIP WAS DUE TO A NEGATIVE FLUX RATE. A THUNDERSTORM WAS IN PROGRESS AND LIGHTNING STRUCK THE CONTAINMENT BUILDING. A POWER SURGE TO THE CONTROL ROD DRIVE SYSTEM RESULTED IN A LOSS OF POWER AND ALL RODS INSERTED.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 VOGTLE 1 INCURRED THREE FORCED OUTAGES DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* VOGTLE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....GEORGIA  
COUNTY.....BURKE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...23 MI SSE OF  
AUGUSTA, GA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 9, 1987  
DATE ELEC ENER 1ST GENER...MARCH 27, 1987  
DATE COMMERCIAL OPERATE....JUNE 1, 1987  
CONDENSER COOLING METHOD...CCCT  
CONDENSER COOLING WATER....SAVANNAH RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GEORGIA POWER  
CORPORATE ADDRESS.....333 PIEDMONT AVENUE, N.E., P. O. BOX 4545  
ATLANTA, GEORGIA 30302  
CONTRACTOR  
ARCHITECT/ENGINEER.....SOUTHERN SERVICES & BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....GEORGIA POWER CO.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE .....II  
IE RESIDENT INSPECTOR.....J. ROGGE  
LICENSING PROJ MANAGER.....J. HOPKINS  
DOCKET NUMBER.....50-424  
LICENSE & DATE ISSUANCE....NPF-68, MARCH 16, 1987  
PUBLIC DOCUMENT ROOM.....BURKE COUNTY LIBRARY  
412 FOURTH ST.  
WAYNESBORO, GA. 30830

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 16-19 (88-22): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF ELECTRICAL CABLES, RACEWAYS, TERMINATIONS INSTALLATION RECORDS, INSTRUMENTATION TRANSMITTERS, ASSOCIATED SENSING LINES, AS-BUILD DRAWINGS, AND AN EMPLOYEE CONCERN. NO MAJOR WEAKNESSES WERE FOUND IN THE AREAS OF INSTRUMENTATION INSTALLATION AND TESTING. THE PROCEDURES APPEARED ADEQUATE TO INSTALL AND TEST INSTRUMENT LOOPS AS EVIDENCED BY THE DOCUMENTATION AND QA RECORDS. ALL RECORDS REVIEWED WERE COMPLETE AND ADEQUATELY REVIEWED. A PROBLEM IDENTIFIED IN THE EMPLOYEE CONCERN PORTION OF THIS REPORT WAS SUBSEQUENTLY RESOLVED AS NOTED. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 6-10 (88-23): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF CONTAINMENT PENETRATIONS, HOUSEKEEPING AND MATERIALS CONTROL ACTIONS ON PREVIOUS INSPECTION FINDINGS AND LICENSEE IDENTIFIED ITEMS (50.55(E)). IN THE AREAS INSPECTED, VIOLATIONS OR DEVIATIONS WERE NOT IDENTIFIED. PROGRAMMATIC STRENGTHS WERE DEMONSTRATED IN MANAGEMENT INVOLVEMENT IN ASSURING QUALITY AND RESPONSIVENESS TO NRC INITIATIVES. HOWEVER, THE POTENTIAL FOR WEAKNESS RELATIVE TO RESOLUTION OF TECHNICAL ISSUES IS INDICATED BY NEW UNRESOLVED ITEM (UNR) 425/88-33-01, AN ADDITIONAL EXAMPLE OF CONDITIONS WHICH CAUSED VIOLATION 424/88-05-02 AND NEED FOR ADDITIONAL TECHNICAL RESPONSE TO UNR 424/88-03-03, 425/88-02-03.

INSPECTION JUNE 7 - JULY 1 (88-25): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED RESIDENT INSPECTION IN THE FOLLOWING AREAS: PLANT OPERATIONS, RADIOLOGICAL CONTROLS, MAINTENANCE, SURVEILLANCE, FIRE PROTECTION, SECURITY, AND QUALITY PROGRAMS AND ADMINISTRATIVE CONTROLS AFFECTING QUALITY. TWO LICENSEE IDENTIFIED VIOLATIONS WERE IDENTIFIED IN WHICH NO NOTICE WAS ISSUED: FAILURE TO PERFORM STROKE TIME TESTING ON FOUR CONTAINMENT ISOLATION VALVES, AND FAILURE TO PERFORM SURVEILLANCE ON CONTAINMENT RADIATION MONITORS.



1. Docket: 50-397 OPERATING STATUS
2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0
3. Utility Contact: LEONARD HUTCHISON (509) 377-2486
4. Licensed Thermal Power (MWT): 3323
5. Nameplate Rating (Gross MWe): 1201
6. Design Electrical Rating (Net MWe): 1100
7. Maximum Dependable Capacity (Gross MWe): 1140
8. Maximum Dependable Capacity (Net MWe): 1095
9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>31,831.2</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,167.7</u>	<u>23,074.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>340.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,010.9</u>	<u>22,152.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>381.7</u>
17. Gross Therm Ener (MWH)	<u>2,419,200</u>	<u>9,294,934</u>	<u>59,677,701</u>
18. Gross Elec Ener (MWH)	<u>792,440</u>	<u>3,084,600</u>	<u>19,901,740</u>
19. Net Elec Ener (MWH)	<u>764,764</u>	<u>2,976,623</u>	<u>19,144,575</u>
20. Unit Service Factor	<u>100.0</u>	<u>58.9</u>	<u>69.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>58.9</u>	<u>70.8</u>
22. Unit Cap Factor (MDC Net)	<u>93.9</u>	<u>53.2</u>	<u>54.9</u>
23. Unit Cap Factor (DER Net)	<u>93.4</u>	<u>52.9</u>	<u>54.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>19.1</u>	<u>9.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>709.2</u>	<u>2,354.3</u>

26. Shutdowns Sched Over Next 6 Mo.ths (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* WASHINGTON NUCLEAR 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WASHINGTON NUCLEAR 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* WASHINGTON NUCLEAR 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
WNP-2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR SIGNIFICANT POWER REDUCTIONS.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)



FACILITY DESCRIPTION

LOCATION  
STATE.....WASHINGTON  
COUNTY.....BENTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI. NW OF  
RICHLAND, WASH.  
TYPE OF REACTOR.....DWR  
DATE INITIAL CRITICALITY...JANUARY 19, 1984  
DATE ELEC ENER 1ST GENER...MAY 27, 1984  
DATE COMMERCIAL OPERATE...DECEMBER 13, 1984  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER...MECHANICAL TOWERS  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
CORPORATE ADDRESS.....P.O. BOX 968  
RICHLAND, WASHINGTON 99352  
CONTRACTOR  
ARCHITECT/ENGINEER.....BURNS & ROE  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....C. BOSTED  
LICENSING PROJ MANAGER....R. SAMWORTH  
DOCKET NUMBER.....50-397  
LICENSE & DATE ISSUANCE...NPF-21, APRIL 13, 1984  
PUBLIC DOCUMENT ROOM.....RICHLAND PUBLIC LIBRARY  
SWIFT AND NORTHGATE STREETS  
RICHLAND, WA 99352

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JUNE 1, 1987 - MAY 31, 1988 (REPORT NO. 50-397/88-08) YEARLY SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE. SENT TO HEADQUARTERS JULY 20, 1988.

+ INSPECTION ON JUNE 6 - 13, 1988 (REPORT NO. 50-397/88-16) AREAS INSPECTED: ANNOUNCED, SPECIAL SAFETY INSPECTION CONDUCTED TO FOLLOW-UP ON FIRE PROTECTION PROGRAM COMPLIANCE AND PREVIOUSLY IDENTIFIED OPEN ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: OF THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

+ INSPECTION ON JUNE 16 - JULY 15, 1988 (REPORT NO. 50-397/88-17) AREAS INSPECTED: UNANNOUNCED, ROUTINE PHYSICAL SECURITY PLAN AND IMPLEMENTING PROCEDURES; SECURITY ORGANIZATION; SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; PHYSICAL BARRIERS; SECURITY SYSTEM POWER SUPPLY; COMPENSATORY MEASURES; ACCESS CONTROL; DETECTION AIDS; ALARM STATIONS; COMMUNICATIONS; PERSONNEL TRAINING AND QUALIFICATIONS PLAN; SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW AND FOLLOW-UP. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: IN THE AREAS INSPECTED, THE LICENSEE'S PROGRAMS APPEARED ADEQUATE TO ACCOMPLISH THEIR SECURITY OBJECTIVES. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED EXCEPT AS FOLLOWS: DETECTION AIDS - PROTECTED AREAS: LACK OF REQUIRED SENSITIVITY ON CERTAIN ZONES OF PERIMETER INTRUSION DETECTION SYSTEM. RECORDS AND REPORTS: FAILURE TO LOG A SECURITY EVENT AS REQUIRED BY 10 CFR 73.71 (C)

INSPECTION SUMMARY

- + INSPECTION ON MAY 20 - JULY 7, 1988 (REPORT NO. 50-397/88-21) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON AUGUST 22 - SEPTEMBER 2, 1988 (REPORT NO. 50-397/88-24) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 19 -22, 1988 (REPORT NO. 50-397/88-25) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 18 - 22, 1988 (REPORT NO. 50-397/88-26) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JULY 8 - AUGUST 9, 1988 (REPORT NO. 50-397/88-27) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS-

+ NONE

FACILITY ITEMS (PLANS AND PROCEDURES)

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT CONTINUED FULL POWER OPERATION DURING JULY.

LAST IE SITE INSPECTION DATE: 08/22 - 09/02/88+

INSPECTION REPORT NO: 50-397/88-24+

Report Period JUL 1988

R E P O R T S F R O M L I C E N S E E

\*\*\*\*\*  
\* WASHINGTON NUCLEAR 2 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-11-10	05-01-88	05-31-88	RPS LOW LEVEL ACTUATION DURING SHUTDOWN COOLING SYSTEM LINEUP
88-12-10	05-06-88	06-06-88	PART-21 ON POTENTIAL UNMONITORED EFFLUENT RELEASE PATH DUE TO DESIGN ERROR BA A/E
88-12-10	05-06-88	06-06-88	POTENTIAL UNMONITORED RELEASED PATH DUE TO DESIGN ERROR BY ARCHITECT-ENGINEER
88-13-10	05-12-88	06-13-88	NSSSS ISOLATIONS CAUSED BY EPA BREAKER-UV TRIPS DUE TO LIGHTNING STRIKES
88-14-10	05-12-88	06-28-88	VOLUNTARY REPORT OF RWCH SYSTEM RES SPILL DUE TO VALVES BEING OPEN-CAUSE UNKNOWN
88-15-10	05-15-88	06-14-88	NSSSS ISOLATIONS CAUSED BY INADVERTENT DE-ENERGIZATION OF RPS BUS 'A' POWER SUPPLY
88-16-10	05-11-88	06-17-88	RPS ACTUATION CAUSED BY APRM MONITOR HIGH POWER TRIP ALTHOUGH NOT REAL
88-17-10	06-15-88	06-20-88	PART-21 ON LIMITORQUE MTR OPERATOR SAFETY HAZARD CAUSED BY TORQUE SWITCH FAILURES
88-18-10	05-22-88	06-21-88	DIESEL GEN #2 INOP DUE TO CONTROL POWER TRANSFER SWITCH IN MID-POSITION
88-19-10	05-20-88	06-27-88	CONTROL ROOM EMERGENCY FILTRATION SYS ACTUATION DURING TESTING
88-20-10	05-27-88	06-24-88	SURVEILLANCE FOR RPV LEVEL SWITCH CHANNEL FUNCTIONAL TEST AND CALIBRATION PERFORMED LATE
88-21-10	05-30-88	06-29-88	NSSSS GROUP 6 ISOLATION DUE TO DE-ENERGIZATION OF THE TRIP LOGIC CIRCUIT

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-382 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: GEORGE MILLER (504) 467-8211

4. Licensed Thermal Power (Mbt): 3390

5. Nameplate Rating (Gross MWe): 1153

6. Design Electrical Rating (Net MWe): 1104

7. Maximum Dependable Capacity (Gross MWe): 1120

8. Maximum Dependable Capacity (Net MWe): 1075

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>25,008.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,604.9</u>	<u>19,709.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>737.5</u>	<u>3,467.8</u>	<u>19,282.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,304,929</u>	<u>11,100,953</u>	<u>62,561,925</u>
18. Gross Elec Ener (MWH)	<u>759,570</u>	<u>3,721,010</u>	<u>21,101,820</u>
19. Net Elec Ener (MWH)	<u>721,871</u>	<u>3,527,028</u>	<u>20,059,486</u>
20. Unit Service Factor	<u>99.1</u>	<u>67.8</u>	<u>77.1</u>
21. Unit Avail Factor	<u>99.1</u>	<u>67.8</u>	<u>77.1</u>
22. Unit Cap Factor (MDC Net)	<u>90.3</u>	<u>64.2</u>	<u>74.6</u>
23. Unit Cap Factor (DER Net)	<u>87.9</u>	<u>62.5</u>	<u>70.7</u>
24. Unit Forced Outage Rate	<u>.9</u>	<u>4.3</u>	<u>8.9</u>
25. Forced Outage Hours	<u>6.5</u>	<u>157.2</u>	<u>1,886.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Current Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
# WATERFORD 3 #  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WATERFORD 3



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* WATERFORD 3 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-07	07/22/88	F	0.0	H	5		SJ	P	UNIT LOAD REDUCTION DUE TO HIGH VIBRATION ON A TEAM GENERATOR FEED PUMP.
88--08	07/22/88	F	6.5	H	9		TA	V	TURBINE TRIP RESULTING FROM A FLUID LEAK IN THE HYDRAULIC CONTROL SYSTEM FOR THE TURBINE VALVES. NO REACTOR TRIP OCCURRED.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 WATERFORD 3 INCURRED ONE LOAD REDUCTION AND ONE FORCED OUTAGE DURING JULY AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NURCG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

FACILITY DESCRIPTION

LOCATION  
STATE.....LOUISIANA  
COUNTY.....ST CHARLES  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI W OF  
NEW ORLEANS, LA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 4, 1985  
DATE ELEC ENER 1ST GENER...MARCH 18, 1985  
DATE COMMERCIAL OPERATE...SEPTEMBER 24, 1985  
CONDENSE? COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....LOUISIANA POWER & LIGHT  
CORPORATE ADDRESS.....142 DELARONDE STREET  
NEW ORLEANS, LOUISIANA 70174  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....T. STAKER  
LICENSING PROJ MANAGER.....D. WIGGINTON  
DOCKET NUMBER.....50-382  
LICENSE & DATE ISSUANCE...NPF-38, MARCH 16, 1985  
PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN  
LOUISIANA COLLECTION  
EARL K. LONG LIBRARY  
UNIVERSITY OF NEW ORLEANS  
LAKEFRONT DRIVE  
NEW ORLEANS, LOUISIANA 70148

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1-JUNE 17, 1988 (88-13) ROUTINE, UNANNOUNCED INSPECTION CONSISTING OF MONTHLY MAINTENANCE OBSERVATION, VERIFICATION OF CONTAINMENT INTEGRITY, ONSITE FOLLOW-UP OF EVENTS, OPERATIONAL SAFETY VERIFICATION, MONTHLY SURVEILLANCE OBSERVATION, FOLLOW-UP OF PREVIOUSLY IDENTIFIED ITEMS, LICENSEE EVENT REPORT FOLLOWUP, CONTAINMENT INTEGRATED LEAK RATE TEST, REFUELING ACTIVITY OBSERVATIONS, STARTUP TESTING OBSERVATIONS, EMERGENCY DIESEL GENERATOR INSPECTION, AND PLANT STATUS. WITHIN THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED. A POTENTIAL VIOLATION INVOLVING TWO EXAMPLES OF FAILURE TO IMPLEMENT PROCEDURES WAS IDENTIFIED. ALSO A POTENTIAL DEVIATION INVOLVING TWO EXAMPLES OF FAILURE TO IMPLEMENT COMMITMENTS MADE IN THE LICENSEE'S RESPONSE TO GENERIC LETTER 87-12.

INSPECTION CONDUCTED MAY 23-27, 1988 (88-14) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S TESTING AND MAINTENANCE PROGRAM, FACILITY LIGHTING, SECURITY TRAINING AND QUALIFICATION PLAN, AND THE SAFEGUARDS INFORMATION PROGRAM. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ONE OPEN ITEM IS IDENTIFIED IN PARAGRAPH 2 OF THIS REPORT.

INSPECTION CONDUCTED MAY 16-20, JUNE 6-9, 1988 (88-15) ROUTINE, UNANNOUNCED INSPECTION OF THE INSERVICE TESTING PROGRAM FOR PUMPS AND VALVES. SUBJECT ACTIVITIES REVIEWED IN THIS AREA OF THE INSPECTION INCLUDED TRACKING METHODOLOGY FOR INSERVICE TESTING: TEST PROCEDURES AND RESULTS, INSERVICE TESTING TREND REPORTS, QUALITY ASSURANCE AUDITS, WITNESSING OF INSERVICE TESTS, AND REVIEW OF POTENTIAL REPORTABLE EVENT. WITHIN THE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period JUL 1988

I N S P E C T I O N   S T A T U S   -   ( C O N T I N U E D )

\*\*\*\*\*  
\*                    W A T E R F O R D   3                    \*  
\*\*\*\*\*

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PURSUANT TO NRC BULLETINE 88-05, THE LICENSEE HAS FOUND 248 WJM FLANGES INSTALLED SAFETY SYSTEMS. OVER HALF HAVE BEEN TESTED AS OF THIS UPDATE. THREE FROM ESSENTIAL CHILLED WATER AND ALL SAFETY VALVES WERE BELOW THE REQUIRED HARDNESS AND TENSILE STRENGTH, HOWEVER ANALYSES SHOW THEM NOT TO BE AN OPERATIONAL PROBLEM.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

PLANT AT FULL POWER

LAST IE SITE INSPECTION DATE: JUNE 17, 1988

INSPECTION REPORT NO: 50-382/88-13

R E P O R T S   F R O M   L I C E N S E E

.....

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

.....



1. Docket: 50-482 OPERATING STATUS  
 2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0  
 3. Utility Contact: M. WILLIAMS (316) 364-8831  
 4. Licensed Thermal Power (Mwt): 3411  
 5. Nameplate Rating (Gross MWe): 1250  
 6. Design Electrical Rating (Net MWe): 1170  
 7. Maximum Dependable Capacity (Gross MWe): 1170  
 8. Maximum Dependable Capacity (Net MWe): 1128  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>25,510.7</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,507.6</u>	<u>19,974.1</u>
14. Rx Reserve Shtdan Hrs	<u>.0</u>	<u>89.5</u>	<u>339.8</u>
15. Hrs Generator On-line	<u>744.0</u>	<u>4,354.4</u>	<u>19,557.5</u>
16. Unit Reserve Shtdan Hrs	<u>.0</u>	<u>.0</u>	<u>19.0</u>
17. Gross Therm Ener (MWH)	<u>2,531,412</u>	<u>19,669,829</u>	<u>64,096,213</u>
18. Gross Elec Ener (MWH)	<u>871,220</u>	<u>5,114,679</u>	<u>22,303,570</u>
19. Net Elec Ener (MWH)	<u>836,590</u>	<u>4,894,835</u>	<u>21,307,143</u>
20. Unit Service Factor	<u>100.0</u>	<u>85.2</u>	<u>76.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>85.2</u>	<u>76.7</u>
22. Unit Cap Factor (MDC Net)	<u>99.7</u>	<u>84.9</u>	<u>74.0</u>
23. Unit Cap Factor (DER Net)	<u>96.1</u>	<u>81.9</u>	<u>71.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>12.8</u>	<u>7.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>640.7</u>	<u>1,517.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - SEPTEMBER 29, 1988 - 65 DAY DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* WOLF CREEK 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WOLF CREEK 1



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

XX  
\* WOLF CREEK 1 \*  
XX

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

XXXXXXXXXXXX      WOLF CREEK OPERATED ROUTINELY DURING JULY WITH NO OUTAGES  
\* SUMMARY \*      OR SIGNIFICANT LOAD REDUCTIONS.  
XXXXXXXXXXXX

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	G-Oper Error	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

\*\*\*\*\*  
\* WOLF CREEK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....KANSAS  
COUNTY.....COFFEY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3.5 MI NE OF  
BURLINGTON, KAN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 22, 1985  
DATE ELEC ENER 1ST GENER...JUNE 12, 1985  
DATE COMMERCIAL OPERATE...SEPTEMBER 3, 1985  
CONDENSER COOLING METHOD...COOLING LAKE  
CONDENSER COOLING WATER...COOLING LAKE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....KANSAS GAS & ELECTRIC  
CORPORATE ADDRESS.....P.O. BOX 208  
WICHITA, KANSAS 67201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....J. CUMMINS  
LICENSING PROJ MANAGER.....P. OCONNOR  
DOCKET NUMBER.....50-482  
LICENSE & DATE ISSUANCE...NPF-42, JUNE 4, 1985  
PUBLIC DOCUMENT.....WILLIAM ALLAN WHITE LIBRARY  
GOVERNMENT DOCUMENTS DIVISION  
EMPORIA STATE UNIVERSITY  
1200 COMMERCIAL STREET  
EMPORIA, KANSAS 66801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 15 - JUN 30, 1988 (88-19) ROUTINE, UNANNOUNCED INSPECTION INCLUDING PLANT STATUS, ALLEGATION FOLLOW-UP 10 CFR PART 21 REPORT FOLLOWUP, OPERATIONAL SAFETY VERIFICATION, MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, ONSITE EVENT FOLLOWUP, STARTUP TESTING AFTER REFUELING, RADIOLOGICAL PROTECTION, AND PHYSICAL SECURITY VERIFICATION. WITHIN THE TEN AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED AND ONE UNRESOLVED ITEM IS IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:



1. Docket: 50-029 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line hrs: 744.0

3. Utility Contact: S. WHIPPLE (617) 872-8100

4. Licensed Thermal Power (MWh): 600

5. Nameplate Rating (Gross MWe): 185 X 1.0 = 185

6. Design Electrical Rating (Net MWe): 175

7. Maximum Dependable Capacity (Gross MWe): 180

8. Maximum Dependable Capacity (Net MWe): 167

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,171.0</u>	<u>242,876.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,008.7</u>	<u>196,121.6</u>
14. Rx Reserve Shutdown Hrs	<u>0</u>	<u>0</u>	<u>0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,947.6</u>	<u>191,029.0</u>
16. Unit Reserve Shutdown Hrs	<u>0</u>	<u>0</u>	<u>0</u>
17. Gross Therm Ener (MWh)	<u>443,419</u>	<u>2,812,669</u>	<u>104,425,719</u>
18. Gross Elec Ener (MWh)	<u>130,511</u>	<u>842,152</u>	<u>51,633,077</u>
19. Net Elec Ener (MWh)	<u>122,067</u>	<u>793,342</u>	<u>29,507,886</u>
20. Unit Service Factor	<u>101.3</u>	<u>96.8</u>	<u>78.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>96.8</u>	<u>78.7</u>
22. Unit Cap Factor (MPC Net)	<u>98.2</u>	<u>92.9</u>	<u>74.7*</u>
23. Unit Cap Factor (DEP Net)	<u>93.3</u>	<u>88.7</u>	<u>71.2*</u>
24. Unit Forced Outage Rate	<u>0</u>	<u>2.5</u>	<u>5.0</u>
25. Forced Outage Hours	<u>0</u>	<u>124.9</u>	<u>9,028.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING, NOVEMBER 12, 1988 - 7 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
X YANKEE-ROWE 1 X  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

AVERAGE DAILY PERCENT LEVEL (MWe) PLOT

YANKEE-ROWE 1



JULY 1988

\* Item calculated with a Weighted Average

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

XX  
\* YANKEE-ROWE 1 \*  
XX

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

XXXXXXXXXXXX YANKEE ROWE OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR  
\* SUMMARY \* SIGNIFICANT POWER REDUCTIONS.  
XXXXXXXXXXXX

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

XX  
X Y7 IE 1 X  
XX

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....MASSACHUSETTS  
COUNTY.....FRANKLIN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI NE OF  
PITTSFIELD, MASS  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 19, 1960  
DATE ELEC ENER...NOVEMBER 10, 1960  
DATE COMMERCIAL...JULY 1, 1961  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...DEERFIELD RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....YANKEE ATOMIC ELECTRIC  
CORPORATE ADDRESS.....1671 WORCESTER RD.  
FRAMINGHAM, MASSACHUSETTS 01701

CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....H. EICHENHOLZ  
LICENSING PROJ MANAGER.....M. FAIRFIE  
DOCKET NUMBER.....50-029  
LICENSE & DATE ISSUANCE...DPR-3, DECEMBER 24, 1963  
PUBLIC DOCUMENT ROOM.....GREENFIELD COMMUNITY COLLEGE  
1 COLLEGE DRIVE  
GREENFIELD, MASSACHUSETTS 01301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period JUL 1988

INSPECTION STATUS - (CONTINUED)

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
\* YANKEE-RONE 1 \*  
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST 12 SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====



1. Docket: 50-295 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: GERRI AUSTIN (312) 746-2084

4. Licensed Thermal Power (MWT): 3250

5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098

6. Design Electrical Rating (Net MWe): 1040


7. Maximum Dependable Capacity (Gross MWe): 1085

8. Maximum Dependable Capacity (Net MWe): 1040

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

\*\*\*\*\*  
X ZION 1 X  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

ZION 1



	MONTH	YEAR	CUMUL. IVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>127,847.0</u>
13. Hours Reactor Critical	<u>635.4</u>	<u>3,279.3</u>	<u>89,364.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,621.8</u>
15. Hrs Generator On-Line	<u>595.6</u>	<u>3,166.2</u>	<u>86,706.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,601,879</u>	<u>9,278,292</u>	<u>250,504,619</u>
18. Gross Elec Ener (MWH)	<u>529,511</u>	<u>3,129,313</u>	<u>80,344,922</u>
19. Net Elec Ener (MWH)	<u>502,187</u>	<u>2,977,549</u>	<u>76,349,942</u>
20. Unit Service Factor	<u>80.1</u>	<u>61.9</u>	<u>67.8</u>
21. Unit Avail Factor	<u>80.1</u>	<u>61.9</u>	<u>67.8</u>
22. Unit Cap Factor (MDC Net)	<u>64.9</u>	<u>56.0</u>	<u>57.4</u>
23. Unit Cap Factor (DER Net)	<u>64.9</u>	<u>56.0</u>	<u>57.4</u>
24. Unit Forced Outage Rate	<u>19.9</u>	<u>4.8</u>	<u>12.6</u>
25. Forced Outage Hours	<u>148.4</u>	<u>160.4</u>	<u>11,828.6</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* ZION 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	07/13/88	F	61.0	A	3				REACTOR TRIP DUE TO LOW STEAM GENERATOR LEVEL WITH FEED FLOW/STEAM FLOW MISMATCH, CAUSED BY A SQUARE ROOT EXTRACTOR IN THE FEEDFLOW CHANNEL CIRCUITRY.
4	07/23/88	F	87.4	H	3				REACTOR TRIP AT TIME OF MANUAL TURBINE TRIP DUE TO REACTOR POWER INCREASING ABOVE 10% DUE TO FEED WATER TRANSIENT.

\*\*\*\*\* ZION 1 INCURRED TWO FORCED OUTAGES IN JULY FOR REASONS STATED  
 \* SUMMARY \* ABOVE.  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ZION 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....LAKE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI N OF  
CHICAGO, ILL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 19, 1973  
DATE ELEC ENER 1ST GENER...JUNE 28, 1973  
DATE COMMERCIAL OPERATE....DECEMBER 31, 1973  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....M. HOLZMER  
LICENSING PROJ MANAGER.....J. NORRIS  
DOCKET NUMBER.....50-295  
LICENSE & DATE ISSUANCE...DPR-39, OCTOBER 19, 1973  
PUBLIC DOCUMENT ROOM.....WAUKEGAN PUBLIC LIBRARY  
128 N. COUNTY STREET  
WAUKEGAN, ILLINOIS 60085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 13-16 (88014; 88015): SECURITY ORGANIZATION; RECORDS AND REPORTS; PHYSICAL BARRIERS-PROTECTED AREAS; LIGHTING; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL-VEHICLES; DETECTION AIDS-PROTECTED AND VITAL AREAS; PROTECTION OF SAFEGUARDS INFORMATION. THE LICENSEE WAS DETERMINED TO BE IN COMPLIANCE WITH NRC REQUIREMENTS IN ALL TEN INSPECTED AREAS. ONE OPEN ITEM CONCERNING TIMELINESS OF WORK ORDERS FOR SECURITY LIGHTING WAS IDENTIFIED. THE INSPECTION RESULTS WERE INDICATIVE OF A WELL MANAGED AND VIGOROUSLY SUPPORTED SECURITY PROGRAM.

ENFORCEMENT SUMMARY

THE ZION STATION TECHNICAL SPECIFICATION PARAGRAPH 4.22.3 REQUIRES THAT THE INSTALLATION AND MAINTENANCE RECORDS FOR EACH SNUBBER SHALL BE REVIEWED TO VERIFY THAT THE INDICATED SERVICE LIFE WILL NOT BE EXCEEDED PRIOR TO THE NEXT SCHEDULED SNUBBER SERVICE LIFE REVIEW. CONTRARY TO THE ABOVE, APPROXIMATELY 140 SNUBBERS, RECONDITIONED IN THE SPRING OF 1982, WERE NOT IDENTIFIED AS NEEDING TO BE RECONDITIONED, REPLACED OR REEVALUATED IN ORDER TO EXTEND THE SERVICE LIFE BEYOND THE INDICATED SEVEN YEARS.

(8801 4)

10 CFR 50, APPENDIX B, CRITERION III, AS IMPLEMENTED BY CECO TOPICAL REPORT CE-1-A, "QUALITY ASSURANCE PROGRAM FOR NUCLEAR GENERATING STATIONS," AND CECO CORPORATE QUALITY ASSURANCE MANUAL, NUCLEAR GENERATING STATIONS, "QUALITY REQUIREMENTS," REQUIRES



1. Docket: 50-304 OPERATING STATUS

2. Reporting Period: 07/01/88 Outage + On-line Hrs: 744.0

3. Utility Contact: GERRI AUSTIN (312) 746-2084

4. Licensed Thermal Power (Mwt): 3250

5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098

6. Design Electrical Rating (Net MWe): 1040

7. Maximum Dependable Capacity (Gross MWe): 1085

8. Maximum Dependable Capacity (Net MWe): 1040

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,111.0</u>	<u>121,560.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,111.0</u>	<u>89,883.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>226.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,111.0</u>	<u>87,475.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,391,266</u>	<u>15,747,459</u>	<u>260,441,226</u>
18. Gross Elec Ener (MWH)	<u>797,222</u>	<u>5,297,009</u>	<u>82,639,142</u>
19. Net Elec Ener (MWH)	<u>763,000</u>	<u>5,076,929</u>	<u>78,702,749</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>72.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>72.0</u>
22. Unit Cap Factor (MDC Net)	<u>98.6</u>	<u>95.5</u>	<u>62.3</u>
23. Unit Cap Factor (DER Net)	<u>98.6</u>	<u>95.5</u>	<u>62.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>13.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>13,795.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - OCTOBER 20, 1988.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ZION 2



JULY 1988

Report Period JUL 1988

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ZION 2 OPERATED ROUTINELY IN JULY WITH NO OUTAGES OR SIGNIFICANT  
POWER REDUCTIONS.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period JUL 1988

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....LAKE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI N OF  
CHICAGO, ILL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 24, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1973  
DATE COMMERCIAL OPERATE...SEPTEMBER 17, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....M. HOLZMER  
LICENSING PROJ MANAGER.....J. NORRIS  
DOCKET NUMBER.....50-304  
LICENSE & DATE ISSUANCE...D-48, NOVEMBER 14, 1973  
PUBLIC DOCUMENT ROOM.....WAUKEGAN PUBLIC LIBRARY  
128 N. COUNTY STREET  
WAUKEGAN, ILLINOIS 60085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 13-16 (88014; 88015): SECURITY ORGANIZATION; RECORDS AND REPORTS; PHYSICAL BARRIERS-PROTECTED AREAS; LIGHTING; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL-VEHICLES; DETECTION AIDS-PROTECTED AND VITAL AREAS; PROTECTION OF SAFEGUARDS INFORMATION. THE LICENSEE WAS DETERMINED TO BE IN COMPLIANCE WITH NRC REQUIREMENTS IN ALL TEN INSPECTED AREAS. ONE OPEN ITEM CONCERNING TIMELINESS OF WORK ORDERS FOR SECURITY LIGHTING WAS IDENTIFIED. THE INSPECTION RESULTS WERE INDICATIVE OF A WELL MANAGED AND VIGOROUSLY SUPPORTED SECURITY PROGRAM.

ENFORCEMENT SUMMARY

THE ZION STATION TECHNICAL SPECIFICATION PARAGRAPH 4.22.3 REQUIRES THAT THE INSTALLATION AND MAINTENANCE RECORDS FOR EACH SNUBBER SHALL BE REVIEWED TO VERIFY THAT THE INDICATED SERVICE LIFE WILL NOT BE EXCEEDED PRIOR TO THE NEXT SCHEDULED SNUBBER SERVICE LIFE REVIEW. CONTRARY TO THE ABOVE, APPROXIMATELY 140 SNUBBERS, RECONDITIONED IN THE SPRING OF 1982, WERE NOT IDENTIFIED AS NEEDING TO BE RECONDITIONED, REPLACED OR REEVALUATED IN ORDER TO EXTEND THE SERVICE LIFE BEYOND THE INDICATED SEVEN YEARS.

(88014)

10 CFR 50, APPENDIX B, CRITERION III, AS IMPLEMENTED BY CECO TOPICAL REPORT CE-1-A, "QUALITY ASSURANCE PROGRAM FOR NUCLEAR GENERATING STATIONS," AND CECO CORPORATE QUALITY ASSURANCE MANUAL, NUCLEAR GENERATING STATIONS, "QUALITY REQUIREMENTS," REQUIRES





**SECTION 3**

**APPENDIX**

\*\*\*\*\*

\* PRESSURIZED \* STATUS OF SPENT FUEL STORAGE CAPABILITY

\* WATER \*

\* REACTORS \*

\*\*\*\*\*

FACILITY *****	(a)		NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	(b) WILL FILL PRESENT AUTH. CAPACITY *****
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****					
ARKANSAS 1	177	968	488	480		09-88	1997
ARKANSAS 2	177	988	289	699		02-88	1999
BEAVER VALLEY 1	157	833	284	549		12-87	1995
BEAVER VALLEY 2						N/S	
BRAIDWOOD 1	193	1050	0	1050		N/S	
BRAIDWOOD 2	193	1050	0	1050			
BYRON 1	193	1050	0	1050		N/S	1995
BYRON 2	193	1050	0	1050		N/S	
CALLAWAY 1	193	1340	180	1160		03-89	2005
CALVERT CLIFFS 1	217	1830(c)	1138(c)	692(c)		04-88	1991
CALVERT CLIFFS 2	217					04-89	1991
CATAWBA 1	193	1418	132	1286		12-88	2011
CATAWBA 2	193	1418	0	1418		12-87	2013
COOK 1	193	2050(c)	866(c)	1184(c)		N/S	1994
COOK 2	193					N/S	1994
CRYSTAL RIVER 3	177	1163	328	829		09-87	1997
DAVIS-BESSE 1	177	735	204	531		03-88	1993
DIABLO CANYON 1	193	1400	0	1400		03-88	1993
DIABLO CANYON 2	193	1400		1400		N/S	
FARLEY 1	157	1407	273	1134		03-88	1991
FARLEY 2	157	1407	240	1167		10-87	1994
FORT CALHOUN 1	133	729	593	336		09-88	1996
GINNA	121	1016	420	596		02-88	1993
HADDAM NECK	157	1168	653	515		07-87	1996
HARRIS 1	157		0			N/S	
INDIAN POINT 1(d)	0	288	160	128		N/S	
INDIAN POINT 2	193	980	460	520		10-87	1993
INDIAN POINT 3	193	840	292	548		N/S	1993
KEWAUNEE	121	990	376	614(m)		03-88	1993
MAINE YANKEE	217	1476	721	755		N/S	1987
MCGUIRE 1	193	1463	293	1170(n)		11-88	2010
MCGUIRE 2	193	1463	424	1039		05-88	2010
MILLSTONE 2	217	1277	512	765		01-88	1994
MILLSTONE 3	193	756	84	672		06-89	1976
NORTH ANNA 1	157	1737(c)	520(c)	1217		04-87	1993
NORTH ANNA 2	157					10-87	1993
OCONEE 1	177	1312(1)	874	438(1)(n)		02-89	1991
OCONEE 2	177					02-88	1991
OCONEE 3	177	875	513	362		07-88	1991
PALISADES	204	798	477	321		N/S	2002
PALO VERDE 1	241	1329	80	1249		10-87	2006
PALO VERDE 2	241	1329	0	1329		02-88	2006
PALO VERDE 3	241	1329	0	0		02-89	2007
POINT BFACH 1	121	1502(c)	875(c)	626(c)		04-88	1995
POINT BEACH 2	121					N/S	1995
PRAIRIE ISLAND 1	121	1586(c)	781(c)	805(c)(m)		N/S	1993
PRAIRIE ISLAND 2	121					01-88	1993

Report Period JUL 1988

\*\*\*\*\*

\* PRESSURIZED\* STATUS OF SPENT FUEL STORAGE CAPABILITY

\* WATER \*

\* REACTORS \*

\*\*\*\*\*

FACILITY *****	(a)		NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	(b)	
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****					WILL FILL AUTH. *****	PRESENT CAPACITY *****
RANCHO SECO 1	177	1080	316	764		03-89	2001	
ROBINSON 2	157	541	274	266(e)	379	N/S	1988(g)	
SALEM 1	193	1170	464	706		03-89	2001	
SALEM 2	193	1170	224	946		09-88	2003	
SAN ONOFRE 1	157	216	146	70		07-88	1988	
SAN ONOFRE 2	217	800	268	532		08-89	1997	
SAN ONOFRE 3	217	800	160	640		04-88	1997	
SEQUOYAH 1	193	1386	348	1033		N/S	1994	
SEQUOYAH 2	193					N/S	1994	
SOUTH TEXAS 1	0	0	0	0				
ST LUCIE 1	217	728	372	356		N/S	1993	
ST LUCIE 2	217	1076	152	924		N/S	1993	
SUMMER 1	157	1276	96	1180		N/S	2008	
SURRY 1	157	1044(c)	901(c)	143(c)		N/S	1987	
SURRY 2	157					N/S	1987	
THREE MILE ISLAND 1	177	752	284	468		07-88	1991	
THREE MILE ISLAND 2	177	442	0	442		N/S		
TROJAN	193	1408	425	983		04-88	1993	
TURKEY POINT 3	157	1404	445	959(m)		N/S	1993	
TURKEY POINT 4	157	1404	482	922		N/S	1993	
VOGTLE 1	0	0	0	0		N/S		
WATERFORD 3	217	1088	0	1088		N/S	1993	
WOLF CREEK 1	193	1340	0	1340		04-88		
YANKEE-ROWE 1	76	721	325	396		N/S	1993	
ZION 1	193	2112(c)	1148(c)	964(c)		02-88	1995	
ZION 2	193					10-88	1995	

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

-----  
N/S = Not Scheduled  
-----

***** * SEALING * STATUS OF SPENT FUEL STORAGE CAPABILITY * WATER * * REACTORS * *****							
FACILITY *****	(a) CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****	NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHD. DATE *****	(b) WILL FILL PRESENT AUTH. CAPACITY *****
	BIG ROCK POINT 1	84	441	212	229		04-88
BROWNS FERRY 1	764	3471	1288	2183		N/S	1993
BROWNS FERRY 2	764	3471	1161	237 (m)	1819	N/S	1993
BROWNS FERRY 3	764	3471	1004	2467 (m)		N/S	1993
BRUNSWICK 1	560	1803	160PWR+1016BWR	787		11-88	1990
BUNSWICK 2	560	9	144PWR+940BWR	899		01-88	1991
CLINTON 1	624	72	3	2672		12-89	2010
COOPER STATION	548	2366	790	1576		03-88	1996
DRESDEN 1 (d)	464	672	221	451		N/S	1990
DRESDEN 2	724	3537	1413	2124		N/S	1993
DRESDEN 3	724	3537	1271	2266		03-88	1993
DUANE ARNOLD	368	2050	824	1226		10-88	1998
FERMI 2						N/S	
FITZPATRICK	560	2244	1200	484		08-88	1992
GRAND GULF 1	800	1440	0	1440		11-87	1993
HATCH 1	560	6026	1580	4446		N/S	1999
HATCH 2	560			1325		03-88	1999
HOPE CREEK 1						02-88	
HUMBOLDT BAY (d)	172	487	251	236		N/S	
LA CROSSE (d)	72	440	261	179		N/S	1992
LASALLE 1	764	2162	191	1971		03-88	1988
LASALLE 2	764					N/S	1988
LIMERICK 1	764	2040	0	2040		N/S	1993
HILLSTONE 1	580	2184	1732	452		03-89	1987

XXXXXXXXXX

\* BOILING \* STATUS OF SPENT FUEL STORAGE CAPABILITY

\* WATER \*

\* REACTORS \*

XXXXXXXXXX

FACILITY *****	(a) CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****	NO. OF ASSEMBLIES STORED (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	(b) WILL FILL PRESENT AUTH. CAPACITY *****
	MONTICELLO	484	2237	822	1415		12-87
NINE MILE POINT 1	532	2776	1377	1399	1788	03-88	1996
NINE MILE POINT 2						N/S	
OYSTER CREEK 1	560	2600	1392	1208		N/S	1994
PEACH BOTTOM 2	764	3819	1462	2357		03-87	1995
PEACH BOTTOM 3	764	3819	1496	2323		03-87	1996
PERRY 1	0	7	0	0		N/S	
PILGRIM 1	580	2326	1320	1000		09-89	1990
QUAD CITIES 1	724	3657	1773	1884		06-89	2008
QUAD CITIES 2	724	3897	1311	2586		04-88	2008
RIVER BEND 1						09-87	
SUSQUEHANNA 1	764	2840	382	2458		N/S	1997
SUSQUEHANNA 2	764	2840	0	2840		03-88	1997
VERMONT YANKEE 1	368	2000	1296	704		N/S	1992
WASHINGTON NUCLEAR*	764	2658	272	2386		04-88	1995

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

-----  
N/S = Not Scheduled  
-----

*****				*****				*****			
	YEARS	1ST ELEC GENERATE	UNIT	YEARS	1ST ELEC GENERATE	UNIT	YEARS	1ST ELEC GENERATE	UNIT		
* LICENSED *	14.00	08/01/74	ARKANSAS 1	9.60	12/26/78	ARKANSAS 2	12.13	06/14/76	BEAVER VALLEY 1		
* OPERATING *	.96	08/17/87	BEAVER VALLEY 2	25.65	12/08/62	BIG ROCK POINT 1	1.06	07/12/87	BRAIDWOOD 1		
* ELECTRICAL *	.19	05/25/88	BRAIDWOOD 2	14.80	10/15/73	BROWNS FERRY 1	13.93	08/28/74	BROWNS FERRY 2		
* PRODUCING *	11.89	09/12/76	BROWNS FERRY 3	11.66	12/04/76	BRUNSWICK 1	13.26	04/29/75	BRUNSWICK 2		
* UNITS *	3.42	03/01/85	BYRON 1	1.48	02/06/87	BYRON 2	3.77	10/24/84	CALLAWAY 1		
*****	13.58	01/03/75	CALVERT CLIFFS 1	11.65	12/07/76	CALVERT CLIFFS 2	3.52	01/22/85	CATAWBA 1		
	2.21	05/18/86	CATAWBA 2	1.27	04/24/87	CLINTON 1	13.47	02/10/75	COOK 1		
	10.36	03/22/78	COOK 2	14.23	05/10/74	COOPER STATION	11.50	01/30/77	CRYSTAL RIVER 3		
	10.93	08/28/77	DAVIS-BESSE 1	3.72	11/11/84	DIABLO CANYON 1	2.78	10/20/85	DIABLO CANYON 2		
	18.30	04/13/70	DRESDEN 2	17.03	07/22/71	DRESDEN 3	14.20	05/19/74	DUANE ARNOLD		
	10.95	08/18/77	FARLEY 1	7.19	05/25/81	FARLEY 2	1.86	09/21/86	FERMI 2		
	13.50	02/01/75	FITZPATRICK	14.93	08/25/73	FORT CALHOUN 1	11.64	12/11/76	FORT ST VRAIN		
	18.66	12/02/69	GINNA	3.78	10/20/84	GRAND GULF 1	20.99	08/07/67	HADDAM NECK		
	1.53	01/19/87	HARRIS 1	13.72	11/11/74	HATCH 1	9.86	09/22/78	HATCH 2		
	2.00	08/01/86	HOPE CREEK 1	15.10	06/26/73	INDIAN POINT 2	12.26	04/27/76	INDIAN POINT 3		
	14.32	04/08/74	KEWAUNEE	5.91	09/04/82	LASALLE 1	4.28	04/20/84	LASALLE 2		
	3.30	04/13/85	LIMERICK 1	15.73	11/08/72	MAINE YANKEE	7.09	06/30/81	MCGUIRE 1		
	5.19	05/23/83	MCGUIRE 2	17.67	11/29/70	MILLSTONE 1	12.73	11/09/75	MILLSTONE 2		
	2.47	02/12/86	MILLSTONE 3	17.41	03/05/71	MONTICELLO	18.73	11/09/69	NINE MILE POINT 1		
	.98	08/08/87	NINE MILE POINT 2	10.29	04/17/78	NORTH ANNA 1	7.93	08/25/80	NORTH ANNA 2		
	15.24	05/06/73	OCONEE 1	14.66	12/05/73	OCONEE 2	13.92	09/01/74	OCONEE 3		
	18.86	09/23/69	OYSTER CREEK 1	16.59	12/31/71	PALISADES	3.14	06/10/85	PALO VERDE 1		
	2.20	05/20/86	PALO VERDE 2	.63	11/28/87	PALO VERDE 3	14.45	02/18/74	PEACH BOTTOM 2		
	13.92	09/01/74	PEACH BOTTOM 3	1.62	12/19/86	PERRY 1	16.04	07/15/72	PILGRIM 1		
	17.74	11/06/70	POINT BEACH 1	16.00	08/02/72	POINT BEACH 2	14.66	12/04/73	PRAIRIE ISLAND 1		
	13.61	12/21/74	PRAIRIE ISLAND 2	16.30	04/12/72	QUAD CITIES 1	16.19	05/23/72	QUAD CITIES 2		
	13.80	10/13/74	RANCHO SECO 1	2.66	12/03/85	RIVER BEND 1	17.85	09/26/70	ROBINSON 2		
	11.60	12/25/76	SALEM 1	7.16	06/03/81	SALEM 2	21.05	07/16/67	SAN ONOFRE 1		
	5.86	09/20/82	SAN ONOFRE 2	4.85	09/25/83	SAN ONOFRE 3	8.03	07/22/80	SEQUOYAH 1		
	6.61	12/23/81	SEQUOYAH 2	.34	03/30/88	SOUTH TEXAS 1	12.24	05/07/76	ST LUCIE 1		
	5.14	06/13/83	ST LUCIE 2	5.71	11/16/82	SUMMER 1	16.08	07/04/72	SURRY 1		
	15.39	03/10/73	SURRY 2	5.71	11/16/82	SUSQUEHANNA 1	4.08	07/03/84	SUSQUEHANNA 2		
	14.12	06/19/74	THREE MILE ISLAND 1	12.61	12/23/75	TROJAN	15.75	11/02/72	TURKEY POINT 3		
	15.11	06/21/73	TURKEY POINT 4	15.86	09/20/72	VERMONT YANKEE 1	1.35	03/27/87	VOGTLE 1		
	4.18	05/27/84	WASHINGTON NUCLEAR 2	3.37	03/18/85	WATERFORD 3	3.14	06/12/85	WOLF CREEK 1		
	27.72	11/10/60	YANKEE-ROWE 1	15.09	06/28/73	ZION 1	14.60	12/26/73	ZION 2		
TOTAL	1121.40	YRS									

*****					*****				
	YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT	YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT	
* PERMANENTLY *	3.80	08/14/64	06/01/68	BONUS	3.04	12/18/63	01/01/67	CVTR	
* OR *	18.54	04/15/60	10/31/78	DRESDEN 1	4.44	08/24/63	02/01/68	ELK RIVER	
* INDEFINITELY *	6.32	08/05/66	11/29/72	FERMI 1	1.26	05/29/63	09/01/64	HALLAM	
* SHUTDOWN *	13.21	04/18/63	07/02/76	HUMBOLDT BAY	12.12	09/16/62	10/31/74	INDIAN POINT 1	
* UNITS *	19.01	04/26/68	04/30/87	LA CROSSE	1.19	07/25/66	10/01/67	PATHFINDER	
*****	7.76	01/27/67	11/01/74	PEACH BOTTOM 1	2.16	11/04/63	01/01/66	PIQUA	
	.93	04/21/78	03/28/79	THREE MILE ISLAND 2					
TOTAL	93.78	YRS							

\*\*\*\*\*  
 \* RESEARCH \*  
 \* REACTORS \*  
 \*\*\*\*\*

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
ALABAMA	TUSKEGEE	TUSKEGEE INSTITUTE	AGN-201 #102	50-406	R-122	08-30-74	0.0001
ARIZONA	TUCSON	UNIVERSITY OF ARIZONA	TRIGA MARK I	50-113	R-52	12-05-58	100.0
CALIFORNIA	BERKELEY	UNIVERSITY OF CALIFORNIA, BERKELEY COLLEGE	TRIGA MK. III	50-224	R-101	08-10-66	1000.0
	CANOGA PARK	ROCKWELL INTERNATIONAL CORP.	L-85	50-375	R-188	01-05-72	0.003
	HAWTHORNE	NORTHROP CORP. LABORATORIES	TRIGA MARK F	50-187	R-90	03-04-63	1000.0
	IRVINE	UNIVERSITY OF CALIFORNIA, IRVINE	TRIGA MARK I	50-326	R-116	11-24-69	250.0
	LOS ANGELES	UNIVERSITY OF CALIFORNIA, L.A.	ARGONAUT	50-142	R-71	10-03-60	100.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK F	50-163	R-67	07-01-60	1500.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK I	50-089	R-38	05-03-58	250.0
	SAN JOSE	GENERAL ELECTRIC COMPANY	NTR	50-073	R-33	10-31-57	100.0
	SAN LUIS OBISPO	CALIFORNIA STATE POLYTECHNIC COLLEGE	AGN-201 #100	50-394	R-121	05-16-73	0.0001
	SAN RAMON	AEROTEST OPERATIONS, INC.	TRIGA (INDUS)	50-228	R-98	07-02-65	250.0
SANTA BARBARA	UNIVERSITY OF CALIFORNIA, SANTA BARBARA	L-77	50-433	R-124	12-03-74	0.01	
COLORADO	DENVER	U.S. GEOLOGICAL SURVEY DEPARTMENT	TRIGA MARK I	50-274	R-113	02-24-69	1000.0
DELAWARE	NEWARK	UNIVERSITY OF DELAWARE	AGN-201 #113	50-098	R-43	07-03-58	0.0001
DIST OF COLUMBIA	WASHINGTON	THE CATHOLIC UNIVERSITY OF AMERICA	AGN-201 #101	50-077	R-31	11-15-67	0.0001
FLORIDA	GAINESVILLE	UNIVERSITY OF FLORIDA	ARGONAUT	50-083	R-56	05-21-59	100.0
GEORGIA	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	HEAVY WATER	50-160	R-97	12-29-64	5000.0
IDAHO	POCATELLO	IDAHO STATE UNIVERSITY	AGN-201 #103	50-284	R-110	10-11-67	0.0001
ILLINOIS	URBANA	UNIVERSITY OF ILLINOIS	LOPRA	50-356	R-117	12-27-71	10.0
	URBANA	UNIVERSITY OF ILLINOIS	TRIGA	50-151	R-115	07-22-69	1500.0
	ZION	WESTINGHOUSE ELECTRIC CORP.	NTR	50-087	R-119	01-28-72	10.0
INDIANA	LAFAYETTE	PURDUE UNIVERSITY	LOCKHEED	50-182	R-87	08-16-62	10.0
IOWA	AMES	IOWA STATE UNIVERSITY	UTR-10	50-116	R-59	10-16-59	10.0
KANSAS	LAWRENCE	UNIVERSITY OF KANSAS	LOCKHEED	50-148	R-78	06-23-61	250.0
	MANHATTAN	KANSAS STATE UNIVERSITY	TRIGA	50-188	R-88	10-16-62	250.0
MARYLAND	BETHESDA	ARMED FORCES RADIOBIOLOGY RESEARCH INSTITUTE	TRIGA	50-170	R-84	06-26-62	1000.0
	COLLEGE PARK	UNIVERSITY OF MARYLAND	TRIGA	50-166	R-70	10-14-60	250.0
MASSACHUSETTS	CAMBRIDGE	MASSACHUSETTS INSTITUTE OF TECHNOLOGY	HWR REFLECTED	50-020	R-37	06-09-58	5000.0

\*\*\*\*\*  
 \* RESEARCH \*  
 \* REACTORS \*  
 \*\*\*\*\*

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
MASSACHUSETTS	LOWELL WORCESTER	UNIVERSITY OF LOWELL WORCESTER POLYTECHNIC INSTITUTE	GE	50-223	R-125	12-24-74	1000.0
			GE	50-134	R-61	12-16-59	10.0
MICHIGAN	ANN ARBOR EAST LANSING MIDLAND	UNIVERSITY OF MICHIGAN MICHIGAN STATE UNIVERSITY DOW CHEMICAL COMPANY	POOL	50-002	R-28	09-13-57	2000.0
			TRIGA MARK I	50-294	R-114	03-21-69	250.0
			TRIGA	50-264	R-108	07-03-67	100.0
MISSOURI	COLUMBIA ROLLA	UNIVERSITY OF MISSOURI, COLUMBIA UNIVERSITY OF MISSOURI	TANK	50-186	R-103	10-11-66	10000.0
			POOL	50-123	R-79	11-21-61	200.0
NEBRASKA	OMAHA	THE VETERANS ADMINISTRATION HOSPITAL	TRIGA	50-131	R-57	06-26-59	18.0
NEW MEXICO	ALBUQUERQUE	UNIVERSITY OF NEW MEXICO	AGN-201M #112	50-252	R-102	09-17-66	0.005
NEW YORK	BRONX BUFFALO ITHACA ITHACA NEW YORK TUXEDO	MANHATTAN COLLEGE - PYHSICS DEPT. STATE UNIVERSITY OF NEW YORK CORNELL UNIVERSITY CORNELL UNIVERSITY COLUMBIA UNIVERSITY IN THE CITY OF NEW YORK CINTICHEM INC.	TANK	50-199	R-94	03-24-64	0.0001
			PULSTAR	50-057	R-77	03-24-61	2000.0
			TRIGA MARK II	50-157	R-80	01-11-62	100.0
			ZPR	50-097	R-89	12-11-62	0.1
			TRIGA MARK II	50-208	R-128	04-14-77	250.0
			POOL	50-054	R-81	09-07-61	5000.0
NORTH CAROLINA	RALEIGH	NORTH CAROLINA STATE UNIVERSITY AT RALEIGH	PULSTAR	50-297	R-120	08-25-72	1000.0
OHIO	COLUMBUS	OHIO STATE UNIVERSITY	POOL	50-150	R-75	02-24-61	10.0
OKLAHOMA	NORMAN	THE UNIVERSITY OF OKLAHOMA	AGN-211 #102	50-112	R-53	12-29-58	0.015
OREGON	CORVALLIS PORTLAND	OREGON STATE UNIVERSITY REED COLLEGE	TRIGA MARK II	50-243	R-106	03-07-67	1000.0
			TRIGA MARK I	50-288	R-112	07-02-68	250.0
PENNSYLVANIA	UNIVERSITY PARK	PENNSYLVANIA STATE UNIVERSITY	TRIGA MK. III	50-005	R-2	07-08-55	1000.0
RHODE ISLAND	NARRAGANSETT	RHODE ISLAND NUCLEAR SCIENCE CENTER	GE POOL	50-193	R-95	07-21-64	2000.0
TENNESSEE	MEMPHIS	MEMPHIS STATE UNIVERSITY	AGN-201 #108	50-538	R-127	12-10-76	0.0001
TEXAS	AUSTIN COLLEGE STATION COLLEGE STATION	UNIVERSITY OF TEXAS TEXAS A&M UNIVERSITY TEXAS A&M UNIVERSITY	TRIGA MARK I	50-192	R-92	08-26-63	250.0
			AGN-201# #106	50-059	R-23	08-26-57	0.005
			TRIGA	50-128	R-83	12-07-61	1000.0
UTAH	PROVO SALT LAKE CITY	BRIGHAM YOUNG UNIVERSITY THE UNIVERSITY OF UTAH	L-77	50-262	R-109	09-07-67	0.01
			TRIGA MARK I	50-407	R-126	09-30-75	100.0



\*\*\*\*\*  
 \* RESEARCH \*  
 \* REACTORS \*  
 \*\*\*\*\*

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
UTAH	SALT LAKE CITY	UNIVERSITY OF UTAH	AGN-201M #107	50-072	R-25	09-12-57	0.005
VIRGINIA	CHARLOTTESVILLE	UNIVERSITY OF VIRGINIA	CAVALIER	50-396	R-123	09-24-74	0.1
		UNIVERSITY OF VIRGINIA	POOL	50-062	R-66	06-27-60	2000.0
		BABCOCK & WILCOX COMPANY	LPR	50-099	R-47	09-05-58	1000.0
WASHINGTON	PULLMAN	WASHINGTON STATE UNIVERSITY	TRIGA	50-027	R-76	03-06-61	1000.0
		UNIVERSITY OF WASHINGTON	ARGONAUT	50-139	R-73	03-31-61	100.0
WISCONSIN	MADISON	UNIVERSITY OF WISCONSIN	TRIGA	50-156	R-74	11-23-60	1000.0
***** * EXPERIMENTAL AND TEST REACTORS * *****							
CALIFORNIA	SAN JOSE	GENERAL ELECTRIC COMPANY	GETR	50-070	TR-1	01-07-59	50.0
DIST OF COLUMBIA	WASHINGTON	NATIONAL BUREAU OF STANDARDS	TEST	50-184	TR-5	06-30-70	10.0
***** * CRITICAL EXPERIMENT FACILITIES * *****							
NEW YORK	TROY	RENSSELAER POLYTECHNIC INSTITUTE		50-225	CX-22	07-03-64	0.0
WASHINGTON	RICHLAND	BATTELLE MEMORIAL INSTITUTE		50-360	CX-26	11-29-71	0.0

**BIBLIOGRAPHIC DATA SHEET**

NUREG-0020, Volume 12, No. 8

SEE INSTRUCTIONS ON THE REVERSE

2. TITLE AND SUBTITLE

Licensed Operating Reactors  
Status Summary Report

3. LEAVE BLANK

4. DATE REPORT COMPLETED

MONTH YEAR

September 1988

5. AUTHOR(S)

Ina Schwartz

6. DATE REPORT ISSUED

MONTH YEAR

September 1988

7. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (include Zip Code)

Policy and Program Management Staff  
Office of Administration and Resources Management  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8. PROJECT/TASK WORK UNIT NUMBER

9. PIN OR GRANT NUMBER

10. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (include Zip Code)

Policy and Program Management Staff  
Office of Administration and Resources Management  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

11a. TYPE OF REPORT

b. PERIOD COVERED (Inclusive dates)

July 1988

12. SUPPLEMENTARY NOTES

Status Summary Report

13. ABSTRACT (200 words or less)

The OPERATING UNITS STATUS REPORT - LICENSED OPERATING REACTORS provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Administration and Resources Management from the Headquarters staff of NRC's Office of Enforcement (OE), from NRC's Regional Offices, and from utilities. The three sections of the report are: monthly highlights and statistics for commercial operating units, and errata from previously reported data; a compilation of detailed information on each unit, provided by NRC's Regional Offices, OE Headquarters and the utilities; and an appendix for miscellaneous information such as spent fuel storage capability, reactor-years of experience and non-power reactors in the U. S. It is hoped the report is helpful to all agencies and individuals interested in maintaining an awareness of the U. S. energy situation as a whole.

14. DOCUMENT ANALYSIS - KEYWORDS/DESCRIPTORS

Licensed Operating Reactors  
Commercial Operating Units

15. AVAILABILITY STATEMENT

Unlimited

16. SECURITY CLASSIFICATION

(This page)  
Unclassified

(This report)  
Unclassified

17. NUMBER OF PAGES

18. PRICE

19. IDENTIFIERS/OPEN ENDED TERMS

DISTRIBUTION LIST - NRC

INTERNAL DISTRIBUTION

Office of the Commissioners	5
Atomic Safety and Licensing Appeal Panel	3
Advisory Committee on Reactor Safeguards	6
Office of Inspector and Auditor	1
Office of Policy Evaluation	1
Office of the General Counsel	1
Office of Public Affairs	21
Office of Congressional Affairs	3
Office of the Executive Director for Operations	7
Office of Administration	2
Office of the Executive Legal Director	2
Office of Analysis and Evaluation of Operational Data	2
Office of International Programs	3
Office of State Programs	1
Office of Information Resources Management	19
Office of Nuclear Material Safety and Safeguards	2
- Division of Fuel Cycle and Material Safety	3
- Division of Safeguards	2
Office of Nuclear Reactor Regulation	138
- Division of Engineering	
- Division of Safety Technology	
- Division of Licensing	
- Division of Systems Integration	
- Division of Human Factors Safety	
Office of Nuclear Regulatory Research	4
Office of Inspection and Enforcement	7
- Region I	11
- Region II	10
- Region III	10
- Region IV	10
- Region V	7
	<u>281</u>

EXTERNAL DISTRIBUTION

SPECIAL REQUESTS

Air Force	1
Congress	10
Department of Energy	32
Government Accounting Office	1
Environmental Protection Agency	1
Electric Power Research Institute	1
Argonne National Laboratory	3
Bureau of Mines	1
Department of Agriculture	1
Department of the Commerce	1
Department of the Interior	1
	<u>53</u>

OTHER

GPO Depository	440
GPO Stores	75
National Technical Information Service	25
Subscriptions (NTIS)	250
Colleges and Libraries (including Public Document Rooms)	128
Utilities and Other Requests	227
	<u>1145</u>

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300

120555139217 1 1AN1NU  
US NRC-OARM-ADM  
DIV FOIA & PUBLICATIONS SVCS  
RRES-PDR NUREG  
P-210  
WASHINGTON DC 20555

FIRST CLASS MAIL  
POSTAGE & FEES PAID  
USNRC  
PERMIT No. 7