

SEP 23 1988

Docket/License Nos.: 50-334/DPR-66  
50-412/NPF-73

Duquesne Light Company  
ATTN: Mr. J. D. Sieber  
Vice President - Nuclear Group  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Gentlemen:

Subject: Combined NRC Region I Inspection Report Nos. 50-334/88-23 and  
50-412/88-18

This refers to the routine resident safety inspection by Messrs. J. Beall and S. Pindale at the Beaver Valley Power Station in Shippingport, Pennsylvania. The reporting period covers the time from July 16 - August 31, 1988. The inspection consisted of document reviews, interviews and observation of activities. The findings were summarized and discussed with you and other members of your staff at the conclusion of the inspection.

Based on the results of this inspection, it appears that activities associated with adherence to administrative procedures regarding analyses of defects were not conducted in compliance with NRC requirements. Please respond to these matters in accordance with the enclosed Appendix A. Due to its potentially generic nature, you are also requested to respond to the concerns regarding use of aluminum cable in Class 1E equipment discussed in Section 9 of the enclosed report.

The responses directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Your cooperation with us is appreciated.

Sincerely,

ORIGINAL SIGNED BY  
JAMES T. WIGGINS

James T. Wiggins, Chief  
Reactor Projects Branch No. 3  
Division of Reactor Projects

Enclosures:

1. NRC Notice of Violation, Appendix A
2. NRC Region I Combined Inspection Report Nos. 50-334/88-23 and 50-412/88-18

OFFICIAL RECORD COPY CIR BV2 88-18 88-23 - 0001.0.0  
09/21/88

8810030186 880923  
PDR ADOCK 05000334  
Q PDC

11  
IEO1


SEP 23 1988

cc w/encls:


J. J. Carey, Executive Vice President, Operations  
J. O. Crockett, General Manager, Corporate Nuclear Services  
W. S. Lacey, General Manager, Nuclear Operations  
N. R. Tonet, Manager, Nuclear Engineering  
T. P. Noonan, Plant Manager  
C. E. Ewing, QA Manager  
K. D. Grada, Manager, Nuclear Safety  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania

bcc w/encls:

Region I Docket Room (with concurrences)  
Management Assistant, DRMA (w/o enclosures)  
J. Wiggins, DRP  
L. Tripp, DRP  
D. Limroth, DRP  
P. Wilson, DRP  
R. Bores, DRSS  
P. Tam, NRR

  
RI:DRP  
JBeall/mjd  
9/2/88

  
RI:DRP  
LTripp  
9/2/88

  
RI:DRP  
JWiggins  
9/23/88