

NOTICE OF VIOLATION

Detroit Edison Company

Docket No. 50-341

As a result of the inspection conducted on August 15 through September 9, 1988, and in accordance with 10 CFR Part 2, Appendix C - General Statement of Policy and Procedure for NRC Enforcement Actions (1988), the following violation was identified:


10 CFR 50, Appendix B, Criterion VI, requires that measures shall be established to control the issuance of documents and shall assure that documents, including changes, are reviewed and approved and used at the location where the activity is performed. The Fermi 2 Updated Safety Analysis Report, Chapter 17.2.6 requires that documents defining the performance of quality related activities are controlled to ensure that only current and correct information is used at the work location.

Contrary to the above, procedures established to control vendor equipment technical information were not adequate to ensure that only reviewed, approved, and current vendor technical information is used at the work location.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each violation: (1) the corrective actions that have been taken and the results achieved; (2) the corrective actions that will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

SEP 27 1988
Dated



J. J. Harrison, Chief
Engineering Branch

8810030215 880927
PDR ADOCK 05000341
G PNU