



Log # TXX-88701
File # 10110
907.1
Ref. # 10CFR50.55(e)

September 30, 1988

William G. Council
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
AUXILIARY FEEDWATER PUMP TURBINE CONTROL PANEL
SDAR: CP-88-25 (SUPPLEMENTAL REPORT)


Gentlemen:

On January 29, 1988, TU Electric notified you via our report logged TXX-88170 of a deficiency in the design of the Auxiliary Feedwater (AFW) Pump Turbine control panel which could impair the Auxiliary Feedwater System's ability to provide emergency feedwater to the Steam Generators. The last report was logged TXX-88519, dated June 30, 1988. The purpose of this supplemental report is to revise the corrective action implementation schedule.

The estimated completion date has been revised for the design modification required to automatically isolate the control panel components when the AFW turbine driven pump is required to auto start. The new completion date is December 19, 1988.

Very truly yours,

W. G. Council

By: 
John W. Beck
Vice President,
Nuclear Engineering

VPC/mlh

c-Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8810030237 880930
PDR ADOCK 05000445
S PDC