



Log # TXX-88703
File # 10110
903.11
Ref. # 10CFR50.55(e)

William G. Council
Executive Vice President

September 30, 1988

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
UNQUALIFIED TERMINAL BLOCKS
SDAR: CP-87-139 (SUPPLEMENTAL REPORT)


Gentlemen:

On January 5, 1988, TU Electric notified you via report logged TXX-88028 of a deficiency involving equipment qualification of terminal blocks inside and outside of containment. The last report was logged TXX-88286, dated March 11, 1988.

TXX-88286 indicated that the replacement of the Weidmuller terminal blocks would be complete by October 1, 1988, for Unit 1 and by fuel load for Unit 2. TU Electric is currently reevaluating the scope of the corrective actions and the schedule for implementation. The next report will be submitted no later than January 17, 1989.

Very truly yours,

W. G. Council

By: 
John W. Beck
Vice President,
Nuclear Engineering

VPC/gj

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8810030 282 880930
PDR ADUCK 05000445
S PDC

IE 27
110