



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 7, 1988

MEMORANDUM FOR: Victor Stello, Jr.  
Executive Director for Operations

FROM: Edward L. Jordan, Chairman  
Committee to Review Generic Requirements

SUBJECT: MINUTES OF CRGR MEETING NUMBER 145

The Committee to Review Generic Requirements (CRGR) met on Wednesday, August 24, 1988 from 1-5 p.m. A list of attendees for this meeting is attached (Enclosure 1). The following items were addressed at the meeting:


1. J. Zwolinski (NRR) and G. West (NRR) presented for CRGR review a proposed Policy Statement on the Professional Conduct of Licensed and Unlicensed Nuclear Power Plant Operators. The Committee recommended that the Policy Statement not be sent forward at this time. This matter is discussed in Enclosure 2.
2. A. Thadani (NRR) and W. Lyon (NRR) presented for CRGR review a proposed Generic Letter, "Loss of Decay Heat Removal," requesting that licensees implement certain short-term actions and longer-term program enhancements to reduce the risk from loss of decay heat removal during nonpower operations. The Committee recommended in favor of issuing the proposed letter, subject to several clarifications and modifications to be coordinated with the CRGR staff. This matter is discussed in Enclosure 3.
3. E. Rossi (NRR) and P. Gill (NRR) presented for CRGR review a proposed NRC Bulletin, "Nonconforming Electrical Equipment, Components, and Devices," requesting that licensees and applicants take actions to assure that installed molded case circuit breakers and motor controllers installed as replacements comply with plant design requirements or original manufacturers' specifications. The Committee recommended in favor of issuing the proposed bulletin, subject to minor clarifications and modifications to be coordinated with the CRGR staff. This matter is discussed in Enclosure 4.

In accordance with the EDO's July 18, 1983 directive concerning "Feedback and Closure of CRGR reviews," a written response is required from the cognizant office to report agreement or disagreement with the CRGR recommendations in these minutes. The response, which is required within five working days after receipt of these minutes, is to be forwarded to the CRGR Chairman and if there is disagreement with CRGR recommendations, to the EDO for decisionmaking.

8810030278 880907  
PDR ORG NRQCRGR  
MEETING145 PDC

*Handwritten:*  
ADM-7  
CRGR  
DFD3  
1/0

Questions concerning these meeting minutes should be referred to Jim Conran (492-9855).

Original Signed By: 

T. M. Novak

Edward L. Jordan, Chairman  
Committee to Review Generic  
Requirements


Enclosures:  
As stated

cc w/enclosures:  
Commission (5)  
SECY  
Office Directors  
Regional Administrators  
CRGR Members  
W. Parler  
G. Arlotto  
J. Roe  
J. Zwolinski  
W. Lyon  
A. Thadani  
E. Rossi  
C. Berlinger


Distribution: w/o enc.

Central File

PDK (NRC/CRGR)  
S. Treby  
W. Little  
M. Lesar  
B. Doolittle (w/enc.)  
CRGR CF (w/enc.)  
CRGR SF (w/enc.)  
M. Taylor (w/enc.)  
E. Jordan (w/enc.)  
J. Heltemes (w/enc.)  
J. Conran (w/enc.)  
C. Sakenas (w/enc.)

  
JC Conran:cg  
9/7/88

AEOD:DD  
CJ Heltemes  
9/ /88

  
C/CRGR:AEOD  
EL Jordan  
9/7/88