



Duquesne Light

Nuclear Group
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

June 1, 1988


U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 2
Docket No. 50-412, License No. NPF-73
Inservice Inspection Program (TAC 62873)

Gentlemen:

Enclosed is the 10 year plan for Inservice Inspection at BVPS-2. Since the program incorporates various features which will require relief from specific portions of the code, the supporting relief requests are enclosed as part of this submittal. In addition to the plan, a piping weld examination summary is also included for your information. This should fully satisfy paragraph 2.c(5) of the license.

Sincerely


J. D. Sieber
Vice President
Nuclear Group

Attachment

cc: Mr. J. Beall, Sr. Resident Inspector, w/attachment
Mr. W. T. Russell, NRC Region I Administrator, w/attachment
Mr. P. Tam, Project Manager, w/attachment

8806060216 880601
PDR AD0CK 05000412
Q DCD

A047
//

UNIT II
PIPING WELD EXAM SUMMARY

CATEGORY B-J

<u>ITEM NO.</u>	<u>TOTAL WELDS</u>	<u>REQUIRED EXAMS</u>	<u>SCHEDULED EXAMS</u>
B9.11	458	115	120
B9.21	850	223	227
B9.31	13	4	4
B9.32	48	12	13
B9.40	225	57	59

CATEGORY C-F-1

<u>SYSTEM</u>	<u>TOTAL WELDS</u>	<u>REQUIRED EXAMS</u>	<u>SCHEDULED EXAMS</u>
<u>ITEM NO C5.11</u>			
QSS	180	14	15
RHS	281	22	22
RSS	186	14	14
SIS	464	35	36
<u>ITEM NO C5.21</u>			
CHS	578	44	45
SIS	369	28	28
<u>ITEM NO C5.30</u>			
CHS	551	42	42
SIS	191	15	15
<u>ITEM NO C5.41</u>			
CHS	6	1	1
SIS	9	1	1
QSS	2	0	N/A
RHS	2	0	N/A

CATEGORY C-F-2

<u>ITEM NO C5.51</u>			
FWS	56	5	7
MSS	74	6	8
SVS	64	5	7
<u>ITEM NO C5.52</u>			
MSS	48	4	5
<u>ITEM NO C5.81</u>			
MSS	3	1	1