

September 28, 1988

DISTRIBUTION  
See attached sheet

Docket No. 50-395

LICENSEE: South Carolina Electric & Gas Company

FACILITY: V. C. Summer Nuclear Station

SUBJECT: SUMMARY OF MEETING WITH SOUTH CAROLINA ELECTRIC & GAS COMPANY

General

On September 21, 1988, the NRC staff met with the South Carolina Electric & Gas Company (SCE&G) and their consultant to discuss the proposed change to Technical Specification (TS) 3.6.1.6, "Containment Structural Integrity," for the V. C. Summer Station. The meeting was held at Headquarters in Rockville, Maryland. A list of those persons who attended the meeting is included as Enclosure 1.

Discussion

The purpose of the meeting was to discuss the NRC's concern on removal of the Technical Specification Tables 4.6-1a, 4.6-1b, and 4.6-2, without providing information on the tendons to be inspected in subsequent surveillances and the acceptable base value forces associated with those tendons. These tables address the tendons which were inspected during the first three surveillance periods. They depict the tendons inspected and the acceptable base value of tendon forces. The tendons which are to be inspected in subsequent inspections are detailed in an SCE&G document entitled, "Surveillance of Reactor Building Post Tensioning System," Revision 7, dated July 15, 1988. The acceptable tendon forces for each of the tendons to be inspected in subsequent surveillance is included in a figure in this document as are the normalizing factors. Discussion focused on the referencing of this report in the Bases of the Technical Specifications with allowance of a tendon to be changed if it was found impossible to test as a result of physical interference.

161

John J. Hayes, Jr., Project Manager  
Project Directorate II-1  
Division of Reactor Projects I/II

BB10030341 880928  
PDR ADOCK 05000395  
P PNU

Enclosures:  
As stated

cc w/enclosures:  
See next page

OFC	: PM: 10/21/88	: DRPR: D: PD31: DRPR	:	:	:	:	:
NAME	: JJHayes: clh	: EAD: sam	:	:	:	:	:
DATE	: 9/27/88	: 9/27/88	:	:	:	:	:

OFFICIAL RECORD COPY

DF01  
111

Mr. O. S. Bradham  
South Carolina Electric & Gas Company

Virgil C. Summer Nuclear Station

cc:

Mr. William A. Williams, Jr.  
Technical Assistant - Nuclear Operations  
Santee Cooper  
P.O. Box 764 (Mail Code 153)  
Columbia, South Carolina 29218

J. B. Knotts, Jr., Esq.  
Bishop, Cook, Purcell  
and Reynolds  
1400 L Street, N.W.  
Washington, D. C. 20005-3502

Resident Inspector/Summer NPS  
c/o U.S. Nuclear Regulatory Commission  
Route 1, Box 64  
Jenkinsville, South Carolina 29065

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission,  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

Chairman, Fairfield County Council  
P.O. Box 293  
Winnsboro, South Carolina 29180

Attorney General  
Box 11549  
Columbia, South Carolina 29211

Mr. Heyward G. Shealy, Chief  
Bureau of Radiological Health  
South Carolina Department of Health  
and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

South Carolina Electric & Gas Company  
Mr. A. R. Koon, Jr., Manager  
Nuclear Licensing  
Virgil C. Summer Nuclear Station  
P. O. Box 88  
Jenkinsville, South Carolina 29065

DISTRIBUTION FOR MEETING SUMMARY DATED: September 28, 1988

Facility: V. C. Summer Nuclear Station

**Docket File**

NRC PDR

Local PDR

PDII-1 Reading

E. Adensam

P. Anderson

J. Hayes

OGC

E. Jordan (MNBB 3302)

B. Grimes (9A2)

C. Tan (8D22)

H. Ashar (8D22)

ACRS (10)

B. Troskoski (17D19)

cc: Licensee/Applicant Service List

OF01  
1/1

ATTENDANCE

SEPTEMBER 21, 1988

NRC

J. Hayes, Jr.  
C. Tan  
H. Ashar

SCE&G

W. Higgins  
J. Todd

Gilbert/Commonwealth  
Associates

D. Krause