

Duke Power Company
P.O. Box 33198
Charlotte, N.C. 28242

Hal B. Tucker
Vice President
Nuclear Production
(704)373-4531



DUKE POWER

September 19, 1988

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Catawba Nuclear Station, Units 2
Docket No. 50-414
Technical Specification Amendment
Steam Generator Level Tap Relocation

This letter contains a proposed amendment to the Technical Specifications for Facility Operating License Nos. NPF-35 and NPF-52 for Catawba Units 1 and 2. The request involves the changing of setpoints for steam generator level trips due to the relocation of the level taps.

The modification to relocate the steam generator level taps is scheduled to be completed during the next refueling outage for Unit 2. The current starting date for the Unit 2 outage is March 3, 1989.

The attachment contains the proposed changes and a discussion of the justification and a No Significant Hazards Analysis. The analysis is included pursuant to 10CFR50.91 and it has been concluded the proposed amendment does not involve significant hazards considerations.

Please note this submittal is not complete in that Westinghouse and Duke have not finalized all calculations to support the attached analysis. However, preliminary studies indicate the attached analysis is correct. We will update this submittal in November. If questions concerning this Technical Specifications amendment arise, arrangements for a meeting at the NRC offices can be made.

This proposal involves one amendment request to Catawba's Technical Specifications. Accordingly, pursuant to 10 CFR 170.21 a check for \$150.00 is enclosed.

Pursuant to 10 CFR 50.91 (b) (1) the appropriate South Carolina Official is being provided a copy of this amendment request.

Very truly yours,

Hal B. Tucker

Attachments

PGL01.D1/lcs

8810030370 880919
PDR ADOCK 05000413
P PDC

A001
w/check \$150
#18029307

U. S. Nuclear Regulatory Commission
September 19, 1988
Page Two

cc: Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Heyward Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health &
Environmental Control
2600 Bull Street
Columbia, South Carolina 29201


American Nuclear Insurers
c/o Dottie Sherman, ANI Library
The Exchange, Suite 245
270 Farmington Avenue
Farmington, CT 06032

M & M Nuclear Consultants
1221 Avenue of the Americas
New York, New York 10020


INPO Records Center
Suite 1530
1100 Circle 75 Parkway
Atlanta, Georgia 30339

Mr. W. T. Orders
NRC Resident Inspector
Catawba Nuclear Station

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the Catawba Nuclear Station Technical Specifications, Appendix A to License No. NPF-35 and NPF-52; and that, all statements and matters set forth therein are true and correct to the best of his knowledge.


Hal B. Tucker, Vice President

Subscribed and sworn to before me this 19th day of September, 1988.


Notary Public

My Commission Expires:



