APPENDIX A

NOTICE OF VIOLATION

Wolf Creek Nuclear Operating Corporation Wolf Creek Generating Station Docket: 50-482 Operating License: NPF-42

During an NRC inspection conducted during the month of August, one violation of NRC requirements was identified. The violation involved a failure to complete a valve checklist. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1988), the violation is listed below.

Failure To Verify Valve Lineup

Technical Specification (TS) 6.8.1 requires, that, "Written procedures shall be established and maintained covering . . . a. The applicable procedures recommended in Appendix A of Regulatory Guide (RG) 1.33, Revision 2, February 1978." Appendix A of RG 1.33 states that, "Instructions for . . . filling, venting, draining . . . should be prepared as appropriate, for the following systems . . . 0. Auxiliary or Reactor Building Heating and Ventilation." Checklist (CKL) GL-121, Revision 8. "Auxiliary Building Heating, Ventilating, and Air Conditioning (HVAC) System Valve Lineup," has been established and implemented in accordance with the above TS.

Contrary to the above, during a review conducted on August 31, 1988, the NRC inspector found that Checklist (CKL) RL-121 had not been completed to indicate that three valves (RL-770, RL-121 had RL-121 had not been completed to their correct position.

This is a Severity Level IV violation, (Supplement I) (482/8822-01)

Pursuant to the provisions of 10 CFR 2.201, Wolf Creek Nuclear Operating Corporation is hereby required to submit to this Office, within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the reason for the violation if admitted, (2) the corrective steps which have been taken and the results achieved, (3) the corrective steps which will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington. Texas this 26 sh day of September 1988.