



South Carolina Electric & Gas Company
P.O. Box 764
Columbia, SC 29218
(803) 748-3513

Dan A. Nauman
Vice President
Nuclear Operations

March 17, 1986

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Virgil C. Summer Nuclear Station
Docket No. 50/395
Operating License No. NPF-12
Administrative Technical
Specification Changes

Dear Mr. Denton:

Enclosed are Attachments 1 and 2, administrative changes to the Virgil C. Summer Nuclear Station Technical Specifications. A discussion of each of these proposed changes follows.

As shown on Attachment 1, South Carolina Electric and Gas Company (SCE&G) requests that the wording for the review of individual overtime by the Director, Nuclear Plant Operations or his designee be clarified for applicability during extended shutdown periods. This request is in accordance with a letter from Elinor G. Adensam of your Staff to O. W. Dixon, Jr. dated June 27, 1985.

As shown on Attachment 2, item d. of the required Emergency Core Cooling System (ECCS) Subsystems during Mode 4 is clarified to reflect the actual ECCS alignment changes that would be required for ECCS operation in Mode 4. Technical Specification 3.5.3, "Emergency Core Cooling Systems," as currently written is not clear in its intent to allow the Residual Heat Removal (RHR) System to be aligned to the Reactor Coolant System (RCS) during Mode 4 and to utilize manual alignment to the Refueling Water Storage Tank (RWST) upon initiation of a Safety Injection signal. The preceding alignment, based upon Westinghouse Standard Technical Specifications, is consistent with Technical Specification 3.4.9.3, "Overpressure Protection Systems," which requires that both trains of RHR be aligned to the RCS during Mode 4.


A finding of no significant hazards is appropriate for these changes because the changes are clarifying and administrative in nature.

This request has been reviewed and approved by both the Plant Safety Review Committee and the Nuclear Safety Review Committee. A check in the amount of one hundred fifty dollars (\$150.00) is enclosed to initiate the processing of this request.

If you have any questions, please advise.

Very truly yours,

8603210210 860317
PDR ADDCK 05000395
P PDR


D. A. Nauman

c: (see page 2)

100 w/check
\$150.00
287539

Mr. Harold R. Denton
Page Two
March 17, 1986

MDB:DAN:tdh

Attachments

c: V. C. Summer
O. W. Dixon, Jr./T. C. Nichols, Jr.
E. H. Crews, Jr.
E. C. Roberts
W. A. Williams, Jr.
J. G. Connelly, Jr.
J. N. Grace
Group Managers
O. S. Bradham
D. R. Moore
C. A. Price
R. M. Campbell
C. L. Ligon (NSRC)
K. E. Nodland
R. A. Stough
G. Percival
R. L. Prevatte
J. B. Knotts, Jr.
H. G. Shealy
NPCF
File