

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

SEP 26 1988

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

SEQUOYAH NUCLEAR PLANT (SQN) - OFFICE OF INSPECTION AND ENFORCEMENT BULLETIN
(IEB) 86-02 - STATIC "O" RING (SOR) DIFFERENTIAL PRESSURE SWITCHES

- References:
1. NRC letter to TVA dated June 23, 1988, "NRC Bulletin 86-02 (TAC NOS. R00321/R00322)"
 2. TVA letter to NRC dated March 18, 1988, "Sequoyah Nuclear Plant (SQN) Units 1 and 2 - Office of Inspection and Enforcement Bulletin (IEB) 86-02 - Static 'O' Ring Differential Pressure Switches"
 3. TVA letter to NRC dated November 7, 1986, "Office of Inspection and Enforcement Bulletin 86-02 - Static 'O' Ring Differential Pressure Switches - Sequoyah Nuclear Plant"

References 2 and 3 transmitted TVA's supplemental and original responses to IEB 86-02. NRC transmitted their safety evaluation to TVA in reference 1 and stated ". . . that TVA has satisfactorily addressed all issues identified by the bulletin." Reference 1 also requested that TVA confirm that the SOR switches in the unit 1 residual heat removal (RHR) and upper head injection (UHI) systems had been replaced with the modified SOR switches before restart. This letter provides that confirmation.

The unit 1 RHR SOR switches were installed by engineering change notice (ECN) 6707 and calibrated by ECN 7149. The unit 1 UHI SOR switches were installed by design change notice (DCN) 00260. Calibration of the UHI switches by DCN 00260 is pending approval of proposed technical specification change 88-20, submitted August 15, 1988.

8810040202 880926
PDR ADDCK 05000327
Q PNU

Handwritten:
IEB
1/0

U.S. Nuclear Regulatory Commission

SEP 26 1988

Please direct questions concerning this issue to Russell R. Thompson at
(615) 870-7470.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

W. J. Ray for
R. Gridley, Manager
Nuclear Licensing and
Regulatory Affairs

cc: Ms. S. C. Black, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. F. R. McCoy, Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Sequoyah Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379