official

SEP 1 5 1988

Docket Nos. 50-327, 50-328 License Nos. DPR-77, DPR-79

Mr. S. A. White Senior Vice President, Nuclear Power Tennessee Vallay Authority 6N 38A Lookout Place 1101 Market Street Chattanooga, TN 37402-2801

Dear Mr. White:

SUBJECT: NOTICE OF VIOLATION

(NRC INSPECTION REPORT NOS. 50-327/88-34 AND 30-328/88-34)

This refers to the routine Nuclear Regulatory Commission (NRC) resident inspection conducted by K. Jenison on June 6 - July 11, 1988. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report. NRC concerns relative to the inspection findings were also discussed in an Enforcement Conference held on July 28, 1988 at the Sequoyah Nuclear Plant. A summary of this Enforcement Conference is contained in paragraph 7.e. of the enclosed report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

The inspection findings indicate that certain activities appeared to violate NRC requirements. The violations, references to pertinent requirements, and elements to be included in your response are described in the enclosed Notice of Violation. Violation A involves operation of the Upper Head Injection System in a condition outside the Technical Specifications for a period of approximately 17 hours. Violation B involves the failure of TVA staff to comply with Technical Specification requirements to verify the operability of the remaining Emergency Diesel Generators (EDG) within one hour whenever one EDG unit is inoperable. Violation C involves the failure to appropriately implement those portions of your Radiological Emergency Plan associated with declaring an Unusual Event and notifying appropriate personnel within required time constraints following the identification of a reactor coolant leak in excess of the requirements set aside in your Technical Specifications. We wish to bring to your attention the similarity of Violation C and the violation associated with NRC Inspection Report 50-327,328/88-33. We are concerned that your operating staff may be responding to alarms and conditions, which by your site Radiological Emergency Plan, require declaring a Notification of Unusual Event, in a manner which is less conservative than required and expected. In your response to Violation C, please ensure this concern is addressed.

\$810040272 \$80915 PDR ADOCK 05000327 PDC

JE01

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2 Title 10, Code of Federal Regulations, a copy of this letter, its enclosures, and any reply will be placed in the NRC's Public Document Room.

The responses directed by this letter and its enclosures are not subjected to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Should you have any questions concerning this letter, please contact us.

Sincerely,

ORIGINAL SIGNED BY FRANK R. McCOY

Frank R. McCoy, Assistant Director for TVA Inspection Programs TVA Projects Division Office of Special Projects

Enclosures:

1. Notice of Violati

2. NRC Inspection Report

cc w/encls:

J. A. Kirkebo, Vice President, Nuclear Engineering

J. L. LaPoint, Acting Site Director Sequoyah Nuclear Plant

R. L. Gridley, Director

Nuclear Safety and Licensing

M. J. Ray, Acting Site Licensing Manager

TVA Representative, Rockville Office

General Counsel, TVA State of Tennessee

bcc w/encls:

J. G. Partlow, OSP

S. D. Richardson, OSP

S. C. Black, OSP

B. D. Liaw, OSP

K. P. Barr, OSP/RII

J. B. Brady, OSP/RII

J. Rutberg, OGC

NRC Resident Inspector DRS, Technical Assistant NRC Document Control Desk

OSP/R11 JBrady:er 09/a/88 OSP/RII ADD AN KDenison 09/9/88

OSP/RII KBasa OSP/88