

DCS

Docket No: 50-336

MAY 27 1988

Northeast Nuclear Energy Company  
ATTN: Mr. Edward J. Mroczka  
Senior Vice President - Nuclear  
Engineering and Operations Group  
P.O. Box 270  
Hartford, Connecticut 06101-0270

Gentlemen:

Subject: Routine Resident Inspection 50-336/88-07 (3/22/88 - 5/2/88)

This transmits the report of the above subject inspection of Millstone 2. The inspection findings have been discussed with Messrs. S. Scace and J. Keenan of your staff.

A violation was identified for improper calibration of the Control Room Ventilation Radiation Monitors. Also, a deviation (Appendix B) was identified on calibration of these radiation monitors. Please respond to the violation and deviation in accordance with Appendices A and B.

We consider it significant that the enclosed violation and deviation were identified by NRC follow-up on an allegation by one of your employees. Further, as is stated in Detail 8.2.5 (Page 25) of the enclosed report, deficiencies in radiation monitor calibrations have been repeatedly noted by the NRC. These circumstances indicate deficiencies in the content and/or management of your programs to elicit and address employee concerns and to address NRC findings. Therefore, with your reply to the enclosed violation, please specifically include your actions to improve the effectiveness of addressal of employee concerns and NRC findings.

We also wish to note the effective implementation of identified and preventive maintenance programs on various safety systems (Report Detail 3.1). Good oversight and management of the programs was found.

Your cooperation with us is appreciated.

Sincerely,

Original Signed by:

*Eugene M. Kelly*  
for Lee H. Bettenhausen, Chief  
Projects Branch No. 1  
Division of Reactor Projects

Enclosures:

1. Appendix A, Notice of Violation
2. Appendix B, Notice of Deviation
3. NRC Region I Inspection Report 50-336/88-07

OFFICIAL RECORD COPY

DL50-336/88-07 - 0001.0.0  
05/20/88

1/1  
JEO/

cc w/encls:

W. D. Romberg, Vice President, Nuclear Operations  
R. M. Kacich, Manager, Generation Facilities Licensing  
D. O. Nordquist, Director of Quality Services  
S. E. Scace, Station Superintendent  
Public Docket Room  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of Connecticut

bcc w/encls:

Region I Docket Room (with concurrences)  
Management Assistant, DRMA (w/o enclosures)  
DRP Section Chief  
W. Raymond, SRI, Millstone 1,2&3  
J. Shedlosky, SRI, Haddam Neck  
D. Jaffe, LPM, NRR  
R. Bores, DRSS  
M. Conner, DRP  
A. Shropshire, RI

RI:DRP

*Raymond*  
Raymond/meo  
5/28/88

RI:DRP

*McCabe*  
McCabe  
5/27

RI:DRP

*Kelly*  
*For* Kelly  
5/27  
Bettenhausen