




UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

#3

MAY 1 1985

NOTE TO: Robert J. Bosnak  
FROM: Robert J. Wright  
SUBJECT: EQB COMMENTS REGARDING RIVER BEND TECHNICAL SPECIFICATIONS

The River Bend Unit 1 Technical Specifications under Containment Systems, Primary Containment Purge System, Limiting Conditions for Operations (3/4 6-14) do not reflect the content of the SER sent to DL from DE (R. Bosnak to T. Novak) dated February 15, 1985. The 36-inch valves must be limited to an opening angle of 65° or less and the 24-inch and 8-inch valves have not been demonstrated operable. These latter size valves, 24-inch and 8-inch, must be closed during operation modes 1, 2, 3 and 4.

  
Robert J. Wright

cc: S. Stern  
D. Houston  
G. Bagchi

B/3



13

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

MAY 15 1985

MEMORANDUM FOR: Dennis M. Crutchfield, Assistant Director  
for Safety Assessment  
Division of Licensing

FROM: William V. Johnston, Assistant Director  
Materials, Chemical & Environmental Technology  
Division of Engineering

SUBJECT: REVIEW OF RIVER BEND UNIT 1 TECHNICAL SPECIFICATIONS

The Chemical Engineering Branch has reviewed Sections 3/4.4.4 Chemistry, 6.8.4.c Post-Accident Sampling, 3.3.7.8 Fire Detection Instrumentation, 3.7.6.1 Fire Suppression Water System, 3.7.6.2 Spray and/or Sprinkler Systems, 3.7.6.3 Halon Systems, 3.7.6.4 Fire Hose Stations, 3.7.6.5 Yard Fire Hydrants and Hydrant Hose Houses and 3.7.7 Fire Rated Assemblies, of the proposed Technical Specification for the River Bend Nuclear Power Plant, Unit No. 1. We have only minor comments. We have discussed and resolved these comments with Dean Houston of the Technical Specification Review Group.

Based on our review of this information, we conclude that the above referenced sections of the proposed Technical Specifications are accepted.

*William V. Johnston*

William V. Johnston, Assistant Director  
Materials, Chemical & Environmental  
Technology  
Division of Engineering

Contact: P. Wu      J. Stang  
          x28555      x28006

cc: J. Knight  
H. Thompson  
W. Butler  
D. Houston  
V. Benaroya  
C. McCracken  
R. Ferguson  
P. Wu  
J. Stang  
E. Weinkam  
T. Sullivan  
S. Pawlicki

Package dupe:

~~8505230/60~~ XA

B/13

R. Benedict  
#1



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

April 19, 1985

Docket No. 50-458

MEMORANDUM FOR: Addressee List

FROM: Dennis M. Crutchfield, Assistant Director  
for Safety Assessment  
Division of Licensing

SUBJECT: FORTHCOMING MEETING TO DISCUSS REVIEW OF RIVER BEND  
TECHNICAL SPECIFICATIONS

A meeting has been scheduled for ~~April 22, 1985~~ to discuss the staff review of the Final Draft of River Bend Technical Specifications to be issued on April 22, 1985. All reviewers with their respective Branch Chief and Assistant Director are requested to attend. The enclosed draft memo provides background information which will be discussed at the meeting. The current schedule for completion of the staff review of the final draft TS is May 6, 1985.

*Dennis M. Crutchfield*  
Dennis M. Crutchfield, Assistant Director  
for Safety Assessment  
Division of Licensing

Enclosure:  
As stated

cc: H. Denton

~~8504250502XA~~

2/R

B/1

ADDRESSEE LIST

H. Thompson	L. Phillips
T. Speis	R. Lobel
J. Knight	L. Hulman
R. Bernero	W. Gammill
W. Russell	F. Congel
G. Lainas	W. Regan
T. Novak	H. Booher
F. Schroeder	W. Brooks
R. Rowsome	G. Thomas
R. Bosnak	R. Kendall
W. Johnston	J. Read
R. Houston	S. Stern
L. Rubenstein	R. Fell
D. Muller	J. Ridgely
D. Beckham	F. Eltawila
A. Schwencer	E. Tomlinson
F. Cherny	J. Minns
G. Lear	J. Levine
L. Reiter	C. Billups
R. LaGrange	R. Wescott
B. Liaw	E. Butcher
V. Benaroya	D. Houston
R. Ballard	R. Benedict
D. Cleary	
B. Sheron	
F. Rosa	
W. Butler	
C. Parr	
M. Srinivasan	
C. Berlinger	