

DMB

MAR 25 1986

*50-456
457*

MEMORANDUM FOR: Region III Files (Braidwood 1 and 2)

FROM: P. R. Pelke, Project Inspector, Braidwood

SUBJECT: CABLE PAN HANGER PLATE WARPAGE AT BRAIDWOOD (50-456; 50-457)
(AMS NO. RIII-86-A-0031)

On March 24, 1986, the Allegation Review Board met to discuss the subject allegation. The outline of the meeting is enclosed.

P. R. Pelke
Project Inspector

Enclosure: Outline for
Allegation Review Board

cc w/enclosure:

- A. Davis
- C. Norelius
- C. Paperiello
- E. Greenman
- W. Little
- J. Harrison
- R. Gardner
- D. Danielson
- J. Jacobson
- C. Weil
- W. Kropp
- J. Stevens, NRR
- M. Farber

8603310099 860325
PDR ADOCK 05000456
Q PDR

PP
Pelke/SITE

3/25/86

IEO/11

OUTLINE FOR ALLEGATION REVIEW BOARD (AMS NO. RIII-86-A-0031)

References: (1) Memorandum from W. Kropp to C. Weil dated March 4, 1986
(2) Memorandum from Charles H. Weil to Charles E. Norelius dated March 11, 1986

Recommended Inspector: W. Kropp

Recommended Completion Date: 05/01/86

RECOMMENDED ACTIONS

- (1) Reference (1) documents actions taken as of March 4, 1986.
- (2) Subsequently, the contractor developed a technical bulletin to outline the acceptance criteria for warpage. However, this bulletin was unacceptable to the NRC in that it did not adequately specify the acceptance criteria. Another meeting was held with the licensee to discuss these concerns. The licensee agreed to resolve the issue.
- (3) One other issue remains regarding the alleged supervisor telling him to accept the warpage so that production can continue. Additionally, the inspector should determine if the licensee addresses the warpage issue generically.