

September 28, 1988

Docket No. 50-334

Mr. J. D. Sieber, Vice President
Duquesne Light Company
Nuclear Group
Post Office Box 4
Shippingport, PA 15077

DISTRIBUTION

Docket File	PTam
NRC & Local PDRs	OGC
Gray File	EJordan
SVarga	BGrimes
BBoger	ACRS(10)
SNorris	

Dear Mr. Sieber,

SUBJECT: BEAVER VALLEY UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION ON YOUR
CHANGE REQUEST NO. 127 (TAC 64076)

By letter dated November 12, 1986, you submitted the subject request for amendment concerning snubber inspection and testing requirement. We have reviewed that request and found that additional information is needed from you to complete our review (See enclosure). Please provide your response within 45 days of receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

/s/
Peter S. Tam, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects I/II

Enclosure:
as stated

cc w/enclosure:
See next page

LA:PDI-4
SN04-73
09/28/88

PM:PDI-4
PTam:cb *fst*
09/28/88

D:PDI-4
JStolz
09/28/88

Df01
1/1

BB10040301 880928
PDR ADOCK 05000334
PNU
Q

Mr. J. Sieber
Duquesne Light Company

cc:

Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Kenny Grada, Manager
Nuclear Safety
Duquesne Light Company
P. O. Box 4
Shippingport, Pennsylvania 15077

William Lacey, Manager
Nuclear Operations Department
Post Office Box 4
Duquesne Light Company
Shippingport, Pennsylvania 15077

John A. Lee, Esquire
Duquesne Light Company
One Oxford Centre
301 Grant Street
Pittsburgh, Pennsylvania 15279

W.F. Carmichael, Commissioner
Department of Labor
1800 Washington Street East
Charleston, West Virginia 25305

John D. Borrows
Director, Utilities Department
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Beaver Valley Power Station
Units 1 & 2

Bureau of Radiation Protection
Pennsylvania Department of Environmental
Resources
ATTN: R. Jarati
Post Office Box 2063
Harrisburg, Pennsylvania 17120

Mayor of the Borough of
Shippingport
Post Office Box 3
Shippingport, Pennsylvania 15077

Ashley C. Schannauer
Assistant City Solicitor
City of Pittsburgh
313 City-County Building
Pittsburgh, Pennsylvania 15219

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 181
Shippingport, Pennsylvania 15077

Director, Pennsylvania Emergency
Management Agency
Post Office Box 3321
Harrisburg, Pennsylvania 17105-3321

REQUEST FOR ADDITIONAL INFORMATION
BEAVER VALLEY UNIT 1
PROPOSED SNUBBER INSPECTION AND TESTING AMENDMENT

(1) Specification 4.7.12.b and c, Visual Inspections.

You proposed to perform visual inspections by snubber type and by system. This proposal deviates from the staff's current position expressed in the Beaver Valley Unit 2 Technical Specifications, and appears to be a large relaxation from the staff's current position. Please justify your proposal.

(2) Specification 4.7.12.c, Visual Inspections Acceptance Criteria

Your proposed change reads "...may be generically susceptible; or (2) the affected...". The staff's technical position, as expressed in the Unit 2 Technical Specifications, uses the word "and", thus requiring both conditions be met before a snubber which appeared inoperable be determined OPERABLE for the purpose of determining the next visual inspection interval. Your use of the word "or" instead of "and" appears to have the effect of relaxing the staff's requirement. Please justify. Also, provide the background information regarding hydraulic snubbers on the top of page 3/4 7-28. Was a similar specification approved for another nuclear plant?

(3) Specification 4.7.12.d, Functional Tests

The last paragraph on page 3/4 7-28 refers to large-bore snubber tests. Provide background information, stating if other nuclear plants have such a specification.